

ASME B16.29-2022
(Revision of ASME B16.29-2017)

Wrought Copper and Wrought Copper Alloy Solder-Joint Drainage Fittings – DWV

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME B16.29-2022
(Revision of ASME B16.29-2017)

Wrought Copper and Wrought Copper Alloy Solder-Joint Drainage Fittings — DWV

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: July 31, 2023

The next edition of this Standard is scheduled for publication in 2027.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark

“ASME” and the above ASME symbol are registered trademarks of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2023 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved

CONTENTS

Foreword	v
Committee Roster	vi
Correspondence With the B16 Committee	vii
Summary of Changes	ix
List of Changes in Record Number Order	x
1 Scope	1
2 General	1
3 Description	1
4 Pitch (Slope)	1
5 Abbreviations	1
6 Component Size	1
7 Marking	2
8 Material	2
9 Laying Lengths	2
10 Ovality	2
11 Threaded Ends	2
12 Design of Threaded Ends	2
13 Alignment	2
14 Gaging	2
Mandatory Appendix	
I References	15
Nonmandatory Appendix	
A Quality System Program	16
Figure	
6.2-1 Size of Fittings	3
Tables	
6.1.1-1 Dimensions of Solder-Joint Ends	4
6.1.2-1 Dimensions of Threaded Ends — DWV	5
9-1 Dimensions of DWV Couplings, Extended Bushings, and Adapters	7
9-2 Dimensions of DWV Soil Pipe Adapters	8
9-3 Dimensions of DWV C × No-Hub Soil Pipe Adapters	9
9-4 Dimensions of DWV Elbows	10
9-5 Dimensions of DWV 45 deg Y's	11
9-6 Dimensions of DWV Tees	12

9-7	Dimensions of DWV Caps	12
9-8	Dimensions of DWV Vent Increases	12
9-9	Dimensions of DWV Closet Flanges	13
9-10	Dimensions of DWV Trap Adapters	14
9-11	Dimensions of DWV Slip-Joint Ends	14

ASMENORMDOC.COM : Click to view the full PDF of ASME B16.29 2022

FOREWORD

Standardization of cast and wrought solder-joint fittings was initiated in Subcommittee 11 of American Standards Association (ASA) Sectional Committee A40 on Plumbing Requirements and Equipment. Development work culminated in publication of ASA A40.3-1941.

In 1949, work on these fittings was transferred to Sectional Committee B16 of ASA, which established Subcommittee 9 (now Subcommittee J). The first standard developed was approved as ASA B16.18-1950, Cast Bronze Solder-Joint Fittings. A later joint effort of the Copper and Brass Research Association and the Manufacturers Standardization Society of the Valve and Fittings Industry (MSS) culminated in a standard on wrought fittings, ultimately approved as B16.22-1951.

Concurrently, recognizing the need for drainage fitting standards, an MSS task group developed the standard later approved as ASA B16.23-1953, Cast Bronze Solder-Joint Drainage Fittings, and a standard for wrought fittings was initially published as MSS SP-64-1961. A revision of that standard was submitted to Subcommittee 9 of B16 and was eventually approved as ASA B16.29-1966.

A revision was published [after reorganization of ASA as the American National Standards Institute (ANSI)] as ANSI B16.29-1973. In this edition, shorter solder cups were specified in larger sizes, since strength to contain pressure is not a factor. In 1979, Subcommittee I (formerly 9, now J) added metric dimensional equivalents and made other minor improvements. That revision was approved by ANSI, after approval by the Committee and secretariat organizations, as ANSI B16.29-1980.

In 1982, American National Standards Committee B16 was reorganized as an ASME Committee operating under procedures accredited by ANSI. The 1986 edition of the standard removed metric equivalents (not functionally applicable in the plumbing industry), updated the referenced standards, and incorporated editorial and format revisions. The 1994 edition removed inspection tolerance requirements, established minimum laying lengths, added soil pipe adapters, and incorporated editorial revisions. Following approval by the Standards Committee and ASME, approval as an American National Standard was given by ANSI on October 10, 1994, with the designator ASME B16.29-1994.

The 2001 edition of this Standard was revised to include Nonmandatory Appendix B, Quality System Program. Editorial revisions were made for the purpose of clarification. Following approval by the B16 Main Committee and ASME Supervisory Board, the Standard was approved as an American National Standard by ANSI on October 11, 2001.

In the 2007 edition, metric units were used as a primary reference unit while maintaining U.S. Customary units in either parenthetical or separate forms. In addition, several editorial revisions were made for clarity.

In the 2012 edition, references to ASME standards were revised to no longer list specific edition years; the latest edition of ASME publications applied unless stated otherwise. Following approval by the B16 Standards Committee and the ASME Supervisory Board, and after public review, the Standard was approved as an American National Standard by ANSI on August 23, 2012.

In the 2017 edition, provisions were made to update verbiage and readings. Following approval by the ASME B16 Standards Committee, approval as an American National Standard was given by ANSI on September 7, 2017, with the new designation ASME B16.29-2017.

In ASME B16.29-2022, the U.S. Customary tables in former Mandatory Appendix I have been merged with the SI tables in the main text. The tables and figures have been redesignated, former Mandatory Appendix I has been deleted, and the subsequent Mandatory Appendix has been redesignated. Cross-references have been updated accordingly. Also, in this edition, the references in Mandatory Appendix I (formerly Mandatory Appendix II) have been updated and reformatted. Following approval by the ASME B16 Standards Committee, ASME B16.29-2022 was approved by ANSI on November 28, 2022.

ASME B16 COMMITTEE

Standardization of Valves, Flanges, Fittings, and Gaskets

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

C. E. Davila, *Chair*
R. M. Bojarczuk, *Vice Chair*
S. J. Rossi, *Secretary*

STANDARDS COMMITTEE PERSONNEL

A. Appleton , Alloy Stainless Products Co., Inc.	D. R. Frikken , Becht Engineering Co., Inc.
J. E. Barker , DeZURIK, Inc.	J. D. Grant , DeZURIK, Inc.
R. Barnes , ANRIC Enterprises, Inc.	D. Hunt, Jr. , Fastenal
K. Barron , Ward Manufacturing	G. A. Jolly , Samshin, Ltd.
D. C. Bayreuther , Metso Automation	E. J. Lain , Exelon Nuclear
W. B. Bedesem , Consultant	T. A. McMahon , Emerson Automation Solutions
R. M. Bojarczuk , ExxonMobil Research & Engineering Co.	R. C. Merrick , Fluor Enterprises
A. M. Cheta , Shell Global Solutions (U.S.)	W. H. Patrick , Dow Chemical Co.
M. A. Clark , NIBCO, Inc.	D. W. Raho , CCM 2000
P. V. Clark , Jomar Group	D. F. Reid , VSP Technologies
G. A. Cuccio , Capitol Manufacturing Co.	S. J. Rossi , The American Society of Mechanical Engineers
J. D'Avanzo , Fluoroseal Valves	R. Schmidt , Candoil
C. E. Davila , Crane Chempharma and Energy	J. Sekerak , CSA Group
B. G. Fabian , Pennsylvania Machine Works	R. A. Schmidt , Canadoil
K. S. Felder , Valero Energy	J. P. Tucker , Flowserve Corp.
F. Feng , China Productivity Center for Machinery	F. R. Volgstadt , Volgstadt & Associates, Inc.

SUBCOMMITTEE J — COPPER AND COPPER ALLOY FLANGES, FLANGED FITTINGS, AND SOLDER JOINT FITTINGS

A. G. Kitera, Jr. , <i>Chair</i> , Copper Development Association, Inc.	J. Atkinson , Mueller Fittings Co., Inc.
M. A. Clark , <i>Vice Chair</i> , NIBCO, Inc.	W. E. Chapin , Professional Code Consulting, LLC
J. Oh , <i>Secretary</i> , The American Society of Mechanical Engineers	J. C. Gast , Mueller Fittings Co., Inc.
D. Wiener , <i>Secretary</i> , The American Society of Mechanical Engineers	

CORRESPONDENCE WITH THE B16 COMMITTEE

General. ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Standard should be sent to the staff secretary noted on the committee's web page, accessible at <https://go.asme.org/B16committee>.

Revisions and Errata. The committee processes revisions to this Standard on a continuous basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published in the next edition of the Standard.

In addition, the committee may post errata on the committee web page. Errata become effective on the date posted. Users can register on the committee web page to receive e-mail notifications of posted errata.

This Standard is always open for comment, and the committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

Cases

(a) The most common applications for cases are

(1) to permit early implementation of a revision based on an urgent need

(2) to provide alternative requirements

(3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Standard

(4) to permit the use of a new material or process

(b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Standard.

(c) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:

(1) a statement of need and background information

(2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)

(3) the Standard and the paragraph, figure, or table number(s)

(4) the edition(s) of the Standard to which the proposed case applies

(d) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Approved cases are posted on the committee web page.

Interpretations. Upon request, the committee will issue an interpretation of any requirement of this Standard. An interpretation can be issued only in response to a request submitted through the online Interpretation Submittal Form at <https://go.asme.org/InterpretationRequest>. Upon submitting the form, the inquirer will receive an automatic e-mail confirming receipt.

ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If based on the information submitted, it is the opinion of the committee that the inquirer should seek assistance, the request will be returned with the recommendation that such assistance be obtained. Inquirers can track the status of their requests at <https://go.asme.org/Interpretations>.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Interpretations are published in the ASME Interpretations Database at <https://go.asme.org/Interpretations> as they are issued.

Committee Meetings. The B16 Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the committee. Information on future committee meetings can be found on the committee web page at <https://go.asme.org/B16committee>.

ASMENORMDOC.COM : Click to view the full PDF of ASME B16.29 2022

ASME B16.29-2022

SUMMARY OF CHANGES

Following approval by the ASME B16 Standards Committee and ASME, and after public review, ASME B16.29-2022 was approved by the American National Standards Institute on November 28, 2022.

In ASME B16.29-2022, the U.S. Customary tables in former Mandatory Appendix I have been merged with the SI tables in the main text. The tables and figures have been redesignated, former Mandatory Appendix I has been deleted, and the subsequent Mandatory Appendix has been redesignated. Cross-references have been updated accordingly. In addition, this edition includes the following change identified by a margin note, **(22)**. The Record Number listed below is explained in more detail in the “List of Changes in Record Number Order” following this Summary of Changes.

<i>Page</i>	<i>Location</i>	<i>Change (Record Number)</i>
15	Mandatory Appendix I	References updated (22-814)

LIST OF CHANGES IN RECORD NUMBER ORDER

<u>Record Number</u>	<u>Change</u>
22-814	Updated references in Mandatory Appendix I (former Mandatory Appendix II).

ASMENORMDOC.COM : Click to view the full PDF of ASME B16.29 2022

Wrought Copper and Wrought Copper Alloy Solder-Joint Drainage Fittings — DWV

1 SCOPE

This Standard for wrought copper and wrought copper alloy solder-joint drainage fittings, designed for use with copper drainage tube conforming to ASTM B306, covers the following:

- (a) description
- (b) pitch (slope)
- (c) abbreviations for end connections
- (d) sizes and method of designating openings for reducing fittings
- (e) marking
- (f) material
- (g) dimensions and tolerances

2 GENERAL

2.1 Convention

For determining conformance with this Standard, the convention for fixing significant digits where limits (maximum and minimum values) are specified shall be as defined in ASTM E29. This requires that an observed or calculated value be rounded off to the nearest unit in the last right-hand digit used for expressing the limit. Decimal values and tolerances do not imply a particular method of measurement.

2.2 Relevant Units

This Standard states values in both SI (metric) and U.S. Customary units. These systems of units are to be regarded separately as standard. Within the text, the U.S. Customary units are shown in parentheses. The values stated in each system are not exact equivalents; therefore, it is required that each system of units be used independently of the other. Combining values from the two systems constitutes nonconformance with the Standard.

2.3 References

Codes, standards, and specifications, containing provisions to the extent referenced herein, constitute requirements of this Standard. These reference documents are listed in [Mandatory Appendix I](#).

2.4 Quality Systems

Guidelines relating to the product manufacturer's quality system programs are described in [Nonmandatory Appendix A](#).

3 DESCRIPTION

These fittings are designed for drainage and vent systems only, using the solder-joint method of connection. The fitting cups (C) are provided with stops so that the ends of the tube, when assembled meet the stops. Sketches and designs of fittings are illustrative only. The dimensions specified herein shall govern in all cases.

4 PITCH (SLOPE)

All nominal 90-deg fittings shall be pitched to result in a slope of 0.20 mm/m (0.25 in./ft) (2%) of horizontal tube length with reference to a horizontal plane.

5 ABBREVIATIONS

The symbols shown below are used to designate the type of fitting end.

Symbols	Definitions
C	Solder-joint fitting end (internal) made to receive copper tube diameter
F	Internal American National Standard taper pipe thread, NPTI
FTG	Solder-joint fitting end (external) made to copper tube diameter
M	External American National Standard taper pipe thread, NPTE
NPSM	American National Standard free-fitting straight mechanical pipe thread
SJ	End of fitting formed to receive outside diameter tube size

6 COMPONENT SIZE

6.1 Nominal Size

As applied in this Standard, the use of the phrase "nominal size" followed by a dimensionless number is for the purpose of fitting end connection size identification.

6.1.1 Tube. The size designations for the fitting end configurations defined in [Table 6.1-1](#) correspond to drainage tube sizes defined in ASTM B306.

6.1.2 Pipe. The size designation of threaded fitting end configurations defined in [Table 6.1.2-1](#) corresponds to thread sizes defined in ASME B1.20.1.

6.2 Identification

Fittings shall be identified by the nominal size of the openings in the sequence illustrated in [Figure 6.2-1](#).

7 MARKING

Each fitting shall be marked permanently and legibly with the manufacturer's name or trademark and with DWV (to indicate drain-waste-vent).

8 MATERIAL

Fittings shall be made of wrought copper or wrought copper alloy material having not less than 84% of copper content.

9 LAYING LENGTHS

Due to widely varying manufacturing processes, laying length dimensions of fittings are not standardized. Consult the manufacturer for these dimensions. Suggested dimensions, including laying lengths, for various fitting configurations are shown in [Tables 9-1](#) through [9-11](#).

10 OVALITY

Maximum ovality shall not exceed 1% of the maximum diameter shown in [Table 6.1.1-1](#). The average of the maximum and minimum diameters must be within the dimensions shown in the table.

11 THREADED ENDS

11.1 General

Fitting threads shall be right hand, conforming to ASME B1.20.1. They shall be American National Standard taper pipe threads (NPT), except for slip-joint ends, which shall have American National Standard free-fitting straight mechanical pipe threads (NPSM).

11.2 Chamfer

All internal threads shall be countersunk a distance not less than one-half the pitch of the thread at an angle of approximately 45 deg with the axis of the thread. All external threads shall be chamfered at an angle of 30 deg to 45 deg from the axis. Countersinking and chamfering shall be concentric with the threads. The length of threads shall be measured to include the countersink or chamfer.

11.3 Threading Tolerances

11.3.1 Internal Threads. Variations in NPT internal threading shall be limited to one turn large or one turn small from the gaging notch when using working gages. The reference point for gaging is the starting end of the fitting, provided the chamfer does not exceed the major diameter of the internal thread. When a chamfer on the internal thread exceeds this limit, the reference point becomes the last thread scratch on the chamfer cone.

11.3.2 External Threads. Variations in NPT external threading shall be limited to one turn large or one turn small from the gage face of ring when using working gages. The reference point for gaging is the end of the thread, provided the chamfer is not smaller than the minor diameter of the external thread. When a chamfer on the external thread exceeds this limit, the reference point becomes the last thread scratch on the chamfer cone.

12 DESIGN OF THREADED ENDS

External and internal threaded ends of fittings will be furnished with a polygon to facilitate installation.

13 ALIGNMENT

The maximum allowable variation in the angular alignment of all openings shall be 5 mm in 1 m (0.06 in. in 1 ft) (0.5%), other than in the direction of pitch (see [section 4](#)).

14 GAGING


14.1 Standard Gaging Method of Solder-Joint Ends

The standard method of gaging the diameter tolerances for external and internal ends shall be by use of plain plug and ring gages designed to hold the product within the limits established in [Table 6.1.1-1](#).

14.2 Optional Gaging Method of Solder-Joint Ends


For gaging the diameter tolerance of external and internal ends, the manufacturer may use direct reading instruments instead of ring and plug gages as specified in [para. 14.1](#). When gaging the diameters of external and internal ends using direct reading instruments, refer to [section 10](#). In case of a dispute, ring/plug gages shall be used as the referee method.

Figure 6.2-1
Size of Fittings



ASMENORMDOC.COM : Click to view the full PDF of ASME B16.29 2022

Table 6.1.1-1
Dimensions of Solder-Joint Ends




Nominal Tube Size [Note (1)]	External End			Internal End			Minimum Metal Thickness, <i>R</i> [Note (4)]	Minimum Inside Diameter of Fitting, <i>O</i> [Note (5)]
	Outside Diameter, <i>A</i> [Note (2)]		Minimum Length, <i>K</i> [Note (3)]	Inside Diameter, <i>F</i> [Note (2)]		Minimum Depth, <i>G</i> [Note (3)]		
	Min.	Max.		Min.	Max.			
1¼	34.85 (1.372)	34.98 (1.377)	14.22 (0.56)	35.00 (1.378)	35.10 (1.382)	12.70 (0.50)	1.02 (0.040)	32.77 (1.29)
1½	41.17 (1.621)	41.33 (1.627)	15.75 (0.62)	41.35 (1.628)	41.48 (1.633)	14.22 (0.56)	1.07 (0.042)	38.86 (1.53)
2	53.87 (2.121)	54.03 (2.127)	17.53 (0.69)	54.05 (2.128)	54.18 (2.133)	15.75 (0.62)	1.07 (0.042)	51.05 (2.01)
3	79.27 (3.121)	79.43 (3.127)	20.57 (0.81)	79.45 (3.128)	79.58 (3.133)	19.05 (0.75)	1.14 (0.045)	75.69 (2.98)
4	104.67 (4.121)	104.83 (4.127)	26.92 (1.06)	104.85 (4.128)	104.98 (4.133)	25.40 (1.00)	1.47 (0.058)	99.82 (3.93)

GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.

NOTES:

- (1) For size designation of fitting, see [section 6](#).
- (2) See [section 10](#).
- (3) *K* dimensions of 11.2 mm (0.44 in.), 12.7 mm (0.50 in.), and 14.2 mm (0.56 in.), and *G* dimensions of 9.7 mm (0.38 in.), 11.2 mm (0.44 in.), and 12.7 mm (0.50 in.), respectively, for sizes 1 $\frac{1}{4}$, 1 $\frac{1}{2}$, and 2 are sound and acceptable from an engineering standpoint. However, the cup depths specified provide greater latitude in making accurate installations.
- (4) *R* dimension is based on DWV tubing, which is intended for aboveground use.
- (5) Inside diameter of fitting is based on Type M copper water tube (ASTM B88).

Table 6.1.2-1
Dimensions of Threaded Ends — DWV



Nominal Thread Size [Note (4)]	Internal End [Note (2)]						External End [Note (3)]				
	Minimum Diameter of Band or Across Flats of Polygon, A	Minimum Band Length, B	Minimum Diameter of Body Over Thread, C	Minimum Inside Diameter of Fitting, O	Minimum Length of Thread, Y	Minimum Depth of Bore, Z	Minimum Inside Diameter of Fitting, O	Maximum Thread End Bore, P	Minimum Length of Effective Thread, ZZ		
1 $\frac{1}{4}$	45.2 (1.78)	8.6 (0.34)	43.7 (1.72)	32.8 (1.29)	10.7 (0.42)	17.5 (0.69)	32.8 (1.29)	34.8 (1.37)	18.0 (0.71)		
1 $\frac{1}{2}$	52.3 (2.06)	9.7 (0.38)	50.3 (1.98)	38.9 (1.53)	10.7 (0.42)	17.5 (0.69)	38.9 (1.53)	40.9 (1.61)	18.3 (0.72)		
2	64.3 (2.53)	12.7 (0.50)	63.0 (2.48)	51.1 (2.01)	11.2 (0.44)	19.1 (0.75)	51.1 (2.01)	52.6 (2.07)	19.3 (0.76)		
3	94.5 (3.72)	14.2 (0.56)	93.5 (3.68)	75.7 (2.98)	19.6 (0.77)	31.0 (1.22)	75.7 (2.98)	78.2 (3.08)	30.5 (1.20)		


GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.

Table 6.1.2-1
Dimensions of Threaded Ends — DWV (Cont'd)


NOTES:

- (1) $1\frac{1}{4}$, $1\frac{1}{2}$, and 2 male threaded ends may have inside chamfer for slip-nut connections.
- (2) Internal threads shall be gaged $\frac{1}{2}$ turn large to $1\frac{1}{2}$ turn small from the gaging notch on the plug when using working gages.
- (3) External threads shall be gaged $\frac{1}{2}$ turn small to $1\frac{1}{2}$ turn large from the face of the ring when using working gages.
- (4) Thread size is as governed by ASME B1.20.1.

Table 9-1
Dimensions of DWV Couplings, Extended Bushings, and Adapters



DWV Couplings




DWV Adapters

Nominal Thread or Tube Size	Minimum Couplings C × C, A	Minimum Coupling Reducer C × C, A	Minimum Couplings Without Stop C × C, C	Minimum Bushing Extended FTG × C, B	Adapters			
					Minimum C × F, B	Minimum C × M, B	Minimum FTG × F, C	Minimum FTG × M, C
1 ¹ / ₄	1.5 (0.06)	... (...)	25.4 (1.00)	... (...)	18.5 (0.73)	21.8 (0.86)	34.5 (1.36)	... (...)
1 ¹ / ₄ × 1 ¹ / ₂	... (...)	... (...)	... (...)	... (...)	... (...)	31.2 (1.23)	... (...)	... (...)
1 ¹ / ₂	1.5 (0.06)	... (...)	28.4 (1.12)	... (...)	18.5 (0.73)	21.8 (0.86)	37.6 (1.48)	42.9 (1.69)
1 ¹ / ₂ × 1 ¹ / ₄	... (...)	4.8 (0.19)	... (...)	20.6 (0.81)	... (...)	24.9 (0.98)	... (...)	... (...)
1 ¹ / ₂ × 2	... (...)	... (...)	... (...)	... (...)	... (...)	37.6 (1.48)	... (...)	... (...)
2	1.5 (0.06)	... (...)	31.8 (1.25)	... (...)	21.8 (0.86)	21.8 (0.86)	40.9 (1.61)	... (...)
2 × 1 ¹ / ₂	... (...)	6.4 (0.25)	... (...)	26.9 (1.06)	... (...)	... (...)	... (...)	... (...)
2 × 1 ¹ / ₄	... (...)	6.4 (0.25)	... (...)	25.4 (1.00)	... (...)	23.4 (0.92)	... (...)	... (...)
3	1.5 (0.06)	... (...)	38.1 (1.50)	... (...)	33.8 (1.33)	36.8 (1.45)	55.9 (2.20)	... (...)
3 × 2	... (...)	6.4 (0.25)	... (...)	28.4 (1.12)	... (...)	... (...)	... (...)	... (...)
3 × 1 ¹ / ₂	... (...)	7.9 (0.31)	... (...)	28.4 (1.12)	... (...)	... (...)	... (...)	... (...)
3 × 1 ¹ / ₄	... (...)	7.9 (0.31)	... (...)	30.2 (1.19)	... (...)	... (...)	... (...)	... (...)
4	1.5 (0.06)	... (...)	50.8 (2.00)	... (...)	... (...)	... (...)	... (...)	... (...)
4 × 3	... (...)	9.7 (0.38)	... (...)	36.6 (1.44)	... (...)	... (...)	... (...)	... (...)

GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.

Table 9-2
Dimensions of DWV Soil Pipe Adapters




DWV Soil Pipe Adapters

Nominal Size	Dimensions					
	A, max.	A, min.	H, min.	J, min.	N	T, min.
2 × 2	69.9 (2.75)	68.3 (2.69)	60 (2.36)	64 (2.50)	62.2 (2.45)	1.37 (0.054)
1½ × 2	69.9 (2.75)	68.3 (2.69)	81 (3.17)	87 (3.44)	62.2 (2.45)	1.37 (0.054)
1¼ × 2	69.9 (2.75)	68.3 (2.69)	81 (3.17)	87 (3.44)	62.2 (2.45)	1.37 (0.054)
3 × 3	98.6 (3.88)	96.8 (3.81)	67 (2.64)	73 (2.88)	88.6 (3.49)	1.60 (0.063)
2 × 3	98.6 (3.88)	96.8 (3.81)	86 (3.39)	95 (3.75)	88.6 (3.49)	1.60 (0.063)
4 × 4	124.0 (4.88)	122.2 (4.81)	73 (2.88)	83 (3.25)	114.0 (4.49)	1.83 (0.072)
3 × 4	124.0 (4.88)	122.2 (4.81)	92 (3.63)	103 (4.06)	114.0 (4.49)	1.83 (0.072)


GENERAL NOTES:

- (a) Dimensions are in millimeters with inch values in parentheses.
- (b) Dimensions are for extra-heavy weight soil pipe (reference ASTM A74). For service weight soil pipe, A and N nominal dimensions may be from 3 mm to 8 mm ($\frac{1}{8}$ in. to $\frac{5}{16}$ in.) smaller than dimensions shown in table.

Table 9-3
Dimensions of DWV C × No-Hub Soil Pipe Adapters



Straight Size




Reducing Size

DWV Soil Pipe Adapters – C × No-Hub
for Use With Stainless Steel Clamp and Elastomer Gasket


Nominal Size	$A \pm 1.5$ ($A \pm 0.06$)	$B \pm 1.5$ ($B \pm 0.06$)	D , Min.	$F \begin{smallmatrix} +3.3 \\ -0.00 \end{smallmatrix}$ ($F \begin{smallmatrix} +0.13 \\ -0.00 \end{smallmatrix}$)
2	60.5 (2.38)	58.7 (2.31)	31.0 (1.22)	6.4 (0.25)
1½ × 2	60.5 (2.38)	58.7 (2.31)	31.8 (1.25)	6.4 (0.25)
1¼ × 2	60.5 (2.38)	58.7 (2.31)	32.5 (1.28)	6.4 (0.25)
3	86.6 (3.41)	84.8 (3.34)	31.0 (1.22)	6.4 (0.25)
2 × 3	86.6 (3.41)	84.8 (3.34)	31.8 (1.25)	6.4 (0.25)
1½ × 3	86.6 (3.41)	84.8 (3.34)	32.5 (1.28)	6.4 (0.25)
4	112.8 (4.44)	111.3 (4.38)	31.0 (1.22)	7.9 (0.31)
3 × 4	112.8 (4.44)	111.3 (4.38)	31.8 (1.25)	7.9 (0.31)

GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.


Table 9-4
Dimensions of DWV Elbows




DWV 90 deg EII
C × C




DWV 60 deg EII
C × C




DWV 45 deg EII
C × C




DWV 90 deg FTG EII
FTC × C



DWV 22¹/₂ deg EII
C × C



DWV 11¹/₄ deg EII
C × C




DWV 45 deg FTG EII
FTG × C

DWV Elbows

Nominal Tube Size, Min.	Dimensions								
	K for 90 deg C × C	K for 60 deg C × C	K for 45 deg C × C	K for 22 ¹ / ₂ deg C × C	K for 11 ¹ / ₄ deg C × C	K for 90 deg FTG × C	G for 90 deg FTG × C	K for 45 deg FTG × C	G for 45 deg FTG × C
1 ¹ / ₄	28.2 (1.11)	15.5 (0.61)	10.7 (0.42)	2.8 (0.11)	1.0 (0.04)	28.2 (1.11)	42.4 (1.67)	10.7 (0.42)	24.9 (0.98)
1 ¹ / ₂	34.5 (1.36)	18.5 (0.73)	12.2 (0.48)	4.3 (0.17)	1.0 (0.04)	33.0 (1.30)	50.3 (1.98)	12.2 (0.48)	28.2 (1.11)
2	47.2 (1.86)	26.4 (1.04)	18.5 (0.73)	7.6 (0.30)	2.8 (0.11)	47.2 (1.86)	64.5 (2.54)	18.5 (0.73)	36.1 (1.42)
3	70.4 (2.77)	40.1 (1.58)	27.4 (1.08)	11.4 (0.45)	3.6 (0.14)	70.4 (2.77)	90.9 (3.58)	27.4 (1.08)	48.0 (1.89)
4	93.7 (3.69)	... (...)	36.6 (1.44)	15.7 (0.62)	7.9 (0.31)	93.7 (3.69)	120.9 (4.76)	36.6 (1.44)	63.5 (2.50)

GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.


Table 9-5
Dimensions of DWV 45 deg Y's



Nominal Tube Size	K	K'	KK, Min.	L, Min.
1 $\frac{1}{4}$	6 (0.23)	... (...)	49.3 (1.94)	47.2 (1.86)
1 $\frac{1}{2}$	8 (0.30)	... (...)	58.7 (2.31)	56.6 (2.23)
1 $\frac{1}{2}$ x 1 $\frac{1}{2}$ x 1 $\frac{1}{4}$	4 (0.17)	... (...)	53.8 (2.12)	51.8 (2.04)
1 $\frac{1}{2}$ x 1 $\frac{1}{4}$ x 1 $\frac{1}{2}$	8 (0.30)	... (...)	60.5 (2.38)	53.6 (2.11)
1 $\frac{1}{2}$ x 1 $\frac{1}{4}$ x 1 $\frac{1}{4}$	4 (0.17)	... (...)	55.6 (2.19)	50.3 (1.98)
2	12 (0.48)	... (...)	71.4 (2.81)	69.3 (2.73)
2 x 2 x 1 $\frac{1}{2}$	3 (0.11)	... (...)	63.5 (2.50)	64.5 (2.54)
2 x 2 x 1 $\frac{1}{4}$	0 (0)	... (...)	58.7 (2.31)	59.9 (2.36)
2 x 1 $\frac{1}{2}$ x 2	12 (0.48)	... (...)	81.0 (3.19)	69.3 (2.73)
2 x 1 $\frac{1}{2}$ x 1 $\frac{1}{2}$	3 (0.11)	... (...)	71.4 (2.81)	39.4 (1.55)
3	19 (0.73)	... (...)	104.6 (4.12)	101.9 (4.01)
3 x 3 x 2	0 (0)	... (...)	90.4 (3.56)	90.9 (3.58)
3 x 3 x 1 $\frac{1}{2}$	... (...)	3 (0.13)	81.0 (3.19)	84.6 (3.33)
3 x 3 x 1 $\frac{1}{4}$	... (...)	5 (0.19)	71.4 (2.81)	78.2 (3.08)
4	24 (0.94)	... (...)	136.7 (5.38)	133.6 (5.26)

GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.

Table 9-6
Dimensions of DWV Tees




DWV Tees
C × C × C

Nominal Tube Size	J, Min.	K, Min.	KK, Min.
1¼	26.7 (1.05)	26.4 (1.04)	19.1 (0.75)
1½	33.0 (1.30)	33.0 (1.30)	20.6 (0.81)
1½ × 1½ × 1¼	29.7 (1.17)	26.4 (1.04)	20.6 (0.81)
1½ × 1¼ × 1½	34.5 (1.36)	34.5 (1.36)	23.9 (0.94)
1½ × 1¼ × 1¼	31.2 (1.23)	28.2 (1.11)	23.9 (0.94)
2	42.4 (1.67)	45.7 (1.80)	26.9 (1.06)
2 × 2 × 1½	37.6 (1.48)	31.2 (1.23)	22.4 (0.88)
2 × 2 × 1¼	36.1 (1.42)	26.4 (1.04)	19.1 (0.75)
2 × 1½ × 2	42.9 (1.69)	45.7 (1.80)	33.3 (1.31)
2 × 1½ × 1½	37.6 (1.48)	33.0 (1.30)	30.2 (1.19)
3	63.8 (2.51)	70.4 (2.77)	42.9 (1.69)
3 × 3 × 2	54.4 (2.14)	45.0 (1.77)	28.7 (1.13)
3 × 3 × 1½	49.5 (1.95)	32.3 (1.27)	23.9 (0.94)
3 × 3 × 1¼	48.0 (1.89)	25.7 (1.01)	20.6 (0.81)
4	95.5 (3.76)	95.5 (3.76)	52.3 (2.06)

GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.

Table 9-7
Dimensions of DWV Caps




DWV Caps
C

Nominal Tube Size	A
1¼	18 (0.69)
1½	19 (0.75)
2	21 (0.81)

GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.

Table 9-8
Dimensions of DWV Vent Increasers




DWV Vent Increasers
C × FTG

Nominal Tube Size	A	B, Max.
3 × 4 × 18	457 (18)	76 (3)
3 × 4 × 24	610 (24)	76 (3)
3 × 4 × 30	762 (30)	76 (3)


GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.

Table 9-9
Dimensions of DWV Closet Flanges




Size 4 Closet Flange

Size 3 Closet Flange



Quarter Slot With Holes



Half Slot

Suggested Slot Arrangements

Nominal Size	D, Min.	DD	EE	UU, Min.	V, Min. [Note (3)]	W
3	171.5 (6.75)	152 (6.0)	105 (4.12)	39.6 (1.56)	74.7 (2.94)	6.4 (0.25)
4	171.5 (6.75)	152 (6.0)	... (...)	15.7 (0.62)	... (...)	6.4 (0.25)

GENERAL NOTE: Dimensions are in millimeters with inch values in parentheses.

NOTES:

- (1) Tube stop optional.
- (2) 45-deg angle may be extended to face of flange.
- (3) For flange with tube stop.