



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 31: Equipment dust ignition protection by enclosure "t"**

**Atmosphères explosives –
Partie 31: Protection contre l'inflammation de poussières par enveloppe "t"
relative au matériel**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

N

ICS 29.260.20

ISBN 978-2-8322-1185-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 General	7
4.1 Levels of protection.....	7
4.2 Equipment groups and ingress protection.....	7
4.3 Requirements for electrical equipment with level of protection “ta”	8
4.3.1 Fault current	8
4.3.2 Maximum surface temperature.....	8
4.3.3 Overpressure.....	8
4.3.4 Dust exclusion	8
4.3.5 Protective devices	8
4.3.6 Protection for arcing and sparking parts.....	9
4.4 Requirements for electrical equipment with Level of Protection “tb” and “tc”.....	9
4.4.1 Maximum surface temperature.....	9
4.4.2 Over pressure.....	9
4.4.3 Dust exclusion	9
5 Construction	9
5.1 Joints	9
5.1.1 General	9
5.1.2 Threaded joints.....	10
5.1.3 Gaskets and seals	10
5.1.4 Cemented joints.....	10
5.1.5 Operating rods, spindles and shafts.....	10
5.1.6 Windows.....	10
5.2 Cable glands.....	11
5.3 Entries	11
5.3.1 Plain entries	11
5.3.2 Threaded entries	11
6 Verification and tests	11
6.1 Type tests	11
6.1.1 Type tests for dust exclusion by enclosures.....	11
6.1.2 Thermal tests.....	12
6.2 Routine tests.....	12
7 Marking	12
Bibliography.....	14
Table 1 – Level of Protection, equipment group and ingress protection (IP) relationship	7

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –

Part 31: Equipment dust ignition protection by enclosure "t"

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-31 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This second edition cancels and replaces the first edition published in 2008. This edition constitutes a technical revision.

The significance of changes between IEC 60079-31, Edition 2.0 (2012) and IEC 60079-31, Edition 1.0 (2008) (including Corrigendum) is as listed below:

Changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Document has been restructured from the first edition	Numerous	X		
The marked maximum surface temperature shall be measured on the external surfaces of the enclosure and the surfaces of the internal components for equipment with types of protection “ta”	4.3.2			C1
Additional protection for arcing and sparking parts for “ta”	4.3.6			C2
Limiting the internal pressure test to enclosures where the seal is not physically constrained from moving.	4.4.2		X	
Requirements for tapered threaded joints without an additional seal or gasket added.	5.1.2		X	
Requirements for cable gland aligned for all levels and Groups the only difference is now the required IP protection	5.2	X		
Requirements for plain entries added	5.3.1		X	
5 threads for parallel threads only required when no seal is used	5.3.2		X	
Test for internal enclosure for level “ta” added.	6.1.1.2			C 3
Eliminating of the “fault” table and reduction of the dust layer depth for the thermal test for type of protection “ta”.	6.1.2		X	

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version. More guidance may be found by referring to the Redline Version of the standard.

Explanations:

A) Definitions

Minor and editorial changes

- clarification
- decrease of technical requirements
- minor technical change
- editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

Extension addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

Major technical changes

addition of technical requirements
increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of 'Major Technical Changes'

C1 – A requirement was added for “ta” to require the temperature marking to be based on the highest of either the temperature produced by the internal components or the external surface temperature.

C2 – Requirements were added for “ta” equipment that contains a normally arcing part to require a supplementary internal enclosure around the arcing part.

C3 – Requires an impact test on the supplementary enclosure for “ta” equipment.

The text of this standard is based on the following documents:

FDIS	Report on voting
31/1079/FDIS	31/1094/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This International Standard is to be used in conjunction with IEC 60079-0.

A list of all parts of the IEC 60079 series, under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

EXPLOSIVE ATMOSPHERES –

Part 31: Equipment dust ignition protection by enclosure "t"

1 Scope

This part of IEC 60079 is applicable to electrical equipment protected by enclosure and surface temperature limitation for use in explosive dust atmospheres. It specifies requirements for design, construction and testing of electrical equipment and Ex Components.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard takes precedence.

This standard does not apply to dusts of explosives, which do not require atmospheric oxygen for combustion, or to pyrophoric substances.

This standard does not apply to electrical equipment or Ex Components intended for use in underground parts of mines as well as those parts of surface installations of such mines endangered by firedamp and/or combustible dust.

This standard does not take account of any risk due to an emission of flammable or toxic gas from the dust.

Consideration of additional protective measures is required where the application of electrical equipment is in atmospheres, which can contain combustible dust as well as explosive gas, whether simultaneously or separately.

Where the electrical equipment has to meet other environmental conditions, for example, protection against ingress of water and resistance to corrosion, additional measures can be necessary. The measures used should not adversely affect the integrity of the enclosure.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60127 (all parts), *Miniature fuses*

IEC 60691, *Thermal-links – Requirements and application guide*

ISO 965-1, *ISO general-purpose metric screw threads – Tolerances – Part 1: Principles and basic data*

SOMMAIRE

AVANT-PROPOS	17
1 Domaine d'application	20
2 Références normatives	20
3 Termes et définitions	21
4 Généralités	21
4.1 Niveaux de protection	21
4.2 Groupes de matériels et protection contre la pénétration	21
4.3 Exigences relatives aux matériels électriques avec le niveau de protection "ta"	22
4.3.1 Courant de défaut	22
4.3.2 Température maximale de surface	22
4.3.3 Surpression	22
4.3.4 Exclusion des poussières	22
4.3.5 Dispositifs de protection	22
4.3.6 Protection pour les parties produisant des arcs et des étincelles	23
4.4 Exigences relatives aux matériels électriques avec des niveaux de protection "tb" et "tc"	23
4.4.1 Température maximale de surface	23
4.4.2 Surpression	24
4.4.3 Exclusion des poussières	24
5 Construction	24
5.1 Joints	24
5.1.1 Généralités	24
5.1.2 Joints filetés	24
5.1.3 Garnitures et scellements	24
5.1.4 Joints scellés	25
5.1.5 Tiges de manœuvre, broches et arbres de puissance	25
5.1.6 Fenêtres	25
5.2 Entrées de câbles	25
5.3 Entrées	25
5.3.1 Entrées lisses	25
5.3.2 Entrées filetées	26
6 Vérification et essais	26
6.1 Essais de type	26
6.1.1 Essais de type pour l'exclusion des poussières par enveloppe	26
6.1.2 Essais thermiques	27
6.2 Essais individuels de série	27
7 Marquage	27
Bibliographie	28
Tableau 1 – Relation entre le Niveau de Protection, le groupe de matériels et la protection contre la pénétration (Ingress Protection (IP))	22

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

ATMOSPHÈRES EXPLOSIVES –

Partie 31: Protection contre l'inflammation de poussières par enveloppe "t" relative au matériel

AVANT-PROPOS

- 1) La Commission Électrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. À cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études; aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de la CEI. La CEI n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de brevet. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

La Norme internationale CEI 60079-31 a été établie par le comité d'études 31 de la CEI: Équipements pour atmosphères explosives.

Cette deuxième édition annule et remplace la première édition parue en 2008. Cette édition constitue une révision technique.