

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC 60079-11
Edition 6.0 2011-06

EXPLOSIVE ATMOSPHERES –

Part 11: Equipment protection by intrinsic safety "i"

INTERPRETATION SHEET 5

This interpretation sheet has been prepared by subcommittee 31G: Intrinsically-safe apparatus, of IEC technical committee 31: Equipment for explosive atmospheres.

The text of this interpretation sheet is based on the following documents:

DISH	Report on voting
31G/306/DISH	31G/308/RVDISH

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

BACKGROUND

As stated in the scope of Edition 6 of IEC 60079-11 (2011), the standard supplements and modifies the general requirements of IEC 60079-0. Subsequent to the publication of Edition 6 of IEC 60079-11, IEC 60079-0 was revised. The revised version of IEC 60079-0 (Edition 7:2017) now contains the 200 mm dust blanketing temperature test for Group III Da equipment (Subclause 5.3.2.3.1), relocated from IEC 60079-18 and IEC 60079-31.

QUESTIONS

- 1) Does the alternative approach of IEC 60079-11:2011 for equipment with components dissipating less power than given in Table 4 and with continuous short-circuit current less than 250 mA still apply when assessing according to IEC 60079-0:2017?
- 2) Is it necessary to conduct the 200 mm dust blanket temperature testing of Group III EPL Da intrinsically safe apparatus when applying IEC 60079-0:2017 in situations where the power limits of IEC 60079-11:2011 Table 4 are exceeded?