

INTERNATIONAL STANDARD



**Low-voltage electrical installations –
Part 5-56: Selection and erection of electrical equipment – Safety services**

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 RLV



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2018 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IECNORM.COM : Click to view the full text of IEC 60384-5-56:2018 PLV



IEC 60364-5-56

Edition 3.0 2018-11
REDLINE VERSION

INTERNATIONAL STANDARD



**Low-voltage electrical installations –
Part 5-56: Selection and erection of electrical equipment – Safety services**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 91.140.50

ISBN 978-2-8322-6220-7

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	3
560.1 Scope	6
560.2 Normative references.....	6
560.3 Terms and definitions.....	7
560.4 Classification	9
560.5 General.....	10
560.6 Electrical sources for safety services	10
560.7 Electrical circuits of safety services.....	13
560.8 Wiring systems	14
560.9 Emergency-escape lighting applications.....	15
560.10 Fire protection applications/equipment.....	17
Annex A (informative) Guidance for emergency lighting	18
Annex B (informative) Guidance for fire protection equipment.....	20
Annex C (informative) List of notes concerning certain countries.....	22
Annex D (informative) Fire switch	29
Annex E (informative) Example of installation methods of safety services with cable management system.....	30
Annex F (informative) Wiring systems	31
F.1 Ambient test temperature rise	31
F.2 Duration of the safety service.....	31
F.3 Expected resistance of feeder conductors.....	31
F.4 Protection against electric shock in the event of a failure by means of the touch voltage reduction	32
F.5 Conductor resistance in case of fire	32
F.6 High temperature effects.....	33
F.7 Feeder circuits	33
Annex G (informative) Guidance on suitable locations for electrical sources for safety services	34
G.1 Recommendations for a suitable location for an electrical source for safety services	34
G.2 Conditions of fire protection	34
Bibliography.....	35
Figure D.1 – Fire switch installation	29
Figure E.1 – Example of cable installation for safety services	30
Table A.1 – Guidance for emergency lighting.....	18
Table B.1 – Guidance for safety equipment.....	20

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 5-56: Selection and erection of electrical equipment – Safety services

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 60364-5-56 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- 1) Modifications to normative references and terms and definitions.
- 2) Under electrical circuits for safety services, addition of requirements concerning circuit and overcurrent protection in order to maintain reliability of safety service power supplies under fire conditions.
- 3) Under electrical circuits for safety services, addition of requirements stating that circuits for safety services are not to be protected by RCDs or AFDDs.
- 4) Under emergency lighting applications, addition of requirements to prevent emergency lighting systems being adversely affected by any control system.
- 5) Addition of requirements for all emergency luminaires in the area to provide full design light output in the event of any final circuit failure.
- 6) Addition of a new Annex D (informative): Fire switch.
- 7) Addition of a new Annex E (informative): Example of installation methods of safety services with cable management system.
- 8) Addition of a new Annex F (informative): Wiring systems.
- 9) Addition of a new Annex G (informative): Guidance on suitable locations for electrical sources for safety services.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
64/2316/FDIS	64/2341/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this standard.

A list of all parts in the IEC 60364 series, published under the general title *Low-voltage electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 RLV

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 5-56: Selection and erection of electrical equipment – Safety services

560.1 Scope

This part of IEC 60364 covers general requirements for safety services, selection and erection of electrical supply systems for safety services and ~~electrical safety sources~~ the electrical source for safety services.

Standby electrical supply systems are outside the scope of this document. This document does not apply to installations in hazardous areas (BE3), for which requirements are given in IEC 60079-14.

560.2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60331 (all parts), *Tests for electric cables under fire conditions – Circuit integrity*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

~~IEC 60364-4-43:2008, Low-voltage electrical installations – Part 4-43: Protection for safety – Protection against overcurrent~~

IEC 60364-5-52, *Low-voltage electrical installations – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60598-2-22, *Luminaires – Part 2-22: Particular requirements – Luminaires for emergency lighting*

IEC 60702-1, *Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V – Part 1: Cables*

IEC 60702-2, *Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V – Part 2: Terminations*

~~IEC 62040-1-1, Uninterruptible power systems (UPS) – Part 1-1: General and safety requirements for UPS in operator access areas~~

~~IEC 62040-1-2, Uninterruptible power systems (UPS) – Part 1-2: General and safety requirements for UPS used in restricted access locations~~

IEC 62040-1, *Uninterruptible power systems (UPS) – Part 1: Safety requirements*

IEC 62040-2, *Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements*

IEC 62040-3, *Uninterruptible power systems (UPS) – Part 3: Method of specifying the performance and test requirements*

ISO 8528-12, *Reciprocating internal combustion engine driven alternating current generating sets – Part 12: Emergency power supply to safety services*

~~GIE S 020~~ ISO 30061:2007, *Emergency lighting*

560.3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

560.3.1

electrical supply system for safety services

supply system intended to maintain the operation of essential parts of an electrical installation and equipment

- for the health and safety of persons and livestock, and/or
- to avoid damage to the environment and to other equipment

Note 1 to entry: The supply system includes the source and the electrical circuits up to the terminals of electrical equipment.

~~NOTE 2—Examples of safety services include:~~

- ~~— emergency (escape) lighting;~~
- ~~— fire pumps;~~
- ~~— fire rescue services/lifts;~~
- ~~— alarm systems, such as fire alarms, CO alarms and intruder alarms;~~
- ~~— evacuation systems;~~
- ~~— smoke extraction systems;~~
- ~~— essential medical systems.~~

560.3.2

electrical source for safety services

electrical source intended to be used as part of an electrical supply system for safety services

560.3.3

electrical circuits for safety services

electrical circuits intended to be used as part of an electrical supply system for safety services

560.3.4

standby electrical supply system

supply system intended to maintain, for reasons other than safety, the functioning of an electrical installation or parts thereof, in case of interruption of the normal supply

**560.3.5
standby electrical source**

electrical source intended to maintain, for reasons other than safety, the supply to an electrical installation or parts thereof, in case of interruption of the normal supply

**560.3.6
emergency lighting**

lighting provided for use when the supply to the normal lighting fails

[SOURCE: ~~CIE S 0-20~~/ISO 30061:2007, 4.1]

**560.3.7
emergency lighting luminaire**

luminaire which may or may not be provided with its own electrical source for safety services and which is used for safety or emergency lighting

**560.3.8
escape sign luminaire**

luminaire that indicates and assists the identification of escape routes

**560.3.9
maintained mode**

operating mode of a lighting system in which the emergency lighting lamps are energized at all times when normal or emergency lighting is required

**560.3.10
non-maintained mode**

operating mode of a lighting system in which the emergency lighting lamps are in operation only when the supply to the normal lighting fails

**560.3.11
response time**

time that elapses between the failure of the normal power supply and the ~~auxiliary power supply~~ electrical source for safety services energizing the equipment

**560.3.12
central power supply system (unlimited power)**

system which supplies the required emergency power to essential safety equipment ~~without any limitation in power output~~

**560.3.13
central low power supply system (low power output)**

~~central power supply system with a limitation of the power output of the system at 500 W for 3 h or 1 500 W for 1 h~~

~~NOTE A low-power supply system normally comprises a maintenance-free battery and a charging and testing unit.~~

**560.3.13
escape route**

~~path~~ route to follow for access to a safe area in the event of an emergency

**560.3.14
preferential circuit**

~~safety source~~ circuit derived directly from the incoming supply to the building intended to supply safety services which, in case of emergency, shall remain in operation for as long as possible

~~NOTE An example of such a safety service is sprinkler pumps.~~

560.3.15
minimum illuminance

illuminance for emergency lighting ~~at the end of~~ throughout the whole rated operating time

560.3.16
safety service

electrical system for electrical equipment provided to protect or warn persons in the event of a hazard, or essential to their evacuation from a location

EXAMPLE:

- emergency (escape) lighting;
- fire pumps;
- fire rescue services lifts;
- alarm systems, such as fire alarms, CO alarms and intruder alarms;
- evacuation systems;
- smoke extraction systems;
- essential medical systems.

Note 1 to entry: Safety services is equipment installed in buildings to detect fire or danger in its initial stage, also limit fire spread and extinguish fire and control smoke and enable safe and effective evacuation

560.3.17
fire condition

condition defined by the temperature-time curve of ISO 834-1, or by local legislation

560.3.18
suitable location

constructional enclosure or separate fire protected compartment or room ensuring normal operation of equipment under fire conditions

560.3.19
fire switch

electrical apparatus, which shall be used to disconnect all circuits with the exception of circuits supplying the equipment whose operation during a fire is necessary

Note 1 to entry: The installation and characteristics of fire switch are described in Annex D (informative).

Note 2 to entry: The switch could be a circuit breaker or disconnector.

560.4 Classification

560.4.1 An electrical supply system for safety services is either:

- a non-automatic supply system, the starting of which is initiated by an operator, or
- an automatic supply system, the starting of which is independent of an operator.

An automatic supply system is classified as follows, according to the maximum changeover time:

- class A – no-break: an automatic supply system which can ensure a continuous supply within specified conditions during the period of transition, for example as regards variations in voltage and frequency;
- class B – very short break: an automatic supply system available within 0,15 s;
- class C – short break: an automatic supply system available within 0,5 s;
- class D – average break: an automatic supply system available within 5 s;
- class E – medium break: an automatic supply system available within 15 s;
- class F – long break: an automatic supply system available in more than 15 s.

560.4.2 The essential equipment for safety services shall be ~~compatible with the changeover time~~ within the specified class according to 560.4.1 in order to maintain the specified operation.

560.5 General

560.5.1 Safety services may be required to operate at all relevant times including during main and local supply failure and through fire conditions. To meet these requirements, specific sources, equipment, circuits and wiring are necessary. Some applications also have particular requirements, as in 560.5.2 and 560.5.3.

560.5.2 For safety services required to operate in fire conditions, the following additional ~~two~~ conditions shall be fulfilled:

- ~~— an electrical source for safety supply shall be selected in order to maintain a supply of adequate duration, and~~
- ~~— all equipment of safety services shall be provided, either by construction or by erection, with protection ensuring fire resistance of adequate duration.~~
- one or more electrical sources for safety services shall be provided to maintain a supply of adequate duration, except for preferential circuits and all equipment of safety services shall be provided, either by construction or by erection, with fire protection ensuring normal operation in fire conditions of adequate duration.

NOTE 1 Equipment includes for example, power sources, feeder conductors, cable management systems, junction boxes.

NOTE 2 The electrical ~~safety supply source~~ source for safety services is generally additional to the normal supply source, for example the public supply network.

NOTE 3 Local legislation can apply.

560.5.3 ~~Where automatic disconnection of supply is used as a protective measure against electric shock, non-disconnection on the first fault is preferred.~~ An IT system is preferred where non-disconnection on the first fault is required. In IT systems for safety services, insulation monitoring devices shall be provided which give an audible and visible indication in the event of a first fault.

NOTE For IT systems after first fault see IEC 60364-4-41:2005, 411.6.4.

560.5.4 ~~Regarding control and bus systems, a failure in the control or bus system of a normal installation shall not adversely affect the function of safety services.~~ A failure in the control or bus systems (control technology) of the non-safety services installation shall not adversely affect the proper function of safety services. This applies to control or bus systems of different safety services as well.

560.6 Electrical sources for safety services

560.6.1 The following electrical sources for safety services are recognized:

- storage batteries;
- primary cells;
- generator sets independent of the normal supply;
- a separate feeder of the supply network that is effectively independent of the normal feeder.

560.6.2 ~~Safety sources~~ The electrical source for safety services shall be installed as fixed equipment and in such a manner that ~~they~~ it cannot be adversely affected by failure of the normal source.

560.6.3 ~~Safety sources~~ The electrical source for safety services shall be installed in a suitable location and be accessible only to skilled or instructed persons (BA5 or BA4). Electrical sources for safety services should be segregated from other sources.

Safety services and sources shall be designed and located so as to minimize hazards that could cause fire, flooding, freezing, vandalism and other adverse conditions and impact the availability of the electrical supply.

NOTE See Annex G for guidance.

560.6.4 The location of the ~~safety source~~ electrical source for safety services shall be properly and adequately ventilated so that exhaust gases, smoke or fumes from the safety source cannot penetrate areas occupied by persons.

560.6.5 Separate, independent feeders from a supply network shall not serve as electrical sources for safety services unless assurance can be obtained that the two supplies are unlikely to fail concurrently.

560.6.6 The ~~safety source~~ electrical source for safety services shall have sufficient capability to supply its related safety service.

560.6.7 ~~A safety source~~ An electrical source for safety services may, in addition, be used for purposes other than safety services, provided the availability for safety services is not thereby impaired. A fault occurring in a circuit for purposes other than safety services shall not cause the interruption of any circuit for safety services.

560.6.8 There are special requirements for safety sources not capable of operation in parallel.

~~560.6.8.1~~ Adequate precautions shall be taken to avoid the paralleling of sources.

Short circuit protection and fault protection within the electrical supply system for safety services shall be provided for each source.

~~NOTE This may be achieved by mechanical interlocking.~~

~~560.6.8.2~~ Short circuit protection and fault protection shall be ensured for each source.

~~560.6.9~~ ~~Special requirements for safety services having sources capable of operation in parallel~~

~~NOTE 1 The parallel operation of independent sources normally requires the authorization of the supply undertaking. This may require special devices, for example to prevent reverse power.~~

~~Short circuit protection and fault protection shall be ensured when the installation is supplied separately by either of the two sources or by both in parallel.~~

~~NOTE 2 Precautions may be necessary to limit current circulation in the connection between the neutral points of the sources, in particular the effect of third harmonics.~~

~~560.6.10~~ ~~Central power supply system~~

~~Batteries shall be of vented or valve-regulated maintenance-free type and shall be of heavy duty industrial design, for example cells complying with IEC 60623 or the IEC 60896 series.~~

~~NOTE The minimum design life of the batteries at 20 °C should be 10 years.~~

~~**560.6.11 Low-power supply system**~~

~~The power output of a low-power supply system is limited to 500 W for a 3 h duration and 1500 W for a 1 h duration. Batteries can be of gas-tight or valve-regulated maintenance-free type and shall be of heavy duty industrial design, for example cells complying with IEC 60623 or the IEC 60896 series.~~

~~NOTE The minimum design life of the batteries at 20 °C should be 5 years.~~

~~**560.6.12 Uninterruptible power supply sources**~~

~~Where an uninterruptible power supply is used, it shall:~~

- ~~a) be able to operate distribution circuit protective devices, and~~
- ~~b) be able to start the safety devices when it is operating in the emergency condition from the inverter supplied by the battery, and~~
- ~~c) comply with the requirements of 560.6.10, and~~
- ~~d) comply with IEC 62040-1-1, IEC 62040-1-2 or IEC 62040-3, as applicable.~~

~~**560.6.13 Safety generating sets**~~

~~Where a safety generating set is used as a safety source, it shall comply with ISO 8528-12.~~

560.6.9 There are special requirements for safety services having sources capable of operation in parallel.

The parallel operation of independent sources may require special devices, for example to prevent reverse power.

NOTE The parallel operation of independent sources with the public supply can require the authorization of the supply undertaking.

Fault protection and short circuit protection shall be provided when installation is supplied separately by either of the two sources or by both in parallel.

Precautions shall be taken to limit current circulation in the connection between the neutral points of the sources, in particular the effect of triple harmonics.

560.6.10 There are requirements for a central power supply system.

Batteries shall be of vented or valve-regulated type with reduced maintenance and shall be of heavy duty industrial design, for example cells complying with IEC 60623 or IEC 60896 (all parts). This does not preclude proven new technologies. The minimum design life of the batteries at 20 °C shall be 10 years.

560.6.11 Where an uninterruptible power supply (UPS) is used, it shall:

- a) be able to operate all protective devices located on the load side of the UPS,
- b) be able to start the safety services when it is operating in the emergency condition,
- c) comply with the requirements of 560.6.10, as applicable,
- d) comply with IEC 62040-1, IEC 62040-2 or IEC 62040-3, as applicable, and
- e) be able to be started independently of the availability of the upstream supply.

560.6.12 Where a safety generating set is used as an electrical source for safety services, a diesel engine driven generating set shall comply with ISO 8528-12.

560.6.13 The condition of the electrical source for safety services (ready for operation, under fault conditions, feeding from the electrical source for safety services) shall be monitored.

560.7 Electrical circuits of safety services

560.7.1 Circuits of safety services shall be independent of other circuits.

NOTE An electrical fault or any ~~intervention or~~ modification in one system ~~must~~ shall not affect the correct functioning of the other. This may necessitate separation by fire-resistant materials or different routes or enclosures.

560.7.2 Circuits of safety services shall not pass through locations exposed to fire risk (BE2 due to nature of processed or stored materials) unless they are fire-resistant. The circuits shall not, in any case, pass through zones exposed to explosion risk (BE3).

NOTE Where practicable, the passage of any circuit through locations presenting a fire risk should be avoided.

560.7.3 In accordance with IEC 60364-4-43:2008, 433.3.3, protection against overload may be omitted where the loss of supply may cause a greater hazard. Where protection against overload is omitted, the occurrence of an overload shall be monitored.

560.7.4 Overcurrent protective devices shall be selected and erected so as to avoid an overcurrent in one circuit impairing the correct operation of circuits of safety services.

560.7.5 Switchgear and controlgear shall be clearly identified and grouped in locations accessible only to skilled or instructed persons (BA5 or BA4).

560.7.6 In equipment supplied by two different circuits ~~with independent sources~~, a fault occurring in one circuit shall not impair the protection against electric shock, nor the correct operation of the other circuit. Such equipment shall be connected to the protective conductors of both circuits, if necessary.

~~**560.7.7** Safety circuit cables, other than metallic screened, fire-resistant cables, shall be adequately and reliably separated by distance or by barriers from other circuit cables, including other safety circuit cables.~~

~~**NOTE** For battery cables, special requirements may apply.~~

560.7.7 Circuits for safety services, with the exception of wiring for fire and rescue services lift supply cables, and wiring for lifts with special requirements, shall not be installed in lift shafts or other flue-like openings (location).

560.7.8 In addition to a general schematic overview diagram, full details of all electrical ~~safety sources~~ sources for safety services shall be given. Information shall be maintained adjacent to the distribution board. A single line diagram is sufficient.

560.7.9 Drawings of the electrical safety installations shall be ~~available~~ provided showing the exact location of:

- all electrical equipment and distribution boards, with equipment designations;
- safety equipment with final circuit designation and particulars and purpose of the equipment;
- special switching and monitoring equipment for the safety power supply (e.g. area switches, visual or acoustic warning equipment).

560.7.10 A list of all the current-using equipment permanently connected to the safety power supply, indicating the nominal electrical power, nominal currents and starting currents and time for current-using equipment, shall be provided.

NOTE This information ~~may be~~ is often included in circuit diagrams.

560.7.11 Operating instructions for safety equipment and electrical safety services shall be available. They shall take into account all the particulars of the installation.

560.7.12 The circuit and overcurrent protection shall be considered in order to maintain reliability of power supply of the safety services under fire conditions. See also 560.6.8.2.

560.7.13 Circuits of safety services shall not be protected by RCDs or AFDDs.

NOTE At elevated temperatures under fire conditions, leakage currents between conductors can occur leading to unwanted tripping and loss of safety service.

560.8 Wiring systems

560.8.1 One or more of the following wiring systems shall be utilized for safety services required to operate in fire conditions:

- mineral insulated cable complying with IEC 60702-1 and IEC 60702-2 and IEC 60332-1-2;
- fire-resistant cables complying with the appropriate part of the IEC 60331 series and with IEC 60332-1-2;
- a wiring system maintaining the necessary fire and mechanical protection.

Wiring systems and their fixings shall be mounted and installed in such a way that the circuit integrity will not be impaired during the fire.

In long vertical installations wiring systems shall have fire protection for their fixings to ensure that under fire condition, cable fixings do not allow the cables to collapse prematurely.

NOTE 1 Examples of a system maintaining the necessary fire and mechanical protection could be constructional enclosures to maintain fire and mechanical protection, or wiring systems in separate fire protected compartments.

NOTE 2 National legislation ~~may~~ can exist.

560.8.2 Wiring for control and bus systems of safety services shall be in accordance with the same requirements as the wiring which is to be used for the safety services. This does not apply to circuits that do not adversely affect the operation of the safety equipment.

This requirement also includes control and bus systems for self-contained luminaires. Wireless control and bus systems shall be considered in an equivalent way.

560.8.3 ~~Precautions shall be taken to prevent excavation damage to buried safety circuits.~~

Circuits for safety services which can be supplied by direct current shall be provided with two-pole overcurrent ~~protection mechanisms~~ protective devices.

560.8.4 The higher resistance of conductors due to high temperature when exposed to fire shall be taken into account when sizing the conductor cross-sectional area.

NOTE Information is given in Annex F for cables with copper conductors.

560.8.5 The wiring systems of safety services should be segregated from other services other than metallic screened fire-resistant cables and installed in such a manner that the safety services are not affected by any fault occurring on non-safety services and mitigate the

effects of a fire. An example of cables installed for safety services is shown in a diagram in Annex E.

NOTE For battery cables, special requirements can apply.

560.8.6 Precautions shall be taken to prevent excavation damage to buried electrical circuits for safety services.

560.8.7 Switchgear and controlgear used for both AC and DC supply sources shall be suitable for both AC and DC operation.

560.9 Emergency ~~escape~~ lighting applications

560.9.1 Emergency ~~escape~~ lighting systems may be powered by a central power supply system or the emergency lighting luminaires may be self-contained. Emergency lighting luminaires shall comply with IEC 60598-2-22. The supply to self-contained emergency lighting luminaires is excluded from the requirements of ~~560.9.1 to 560.9.4 inclusive~~ 560.9.2.

560.9.2 Wiring systems for a centrally powered emergency lighting system shall retain the continuity of supply from the source to each fire protected compartment where the emergency lighting luminaires are installed for an adequate period in the event of a fire. This shall be achieved by using ~~cables~~ wiring systems with a high resistance to fire, as detailed in 560.8.1 and 560.8.2, to transfer power through ~~a~~ other fire protected compartments.

~~Within the fire compartment, the supplies to the luminaire shall either use cables with a high resistance to attack by fire or, for compartments having more than one emergency lighting luminaire, such luminaires shall be wired alternately from at least two separate circuits so that a level of illuminance is maintained along the escape route in the event of the loss of one circuit.~~

Within fire protected compartments where the emergency lighting luminaires are installed, the wiring system between emergency lighting luminaires has no requirements against fire.

For fire protected compartments having more than one emergency lighting luminaire, such emergency lighting luminaires shall be wired alternately from at least two separate circuits so that a suitable level of illuminance is maintained along the escape route in the event of the loss of one circuit.

560.9.3 Where alternate emergency lighting luminaires are supplied by separate circuits, overcurrent protective devices shall be used so that a short-circuit in one circuit does not interrupt the supply to the adjacent emergency lighting luminaires within the fire protected compartment or the emergency lighting luminaires in other fire protected compartments.

No more than 20 emergency lighting luminaires with a total load not exceeding 60 % of the nominal current of the overcurrent protective device shall be supplied from any final circuit.

~~Any circuit distribution, control or protective devices shall not impair the circuit integrity.~~

560.9.4 A safe value of minimum illuminance, response time and rated operation time is required to enable evacuation of a building. Where there are no national or local rules, illumination systems ~~should~~ shall comply with ~~CIE S 020/~~ISO 30061:2007.

NOTE Guidance on appropriate systems is given in Annex A (see Table A.1).

560.9.5 Emergency lighting shall be wired in maintained or non-maintained mode. These modes may also be combined.

560.9.6 In the non-maintained mode, the power supply for the normal lighting shall be monitored at ~~the final circuit for~~ that area. If a loss of supply to the normal lighting in an area causes the normal lighting to fail, the emergency lighting shall be activated automatically. In all cases, arrangements shall be made to ensure that local emergency ~~escape~~ lighting will operate in the event of failure of normal supply to the corresponding local area.

560.9.7 Where maintained and non-maintained modes are used in combination, the changeover devices shall each have their own monitoring device and shall be able to be switched separately.

560.9.8 The maintained mode of emergency lighting may be simultaneously switched with normal lighting in locations which either

- cannot be darkened when in use, or
- are not constantly occupied.

~~**560.9.8** Control and bus systems for safety illumination shall be independent of control and bus systems for general illumination; coupling of both systems is permitted only with interfaces that ensure a decoupling/isolation of both busses from each other. A failure in the control and bus system of the general illumination shall not influence the proper function of the safety illumination.~~

560.9.9 Emergency lighting systems shall not be adversely affected by any control systems. Any future modifications of the control systems shall continue to comply with this functional safety requirement. If a failure causes normal lighting in an area to fail, all emergency lighting luminaires in the area shall operate. The emergency lighting luminaires in the area shall provide full emergency design light output.

NOTE 1 For the definition of functional safety see IEC 61508-4:2010, 3.1.12.

NOTE 2 Here failure means a loss of supply or a failure of the control system.

560.9.10 Changeover from normal to emergency mode shall start automatically if the supply voltage drops below 0,6 times the rated supply voltage for at least 0,5 s. ~~+~~ Normal mode shall be restored if the supply voltage is greater than 0,85 times the rated supply voltage.

NOTE 1 The actual time for changeover ~~may~~ can depend on national rules.

NOTE 2 The level of changeover depends on the equipment used for safety services.

560.9.11 When the normal supply is restored to the distribution board or monitored circuit, the emergency lighting in non-maintained mode shall automatically switch off. Account shall be taken of the time necessary for the lamps in the normal lighting to return to normal luminance. Account shall also be taken of rooms which had been intentionally 'blacked-out' before the supply was lost; in these cases, emergency lighting shall not switch off automatically.

~~**560.9.11** In addition to central switching, it is permissible to monitor and control the supply to parts of a building which are occupied.~~

560.9.12 In emergency lighting systems the type of lamps shall be compatible with the changeover time in order to maintain the specified lighting level.

560.9.13 Control switches for emergency lighting shall be placed at a designated location and be arranged and installed in such a way that they cannot be operated by unauthorized persons.

560.9.14 The switched-on position of the emergency lighting shall be indicated at a convenient location for each source of supply.

560.9.15 Emergency lighting luminaires and associated circuit equipment shall be identified by for example a red label of at least 30 mm in diameter.

560.9.16 A switching facility may be provided to prevent discharging of the electrical storage source for safety services when the building is not occupied

560.9.17 Each single phase circuit shall have its own neutral conductor. A common neutral for more than one circuit is not permitted.

560.10 Fire protection applications/equipment

560.10.1 Wiring systems for fire detection and firefighting power supplies shall be supplied by a separate circuit from the main incoming supply.

If a fire switch is required, conductors supplying fire protection equipment whose operation is necessary during a fire, shall be connected at the power supply side of the fire switch. It shall be clearly identified.

NOTE If a fire switch is required to disconnect all non-safety services an example of such a system is shown in a schematic diagram in informative Annex D.

560.10.2 Preferential circuits, if any, shall be directly connected on the supply side of the isolating switch of the main distribution board.

~~NOTE—A private distribution network is regarded as equivalent to the distribution network of a public electricity company.~~

560.10.3 Alarm devices shall be clearly identified.

560.10.4 Except where there are applicable national rules, the minimum requirements for fire protection systems should be in accordance with Annex B. See Table B.1.

Annex A
(informative)

Guidance for emergency lighting

The values in ~~CIE S-020~~/ISO 30061:2007 should be considered but additional details of suitable systems are given in Table A.1. Annex A serves as an informative guide for countries that do not have specific rules or their own guidelines.

Table A.1 – Guidance for emergency lighting

Examples of applications	Requirements								
	1	2	3	4	5	6	7	8	9
	Extended duration or remote-controlled circuit	Escape sign luminaires in maintained mode	Central power supply system	Low power supply system	Self-contained battery unit	Motor-generator unit with no break (0 s)	Motor-generator unit with short break (<= 0.5 s)	Motor-generator unit with medium break (<= 15 s)	Dual supply system
Assembly halls, assembly rooms	**	✓	✓	✓	✓	✓	✓		
Exhibition halls	**	✓	✓	✓	✓	✓	✓		
Theatres, cinemas	**	✓	✓	✓	✓	✓	✓		
Sports arenas	**	✓	✓	✓	✓	✓	✓		
Sales areas	**	✓	✓	✓	✓	✓	✓		
Restaurants	**	✓	✓	✓	✓	✓	✓		
Hospitals, treatment centres	**	✓	✓	✓	✓	✓	✓	✓	
Hotels, guest houses *	**	✓	✓	✓	✓	✓	✓	✓	
Residential care homes *	**	✓	✓	✓	✓	✓	✓	✓	
High-rise buildings	**	✓	✓	✓	✓	✓	✓	✓	
Schools	**	✓	✓	✓	✓	✓	✓	✓	
Enclosed car parks		✓	✓	✓	✓	✓	✓	✓	
Escape routes in workplaces		-	✓	✓	✓	✓	✓	✓	✓
High-risk task areas		-	✓	✓	✓	✓	✓	✓	✓
Stages	**	✓	✓	✓	✓	✓	✓		
<p>✓ denotes suitable systems.</p> <p>* In premises (guest houses, hotels, residential care homes and high-rise buildings) used the whole day, the rated operating time for the emergency lighting should be 8 h or shall be switchable with illuminated push buttons for a fixed time by the occupants. In this case, the push buttons and their timing equipment should also run in the emergency mode.</p> <p>** Denotes applications which require either extended duration or a circuit like the remote-controlled circuit to ensure protection for longer than 60 min.</p>									

Examples of applications	Requirements							
	1	2	3	4	5	6	7	8
	Extended duration or remote controlled circuit	Escape sign luminaires in maintained mode	Central power supply system	Self-contained battery unit	Motor-generator unit with no break (0 s)	Motor-generator unit with short break (< 0,5 s)	Motor-generator unit with medium break (< 15 s)	Dual supply system
Assembly halls, assembly rooms	**	✓	✓	✓	✓	✓		
Exhibition halls	**	✓	✓	✓	✓	✓		
Theatres, cinemas	**	✓	✓	✓	✓	✓		
Sports arenas	**	✓	✓	✓	✓	✓		
Sales areas	**	✓	✓	✓		✓		
Restaurants	**	✓	✓	✓	✓	✓		
Hospitals, treatment centres	**	✓	✓	✓	✓	✓	✓	
Hotels, guest houses *	**	✓	✓	✓	✓	✓	✓	
Residential care homes *	**	✓	✓	✓	✓	✓	✓	
High-rise buildings *	**	✓	✓	✓	✓	✓	✓	
Schools	**	✓	✓	✓	✓	✓	✓	
Enclosed car parks			✓	✓	✓	✓	✓	
Escape routes in workplaces		-	✓	✓	✓	✓	✓	✓
High risk task areas		-	✓	✓	✓	✓		✓
Stages	**	✓	✓	✓	✓	✓		
Key ✓ Denotes suitable systems. * In premises (guest houses, hotels, residential care homes and high-rise buildings) used the whole day, the rated operating time for the emergency lighting should be 8 h or shall be switchable with illuminated push buttons for a fixed time by the occupants. In this case, the push buttons and their timing equipment should also run in the emergency mode. ** Denotes applications which require either extended duration or a circuit such as a remote controlled circuit to ensure protection for longer than 60 min.								

Annex B (informative)

Guidance for fire protection equipment

Annex B serves as an informative guide for countries that do not have specific rules or their own guidelines.

Table B.1 – Guidance for safety equipment

Examples for safety equipment	Requirements									
	1	2	3	4	5	6	7	8	9	10
	Rated operating time of the source, h	Response time of the source, s, max.	Central power supply system	Low power supply system	Self-contained battery unit	Motor-generator unit with no break (0 s)	Motor-generator unit with short break (< 0,5 s)	Motor-generator unit with medium break (< 15 s)	Dual supply system	Monitoring and changeover in the case of failure of the source
Installations for fire pumps	12	15				✓	✓	✓	✓	✓
Fire rescue service lifts	8	15				✓	✓	✓	✓	✓
Lifts with special requirements	3	15				✓	✓	✓	✓	✓
Devices of alarm and issue of instructions	3	15	✓	✓		✓	✓	✓	✓	✓ ^a
Smoke and heat extraction equipment	3	15	✓	✓	✓	✓	✓	✓	✓	✓ ^a
CO warning equipment	1	15	✓	✓	✓	✓	✓	✓	✓	✓ ^a
^a Only in case of no separate safety supply equipment. ✓ Denotes suitable systems.										

Examples for safety equipment	Requirements								
	1	2	3	4	5	6	7	8	9
	Rated operating time of the source, (h)	Response time of the source, (s. max.)	Central power supply system	Self-contained battery unit	Motor-generator unit with no break (0 s)	Motor-generator unit with short break (< 0,5 s)	Motor-generator unit with medium break (< 15 s)	Dual supply system	Monitoring and changeover in the case of failure of the source
Installations for fire pumps	12	15			✓	✓		✓	✓
Fire rescue service lifts	8	15			✓	✓	✓	✓	✓
Lifts with special requirements	3	15			✓		✓	✓	✓
Devices of alarm and issue of instructions	3	15	✓			✓	✓	✓	✓ ^a
Smoke and heat extraction equipment	3	15	✓	✓	✓	✓	✓	✓	✓ ^a
CO warning equipment	1	15	✓	✓	✓	✓	✓	✓	✓ ^a
Key									
✓ Denotes suitable systems.									
^a Only in case of no separate safety supply equipment.									

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 RLV

Annex C
(informative)

List of notes concerning certain countries

Country	Clause No	Nature (permanent or less permanent according to IEC directives)	Rationale (detailed justification for the requested country note)	Wording
Germany	560.5.2			In Germany, in addition to 560.5.2, statutory building provisions exist regarding more detailed requirements for wiring systems to operate in fire conditions
Norway	560.6.1			In Norway, a separate feeder from the supply network cannot be used as a safety source
Austria	560.6.1			In Austria, primary cells are not allowed for emergency lighting
Germany	560.6.3			In Germany, in addition to 560.6.3, statutory building provisions exist regarding more detailed requirements for wiring systems to operate in fire conditions
	560.6.4			In Germany, in addition to 560.6.4, statutory building provisions exist regarding more detailed requirements for wiring systems to operate in fire conditions
Austria	560.6.5			In Austria, separated independent feeders are e.g. supply from a separate power plant or supply from alternative mains separated up to 110 kV within the mains distribution network
Denmark	560.6.5			In Denmark, it is not allowed to use a separate supply from the public network as safety supply
Austria	560.6.10			In Austria, valve-regulated maintenance-free types are also permitted
Germany	560.7.1			In Germany, in addition to clause 560.7.1 statutory building provisions exist regarding more detailed requirements for wiring systems to operate in fire conditions
	560.7.2			In Germany, in addition to 560.7.2, statutory building provisions exist regarding more detailed requirements for wiring systems to operate in fire conditions
	560.7.7			In Germany, instead of 560.7.7, second sentence, electric cables to operate in fire conditions have to meet the following requirements because of statutory building provisions: — they have to meet the requirements of DIN 4102-12:1998-11 (classes from E—30 to E—90) or — they have to be laid on concrete ceilings and under the screed with a minimum thickness of 30 mm

Country	Clause No	Nature (permanent or less permanent according to IEC directives)	Rationale (detailed justification for the requested country note)	Wording
				or — they have to be laid in the ground
Austria	560.7.7			In Austria, all types of fire-resistant cables complying with DIN 4102-12 are also permitted
Denmark	560.8			In Denmark, to minimize the risk of tensions in the wiring system, it is not allowed to fix the wiring to flammable building parts. Also, connection of fire-resistant cables in thermoplastic connection boxes is only allowed if the terminals are made of porcelain or similar. If the insulation of the inner conductors of the fire-resistant cable is made of non fire-resistant insulation material, a fire-resistant hose shall be provided.
Germany	560.8.1			In Germany, instead of 560.8.1, electric cables to operate in fire conditions have to meet the following requirements because of statutory building provisions: — they have to meet the requirements of DIN 4102-12:1998-11 (classes from E-30 to E-90) or — they have to be laid concrete ceilings and under the screed with a minimum thickness of 30 mm or — they have to be laid in the ground
Denmark	560.8.1			In Denmark, clamps and the like used for the wiring shall be fire-resistant e.g. made of iron. Thermoplastic clamps are not allowed. Also, silicone-insulated conductors H05SJ-K in visible conduits and conduits buried in flammable building parts shall be in iron conduits
Italy	560.8.1			In Italy, wiring systems with cables having low emission of toxic and corrosive smoke and gas during fire are used in installations where, from a relevant risk evaluation, a high risk to persons is envisaged
Austria	560.8.1			In Austria, constructional enclosures to maintain fire and mechanical protection or wiring systems in separate fire compartments also comply with these requirements
United Kingdom	560.9			In the United Kingdom, the national requirements for emergency escape lighting applications contained in the BS 5266 series shall apply
Germany	560.9.1			In Germany, instead of the third subclause, electric cables operating in fire conditions have to meet the following requirements because of statutory building provisions — they have to meet the requirements of DIN 4102-12:1998-11 (classes from E-30 to E-90) or — they have to be layered on concrete ceilings and under the screed with a

Country	Clause No	Nature (permanent or less permanent according to IEC directives)	Rationale (detailed justification for the requested country note)	Wording
				minimum thickness of 30 mm or — they have to be laid in the ground
Austria	560.9.2			In Austria, the national wiring conditions for emergency lighting shall apply
Spain	560.9.2			In Spain, no more than 12 luminaires shall be supplied from any final circuit
Austria	560.9.7			In Austria, the use of maintained or non-maintained mode shall be determined by national regulations
Spain	560.9.9			In Spain, changeover from normal to emergency mode of safety lighting circuits shall start automatically if the supply voltage drops below 70 % rated supply voltage
Austria	560.9.18			In Austria, a red or green label, which shall be of good visibility and easily legible, shall be used
Italy	560.10			In Italy, fire prevention regulations are issued by the Ministry of the Interior that apply to particular applications, such as locations open to the public, hotels, hospitals, high-rise buildings and similar premises
United Kingdom	560.10			In the United Kingdom, the national requirements for fire protection applications contained in the BS 5839 series shall apply
Spain	Annex A			In Spain, the rated operating time shall be: 2 h in hospitals, clinics and similar; the time required to evacuate a high-risk area or to abandon the activity which is taking place in that area — 1 h in other kinds of installations
Austria	Annex B			In Austria, national rules exist for the rated operating time

Country	Clause No.	Nature (permanent or less permanent according to IEC directives)	Rationale (detailed justification for the requested country note)	Wording
France	560.1			In France, national regulations define installation rules for safety services: "arrêté du 25 juin 1980 modifié" and "arrêté du 31 janvier 1986 modifié".
Austria	560.4.1			In Austria, a non-automatic supply, the starting of which is initiated by an operator, is not permitted as electrical supply system for safety services.
Germany	560.4.1 1 st bullet point			In Germany, a non-automatic supply, the starting of which is initiated by an operator, is not permitted as electrical supply system for safety services for the health and safety of persons.

Country	Clause No.	Nature (permanent or less permanent according to IEC directives)	Rationale (detailed justification for the requested country note)	Wording
Germany	560.5.2			In Germany, the necessity of providing wiring systems required to operate in fire conditions and their construction is governed by statutory building provisions of the Lands of the Federal Republic of Germany. In case of doubt the building supervisory board should be consulted.
Norway	560.6.1			In Norway, a separate feeder from the supply network cannot be used as a safety source.
Austria	560.6.1			In Austria, primary cells are not allowed for emergency lighting.
Germany	560.6.1 2 nd bullet point			In Germany, primary cells are not permitted as an electrical source for safety services for the health and safety of persons.
Germany	560.6.3			In Germany, in the Lands of the Federal Republic of Germany, partially special statutory building provisions exist regarding rooms in which electric sources for safety services are allowed to be installed. In case of doubt the building supervisory board should be consulted.
	560.6.4			In Germany, in the Lands of the Federal Republic of Germany, partially special statutory building provisions exist regarding rooms in which electric sources for safety services are allowed to be installed. In case of doubt the building supervisory board should be consulted.
UK	560.6.10			In the United Kingdom, the national requirement is for maintenance free batteries.
Austria	560.6.10			In Austria, valve-regulated maintenance-free types are also permitted.
Germany	560.7.1			In Germany, the necessity of providing wiring systems required to operate in fire conditions and their construction is governed by statutory building provisions of the Lands of the Federal Republic of Germany. In case of doubt the building supervisory board should be consulted.
	560.7.2			In Germany, the necessity of providing wiring systems required to operate in fire conditions and their construction is governed by statutory building provisions of the Lands of the Federal Republic of Germany. In case of doubt the building supervisory board should be consulted.
Germany	560.7.12			In Germany, the necessity of providing wiring systems required to operate in fire conditions and their construction is governed by statutory building provisions of the Lands of the Federal

Country	Clause No.	Nature (permanent or less permanent according to IEC directives)	Rationale (detailed justification for the requested country note)	Wording
				Republic of Germany. In case of doubt the building supervisory board should be consulted.
United Kingdom	560.7.13			In the UK, the national requirements for RCDs in these applications are covered by BS 5839, BS 5266 and BS 8519.
France	560.8			In France, Clause 560.8 does not apply because of national regulations.
Austria	560.8.1			In Austria, constructional enclosures to maintain fire and mechanical protection or wiring systems in separate fire compartments also comply with these requirements. In Austria, all types of fire-resistant cables complying with DIN 4102-12 are also permitted.
Germany	560.8.1			In Germany, the necessity of providing wiring systems required to operate in fire conditions and their construction is governed by statutory building provisions of the Lands of the Federal Republic of Germany. In case of doubt the building supervisory board should be consulted.
Italy	560.8.1			In Italy, wiring systems with cables having low emission of toxic and corrosive smoke and gas during fire are used in installations where, from a relevant risk evaluation, a high risk to persons is envisaged.
United Kingdom	560.8.1			In the United Kingdom, to take into account national requirements, the following new bullet point is required: – fire-resistant cables complying with the test requirements of BS EN 50200, BS 8434 or BS 8491, appropriate for the cable size and with BS EN 60332-1-2.
United Kingdom	560.8.5			In the United Kingdom, segregation of safety services for emergency lighting and fire detection and fire alarm systems are described in BS 5266, BS 5839 and BS 8519.
Germany	560.8.5			In Germany, the necessity of providing wiring systems required to operate in fire conditions and their construction is governed by statutory building provisions of the Lands of the Federal Republic of Germany. In case of doubt the building supervisory board should be consulted.
United Kingdom	560.8.5			In the United Kingdom, segregation of safety services are described in BS 5266, BS 5839 and BS 8519.
France	560.9			In France, Clause 560.9 does not apply because of national regulations.
United Kingdom	560.9			In the United Kingdom, the national requirements for emergency escape lighting applications contained in the

Country	Clause No.	Nature (permanent or less permanent according to IEC directives)	Rationale (detailed justification for the requested country note)	Wording
				BS 5266 series shall apply.
Ireland	560.9			In Ireland, this item is the subject of a separate Irish standard IS 3217, and does not appear in the national rules for electrical installations.
Finland	560.9.2			In Finland, the third paragraph is not valid.
Germany	560.9.2			In Germany, the necessity of providing wiring systems required to operate in fire conditions and their construction is governed by statutory building provisions of the Lands of the Federal Republic of Germany. In case of doubt the building supervisory board should be consulted.
Switzerland	560.9.2			In Switzerland, with respect to 560.9.2, high fire resistance requirements for the wiring system and the cabling are only mandatory up to the first luminaire or connecting block of an individual fire compartment. High fire resistance requirements for the wiring system and the cabling connecting the luminaires within the fire compartment are not mandatory.
Austria	560.9.3			In Austria, the national wiring conditions for emergency lighting shall apply.
Spain	560.9.3			In Spain, no more than 12 luminaires shall be supplied from any final circuit.
Austria	560.9.8			In Austria, the use of maintained or non-maintained mode shall be determined by national regulations.
Finland	560.9.8			In Finland this subclause is not valid.
United Kingdom	560.9.9			In the United Kingdom, the national requirements for emergency escape lighting applications contained in the BS 5266 series shall apply.
Spain	560.9.10			In Spain, changeover from normal to emergency mode of safety lighting circuits shall start automatically if the supply voltage drops below 70 % of the rated supply voltage.
Switzerland	560.9.15			In Switzerland, with respect to 560.9.15, a red or green label shall be used. Within a building the colour coding scheme has to be the same.
Finland	560.9.15			In Finland this subclause is not valid.
Austria	560.9.17			In Austria, a red or green label, which shall be of good visibility and easily legible, shall be used.
Italy	560.10			In Italy, fire prevention regulations are issued by the Ministry of the Interior that apply to particular applications, such as locations open to the public, hotels, hospitals, high-rise buildings and similar premises.


Country	Clause No.	Nature (permanent or less permanent according to IEC directives)	Rationale (detailed justification for the requested country note)	Wording
United Kingdom	560.10			In the United Kingdom, the national requirements for fire protection applications contained in the BS 5839 series shall apply.
Spain	Annex A			In Spain, the rated operating time shall be: <ul style="list-style-type: none"> – 2 h in hospitals, clinics and similar, the time required to evacuate a high-risk area or to abandon the activity which is taking place in that area; – 1 h in other kinds of installation.
Austria	Annex A			In Austria, national rules exist, therefore Annex A does not apply.
United Kingdom	Annex A			In the United Kingdom, national rules exist for the operating time.
Austria	Annex B			In Austria, national rules exist for the rated operating time.
United Kingdom	Annex B			In the United Kingdom, national rules exist for the operating time.
Germany	Annex F			In Germany, statutory building provisions exist regarding more detailed requirements for wiring systems to operate in fire conditions.

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 RLV

Annex D (informative)

Fire switch

A schematic diagram showing the installation of a fire switch used to disconnect all circuits with the exception of circuits supplying the equipment whose operation during a fire is necessary is shown in Figure D.1.



IEC


Figure D.1 – Fire switch installation

Annex E (informative)

Example of installation methods of safety services with cable management system

Safety services should be segregated from other services and installed in such a manner that the safety services are not affected by any fault occurring on non-safety services and mitigate the effects of a fire. An example of cables installed for safety services is shown in Figure E.1.

These are permissible installation methods of safety services with cable management system



IEC

NOTE Cable trays are numbered from the top down, starting at tray 1:

Tray 1 = Safety services

Tray 2 = Main power cabling

Tray 3 = Measurement/instrumentation

Tray 4 = Information technology

Figure E.1 – Example of cable installation for safety services

Annex F (informative)

Wiring systems

F.1 Ambient test temperature rise

The standard temperature time curve defines the ambient test temperature rise in time under fire conditions and it is defined in ISO 834-1 as:

$$T = 345 \times \log_{10}(8 \times t + 1) + 20 \quad (\text{F.1})$$

where

T is the temperature in degrees Celsius;

t is the time in minutes.

F.2 Duration of the safety service

The adequate duration of the safety service under fire conditions should be defined.

NOTE Local legislation can apply or can be defined by risk analysis by the designer.

F.3 Expected resistance of feeder conductors

The expected resistance of feeder conductors supplying fire protection equipment that should remain functional during a fire should be determined from Formula (F.2), for copper conductors only:

$$R_0 = R_{20} \cdot k_X \cdot \left(\frac{T_0}{293}\right)^{1,16} \quad (\text{F.2})$$

where:

R_{20} is the conductor resistance at the temperature of 20 °C, (Ω);

R_0 is the conductor resistance at the expected fire temperature, (Ω);

k_X is the coefficient determining the relative contribution of the section X , of the entire feeder circuit length l , exposed to a high temperature, according to Formula (F.3), (-);

T_0 is the expected ambient temperature of feeder conductors that may occur during a fire, (K)

$$k_x = \frac{l_x}{l} \quad (\text{F.3})$$

where:

l is the length of the feeder circuit conductor, (m);

l_x is the section of the feeder circuit conductor exposed to a high temperature, (m).

If a conductor route with the length l is located within a single fire protected compartment it is assumed that the entire length of feeder conductor can be exposed to a high temperature. In such a case $k_x = 1$.

Where a conductor with the length l is routed through different fire protected compartments, the coefficient k_x shall be determined assuming the conductor section with the length l_x located in the fire zone is the greatest.

Once the expected resistance in presence of fire has been calculated, the criteria for the permissible voltage drop as defined in IEC 60364-5-52 and the automatic disconnection during phase to earth fault as defined in IEC 60364-4-41 shall be checked for the elevated temperature.

Where the electrical source for safety services is an engine-generator set the phase-to-earth short circuit impedance may be calculated from the formulae with inclusion of the impedance of generator windings:

$$X_G = \frac{1}{n} \times \frac{U_{nG}^2}{S_{nG}} \quad (\text{F.4})$$

$$R_G = 0,03 \times \frac{U_{nG}^2}{S_{nG}} \quad (\text{F.5})$$

where:

U_{nG} is the generator nominal voltage, (kV);

S_{nG} is the generator nominal apparent power, (MVA);

n is the multiple of the generator rated current during a short circuit at the generator terminals, taken according to the generating set manufacturer's maintenance and operating instruction, (-).

NOTE For cross sectional area of conductors of 25 mm² and below the reactance needed to calculate the phase-to-earth short circuit impedance can be ignored.

F.4 Protection against electric shock in the event of a failure by means of the touch voltage reduction

Where the condition for automatic disconnection, mentioned in Clause F.3, cannot be satisfied, as the fault current is too low to trip the protection device, the protection against electric shock by reduction of the touch voltage, that may occur at accessible conducting parts of the protected equipment, shall be used. The reduced conventional touch voltage limit $U_L \leq 25$ V may be used.

In this case, the resistance value needed for the calculation of the value of touch voltage should be derived according to the methodology described in Clauses F.1 to F.3.

F.5 Conductor resistance in case of fire

The increase in the conductors' resistance can be neglected if conductors or cables are laid in approved fire resistant cable ducts whose manufacturer guarantees that during the required operation time of the supplied electrical equipment that needs to function during a fire, the temperature inside a duct will not rise above 70 °C.

The expected temperature inside the cable duct should not exceed the continuous permissible temperature of a cable or conductor.

F.6 High temperature effects

Conductors laid under a layer of plaster are not protected against high temperature effects. The heat generated during a fire penetrates through space dividing elements and results in an increased resistance of conductors.

F.7 Feeder circuits

The safety services switchboard feeder circuit should be installed using a cable or conductor having fire resistance not less than for example 90 min, which is water-resistant or protected against water, and which may be connected before the fire switch. The same conditions for the feeder applies if the fire switch is installed at the building main distribution panel.

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 RLV

Annex G (informative)

Guidance on suitable locations for electrical sources for safety services

G.1 Recommendations for a suitable location for an electrical source for safety services

Annex G serves as an informative guide for countries that do not have specific rules or their own guidelines.

All electrical sources for safety services should be segregated from any other electrical source for safety services and any other electrical source.

In order for the location to provide for normal operation of the electrical source for safety services under fire conditions one of these should be fulfilled:

- a) a constructional enclosure, whereby the function is tested, together with the electrical source for safety services, by an independent body, or
- b) a separate fire protected compartment type tested and certified by the fire protected compartment manufacturer, or
- c) a room formed of fire protective building material and large enough to house the electrical sources for safety.

G.2 Conditions of fire protection

The following conditions of fire protection should be fulfilled:

- a) health and safety requirements;
- b) environmental requirements specified by the electrical (safety service source) manufacturer;
- c) protection against heat transfer including fire and smoke.

One exception is when the electrical source for safety services controls only one safety system and is located close to the safety equipment and will automatically operate in the event of the temperature exceeding 55 °C (for example a safety services smoke curtain).

Bibliography

IEC 60079-14, *Explosive atmospheres – Part 14: Electrical Installations design, selection and erection*

~~IEC 60598-2-22, *Luminaires – Part 2-22: Particular requirements – Luminaires for emergency lighting*~~

IEC 60364-4-43:2008, *Low-voltage electrical installations – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 60623, *Secondary cells and batteries containing alkaline or other non-acid electrolytes – Vented nickel-cadmium prismatic rechargeable single cells*

IEC 60896 (all parts), *Stationary lead-acid batteries*

IEC 61508-4:2010, *Functional safety of electrical/electronic/programmable electronic safety-related systems – Part 4: Definitions and abbreviations*

IEC 62091, *Low-voltage switchgear and controlgear – Controllers for drivers of stationary fire pumps*

IEC 62034, *Automatic test systems for battery powered emergency escape lighting*

ISO 834-1, *Fire-resistance tests – Elements of building construction – Part 1: General requirements*

DIN 4102-12, *Fire behaviour of building materials and elements – Fire resistance of electric cable systems required to maintain circuit integrity – Requirements and testing*

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 RLV

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 RLV

INTERNATIONAL STANDARD

**Low-voltage electrical installations –
Part 5-56: Selection and erection of electrical equipment – Safety services**

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 RLV

CONTENTS

FOREWORD.....	3
560.1 Scope	5
560.2 Normative references.....	5
560.3 Terms and definitions.....	6
560.4 Classification	8
560.5 General.....	8
560.6 Electrical sources for safety services	9
560.7 Electrical circuits of safety services.....	10
560.8 Wiring systems	11
560.9 Emergency lighting applications.....	12
560.10 Fire protection applications/equipment.....	14
Annex A (informative) Guidance for emergency lighting	15
Annex B (informative) Guidance for fire protection equipment.....	16
Annex C (informative) List of notes concerning certain countries.....	17
Annex D (informative) Fire switch	21
Annex E (informative) Example of installation methods of safety services with cable management system.....	22
Annex F (informative) Wiring systems	23
F.1 Ambient test temperature rise	23
F.2 Duration of the safety service.....	23
F.3 Expected resistance of feeder conductors.....	23
F.4 Protection against electric shock in the event of a failure by means of the touch voltage reduction	24
F.5 Conductor resistance in case of fire	24
F.6 High temperature effects.....	25
F.7 Feeder circuits	25
Annex G (informative) Guidance on suitable locations for electrical sources for safety services	26
G.1 Recommendations for a suitable location for an electrical source for safety services	26
G.2 Conditions of fire protection	26
Bibliography.....	27
Figure D.1 – Fire switch installation	21
Figure E.1 – Example of cable installation for safety services	22
Table A.1 – Guidance for emergency lighting.....	15
Table B.1 – Guidance for safety equipment.....	16

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –**Part 5-56: Selection and erection of electrical equipment –
Safety services**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60364-5-56 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- 1) Modifications to normative references and terms and definitions.
- 2) Under electrical circuits for safety services, addition of requirements concerning circuit and overcurrent protection in order to maintain reliability of safety service power supplies under fire conditions.
- 3) Under electrical circuits for safety services, addition of requirements stating that circuits for safety services are not to be protected by RCDs or AFDDs.

- 4) Under emergency lighting applications, addition of requirements to prevent emergency lighting systems being adversely affected by any control system.
- 5) Addition of requirements for all emergency luminaires in the area to provide full design light output in the event of any final circuit failure.
- 6) Addition of a new Annex D (informative): Fire switch.
- 7) Addition of a new Annex E (informative): Example of installation methods of safety services with cable management system.
- 8) Addition of a new Annex F (informative): Wiring systems.
- 9) Addition of a new Annex G (informative): Guidance on suitable locations for electrical sources for safety services.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
64/2316/FDIS	64/2341/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this standard.

A list of all parts in the IEC 60364 series, published under the general title *Low-voltage electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 5-56: Selection and erection of electrical equipment – Safety services

560.1 Scope

This part of IEC 60364 covers general requirements for safety services, selection and erection of electrical supply systems for safety services and the electrical source for safety services.

Standby electrical supply systems are outside the scope of this document. This document does not apply to installations in hazardous areas (BE3), for which requirements are given in IEC 60079-14.

560.2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60331 (all parts), *Tests for electric cables under fire conditions – Circuit integrity*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-5-52, *Low-voltage electrical installations – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60598-2-22, *Luminaires – Part 2-22: Particular requirements – Luminaires for emergency lighting*

IEC 60702-1, *Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V – Part 1: Cables*

IEC 60702-2, *Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V – Part 2: Terminations*

IEC 62040-1, *Uninterruptible power systems (UPS) – Part 1: Safety requirements*

IEC 62040-2, *Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements*

IEC 62040-3, *Uninterruptible power systems (UPS) – Part 3: Method of specifying the performance and test requirements*

ISO 8528-12, *Reciprocating internal combustion engine driven alternating current generating sets – Part 12: Emergency power supply to safety services*

ISO 30061:2007, *Emergency lighting*

560.3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

560.3.1

electrical supply system for safety services

supply system intended to maintain the operation of essential parts of an electrical installation and equipment

- for the health and safety of persons and livestock, and/or
- to avoid damage to the environment and to other equipment

Note 1 to entry: The supply system includes the source and the electrical circuits up to the terminals of electrical equipment.

560.3.2

electrical source for safety services

electrical source intended to be used as part of an electrical supply system for safety services

560.3.3

electrical circuits for safety services

electrical circuits intended to be used as part of an electrical supply system for safety services

560.3.4

standby electrical supply system

supply system intended to maintain, for reasons other than safety, the functioning of an electrical installation or parts thereof, in case of interruption of the normal supply

560.3.5

standby electrical source

electrical source intended to maintain, for reasons other than safety, the supply to an electrical installation or parts thereof, in case of interruption of the normal supply

560.3.6

emergency lighting

lighting provided for use when the supply to the normal lighting fails

[SOURCE: ISO 30061:2007, 4.1]

560.3.7

emergency lighting luminaire

luminaire which may or may not be provided with its own electrical source for safety services and which is used for safety or emergency lighting

560.3.8

escape sign luminaire

luminaire that indicates and assists the identification of escape routes

560.3.9**maintained mode**

operating mode of a lighting system in which the emergency lighting lamps are energized at all times when normal or emergency lighting is required

560.3.10**non-maintained mode**

operating mode of a lighting system in which the emergency lighting lamps are in operation only when the supply to the normal lighting fails

560.3.11**response time**

time that elapses between the failure of the normal power supply and the electrical source for safety services energizing the equipment

560.3.12**central power supply system**

system which supplies the required emergency power to essential safety equipment

560.3.13**escape route**

route to follow for access to a safe area in the event of an emergency

560.3.14**preferential circuit**

circuit derived directly from the incoming supply to the building intended to supply safety services which, in case of emergency, shall remain in operation for as long as possible

560.3.15**minimum illuminance**

illuminance for emergency lighting throughout the whole rated operating time

560.3.16**safety service**

electrical system for electrical equipment provided to protect or warn persons in the event of a hazard, or essential to their evacuation from a location

EXAMPLE:

- emergency (escape) lighting;
- fire pumps;
- fire rescue services lifts;
- alarm systems, such as fire alarms, CO alarms and intruder alarms;
- evacuation systems;
- smoke extraction systems;
- essential medical systems.

Note 1 to entry: Safety services is equipment installed in buildings to detect fire or danger in its initial stage, also limit fire spread and extinguish fire and control smoke and enable safe and effective evacuation

560.3.17**fire condition**

condition defined by the temperature-time curve of ISO 834-1, or by local legislation

560.3.18**suitable location**

constructional enclosure or separate fire protected compartment or room ensuring normal operation of equipment under fire conditions

560.3.19 fire switch

electrical apparatus, which shall be used to disconnect all circuits with the exception of circuits supplying the equipment whose operation during a fire is necessary

Note 1 to entry: The installation and characteristics of fire switch are described in Annex D (informative).

Note 2 to entry: The switch could be a circuit breaker or disconnector.

560.4 Classification

560.4.1 An electrical supply system for safety services is either:

- a non-automatic supply system, the starting of which is initiated by an operator, or
- an automatic supply system, the starting of which is independent of an operator.

An automatic supply system is classified as follows, according to the maximum changeover time:

- class A – no-break: an automatic supply system which can ensure a continuous supply within specified conditions during the period of transition, for example as regards variations in voltage and frequency;
- class B – very short break: an automatic supply system available within 0,15 s;
- class C – short break: an automatic supply system available within 0,5 s;
- class D – average break: an automatic supply system available within 5 s;
- class E – medium break: an automatic supply system available within 15 s;
- class F – long break: an automatic supply system available in more than 15 s.

560.4.2 The essential equipment for safety services shall be within the specified class according to 560.4.1 in order to maintain the specified operation.

560.5 General

560.5.1 Safety services may be required to operate at all relevant times including during main and local supply failure and through fire conditions. To meet these requirements, specific sources, equipment, circuits and wiring are necessary. Some applications also have particular requirements, as in 560.5.2 and 560.5.3.

560.5.2 For safety services required to operate in fire conditions, the following additional conditions shall be fulfilled:

- one or more electrical sources for safety services shall be provided to maintain a supply of adequate duration, except for preferential circuits and all equipment of safety services shall be provided, either by construction or by erection, with fire protection ensuring normal operation in fire conditions of adequate duration.

NOTE 1 Equipment includes for example, power sources, feeder conductors, cable management systems, junction boxes.

NOTE 2 The electrical source for safety services is generally additional to the normal supply source, for example the public supply network.

NOTE 3 Local legislation can apply.

560.5.3 An IT system is preferred where non-disconnection on the first fault is required. In IT systems for safety services, insulation monitoring devices shall be provided which give an audible and visible indication in the event of a first fault.

NOTE For IT systems after first fault see IEC 60364-4-41:2005, 411.6.4.

560.5.4 A failure in the control or bus systems (control technology) of the non-safety services installation shall not adversely affect the proper function of safety services. This applies to control or bus systems of different safety services as well.

560.6 Electrical sources for safety services

560.6.1 The following electrical sources for safety services are recognized:

- storage batteries;
- primary cells;
- generator sets independent of the normal supply;
- a separate feeder of the supply network that is effectively independent of the normal feeder.

560.6.2 The electrical source for safety services shall be installed as fixed equipment and in such a manner that it cannot be adversely affected by failure of the normal source.

560.6.3 The electrical source for safety services shall be installed in a suitable location and be accessible only to skilled or instructed persons (BA5 or BA4). Electrical sources for safety services should be segregated from other sources.

Safety services and sources shall be designed and located so as to minimize hazards that could cause fire, flooding, freezing, vandalism and other adverse conditions and impact the availability of the electrical supply.

NOTE See Annex G for guidance.

560.6.4 The location of the electrical source for safety services shall be properly and adequately ventilated so that exhaust gases, smoke or fumes from the safety source cannot penetrate areas occupied by persons.

560.6.5 Separate, independent feeders from a supply network shall not serve as electrical sources for safety services unless assurance can be obtained that the two supplies are unlikely to fail concurrently.

560.6.6 The electrical source for safety services shall have sufficient capability to supply its related safety service.

560.6.7 An electrical source for safety services may, in addition, be used for purposes other than safety services, provided the availability for safety services is not thereby impaired. A fault occurring in a circuit for purposes other than safety services shall not cause the interruption of any circuit for safety services.

560.6.8 There are special requirements for safety sources not capable of operation in parallel.

Adequate precautions shall be taken to avoid the paralleling of sources.

Short circuit protection and fault protection within the electrical supply system for safety services shall be provided for each source.

560.6.9 There are special requirements for safety services having sources capable of operation in parallel.

The parallel operation of independent sources may require special devices, for example to prevent reverse power.

NOTE The parallel operation of independent sources with the public supply can require the authorization of the supply undertaking.

Fault protection and short circuit protection shall be provided when installation is supplied separately by either of the two sources or by both in parallel.

Precautions shall be taken to limit current circulation in the connection between the neutral points of the sources, in particular the effect of triple harmonics.

560.6.10 There are requirements for a central power supply system.

Batteries shall be of vented or valve-regulated type with reduced maintenance and shall be of heavy duty industrial design, for example cells complying with IEC 60623 or IEC 60896 (all parts). This does not preclude proven new technologies. The minimum design life of the batteries at 20 °C shall be 10 years.

560.6.11 Where an uninterruptible power supply (UPS) is used, it shall:

- a) be able to operate all protective devices located on the load side of the UPS,
- b) be able to start the safety services when it is operating in the emergency condition,
- c) comply with the requirements of 560.6.10, as applicable,
- d) comply with IEC 62040-1, IEC 62040-2 or IEC 62040-3, as applicable, and
- e) be able to be started independently of the availability of the upstream supply.

560.6.12 Where a safety generating set is used as an electrical source for safety services, a diesel engine driven generating set shall comply with ISO 8528-12.

560.6.13 The condition of the electrical source for safety services (ready for operation, under fault conditions, feeding from the electrical source for safety services) shall be monitored.

560.7 Electrical circuits of safety services

560.7.1 Circuits of safety services shall be independent of other circuits.

An electrical fault or any modification in one system shall not affect the correct functioning of the other. This may necessitate separation by fire-resistant materials or different routes or enclosures.

560.7.2 Circuits of safety services shall not pass through locations exposed to fire risk (BE2 due to nature of processed or stored materials) unless they are fire-resistant. The circuits shall not, in any case, pass through zones exposed to explosion risk (BE3). Where practicable, the passage of any circuit through locations presenting a fire risk should be avoided.

560.7.3 In accordance with IEC 60364-4-43:2008, 433.3.3, protection against overload may be omitted where the loss of supply may cause a greater hazard. Where protection against overload is omitted, the occurrence of an overload shall be monitored.

560.7.4 Overcurrent protective devices shall be selected and erected so as to avoid an overcurrent in one circuit impairing the correct operation of circuits of safety services.

560.7.5 Switchgear and controlgear shall be clearly identified and grouped in locations accessible only to skilled or instructed persons (BA5 or BA4).

560.7.6 In equipment supplied by two different circuits, a fault occurring in one circuit shall not impair the protection against electric shock, nor the correct operation of the other circuit. Such equipment shall be connected to the protective conductors of both circuits, if necessary.

560.7.7 Circuits for safety services, with the exception of wiring for fire and rescue services lift supply cables, and wiring for lifts with special requirements, shall not be installed in lift shafts or other flue-like openings (location).

560.7.8 In addition to a general schematic overview diagram, full details of all electrical sources for safety services shall be given. Information shall be maintained adjacent to the distribution board. A single line diagram is sufficient.

560.7.9 Drawings of the electrical safety installations shall be provided showing the exact location of:

- all electrical equipment and distribution boards, with equipment designations;
- safety equipment with final circuit designation and particulars and purpose of the equipment;
- special switching and monitoring equipment for the safety power supply (e.g. area switches, visual or acoustic warning equipment).

560.7.10 A list of all the current-using equipment permanently connected to the safety power supply, indicating the nominal electrical power, nominal currents and starting currents and time for current-using equipment, shall be provided.

NOTE This information is often included in circuit diagrams.

560.7.11 Operating instructions for safety equipment and electrical safety services shall be available. They shall take into account all the particulars of the installation.

560.7.12 The circuit and overcurrent protection shall be considered in order to maintain reliability of power supply of the safety services under fire conditions. See also 560.6.8.2.

560.7.13 Circuits of safety services shall not be protected by RCDs or AFDDs.

NOTE At elevated temperatures under fire conditions, leakage currents between conductors can occur leading to unwanted tripping and loss of safety service.

560.8 Wiring systems

560.8.1 One or more of the following wiring systems shall be utilized for safety services required to operate in fire conditions:

- mineral insulated cable complying with IEC 60702-1 and IEC 60702-2 and IEC 60332-1-2;
- fire-resistant cables complying with the appropriate part of the IEC 60331 series and with IEC 60332-1-2;
- a wiring system maintaining the necessary fire and mechanical protection.

Wiring systems and their fixings shall be mounted and installed in such a way that the circuit integrity will not be impaired during the fire.

In long vertical installations wiring systems shall have fire protection for their fixings to ensure that under fire condition, cable fixings do not allow the cables to collapse prematurely.

NOTE 1 Examples of a system maintaining the necessary fire and mechanical protection could be constructional enclosures to maintain fire and mechanical protection, or wiring systems in separate fire protected compartments.

NOTE 2 National legislation can exist.

560.8.2 Wiring for control and bus systems of safety services shall be in accordance with the same requirements as the wiring which is to be used for the safety services. This does not apply to circuits that do not adversely affect the operation of the safety equipment.

This requirement also includes control and bus systems for self-contained luminaires. Wireless control and bus systems shall be considered in an equivalent way.

560.8.3 Circuits for safety services which can be supplied by direct current shall be provided with two-pole overcurrent protective devices.

560.8.4 The higher resistance of conductors due to high temperature when exposed to fire shall be taken into account when sizing the conductor cross-sectional area.

NOTE Information is given in Annex F for cables with copper conductors.

560.8.5 The wiring systems of safety services should be segregated from other services other than metallic screened fire-resistant cables and installed in such a manner that the safety services are not affected by any fault occurring on non-safety services and mitigate the effects of a fire. An example of cables installed for safety services is shown in a diagram in Annex E.

NOTE For battery cables, special requirements can apply.

560.8.6 Precautions shall be taken to prevent excavation damage to buried electrical circuits for safety services.

560.8.7 Switchgear and controlgear used for both AC and DC supply sources shall be suitable for both AC and DC operation.

560.9 Emergency lighting applications

560.9.1 Emergency lighting systems may be powered by a central power supply system or the emergency lighting luminaires may be self-contained. Emergency lighting luminaires shall comply with IEC 60598-2-22. The supply to self-contained emergency lighting luminaires is excluded from the requirements of 560.9.2

560.9.2 Wiring systems for a centrally powered emergency lighting system shall retain the continuity of supply from the source to each fire protected compartment where the emergency lighting luminaires are installed for an adequate period in the event of a fire. This shall be achieved by using wiring systems with a high resistance to fire, as detailed in 560.8.1 and 560.8.2, to transfer power through other fire protected compartments.

Within fire protected compartments where the emergency lighting luminaires are installed, the wiring system between emergency lighting luminaires has no requirements against fire.

For fire protected compartments having more than one emergency lighting luminaire, such emergency lighting luminaires shall be wired alternately from at least two separate circuits so that a suitable level of illuminance is maintained along the escape route in the event of the loss of one circuit.

560.9.3 Where alternate emergency lighting luminaires are supplied by separate circuits, overcurrent protective devices shall be used so that a short-circuit in one circuit does not interrupt the supply to the adjacent emergency lighting luminaires within the fire protected compartment or the emergency lighting luminaires in other fire protected compartments.

No more than 20 emergency lighting luminaires with a total load not exceeding 60 % of the nominal current of the overcurrent protective device shall be supplied from any final circuit.

560.9.4 A safe value of minimum illuminance, response time and rated operation time is required to enable evacuation of a building. Where there are no national or local rules, illumination systems shall comply with ISO 30061:2007

NOTE Guidance on appropriate systems is given in Annex A (see Table A.1).

560.9.5 Emergency lighting shall be wired in maintained or non-maintained mode. These modes may also be combined.

560.9.6 In the non-maintained mode, the power supply for the normal lighting shall be monitored at that area. If a loss of supply to the normal lighting in an area causes the normal lighting to fail, the emergency lighting shall be activated automatically. In all cases, arrangements shall be made to ensure that local emergency lighting will operate in the event of failure of normal supply to the corresponding local area.

560.9.7 Where maintained and non-maintained modes are used in combination, the changeover devices shall each have their own monitoring device and shall be able to be switched separately.

560.9.8 The maintained mode of emergency lighting may be simultaneously switched with normal lighting in locations which either

- cannot be darkened when in use, or
- are not constantly occupied.

560.9.9 Emergency lighting systems shall not be adversely affected by any control systems. Any future modifications of the control systems shall continue to comply with this functional safety requirement. If a failure causes normal lighting in an area to fail, all emergency lighting luminaires in the area shall operate. The emergency lighting luminaires in the area shall provide full emergency design light output.

NOTE 1 For the definition of functional safety see IEC 61508-4:2010, 3.1.12.

NOTE 2 Here failure means a loss of supply or a failure of the control system.

560.9.10 Changeover from normal to emergency mode shall start automatically if the supply voltage drops below 0,6 times the rated supply voltage for at least 0,5 s. Normal mode shall be restored if the supply voltage is greater than 0,85 times the rated supply voltage.

NOTE 1 The actual time for changeover can depend on national rules.

NOTE 2 The level of changeover depends on the equipment used for safety services.

560.9.11 When the normal supply is restored to the distribution board or monitored circuit, the emergency lighting in non-maintained mode shall automatically switch off. Account shall be taken of the time necessary for the lamps in the normal lighting to return to normal luminance. Account shall also be taken of rooms which had been intentionally 'blacked-out' before the supply was lost; in these cases, emergency lighting shall not switch off automatically.

560.9.12 In emergency lighting systems the type of lamps shall be compatible with the changeover time in order to maintain the specified lighting level.

560.9.13 Control switches for emergency lighting shall be placed at a designated location and be arranged and installed in such a way that they cannot be operated by unauthorized persons.

560.9.14 The switched-on position of the emergency lighting shall be indicated at a convenient location for each source of supply.

560.9.15 Emergency lighting luminaires and associated circuit equipment shall be identified by for example a red label of at least 30 mm in diameter.

560.9.16 A switching facility may be provided to prevent discharging of the electrical storage source for safety services when the building is not occupied

560.9.17 Each single phase circuit shall have its own neutral conductor. A common neutral for more than one circuit is not permitted.

560.10 Fire protection applications/equipment

560.10.1 Wiring systems for fire detection and firefighting power supplies shall be supplied by a separate circuit from the main incoming supply.

If a fire switch is required, conductors supplying fire protection equipment whose operation is necessary during a fire, shall be connected at the power supply side of the fire switch. It shall be clearly identified.

NOTE If a fire switch is required to disconnect all non-safety services an example of such a system is shown in a schematic diagram in informative Annex D.

560.10.2 Preferential circuits, if any, shall be directly connected on the supply side of the isolating switch of the main distribution board.

560.10.3 Alarm devices shall be clearly identified.

560.10.4 Except where there are applicable national rules, the minimum requirements for fire protection systems should be in accordance with Annex B. See Table B.1.

IECNORM.COM : Click to view the full PDF of IEC 60364-5-56:2018 PLV

Annex A (informative)

Guidance for emergency lighting

The values in ISO 30061:2007 should be considered but additional details of suitable systems are given in Table A.1. Annex A serves as an informative guide for countries that do not have specific rules or their own guidelines.

Table A.1 – Guidance for emergency lighting

Examples of applications	Requirements							
	1	2	3	4	5	6	7	8
	Extended duration or remote controlled circuit	Escape sign luminaires in maintained mode	Central power supply system	Self-contained battery unit	Motor-generator unit with no break (0 s)	Motor-generator unit with short break (< 0.5 s)	Motor-generator unit with medium break (< 15 s)	Dual supply system
Assembly halls, assembly rooms	**	✓	✓	✓	✓	✓		
Exhibition halls	**	✓	✓	✓	✓	✓		
Theatres, cinemas	**	✓	✓	✓	✓	✓		
Sports arenas	**	✓	✓	✓	✓	✓		
Sales areas	**	✓	✓	✓	✓	✓		
Restaurants	**	✓	✓	✓	✓	✓		
Hospitals, treatment centres	**	✓	✓	✓	✓	✓	✓	
Hotels, guest houses *	**	✓	✓	✓	✓	✓	✓	
Residential care homes *	**	✓	✓	✓	✓	✓	✓	
High-rise buildings *	**	✓	✓	✓	✓	✓	✓	
Schools	**	✓	✓	✓	✓	✓	✓	
Enclosed car parks		✓	✓	✓	✓	✓	✓	
Escape routes in workplaces		–	✓	✓	✓	✓	✓	✓
High risk task areas		–	✓	✓	✓	✓		✓
Stages	**	✓	✓	✓	✓	✓		
Key								
✓ Denotes suitable systems.								
* In premises (guest houses, hotels, residential care homes and high-rise buildings) used the whole day, the rated operating time for the emergency lighting should be 8 h or shall be switchable with illuminated push buttons for a fixed time by the occupants. In this case, the push buttons and their timing equipment should also run in the emergency mode.								
** Denotes applications which require either extended duration or a circuit such as a remote controlled circuit to ensure protection for longer than 60 min.								

Annex B (informative)

Guidance for fire protection equipment

Annex B serves as an informative guide for countries that do not have specific rules or their own guidelines.

Table B.1 – Guidance for safety equipment

Examples for safety equipment	Requirements								
	1	2	3	4	5	6	7	8	9
	Rated operating time of the source, (h)	Response time of the source, (s. max.)	Central power supply system	Self-contained battery unit	Motor-generator unit with no break (0 s)	Motor-generator unit with short break (< 0,5 s)	Motor-generator unit with medium break (< 15 s)	Dual supply system	Monitoring and changeover in the case of failure of the source
Installations for fire pumps	12	15			✓	✓	✓	✓	✓
Fire rescue service lifts	8	15			✓	✓	✓	✓	✓
Lifts with special requirements	3	15			✓	✓	✓	✓	✓
Devices of alarm and issue of instructions	3	15	✓		✓	✓	✓	✓	✓ ^a
Smoke and heat extraction equipment	3	15	✓	✓	✓	✓	✓	✓	✓ ^a
CO warning equipment	1	15	✓	✓	✓	✓	✓	✓	✓ ^a
Key									
✓ Denotes suitable systems.									
^a Only in case of no separate safety supply equipment.									