

INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**IEC 60598-1**  
Edition 9.0 2020-08

**LUMINAIRES –**

**Part 1: General requirements and tests**

**INTERPRETATION SHEET 1**

This interpretation sheet has been prepared by subcommittee 34D: Luminaires, of IEC technical committee 34: Lighting.

The text of this interpretation sheet is based on the following documents:

DISH	Report on voting
34D/1697/DISH	34D/1702/RVDISH

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

---

**Subclause 3.2.27**

**Annex R – Schedule of amended clauses and subclauses containing more serious/critical requirements which call for products to be retested**

The requirements of Subclause 3.2.27, and consequently the relevant requirements related to Subclause 3.2.27 in Annex R, are to be considered applicable only to luminaires with built-in or independent settable or programmable LED controlgear or incorporating a constant lighting output function. The requirements are not applicable to luminaires with built-in or independent controlgear having only a fixed output.