

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE  
NORME DE LA CEI

INTERNATIONAL ELECTROTECHNICAL COMMISSION  
IEC STANDARD

**Modification**

n° 1  
Juillet 1985  
à la

Publication 694  
1980

**Amendment**

No. 1  
July 1985  
to


---

Clauses communes pour les normes de  
l'appareillage à haute tension

---

Common clauses for high-voltage switchgear  
and controlgear standards

---



Bureau Central de la Commission Electrotechnique Internationale

3, rue de Varembe  
Genève, Suisse

IECNORM.COM . Click to view the full PDF of IEC 60694:1980/AMD1:1985

# Withdrawn

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE  
NORME DE LA CEI

INTERNATIONAL ELECTROTECHNICAL COMMISSION  
IEC STANDARD

**Modification**

n° 1  
Juillet 1985  
à la

Publication 694  
1980

**Amendment**

No. 1  
July 1985  
to

---

Clauses communes pour les normes de  
l'appareillage à haute tension

---

Common clauses for high-voltage switchgear  
and controlgear standards

---

Les modifications contenues dans le présent document ont été approuvées suivant la Règle des Six Mois.

Les projets de modifications, discutés par le Sous-Comité 17A du Comité d'Etudes n° 17, furent diffusés en mai 1984 pour approbation suivant la Règle des Six Mois, sous forme de document 17A(Bureau Central)182.

Pour de plus amples renseignements, consulter le rapport de vote suivant: Document 17A(Bureau Central)193.

The amendments contained in this document have been approved under the Six Months' Rule.

The draft amendments, discussed by Subcommittee 17A of Technical Committee No. 17, were circulated for approval under the Six Months' Rule in May 1984, as Document 17A(Central Office)182.

Further details can be found in the following Report on Voting: Document 17A(Central Office)193.

© CEI 1985

Droits de reproduction réservés — Copyright - all rights reserved

Page 30

5.3 *Raccordement à la terre des appareils de connexion*

Remplacer la dernière phrase de ce paragraphe par la suivante:

Le point de raccordement est marqué du symbole "Terre de protection" n° 5019 de la Publication 417 de la CEI: Symboles graphiques utilisables sur le matériel. Index, relevé et compilation des feuilles individuelles.

Page 31

5.3 *Earthing of switching devices*

Replace the last sentence of this sub-clause by the following:

The connecting point shall be marked with the symbol for protective earth, No. 5019 of IEC Publication 417: Graphical Symbols for Use on Equipment. Index, Survey and Compilation of the Single Sheets.