

NORME  
INTERNATIONALE  
INTERNATIONAL  
STANDARD

CEI  
IEC  
726

1982

AMENDEMENT 1  
AMENDMENT 1

1986

---

---

Amendement 1

**Transformateurs de puissance de type sec**

Amendment 1

**Dry-type power transformers**

© CEI 1986 Droits de reproduction réservés — Copyright — all rights reserved

Bureau Central de la Commission Electrotechnique Internationale 3, rue de Varembe Genève, Suisse



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

CODE PRIX  
PRICE CODE

**A**

*Pour prix, voir catalogue en vigueur  
For price, see current catalogue*

## TRANSFORMATEURS DE PUISSANCE DE TYPE SEC

---

### PREFACE

La présente modification a été établie par le Comité d'Etudes n° 14 de la CEI: Transformateurs de puissance.

Le texte de cette modification est issu des documents suivants:

Règle des Six Mois	Rapport de vote
14(BC)61	14(BC)64

Pour de plus amples renseignements, consulter le rapport de vote mentionné dans le tableau ci-dessus.

---

Page 18

Tableau IV: Limites d'échauffement

Dans la colonne 2 de ce tableau, remplacer "185 (H)" par "180 (H)".

---

## DRY-TYPE POWER TRANSFORMERS

## PREFACE

This amendment has been prepared by IEC Technical Committee No. 14: Power Transformers.

The text of this amendment is based upon the following documents:

Six Months' Rule	Report on Voting
14(C0)61	14(C0)64

Further information can be found in the Report on Voting indicated in the table above.

Page 19

Table IV: Temperature-rise limits

In column 2 of this table, replace "185 (H)" by "180 (H)".