

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –
Part 5-4: Application layer service definition – Type 4 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-4: Définition des services de la couche application – Éléments de type 4**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –
Part 5-4: Application layer service definition – Type 4 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-4: Définition des services de la couche application – Éléments de type 4**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-9265-5

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 General.....	8
1.2 Specifications	9
1.3 Conformance	9
2 Normative references	9
3 Terms, definitions, symbols, abbreviations and conventions	10
3.1 ISO/IEC 7498-1 terms	10
3.2 ISO/IEC 8822 terms	10
3.3 ISO/IEC 9545 terms	10
3.4 ISO/IEC 8824-1 terms	11
3.5 Fieldbus data-link layer terms	11
3.6 Fieldbus application layer specific definitions	11
3.7 Abbreviations and symbols	17
3.8 Conventions.....	18
3.8.1 Overview	18
3.8.2 General conventions	19
3.8.3 Conventions for class definitions	19
3.8.4 Conventions for service definitions	20
4 Concepts.....	21
4.1 Overview	21
4.2 Architectural relationships.....	22
4.2.1 Relationship to the Application Layer of the OSI basic reference model	22
4.2.2 Relationships to other fieldbus entities	22
4.3 Fieldbus Application Layer structure	24
4.3.1 Overview	24
4.3.2 Fundamental concepts.....	24
4.3.3 Fieldbus application processes	24
4.3.4 Application process objects	28
4.3.5 Application entities	30
4.3.6 Fieldbus application service elements.....	31
4.3.7 Application relationships	34
4.4 Fieldbus Application Layer naming and addressing	36
4.4.1 General	36
4.4.2 Identifying objects accessed through the FAL	36
4.4.3 Addressing APs accessed through the FAL	37
4.5 Architecture summary	37
4.6 FAL service procedures	37
4.6.1 FAL confirmed service procedures.....	37
4.6.2 FAL unconfirmed service procedures	38
4.7 Common FAL attributes	38
4.8 Common FAL service parameters	39
4.9 APDU size	39

5	Type 4 communication model specification	40
5.1	Concepts	40
5.1.1	Overview	40
5.1.2	Application entities	40
5.1.3	Gateway and routing	42
5.1.4	Architecture summary	43
5.1.5	FAL service procedures and time sequence diagrams	44
5.2	Variable ASE	46
5.2.1	Variable types	46
5.2.2	Variable model class specification	48
5.2.3	Basic variable type specifications	49
5.2.4	Constructed variable type specifications	53
5.2.5	Route endpoint ASE	57
5.2.6	Route endpoint ASE service specification	60
5.3	Application relationship ASE	64
5.3.1	Overview	64
5.3.2	Application relationship class specification	65
5.3.3	Application relationship ASE service specifications	66
	Bibliography	71
	Figure 1 – Relationship to the OSI basic reference model	22
	Figure 2 – Architectural positioning of the fieldbus Application Layer	23
	Figure 3 – Client/server interactions	25
	Figure 4 – Pull model interactions	26
	Figure 5 – Push model interactions	27
	Figure 6 – APOs services conveyed by the FAL	29
	Figure 7 – Application entity structure	30
	Figure 8 – Example FAL ASEs	32
	Figure 9 – FAL management of objects	32
	Figure 10 – ASE service conveyance	33
	Figure 11 – Defined and established AREPs	36
	Figure 12 – FAL architectural components	37
	Figure 13 – FAL AE	41
	Figure 14 – Summary of the FAL architecture	43
	Figure 15 – FAL service procedure overview	44
	Figure 16 – Time sequence diagram for the confirmed services	45
	Figure 17 – Time sequence diagram for unconfirmed services	46
	Table 1 – REQUEST service parameters	60
	Table 2 – RESPONSE service parameters	61
	Table 3 – Error codes by source	62
	Table 4 – Reserve REP service parameters	63
	Table 5 – Free AREP service parameters	63

Table 6 – Get REP attribute service parameters	63
Table 7 – Set REP attribute service parameters	64
Table 8 – AR send service parameters	68
Table 9 – AR acknowledge service parameters	68
Table 10 – AR get attributes service parameters	69
Table 11 – AR set attributes service parameters	69

IECNORM.COM : Click to view the full PDF of IEC 61158-5-4:2019

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 5-4: Application layer service definition –
Type 4 elements****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-5-4 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This third edition cancels and replaces the second edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) additional user parameters to services;
- b) additional services to support distributed objects;
- c) additional secure services;

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/947/FDIS	65C/950/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all the parts of the IEC 61158 series, under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This document defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

IECNORM.COM : Click to view the full PDF of IEC 61158-5-4:2019

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-4: Application layer service definition – Type 4 elements

1 Scope

1.1 General

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs”.

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 4 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the Type 4 fieldbus application layer in terms of:

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to:

- 1) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- 2) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This document specifies the structure and services of the Type 4 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this document to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this document is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in IEC 61158-6 (all subparts).

This specification may be used as the basis for formal application programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This document does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill the Type 2 application layer services as defined in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61158-3-4:2019, *Industrial communication networks – Fieldbus specifications – Part 3-4: Data-link layer service definition – Type 4 elements*

IEC 61158-4-4:2019, *Industrial communication networks – Fieldbus specifications – Part 4-4: Data-link layer protocol specification – Type 4 elements*

IEC 61158-6-4:2019, *Industrial communication networks – Fieldbus specifications – Part 6-4: Application layer protocol specification – Type 4 elements*

IEC 61158-6 (all subparts), *Industrial communication networks – Fieldbus specifications – Part 6: Application layer protocol specification*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model – Part 1: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model – Part 3: Naming and addressing*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC/IEEE 60559, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

3 Terms, definitions, symbols, abbreviations and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 ISO/IEC 7498-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 7498 1 apply:

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation
- g) application transaction
- h) real open system
- i) transfer syntax

3.2 ISO/IEC 8822 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8822 apply:

- a) abstract syntax
- b) presentation context

3.3 ISO/IEC 9545 terms

For the purposes of this document, the following terms as defined in ISO/IEC 9545 apply:

- a) application-association

- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type
- h) application-service-element
- i) application control service element

3.4 ISO/IEC 8824-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8824-1 apply:

- a) object identifier
- b) type

3.5 Fieldbus data-link layer terms

For the purposes of this document, the following terms apply.

- a) DL-Time
- b) DL-Scheduling-policy
- c) DLCEP
- d) DLC
- e) DLPDU
- f) DLSDU
- g) DLSAP
- h) fixed tag
- i) generic tag
- j) link
- k) network address
- l) node address
- m) node
- n) tag
- o) scheduled
- p) unscheduled

3.6 Fieldbus application layer specific definitions

For the purposes of this document, the following terms and definitions apply.

3.6.1

application

function or data structure for which data is consumed or produced

3.6.2

application objects

multiple object classes that manage and provide a run time exchange of messages across the network and within the network device

3.6.3

application process

part of a distributed application on a network, which is located on one device and unambiguously addressed

3.6.4

application process identifier

a value that distinguishes an application process among multiple application processes used in a device

3.6.5

application process object

component of an application process that is identifiable and accessible through an FAL application relationship

Note 1 to entry: Application process object definitions are composed of a set of values for the attributes of their class (see the definition for Application Process Object Class Definition). Application process object definitions may be accessed remotely using the services of the FAL Object Management ASE. FAL Object Management services can be used to load or update object definitions, to read object definitions, and to dynamically create and delete application objects and their corresponding definitions.

3.6.6

application process object class

class of application process objects defined in terms of the set of their network-accessible attributes and services

3.6.7

application relationship

cooperative association between two or more application-entity-invocations for the purpose of exchange of information and coordination of their joint operation

Note 1 to entry: This relationship is activated either by the exchange of application-protocol-data-units or as a result of preconfiguration activities.

3.6.8

application relationship application service element

application-service-element that provides the exclusive means for establishing and terminating all application relationships

3.6.9

application relationship endpoint

context and behavior of an application relationship as seen and maintained by one of the application processes involved in the application relationship

Note 1 to entry: Each application process involved in the application relationship maintains its own application relationship endpoint.

3.6.10

attribute

description of an externally visible characteristic or feature of an object

Note 1 to entry: The attributes of an object contain information about variable portions of an object. Typically, they provide status information or govern the operation of an object. Attributes may also affect the behaviour of an object. Attributes are divided into class attributes and instance attributes.

3.6.11

behaviour

indication of how an object responds to particular events

3.6.12

bit-no

designates the number of a bit in a bitstring or an octet

3.6.13**channel**

single physical or logical link of an input or output application object of a server to the process

3.6.14**class**

set of objects, all of which represent the same kind of system component

Note 1 to entry: A class is a generalisation of an object; a template for defining variables and methods. All objects in a class are identical in form and behaviour, but usually contain different data in their attributes.

3.6.15**class attributes**

attribute that is shared by all objects within the same class

3.6.16**class code**

unique identifier assigned to each object class

3.6.17**class specific service**

service defined by a particular object class to perform a required function which is not performed by a common service

Note 1 to entry: A class specific object is unique to the object class which defines it.

3.6.18**client**

<object> object which uses the services of another (server) object to perform a task

3.6.19**client**

<message> initiator of a message to which a server reacts

3.6.20**communication objects**

components that manage and provide a run time exchange of messages across the network

EXAMPLES: Connection Manager object, Unconnected Message Manager (UCMM) object, and Message Router object.

3.6.21**connection**

logical binding between application objects that may be within the same or different devices

Note 1 to entry: Connections may be either point-to-point or multipoint.

3.6.22**conveyance path**

unidirectional flow of APDUs across an application relationship

3.6.23**dedicated AR**

AR used directly by the FAL User

Note 1 to entry: On Dedicated ARs, only the FAL Header and the user data are transferred.

3.6.24

default DL-address

value 126 as an initial value for DL-address, which has to be changed (e.g. by assignment of a DL-address via the fieldbus) before operation with a DP-master (class 1)

3.6.25

device

physical hardware connected to the link

Note 1 to entry: A device may contain more than one node.

3.6.26

dynamic AR

AR that requires the use of the AR establishment procedures to place it into an established state

3.6.27

endpoint

one of the communicating entities involved in a connection

3.6.28

error

discrepancy between a computed, observed or measured value or condition and the specified or theoretically correct value or condition

3.6.29

error class

general grouping for related error definitions and corresponding error codes

3.6.30

error code

identification of a specific type of error within an error class

3.6.31

event

instance of a change of conditions

3.6.32

FAL subnet

subnetworks composed of one or more data link segments, identified by a subset of the network address

Note 1 to entry: FAL subnets are permitted to contain bridges but not routers.

3.6.33

FIFO variable

Variable Object class, composed of a set of homogeneously typed elements, where the first written element is the first element that can be read.

Note 1 to entry: On the fieldbus only one, complete element can be transferred as a result of one service invocation.

3.6.34

frame

denigrated synonym for DLPDU

3.6.35**interface**

<functional unit> shared boundary between two functional units, defined by functional characteristics, signal characteristics, or other characteristics as appropriate

3.6.36**interface**

<communication protocol> collection of FAL class attributes and services that represents a specific view on the FAL class

3.6.37**invocation**

act of using a service or other resource of an application process

Note 1 to entry: Each invocation represents a separate thread of control that may be described by its context. Once the service completes, or use of the resource is released, the invocation ceases to exist. For service invocations, a service that has been initiated but not yet completed is referred to as an outstanding service invocation. Also for service invocations, an Invoke ID may be used to unambiguously identify the service invocation and differentiate it from other outstanding service invocations.

3.6.38**index**

address of an object within an application process

3.6.39**instance**

actual physical occurrence of an object within a class that identifies one of many objects within the same object class

EXAMPLE California is an instance of the object class state.

Note 1 to entry: The terms object, instance, and object instance are used to refer to a specific instance.

3.6.40**instance attributes**

attribute that is unique to an object instance and not shared by the object class

3.6.41**instantiated**

object that has been created in a device

3.6.42**logical device**

certain FAL class that abstracts a software component or a firmware component as an autonomous self-contained facility of an automation device

3.6.43**manufacturer ID**

identification of each product manufacturer by a unique number

3.6.44**management information**

network-accessible information that supports managing the operation of the fieldbus system, including the application layer

Note 1 to entry: Managing includes functions such as controlling, monitoring, and diagnosing.

3.6.45**member**

piece of an attribute that is structured as an element of an array

3.6.46

method

<object> a synonym for an operational service which is provided by the server ASE and invoked by a client

3.6.47

module

hardware or logical component of a physical device

3.6.48

network

set of nodes connected by some type of communication medium, including any intervening repeaters, bridges, routers and lower-layer gateways

3.6.49

object

abstract representation of a particular component within a device, usually a collection of related data (in the form of variables) and methods (procedures) for operating on that data that have clearly defined interface and behaviour

3.6.50

object specific service

service unique to the object class which defines it

3.6.51

peer

role of an AR endpoint in which it is capable of acting as both client and server

3.6.52

physical device

automation or other network device

3.6.53

property

general term for descriptive information about an object

3.6.54

provider

source of a data connection

3.6.55

publisher

role of an AR endpoint that transmits APDUs onto the fieldbus for consumption by one or more subscribers

Note 1 to entry: A publisher may not be aware of the identity or the number of subscribers and it may publish its APDUs using a dedicated AR.

3.6.56

publishing manager

role of an AR endpoint in which it issues one or more confirmed service request APDUs to a publisher to request the publisher to publish a specified object

Note 1 to entry: Two types of publishing managers are defined by this document, pull publishing managers and push publishing managers, each of which is defined separately

3.6.57**pull subscriber**

type of subscriber that recognizes received confirmed service response APDUs as published object data

3.6.58**resource**

processing or information capability of a subsystem

3.6.59**route endpoint**

object container containing Variable Objects of a variable class

3.6.60**server**

<communication protocol> role of an AREP in which it returns a confirmed service response APDU to the client that initiated the request

3.6.61**server**

<object> object which provides services to another (client) object

3.6.62**service**

operation or function than an object and/or object class performs upon request from another object and/or object class

3.6.63**subscriber**

role of an AREP in which it receives APDUs produced by a publisher

3.7 Abbreviations and symbols

AE	Application Entity
AL	Application Layer
ALME	Application Layer Management Entity
ALP	Application Layer Protocol
APO	Application Object
AP	Application Process
APDU	Application Protocol Data Unit
API	Application Process Identifier
AR	Application Relationship
AREP	Application Relationship End Point
ASCII	American Standard Code for Information Interchange
ASE	Application Service Element
Cnf	Confirmation
CR	Communication Relationship
CREP	Communication Relationship End Point
DL-	(as a prefix) Data Link-
DLC	Data Link Connection
DLCEP	Data Link Connection End Point
DLL	Data Link Layer

DLM	Data Link-management
DLSAP	Data Link Service Access Point
DLSDU	DL-service-data-unit
DNS	Domain Name Service
DP	Decentralised Peripherals
FAL	Fieldbus Application Layer
FIFO	First In First Out
HMI	Human-Machine Interface
ID	Identifier
IDL	Interface Definition Language
IEC	International Electrotechnical Commission
Ind	Indication
IP	Internet Protocol
ISO	International Organization for Standardization
LDev	Logical Device
LME	Layer Management Entity
OSI	Open Systems Interconnect
PDev	Physical Device
PDU	Protocol Data Unit
PL	Physical Layer
QoS	Quality of Service
REP	Route Endpoint
Req	Request
Rsp	Response
RT	Runtime
SAP	Service Access Point
SCL	Security Level
SDU	Service Data Unit
SEM	State event matrix
SMIB	System Management Information Base
SMK	System Management Kernel
STD	State transition diagram, used to describe object behaviour
VAO	Variable Object

3.8 Conventions

3.8.1 Overview

The FAL is defined as a set of object-oriented ASEs. Each ASE is specified in a separate subclause. Each ASE specification is composed of two parts, its class specification, and its service specification.

The class specification defines the attributes of the class. The attributes are accessible from instances of the class using the Object Management ASE services specified in Clause 5 of this document. The service specification defines the services that are provided by the ASE.

3.8.2 General conventions

This document uses the descriptive conventions given in ISO/IEC 10731.

3.8.3 Conventions for class definitions

Class definitions are described using templates. Each template consists of a list of attributes for the class. The general form of the template is shown below:

FAL ASE:	ASE Name
CLASS:	Class Name
CLASS ID:	#
PARENT CLASS:	Parent Class Name
ATTRIBUTES:	
1 (o) Key Attribute:	numeric identifier
2 (o) Key Attribute:	name
3 (m) Attribute:	attribute name(values)
4 (m) Attribute:	attribute name(values)
4.1 (s) Attribute:	attribute name(values)
4.2 (s) Attribute:	attribute name(values)
4.3 (s) Attribute:	attribute name(values)
5. (c) Constraint:	constraint expression
5.1 (m) Attribute:	attribute name(values)
5.2 (o) Attribute:	attribute name(values)
6 (m) Attribute:	attribute name(values)
6.1 (s) Attribute:	attribute name(values)
6.2 (s) Attribute:	attribute name(values)
SERVICES:	
1 (o) OpsService:	service name
2. (c) Constraint:	constraint expression
2.1 (o) OpsService:	service name
3 (m) MgtService:	service name

- (1) The "FAL ASE:" entry is the name of the FAL ASE that provides the services for the class being specified.
- (2) The "CLASS:" entry is the name of the class being specified. All objects defined using this template will be an instance of this class. The class may be specified by this document, or by a user of this document.
- (3) The "CLASS ID:" entry is a number that identifies the class being specified. This number is unique within the FAL ASE that will provide the services for this class. When qualified by the identity of its FAL ASE, it unambiguously identifies the class within the scope of the FAL. The value "NULL" indicates that the class cannot be instantiated. Class IDs between 1 and 255 are reserved by this document to identify standardized classes. They have been assigned to maintain compatibility with existing national standards. CLASS IDs between 256 and 2048 are allocated for identifying user defined classes.
- (4) The "PARENT CLASS:" entry is the name of the parent class for the class being specified. All attributes defined for the parent class and inherited by it are inherited for the class being defined, and therefore do not have to be redefined in the template for this class.

NOTE The parent-class "TOP" indicates that the class being defined is an initial class definition. The parent class TOP is used as a starting point from which all other classes are defined. The use of TOP is reserved for classes defined by this document.

- (5) The "ATTRIBUTES" label indicate that the following entries are attributes defined for the class.
- a) Each of the attribute entries contains a line number in column 1, a mandatory (m) / optional (o) / conditional (c) / selector (s) indicator in column 2, an attribute type label in column 3, a name or a conditional expression in column 4, and optionally a list of enumerated values in column 5. In the column following the list of values, the default value for the attribute may be specified.
 - b) Objects are normally identified by a numeric identifier or by an object name, or by both. In the class templates, these key attributes are defined under the key attribute.
 - c) The line number defines the sequence and the level of nesting of the line. Each nesting level is identified by period. Nesting is used to specify
 - i) fields of a structured attribute (4.1, 4.2, 4.3),
 - ii) attributes conditional on a constraint statement (5). Attributes may be mandatory (5.1) or optional (5.2) if the constraint is true. Not all optional attributes require constraint statements as does the attribute defined in (5.2)
 - iii) the selection fields of a choice type attribute (6.1 and 6.2).
- (6) The "SERVICES" label indicates that the following entries are services defined for the class.
- a) An (m) in column 2 indicates that the service is mandatory for the class, while an (o) indicates that it is optional. A (c) in this column indicates that the service is conditional. When all services defined for a class are defined as optional, at least one has to be selected when an instance of the class is defined.
 - b) The label "OpsService" designates an operational service (1).
 - c) The label "MgtService" designates an management service (2).
 - d) The line number defines the sequence and the level of nesting of the line. Each nesting level is identified by period. Nesting within the list of services is used to specify services conditional on a constraint statement.

3.8.4 Conventions for service definitions

3.8.4.1 General

The service model, service primitives, and time-sequence diagrams used are entirely abstract descriptions; they do not represent a specification for implementation.

3.8.4.2 Service parameters

Service primitives are used to represent service user/service provider interactions (ISO/IEC 10731). They convey parameters which indicate information available in the user/provider interaction. In any particular interface, not all parameters need be explicitly stated.

The service specifications of this document uses a tabular format to describe the component parameters of the ASE service primitives. The parameters which apply to each group of service primitives are set out in tables. Each table consists of up to five columns for the

- 1) Parameter name,
- 2) request primitive,
- 3) indication primitive,

- 4) response primitive, and
- 5) confirm primitive.

One parameter (or component of it) is listed in each row of each table. Under the appropriate service primitive columns, a code is used to specify the type of usage of the parameter on the primitive specified in the column:

- M parameter is mandatory for the primitive
- U parameter is a User option, and may or may not be provided depending on dynamic usage of the service user. When not provided, a default value for the parameter is assumed.
- C parameter is conditional upon other parameters or upon the environment of the service user.
- (blank) parameter is never present.
- S parameter is a selected item.

Some entries are further qualified by items in brackets. These may be

- a) a parameter-specific constraint:

“(=)” indicates that the parameter is semantically equivalent to the parameter in the service primitive to its immediate left in the table.

- b) an indication that some note applies to the entry:

“(n)” indicates that the following note “n” contains additional information pertaining to the parameter and its use.

3.8.4.3 Service procedures

The procedures are defined in terms of

- the interactions between application entities through the exchange of fieldbus Application Protocol Data Units, and
- the interactions between an application layer service provider and an application layer service user in the same system through the invocation of application layer service primitives.

These procedures are applicable to instances of communication between systems which support time-constrained communications services within the fieldbus Application Layer.

4 Concepts

4.1 Overview

The fieldbus is intended to be used in factories and process plants to interconnect primary automation devices (e.g. sensors, actuators, local display devices, annunciators, programmable logic controllers, small single loop controllers, and stand-alone field controls) with control and monitoring equipment located in control rooms.

Primary automation devices are associated with the lowest levels of the industrial automation hierarchy and perform a limited set of functions within a definite time window. Some of these functions include diagnostics, data validation, and handling of multiple inputs and outputs.

These primary automation devices, also termed field devices, are located close to the process fluids, the fabricated part, the machine, the operator and the environment. This use positions the fieldbus at the lowest levels of the Computer Integrated Manufacturing (CIM) architecture.

Some of the expected benefits in using fieldbus are reduction in wiring, increase in amount of data exchanged, wider distribution of control between the primary automation devices and the control room equipment, and the satisfaction of time critical constraints.

Clause 4 describes fundamentals of the FAL. Detailed descriptive information about each of the FAL ASEs can be found in the “Overview” subclause of each of the Communication Model specifications.

4.2 Architectural relationships

4.2.1 Relationship to the Application Layer of the OSI basic reference model

The functions of the FAL have been described according to OSI layering principles. However, its architectural relationship to the lower layers is different, as shown in Figure 1.

- The FAL includes OSI functions together with extensions to cover time-critical requirements. The OSI Application Layer Structure standard (ISO/IEC 9545) was used as a basis for specifying the FAL.
- The FAL directly uses the services of the underlying layer. The underlying layer may be the data link layer or any layer in between. When using the underlying layer, the FAL may provide functions normally associated with the OSI Middle Layers for proper mapping onto the underlying layer.




Figure 1 – Relationship to the OSI basic reference model

4.2.2 Relationships to other fieldbus entities

4.2.2.1 General

The fieldbus Application Layer (FAL) architectural relationships, as illustrated in Figure 2, have been designed to support the interoperability needs of time-critical systems distributed within the fieldbus environment.

Within this environment, the FAL provides communications services to time-critical and non-time-critical applications located in fieldbus devices.

In addition, the FAL directly uses the Data Link Layer to transfer its application layer protocol data units. It does this using a set of data transfer services and a set of supporting services used to control the operational aspects of the Data Link Layer.




Figure 2 – Architectural positioning of the fieldbus Application Layer

4.2.2.2 Use of the fieldbus Data Link Layer

The fieldbus Application Layer (FAL) provides network access to fieldbus APs. It interfaces directly to the fieldbus Data Link Layer for transfer of its APDUs.

The Data Link Layer provides various types of services to the FAL for the transfer of data between Data Link endpoints (e.g. DLSAPs, DLCEPs).

4.2.2.3 Support for fieldbus applications

Fieldbus applications are represented to the network as application processes (APs). APs are the components of a distributed system that may be individually identified and addressed.

Each AP contains an FAL application entity (AE) that provides network access for the AP. That is, each AP communicates with other APs through its AE. In this sense, the AE provides a window of visibility into the AP.

APs contain identifiable components that are also visible across the network. These components are represented to the network as Application Process Objects (APO). They may be identified by one or more key attributes. They are located at the address of the application process that contains them.

The services used to access them are provided by APO-specific application service elements (ASEs) contained within the FAL. These ASEs are designed to support user, function block, and management applications.

4.2.2.4 Support for system management

The FAL services can be used to support various management operations, including management of fieldbus systems, applications, and the fieldbus network.

4.2.2.5 Access to FAL layer management entities

One layer management entity (LME) may be present in each FAL entity on the network. FALMEs provide access to the FAL for system management purposes.

The set of data accessible by the System Manager is referred to as the System Management Information Base (SMIB). Each fieldbus Application Layer Management Entity (FALME) provides the FAL portion of the SMIB. How the SMIB is implemented is beyond the scope of this document.

4.3 Fieldbus Application Layer structure

4.3.1 Overview

The structure of the FAL is a refinement of the OSI Application Layer Structure (ISO/IEC 9545). As a result, the organization of 4.3 is similar to that of ISO/IEC 9545. Certain concepts presented here have been refined from ISO/IEC 9545 for the fieldbus environment.

The FAL differs from the other layers of OSI in two principal aspects.

- OSI defines a single type of application layer communications channel, the association, to connect APs to each other. The FAL defines the Application Relationship (AR), of which there are several types, to permit application processes (APs) to communicate with each other.
- The FAL uses the DLL to transfer its PDUs and not the presentation layer. Therefore, there is no explicit presentation context available to the FAL. Between the same pair (or set) of data link service access points the FAL protocol may not be used concurrently with other application layer protocols.

4.3.2 Fundamental concepts

The operation of time critical real open systems is modeled in terms of interactions between time-critical APs. The FAL permits these APs to pass commands and data between them.

Cooperation between APs requires that they share sufficient information to interact and carry out processing activities in a coordinated manner. Their activities may be restricted to a single fieldbus segment, or they may span multiple segments. The FAL has been designed using a modular architecture to support the messaging requirements of these applications.

Cooperation between APs also sometimes requires that they share a common sense of time. The FAL or the Data Link Layer (IEC 61158-3-4 and IEC 61158-4-4) may provide for the distribution of time to all devices. They also may define local device services that can be used by APs to access the distributed time.

The remainder of 4.3 describes each of the modular components of the architecture and their relationships with each other. The components of the FAL are modeled as objects, each of which provides a set of FAL communication services for use by applications. The FAL objects and their relationships are described below. The detailed specifications of FAL objects and their services are provided in the following clauses of this document. IEC 61158-6-4 specifies the protocols necessary to convey these object services between applications.

4.3.3 Fieldbus application processes

4.3.3.1 Definition of the fieldbus AP

In the fieldbus environment, an application may be partitioned into a set of components and distributed across a number of devices on the network. Each of these components is referred to as a fieldbus Application Process (AP). A fieldbus AP is a variation of an Application Process as defined in ISO OSI Reference Model (ISO/IEC 7498). Fieldbus APs may be unambiguously addressed by at least one individual Data Link Layer service access point address. Unambiguously addressed, in this context, means that no other AP may simultaneously be located by the same address. This definition does not prohibit an AP from being located by more than one individual or group data link service access point address.

4.3.3.2 Communication services

Fieldbus APs communicate with each other using confirmed and unconfirmed services (ISO/IEC 10731). The services defined in this document for the FAL specify the semantics of the services as seen by the requesting and responding APs. The syntax of the messages used to convey the service requests and responses is defined in IEC 61158-6-4. The AP behavior associated with the services is specified by the AP.

Confirmed services are used to define request/response exchanges between APs.

Unconfirmed services, in contrast, are used to define the unidirectional transfer of messages from one AP to one or more remote APs. From a communications perspective, there is no relationship between separate invocations of unconfirmed services as there is between the request and response of a confirmed service.

4.3.3.3 AP interactions

4.3.3.3.1 General

Within the fieldbus environment, APs may interact with other APs as necessary to achieve their functional objectives. No constraints are imposed by this document on the organization of these interactions or the possible relationships that may exist between them.

For example, in the fieldbus environment, interactions may be based on request/response messages sent directly between APs, or on data/events sent by one AP for use by others. These two models of interactions between APs are referred to as client/server and publisher/subscriber interactions.

The services supported by an interaction model are conveyed by application relationship endpoints (AREPs) associated with the communicating APs. The role that the AREP plays in the interaction (e.g. client, server, peer, publisher, subscriber) is defined as an attribute of the AREP.

4.3.3.3.2 Client/server interactions

Client/server interactions are characterized by a bi-directional data flow between a client AP and one or more server APs. Figure 3 illustrates the interaction between a single client and a single server. In this type of interaction, the client may issue a confirmed or unconfirmed request to the server to perform some task. If the service is confirmed then the server will always return a response. If the service is unconfirmed, the server may return a response using an unconfirmed service defined for this purpose.




Figure 3 – Client/server interactions

4.3.3.3.3 Publisher/subscriber interactions

4.3.3.3.3.1 General

Publisher/subscriber interactions, on the other hand, involve a single publisher AP, and a group of one or more subscriber APs. This type of interaction has been defined to support variations of two models of interaction between APs, the "pull" model and the "push" model. In both models, the setup of the publishing AP is performed by management and is outside the scope of this document.

4.3.3.3.3.2 Pull model interactions

In the "pull" model, the publisher receives a request to publish from a remote publishing *manager*, and broadcasts (or multicasts) its response across the network. The publishing manager is responsible only for initiating publishing by sending a request to the publisher.

Subscribers wishing to receive the published data listen for responses transmitted by the publisher. In this fashion, data is "pulled" from the publisher by requests from the publishing manager.

Confirmed FAL services are used to support this type of interaction. Two characteristics of this type of interaction differentiate it from the other types of interaction. First, a typical confirmed request/response exchange is performed between publishing manager and the publisher. However, the underlying conveyance mechanism provided by the FAL returns the response not just to the publishing manager, but also to all subscribers wishing to receive the published information. This is accomplished by having the Data Link Layer transmit the response to a group address, rather than to the individual address of the publishing manager. Therefore, the response sent by the publisher contains the published data and is multicast to the publishing manager and to all subscribers.

The second difference occurs in the behavior of the subscribers. Pull model subscribers, referred to as pull subscribers, are capable of accepting published data in confirmed service responses without having issued the corresponding request. Figure 4 illustrates these concepts.




Figure 4 – Pull model interactions

4.3.3.3.3 Push model interactions

In the "push" model, two services may be used, one confirmed and one unconfirmed. The confirmed service is used by the subscriber to request to join the publishing. The response to this request is returned to the subscriber, following the client/server model of interaction. This exchange is only necessary when the subscriber and the publisher are located in different APs.

The unconfirmed service used in the Push Model is used by the publisher to distribute its information to subscribers. In this case, the publisher is responsible for invoking the correct unconfirmed service at the appropriate time and for supplying the appropriate information. In this fashion, it is configured to "push" its data onto the network.

Subscribers for the Push Model receive the published unconfirmed services distributed by publishers. Figure 5 illustrates the concept of the Push Model.




Figure 5 – Push model interactions

4.3.3.3.4 Timeliness of published information

To support the perishable nature of published information, the FAL may support four types of timeliness defined for publisher/subscriber interactions. Each make it possible for subscribers of published data to determine if the data they are receiving is up-to-date or "stale". These types are realized through mechanisms within the Data Link Layer (DLL). Each is described briefly below. For a more detailed description, refer to IEC 61158-3-4 and IEC 61158-4-4.

Type	Description
Transparent	This type of timeliness allows the user application process to determine the timeliness quality of data that it generates and have the timeliness quality accompany the information when it is transferred across the network. In this type of timeliness, the network provides no computation or measurement of timeliness. It merely conveys the timeliness quality provided with the data by the user application process.
Residence	When the FAL submits data from the publishing AP to the DLL for transmission, the DLL starts a timer. If the timer expires before the data has been transmitted, the DLL marks the buffer as "not timely" and conveys this timeliness information with the data.

Type	Description
Synchronized	This type of timeliness requires the coordination of two pieces of published information. One is the data to be published and the other is a special "sync mark". When the sync mark is received from the network a timer starts in each of the participating stations. Subsequently, when data is received for transmission by the DLL at the publishing station, or when the transmitted data is received from the network at a subscribing station, the DLL timeliness attribute for the data is set to TRUE. It remains TRUE until the reception of the next sync mark or until the timer expires. Data received after the timer expires but before the next sync mark does not cause the timeliness attribute to be reset to TRUE. It is only reset to TRUE if data is received within the time window after receipt of the sync mark. Data transmitted by the publisher station with the timeliness attribute set to FALSE maintains the setting of FALSE at each of the subscribers, regardless of their timer operation.
Update	This type of timeliness requires the coordination of the same two pieces of published information defined for <i>synchronized</i> timeliness. In this type, the sync mark also starts a timer in each of the participating stations. Like <i>synchronized</i> timeliness, expiration of the timer always causes the timeliness attribute to be set to FALSE. Unlike <i>synchronized</i> timeliness, receipt of new data at any time (not just within the time window started with the receipt of a sync mark) causes the timeliness attribute to be set to TRUE.

4.3.3.4 AP structure

The internals of APs may be represented by one, or more Application Process Objects (APOs) and accessed through one or more Application Entities (AEs). AEs provide the communication capabilities of the AP. For each fieldbus AP, there is one and only one FAL AE. APOs are the network representation of application specific capabilities (user application process objects) of an AP that are accessible through its FAL AE.

4.3.3.5 AP class

An AP class is a definition of the attributes and services of an AP. The standard class definition for APs is defined in this document. User defined classes also may be specified. Class identifiers (described in 3.8.2) are assigned from a set reserved for this purpose.

4.3.3.6 AP type

As described above in the previous subclauses, APs are defined by instantiating an AP class. Each AP definition is composed of the attributes and services selected for the AP from those defined by its AP class. In addition, an AP definition contains values for one or more of the attributes selected for it. When two APs share the same definition, that definition is referred to as an AP type. Thus, an AP type is a generic specification of an AP that may be used to define one or more APs.

4.3.4 Application process objects

4.3.4.1 Definition of APO

An application process object (APO) is a network representation of a specific aspect of an AP. Each APO represents a specific set of information and processing capabilities of an AP that are accessible through services of the FAL. APOs are used to represent these capabilities to other APs in a fieldbus system.

From the perspective of the FAL, an APO is modeled as a network accessible object contained within an AP or within another APO (APOs may contain other APOs). APOs provide the network definition for objects contained within an AP that are remotely accessible. The definition of an APO includes an identification of the FAL services that can be used by remote APs for remote access. The FAL services, as shown in Figure 6, are provided by the FAL communications entity of the AP, known as the FAL Applications Entity (FAL AE).




Figure 6 – APOs services conveyed by the FAL

In Figure 6, remote APs acting as clients may access the real object by sending requests through the APO that represents the real object. Local aspects of the AP convert between the network view (the APO) of the real object and the internal AP view of the real object.

To support the publisher/subscriber model of interaction, information about the real object can be published through its APO. Remote APs acting as subscribers see the APO view of the published information instead of having to know any of the real object specific details.

4.3.4.2 APO classes

An APO Class is a generic specification for a set of APOs, each of which is described by the same set of attributes and accessed using the same set of services.

APO Classes provide the mechanism for standardizing network visible aspects of APs. Each standard APO Class definition specifies a particular set of network accessible AP attributes and services. IEC 61158-6-4 specifies the syntax and the procedures used by the FAL protocol to provide remote access to the attributes and services of an APO Class.

Standard APO Classes are specified by this document for the purpose of standardizing remote access to APs. User defined classes may also be specified.

User defined classes are defined as subclasses of standardized APO Classes or of other user-defined classes. They may be defined by identifying new attributes or by indicating that optional attributes for the parent class are mandatory for the subclass. The conventions for defining classes defined in 3.8.2 may be used for this purpose. The method for registering or otherwise making these new class definitions available for public use is beyond the scope of this document.

4.3.4.3 APOs as instances of APO classes

APO Classes are defined in this document using templates. These templates are used not only to define APO Classes, but also to specify the instances of a class.

Each APO defined for an AP is an instance of an APO Class. Each APO provides the network view of a real object contained in an AP. An APO is defined by

- (1) selecting the attributes from its APO Class template that are to be accessible from the real object;

- (2) assigning values to one or more attributes indicated as key in the template. Key attributes are used to identify the APO;
- (3) assigning values to zero, one, or more non-key attributes for the APO. Non-key attributes are used to characterize the APO;
- (4) selecting the services from the template that may be used by remote APs to access the real object.

Subclause 3.8.2 of this document specifies the conventions for class templates. These conventions provide for the definition of mandatory, optional, and conditional attributes and services.

Mandatory attributes and services are required to be present in all APOs of the class. Optional attributes and services may be selected, on an APO by APO basis, for inclusion in an APO. Conditional attributes and services are defined with an accompanying constraint statement. Constraint statements specify the conditions that indicate whether or not the attribute is to be present in an APO.

4.3.4.4 APO types

APO types provide the mechanism for defining standard APOs.

As described above in the previous subclauses, APOs are defined by instantiating an APO class. Each APO definition is composed of the attributes and services selected for the APO from those defined by its APO class. In addition, an APO definition contains values for one or more of the attributes selected for it. When two APOs share the same definition, except for the key attribute settings, that definition is referred to as an APO type. Thus, an APO type is a generic specification of an APO that may be used to define one or more APOs.

4.3.5 Application entities

4.3.5.1 Definition of FAL AE

An application entity provides the communication capabilities for a single AP. An FAL AE provides a set of services and the supporting protocols to enable communications between APs in a fieldbus environment. The services provided by FAL AEs are grouped into Application Service Elements (ASE), such that the FAL services provided to an AP are defined by the ASEs its FAL AE contains. Figure 7 illustrates this concept.




Figure 7 – Application entity structure

4.3.5.2 AE type

Application entities that provide the same set of ASEs are of the same AE-type. Two AEs that share a common set of ASEs are capable of communicating with each other.

4.3.6 Fieldbus application service elements

4.3.6.1 General

An application service element (ASE), as defined in ISO/IEC 9545, is a set of application functions that provide a capability for the interworking of application-entity-invocations for a specific purpose. ASEs provide a set of services for conveying requests and responses to and from application processes and their objects. AEs, as defined above, are represented by a collection of ASE invocations within the AE.

4.3.6.2 FAL services

FAL Services convey functional requests/responses between APs. Each FAL service is defined to convey requests and responses for access to a real object modeled as an FAL accessible object.

The FAL defines both confirmed and unconfirmed services. Confirmed service requests are sent to the AP containing the real object. An invocation of a confirmed service request may be identified by a user supplied Invoke ID. This Invoke ID is returned in the response by the AP containing the real object. When present, it is used by the requesting AP and its FAL AE to associate the response with the appropriate request.

Unconfirmed services may be sent from the AP containing the real object to send information about the object. They also may be sent to the AP containing the real object to access the real object. Both types of unconfirmed services may be defined for the FAL.

4.3.6.3 Definition of FAL ASEs

4.3.6.3.1 General

A modular approach has been taken in the definition of FAL ASEs. The ASEs defined for the FAL are also object-oriented. In general, ASEs provide a set of services designed for one specific object class or for a related set of classes. Common object management ASEs, when present, provide a common set of management services applicable to all classes of objects.

To support remote access to the AP, the Application Relationship ASE is defined. It provides services to the AP for defining and establishing communication relationships with other APs, and it provides services to the other ASEs for conveying their service requests and responses.

Each FAL ASE defines a set of services, APDUs, and procedures that operate on the classes that it represents. Only a subset of the ASE services may be provided to meet the needs of an application. Profiles may be used to define such subsets. Definition of profiles is beyond the scope of this document.

APDUs are sent and received between FAL ASEs that support the same services. Each FAL AE contains, at a minimum, the AR ASE and at least one other ASE. Figure 8 illustrates an example set of the FAL ASEs and their architectural relationships. All APO ASEs follow this example.




Figure 8 – Example FAL ASEs

4.3.6.3.2 Object management ASE

A special object management ASE may be specified for the FAL to provide services for the management of objects. Its services are used to access object attributes, and create and delete object instances. These services are used to manage network visible AP objects accessed through the FAL. The specific operational services that apply to each object type are specified in the definition of the ASE for the object type. Figure 9 illustrates the integration of management and operational services for an object within an AP.




Figure 9 – FAL management of objects

4.3.6.3.3 AP ASE

An AP ASE may be specified for the identification and control of FAL APs. The attributes defined by the AP ASE specify characteristics of the AP about its manufacturer, and list its contents and capabilities.

4.3.6.3.4 APO ASEs

The FAL specifies a set of ASEs with services defined for accessing the APOs of an AP. The APO ASEs defined for the FAL are defined by each Communication Model.

4.3.6.3.5 AR ASE

An AR ASE is specified to establish and maintain application relationships (ARs) that are used to convey FAL APDUs between/among APs. ARs represent application layer communication channels between APs. AR ASEs are responsible for providing services at the endpoints of ARs. AR ASE services may be defined for establishing, terminating, and aborting ARs, for conveying APDUs for the AE, and for indicating the local status of the AR to the user. In addition, local services may be defined for accessing certain aspects of AR endpoints.

4.3.6.4 FAL service conveyance

FAL APO ASEs provide services to convey requests and responses between service users and real objects.

To accomplish the task of conveying service requests and responses, three types of activities for the sending user and three corresponding types for the receiving user are defined. At the sending user, they accept service requests and responses to be conveyed. Second, they select the type of FAL APDU that will be used to convey the request or response and encode the service parameters into its body portion. Then they submit the encoded APDU body to the AR ASE for conveyance.

At the receiving user, they receive encoded APDU bodies from the AR ASE. They decode the APDU bodies and extract the service parameters conveyed by them. To conclude the conveyance, they deliver the service request or response to the user. Figure 10 illustrates these concepts.




Figure 10 – ASE service conveyance

4.3.6.5 FAL presentation context

The presentation context in the OSI environment is used to distinguish the APDUs of one ASE from another, and to identify the transfer syntax rules used to encode each APDU. However, the fieldbus communications architecture does not include the presentation layer. Therefore, an alternate mechanism is provided for the FAL by each of the specific types of Communication Models.

4.3.7 Application relationships

4.3.7.1 Definition of AR

ARs represent communication channels between APs. They define how information is communicated between APs. Each AR is characterized by how it conveys ASE service requests and responses from one AP to another. These characteristics are described below.

4.3.7.2 AR-endpoints

ARs are defined as a set of cooperating APs. The AR ASE in each AP manages an endpoint of the AR, and maintains its local context. The local context of an AR endpoint is used by the AR ASE to control the conveyance of APDUs on the AR.

4.3.7.3 AR-endpoint classes

ARs are composed of a set of endpoints of compatible classes. AR endpoint classes are used to represent AR endpoints that convey APDUs in the same way. Through the standardization of endpoint classes, ARs for different models of interaction can be defined.

4.3.7.4 AR cardinality

ARs characterize communications between APs. One of the characteristics of an AR is the number of AR endpoints in the AR. ARs that convey services between two APs have a cardinality of 1-to-1. Those that convey services from one AP to a number of APs have a cardinality of 1-to-many. Those that convey services from/to multiple APs have a cardinality of many-to-many.

4.3.7.5 Accessing objects through ARs

ARs provide access to APs and the objects within them through the services of one or more ASEs. Therefore, one characteristic is the set of ASE services that may be conveyed to and from these objects by the AR. The list of services that can be conveyed by the AR are selected from those defined for the AE.

4.3.7.6 AR conveyance paths

ARs are modeled as one or two conveyance paths between AR endpoints. Each conveyance path conveys APDUs in one direction between one or more AR endpoints. Each receiving AR endpoint for a conveyance path receives all APDUs transmitting on the AR by the sending AR endpoint.

4.3.7.7 AREP roles

Because APs interact with each other through endpoints, a basic determinant of their compatibility is the role that they play in the AR. The role defines how an AREP interacts with other AREPs in the AR.

For example, an AREP may operate as a client, a server, a publisher, or a subscriber. When an AREP interacts with another AREP on a single AR as both a client and a server, it is defined to have the role of “peer”.

Certain roles may be capable of initiating service requests, while others may be capable only of responding to service requests. This part of the definition of a role identifies the requirement for an AR to be capable of conveying requests in either direction, or only in one direction.

4.3.7.8 AREP buffers and queues

AREPs may be modeled as a queue or as a buffer. APDUs transferred over a queued AREP are delivered in the order received for conveyance. The transfer of APDUs over a buffered AREP is different. In this case, an APDU to be conveyed by the AR ASE is placed in a buffer for transfer. When the Data Link Layer gains access to the network, it transmits the contents of the buffer.

When the AR ASE receives another conveyance request, it replaces the previous contents of the buffer whether or not they were transmitted. Once an APDU is written into a buffer for transfer, it is preserved in the buffer until the next APDU to be transmitted replaces it. While in the buffer, an APDU may be read more than once without deleting it from the buffer or changing its contents.

At the receiving end, the operation is similar. The receiving endpoint places a received APDU into a buffer for access by the AR ASE. When a subsequent APDU is received, it overwrites the previous APDU in the buffer whether or not it was read. Reading the APDU from the buffer is not destructive — it does not destroy or change the contents of the buffer, allowing the contents to be read from the buffer one or more times.

4.3.7.9 User-triggered and scheduled conveyance

Another characteristic of an AREP is when they convey service requests and responses. AREPs that convey them upon submission by the user are called user-triggered. Their conveyance is asynchronous with respect to network operation.

AREPs that convey requests and responses at predefined intervals, regardless of when they are received for transfer are termed scheduled. Scheduled AREPs may be capable of indicating when transferred data was submitted late for transmission, or when it was submitted on time, but transmitted late.

4.3.7.10 AREP timeliness

AREPs convey APDUs between applications using the services of the Data Link Layer. When the timeliness capabilities are defined for an AREP and supported by the Data Link Layer, the AREP forwards the timeliness indicators provided by the Data Link Layer. These timeliness indicators make it possible for subscribers of published data to determine if the data they are receiving is up-to-date or "stale".

To support these types of timeliness, the publishing AREP establishes a publisher data link connection reflecting the type of timeliness configured for it by management. After connection establishment, the AREP receives user data and submits it to the DLL for transmission, where timeliness procedures are performed. When the Data Link Layer has the opportunity to transmit the data, it transmits the current timeliness status with the data.

At the subscriber AREP, a data link connection is opened to receive published data that reflects the type of timeliness configured for it by management. The Data Link Layer computes the timeliness of received data and then delivers it to the AREP. The data is then delivered to the user AP through the appropriate ASE.

4.3.7.11 Definition and creation of AREPs

AREP definitions specify instances of AREP classes. AREPs may be predefined or they may be defined using a "create" service if their AE supports this capability.

AREPs may be pre-defined and pre-established, or they may be pre-defined and dynamically established. Figure 11 depicts these two cases. AREPs also may require both dynamic definition and establishment or they may be dynamically defined such that they may be used without any establishment (they are defined in an established state).




Figure 11 – Defined and established AREPs

4.3.7.12 AR establishment and termination

ARs may be established either before the operational phase of the AP or during its operation. When established during the operation of an AP, the AR is established through the exchange of AR APDUs.

Once an AR has been established, an AR may be terminated gracefully or it may be aborted, depending on the capabilities of the AR.

4.4 Fieldbus Application Layer naming and addressing

4.4.1 General

Subclause 4.4 refines the principles defined in ISO 7498-3 that involve the identification (naming) and location (addressing) of APOs referenced through the fieldbus Application Layer.

Subclause 4.4 defines how names and numeric identifiers are used to identify APOs accessible through the FAL. Subclause 4.4 also indicates how addresses from underlying layers are used to locate APs in the fieldbus environment.

4.4.2 Identifying objects accessed through the FAL

4.4.2.1 General

APOs accessed through the FAL are identified independent of their location. That is, if the location of the AP that contains the APO changes, the APO may still be referenced using the same set of identifiers.

Identifiers for APs and APOs within the FAL are defined as key attributes in the class definitions for APOs. Within these APO definitions, two types of key attributes are commonly used, names and numeric identifiers.

4.4.2.2 Names

Names are string-oriented identifiers. They are defined to permit APs and APOs to be named within the system where they are used. Therefore, although the scope of the name of an APO is specific to the AP in which it resides, the assignment of the name is administered within the system in which it is configured.

Names may be descriptive, although they do not have to be. Descriptive names make it possible to provide meaningful information, such as its use, about the object they name.

Names may also be coded. Coded names make it possible to identify an object using a short, compressed form of a name. They are typically simpler to transfer and process, but not as easy to understand as descriptive names.

4.4.2.3 Numeric identifiers

Numeric identifiers are identifiers whose values are numbers. They are designed for efficient use within the fieldbus system, and may be assigned for efficient access to APOs by their AP.

4.4.3 Addressing APs accessed through the FAL

Fieldbus addresses represent the network locations of APs. Addresses relevant to the FAL are the addresses of the underlying layers that are used to locate the AREPs of an AP.

4.5 Architecture summary

The summary of the FAL architecture is presented in 4.5. Figure 12 illustrates the major components of the FAL architecture and how they relate to each other.




Figure 12 – FAL architectural components

Figure 12 depicts an AP that communicates through the FAL AE. The AP represents its internal real objects as APOs for remote access to them. Two ASEs are shown that provide the remote access services to their related APOs. The AR ASE contains a single AREP that conveys service requests and responses for the ASEs to one or more remote AREPs located in remote APs.

4.6 FAL service procedures

4.6.1 FAL confirmed service procedures

The requesting user submits a confirmed service request primitive to its FAL. The appropriate FAL ASE builds the related confirmed service request APDU Body and conveys it on the specified AR.

Upon receipt of the confirmed service request APDU Body, the responding ASE decodes it. If a protocol error did not occur, the ASE delivers a confirmed service indication primitive to its user.

If the responding user is able to successfully process the request, the user returns a confirmed service response (+) primitive.

If the responding user is unable to successfully process the request, the service fails and the user issues a confirmed service response (-) primitive indicating the reason.

The responding ASE builds a confirmed service response APDU Body for a confirmed service response (+) primitive or a confirmed service error APDU Body for a confirmed service response (-) primitive and conveys it on the specified AR.

Upon receipt of the returned APDU Body the initiating ASE delivers a confirmed service confirmation primitive to its user which specifies success or failure, and the reason for failure if a failure occurred.

4.6.2 FAL unconfirmed service procedures

The requesting user submits an unconfirmed service request primitive to its FAL AE. The appropriate FAL ASE builds the related unconfirmed service request APDU Body and conveys it on the specified AR.

Upon receipt of the unconfirmed request APDU Body, the receiving ASE(s) participating in the AR delivers the appropriate unconfirmed service indication primitive to its user. Timeliness parameters are included in the indication primitive if the AR that conveyed the APDU Body supports timeliness.

4.7 Common FAL attributes

In the specifications of the FAL classes that follow, many classes use the following attributes. Therefore, these attributes are defined here instead of with the other attributes for each of the classes, except for the Data Type class.

ATTRIBUTES:

- | | | |
|---|--------------------|--------------------|
| 1 | (o) Key Attribute: | Numeric Identifier |
| 2 | (o) Key Attribute: | Name |
| 3 | (o) Attribute: | User Description |
| 4 | (o) Attribute: | Object Revision |

1) Numeric Identifier

This optional key attribute specifies the numeric id of the object. It is used as a shorthand reference by the FAL protocol to identify the object. There are three possibilities for identification purposes: numeric identifier or name or both. This attribute is required for the Data Type model.

2) Name

This optional key attribute specifies the name of the object. There are three possibilities for identification purposes: numeric identifier or name or both.

3) User description

This optional attribute contains user defined descriptive information about the object.

4) Object revision

This optional attribute specifies the revision level of the object. It is a structured attribute composed of major and minor revision numbers. If Object Revision is supported, it contains both a Major Revision and a Minor Revision with a value range 0 to 15 for each. The use of major/minor fields is intended to provide the following features:

- Major revision

The Major Revision field contains the major revision value for the object. A change to the major revision indicates that interoperability is affected by the change.

- Minor revision

The Minor Revision field contains the minor revision value for the object. A change to the minor revision indicates that interoperability was not affected by the change - that is users of the object will continue to be capable of interoperating with the object when its minor revision is changed, provided that the major revision remains the same.

4.8 Common FAL service parameters

In the specifications of the FAL services that follow, many services use the following parameters. Therefore, they are defined here instead of with the other parameters for each of the services.

- AREP

This parameter contains sufficient information to locally identify the AREP to be used to convey the service. This parameter may use a key attribute of the AREP to identify the application relationship. When an AREP supports multiple contexts (established using the Initiate service) at the same time, the AREP parameter is extended to identify the context as well as the AREP.

- Invoke ID

This parameter identifies this invocation of the service. It is used to associate service requests with responses. Therefore, no two outstanding service invocations may be identified by the same Invoke ID value.

- FAL ASE/FAL class

This parameter specifies the FAL ASE (e.g. AP, AR, Variable, Data Type, Event, Function Invocation, Load Region) and the FAL Class within the ASE (e.g. AREP, Variable List, Notifier, Action).

- Numeric ID

This parameter is the numeric identifier of the object.

- Error info

This parameter provides error information for service errors. It is returned in confirmed service response(-) primitives. It is composed of the following elements.

- Error class

This parameter indicates the general class of error. Valid values are specified in the definition of Error Code parameter, below.

- Error code

This parameter identifies the specific service error.

- Additional code

This optional parameter identifies the error encountered when processing the request specific to the object being accessed. When used, the value submitted in the response primitive is delivered unchanged in the confirmation primitive.

- Additional detail

This optional parameter contains user data that accompanies the negative response. When used, the value submitted in the response primitive is delivered unchanged in the confirmation primitive.

4.9 APDU size

APDU size is Communication Model dependent.

5 Type 4 communication model specification

5.1 Concepts

5.1.1 Overview

The concepts of this model basically follow the common concepts with a few exceptions. The basic principle described in 4.2.2.1 through 4.2.2.3 are applicable for Clause 5. This Type supports Gateway functionality within the application layer. Part of this can also be recognised from the common concepts. However, to promote readability, some elements from Clause 4 are repeated in Clause 5.

5.1.2 Application entities

5.1.2.1 Definition of FAL AE

An FAL AE provides a set of services to enable communications between APs in a fieldbus environment. These services enable a user application in a Client to access user objects in a server.

The functionality of the FAL AE can be divided into two groups.

Application Relation (AR). The AR functionality is responsible for arranging the transportation of APDUs via the network.

Variable Access (VA). The Variable Access functionality is responsible for coding and encoding of APDUs. In a server the VA also convey data directly to / from user objects. How this is done is a local matter and out of scope for this document.

5.1.2.2 FAL services

The services offered by the FAL AE to the user application are called FAL Services. Services for the AR are called AR ASE services and services for the Variable Access are called Route Endpoint ASE services (REP ASE services).

The FAL services provide access to local AR objects, and provide conveyance of requests and responses for access to real objects modelled as FAL accessible objects. The FAL provides as well confirmed as unconfirmed services. Service requests are conveyed to the AP containing the real object.

Figure 13 illustrates the FAL AE and the architectural relationships.




Figure 13 – FAL AE

5.1.2.3 AR ASE

To support access to the remote AP, the Application Relationship ASE is defined. It provides services to the AP for accessing communication-related parameters, and it provides services to the REP ASE for conveying service requests and responses.

The AR ASE provides services at the endpoints of ARs (AREPs).

5.1.2.4 REP ASE

The REP ASE provides a set of services used to read and write network visible attributes of Variable Objects and their application data. As only one ASE type is used remotely, the type is implicit and not transferred.

5.1.2.5 FAL service conveyance and gateway

The FAL AE provides services to convey requests and responses between User Applications and Variable Objects including Gateway functionality.

In a distributed system, application processes communicate with each other by exchanging application layer messages. The AR is defined to support the on-demand exchange of confirmed and unconfirmed services between two application processes. Connectionless data link services are used for the exchanges. The data link layer transfers may be either acknowledged or unacknowledged.

5.1.2.6 Application relationships

5.1.2.6.1 Definition of AR

The AR is responsible for conveying messages between applications. The messages that are conveyed are FAL service requests and responses. Each service request and response is submitted to the AR ASE for transfer. Within the AR only one object type exist, the AR-Endpoint (AREP).

5.1.2.6.2 AR-endpoints

An AR-Endpoint (AREP) represents a service access point to a DLE within the AE. The AR Send Service conveys APDU and route information to the AREP and implicit to the DLE. The AREP is a system management object presenting the user configurable parameters of the related DLE.

This Type has no special system management services, because the attributes of the AREP objects are declared as Variable Objects by the user application. This makes the attributes network visible. The AR Get Attribute and AR Set Attribute services are used by these Variable Objects to access the attribute values.

When an AREP receives an APDU from its DLE (User-triggered) it conveys the APDU to the REP ASE or an AREP (gateway).

5.1.3 Gateway and routing

5.1.3.1 Overview

This Type supports gateway functionality. To identify the destination of a request, a route description is used. This route description holding a complete list of points to pass is sent with the request. On its way to the destination the route evolves in such a way that it always contains the route back to the requester and the route to the destination. The elements in the route are endpoint and DL addresses.

5.1.3.2 Route endpoint

Within the REP ASE, Route Endpoint objects (REPs) represent endpoints, holding a Route description. An REP represents the starting point for conveying a message. An REP also represents the destination of the APDU.

5.1.3.3 Identification of endpoints

The endpoints are identified by endpoint addresses. These EP addresses are numerical Addresses, taken within an AE from the same name space of numbers, to achieve a unique identification. These EP addresses are used to identify AREPs and REPs.

5.1.3.4 DL addresses

The DLE is identified from the Link by a DL-address. DL-addresses are defined in IEC 61158-4-4, but as they are part of the route, they are mentioned here. There is a one to one relation between the DL-address of a DLE and the endpoint address of the corresponding AREP.

5.1.3.5 Route

The complete Route contains a Destination-Route and a Source-Route.

The Destination-Route describes how to reach the destination REP. It is a sequence of Endpoint addresses and DL-addresses. On its way to the destination, the first element always indicates the address of the receiving DLE, AREP or REP.

The Source Route in the same way describes how to find the way back to the endpoint that initiated the request. It is a sequence of endpoint addresses and DL-addresses. On its way to the destination, the first element always indicates the address of the transmitting DLE, AREP or REP.

5.1.3.6 Destination /source route conversion

A Destination-Route conveyed by an REP is starting with the endpoint address of the local AREP. The next element is the DL-address of the receiving DLE. If the route goes through gateways a pair of addresses shall be added for each gateway, a DL-address and an AREP address. The final address is the endpoint address of the destination REP. The Source address is the endpoint address of the source REP.

The AR Send service removes the first element of the Destination-Route. The DLE inserts its own DL-address in front of the current Source Route before conveying the request to the link.

When a DLE receives an indication from the link, it removes the first element of the Destination Route (its own DL-address). The corresponding AREP inserts its own AREP address in front of the current Source Route before conveying the request to a REP or an AREP.

At the destination REP the Destination-Route holds the endpoint address of the REP, and the Source Route holds the complete route back to the requesting REP.

If any error appears with a request on its way to the destination, the current Source Route can be used for returning an error response.

5.1.4 Architecture summary

A summary of the FAL architecture is presented in Figure 14. It illustrates the major components of the FAL architecture and how they relate to each other.




Figure 14 – Summary of the FAL architecture

5.1.5 FAL service procedures and time sequence diagrams

5.1.5.1 Overview

Subclause 5.1.5 describes service procedures for FAL confirmed and unconfirmed services. An overview of the FAL service procedures is given in Figure 15.




Figure 15 – FAL service procedure overview

5.1.5.2 FAL confirmed service procedures

– At requesting AP:

The user application uses the REP ASE service "Reserve REP" to reserve a REP. The user application then uses the REP ASE service "Set REP Attribute" to set attributes of the REP, including the Destination Route to the remote REP.

The requesting user submits a confirmed request primitive to the REP ASE with the REP address as a parameter. The REP ASE builds the related confirmed request APDU and conveys it on the AREP, using an AR Send request primitive. The AREP address is indicated by the first element of the Destination route. The REP ASE starts an associated timer to monitor the request.

The AREP builds a request DLSDU and submits the route info together with the DLSDU to its DLE. The DLE sends the DLSDU at the first opportunity.

– At responding server AP:

Upon receipt of the DLSDU, the receiving AREP builds an APDU and delivers the APDU and the received Route to the addressed REP by an AR Send indication primitive.

The REP ASE handles the indication by data exchange with the addressed Variable Object, builds the related unconfirmed response APDU and conveys it on the AREP, using

an AR Send request primitive. The received Source route is used as Destination route for the response.

The AREP builds a request DLSDU and submits the route info, together with the DLSDU to its DLE. It is the task of the DL layer to decide whether to “queue” the DLSDU or send it immediately.

If the REP ASE is not able to process the indication and respond within “MaxIndicationDelay”, the REP ASE shall submit an AR Acknowledge request primitive to the receiving AREP, and in this way free the Token. The AR Acknowledge is submitted to the DLE.

- At requesting AP receiving the response:

Upon receipt of the response DLSDU, the receiving AREP conveys the response to the REP ASE. The destination address conveyed to the REP ASE holds the endpoint address of the requesting REP. The REP object can now deliver the response to the requesting user application. This is accomplished by the user invocation of the REP ASE RESPONSE Service.

If the timer expires before the requesting REP has received the response, the REP cancels the associated transaction state machine and delivers the Error response “No answer” to the user application.

5.1.5.3 Confirmed service time sequence diagram

Figure 16 shows the time sequence diagram for the confirmed services.




Figure 16 – Time sequence diagram for the confirmed services

5.1.5.4 Unconfirmed request service procedure

- At requesting AP:

The user application uses the REP ASE service "Reserve REP" to reserve a REP. The user application then uses the REP ASE service "Set REP Attribute" to set attributes of the REP, including the Destination Route to the remote REP.

The requesting user submits an unconfirmed request primitive to the REP ASE with the REP address as a parameter. The REP ASE builds the related unconfirmed request APDU and conveys it on the AREP, using an AR Send request primitive. The AREP address is indicated by the first element of the Destination route.

The AREP builds a request DLSDU and submits the route info together with the DLSDU to its DLE. The DLE sends the DLSDU at the first opportunity.

- At responding server AP:

Upon receipt of the DLSDU, the receiving AREP builds an APDU and delivers that and the received Route to the addressed REP by an AR Send indication primitive.

The REP ASE handles the indication by data exchange with the addressed Variable Object.

5.1.5.5 Unconfirmed service time sequence diagram

Figure 17 shows the time sequence diagram for the unconfirmed services.




Figure 17 – Time sequence diagram for unconfirmed services

5.1.5.6 Confirmed / unconfirmed service procedure through gateways

Upon receipt of a DLSDU, the receiving AREP delivers an AR Send indication primitive to the local destination. If the endpoint address is a REP address, the APDU + Route is delivered to the REP ASE. If the endpoint address is an AREP address, the AR send service is used to pass it on to the network (Gateway).

For confirmed service Request, an AR Acknowledge is submitted to the “source AREP” unless the response is expected within “MaxIndicationDelay”. “MaxIndicationDelay” is an attribute of the “source AREP”.

5.2 Variable ASE

5.2.1 Variable types

5.2.1.1 Overview

The Variable ASE specifies the machine independent syntax for application data conveyed by FAL services. The application layer supports the transfer of both basic and constructed variables. The encoding rules for basic variables and constructed variables as specified in 5.2 are provided in IEC 61158-6-4.

Variable Objects (VAOs) are defined as instances of a variable class. The Variable ASE provides access to VAOs. VAOs are identified by a numeric Variable Identifier, and are instances of a variable class.

Basic types are atomic types that cannot be decomposed into more elemental types. Constructed types are types composed of basic types and other constructed types. Their complexity and depth of nesting is free.

Constructed types are packed according to the encoding rules for constructed types. The structure of a constructed type is not network visible. The structure of a constructed type is generated by a compiler and transferred by other means.

All variable classes have the common attributes Variable Identifier, Data Type Identifier, Octet length, Read enable, Write enable and Write protected. All variable classes have the common services Read, Write, Get Variable Attribute and Set Variable Attribute.

This document recommends using floating point representation of measurement values scaled in SI units.

5.2.1.2 Basic variable types

Basic variable types have a constant length. The length of basic variable types is an integral number of octets. Defining new basic variable types is accomplished by defining new basic variable type classes.

5.2.1.3 Constructed variable types

5.2.1.3.1 Overview

Constructed variable types are needed to completely convey the variety of information present on the fieldbus. Four kinds of constructed variable types are defined in four classes in this standard: Complex, String, BitString and FIFO. Defining new kinds of constructed variable types is accomplished by defining new constructed variable type classes.

On the fieldbus a complete constructed variable can be transferred, or a part of it, e.g. a single field of a complex variable or an element of a string. When transferring only part of a variable, addressing with offset and maybe Bit-no is used. Offset indicates the distance (in octets) from the first octet of the variable to the part to be transferred, Bit-no indicates the bit number in one octet.

5.2.1.3.2 Complex variable type

A Complex variable type defines Arrays and Structures.

An Array is composed of an ordered set of homogeneously typed elements. This document places no restriction on the type of array elements, but it does require that each element be of the same type. Once defined, the number of elements in an Array may not be changed.

A Structure is made of an ordered set of heterogeneously typed elements called fields. Like Arrays, this document does not restrict the type of fields. However, the fields within a Structure can be of different types.

5.2.1.3.3 String variable type

A String is composed of an ordered set of an Actual Number of Elements field and a number of homogeneously typed elements. Once defined, the maximum number of elements in a String may not be changed.

5.2.1.3.4 BitString variable type

A BitString is defined as a series of bits. Once defined, the number of elements in a BitString may not be changed. The octet length of a BitString is the integral part of $((\text{the number of elements} + 7) \text{ divided by } 8)$.

5.2.1.3.5 FIFO variable type

A FIFO queue is composed of a set of homogeneously typed elements. This document places no restriction on the type of FIFO elements, but it does require that each element be of the same type. The first written element will be the first element that can be read. On the fieldbus only one, complete element can be transferred as a result of one service invocation.

5.2.2 Variable model class specification

5.2.2.1 Variable model

5.2.2.1.1 Formal model

The Variable formal model defines the characteristics common to all Variable classes. This class is not capable of being instantiated. It is present only for the inheritance of its attributes and services of its subclasses.

FAL ASE:		VARIABLE ASE
CLASS:	VARIABLE	
CLASS ID:		1
PARENT CLASS:		TOP
ATTRIBUTES:		
1	(m)	Key Attribute: Variable Identifier
2	(o)	Attribute: VariableTypeIdentifier
3	(o)	Attribute: Octet Length
4	(o)	Attribute: Read enable
5	(o)	Attribute: Write enable
6	(o)	Attribute: Write protected
SERVICES:		
1	(m)	OpService: Method
1	(m)	OpService: Read
2	(m)	OpService: Write
3	(o)	OpService: Get Variable Attribute
4	(o)	OpService: Set Variable Attribute

5.2.2.1.2 Attributes

1) Variable identifier

This attribute identifies the Variable Object instantiating the variable type class.

2) VariableTypeIdentifier

This optional attribute identifies the variable type as a Boolean, Integer8, Integer16, Integer32, Unsigned8, Unsigned16, Float32, Float64, UNICODE Char, Array, String, Structure or FIFO. The VariableTypeIdentifier is a numerical identifier, defined in IEC 61158-6-4. In this document, a descriptive name corresponding to the identifier is stated.

3) Octet length

This optional attribute indicates the length in octets of the data of the Variable Object. For all types except FIFO octet length indicates the total number of octets. For FIFO types, octet length indicates the number of octets in one element.

4) Read enable

The value of this optional attribute indicates, whether the data value of the Variable Object can be read via the fieldbus.

5) Write enable

The value of this optional attribute indicates, whether the data value of the Variable Object can be updated via the fieldbus.

6) Write protected

The value of this optional attribute indicates, whether the data value of the Variable Object can only be updated via the fieldbus under certain conditions. The conditions for permitting update of a Write protected VAO are out of scope of this document.

5.2.2.1.3 Services

1) Method

This service is used to activate a method that is related to the specified Variable Object.

2) Read

This service is used to read the data value of the Variable Object.

3) Write

This service is used to update the data value of the Variable Object.

4) Get variable attribute

This service is used to read an attribute of the Variable Object.

5) Set variable attribute

This service is used to update an attribute of the Variable Object.

5.2.3 Basic variable type specifications

5.2.3.1 Boolean variable type model

5.2.3.1.1 Formal model

This data type expresses a Boolean variable type with the possible values TRUE and FALSE.

FAL ASE: VARIABLE ASE

CLASS: BOOLEAN VARIABLE TYPE

CLASS ID: 2

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

- | | | | |
|---|-----|-------------|--------------|
| 1 | (m) | OpsService: | And |
| 2 | (m) | OpsService: | Or |
| 3 | (m) | OpsService: | Test-And-Set |

5.2.3.1.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

2 VariableTypeIdentifier = Boolean

3 Octet Length = 1

5.2.3.1.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation.

3) Test-And-Set

This service is used to read and update the data value of the Variable Object, by returning the result of a logical AND operation, and storing the result of a logical OR operation.

5.2.3.2 Integer8 variable type model

5.2.3.2.1 Formal model

This integer type is a two's complement binary number with a length of one octet.

FAL ASE: VARIABLE ASE

CLASS: INTEGER8 VARIABLE TYPE

CLASS ID: 3

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

- | | | | |
|---|-----|-------------|--------------|
| 1 | (m) | OpsService: | And |
| 2 | (m) | OpsService: | Or |
| 3 | (m) | OpsService: | Test-And-Set |

5.2.3.2.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

- | | | |
|---|----------------|------------|
| 2 | VariableTypeId | = Integer8 |
| 3 | Octet Length | = 1 |

5.2.3.2.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation.

3) Test-And-Set

This service is used to read and update the data value of the Variable Object, by returning the result of a logical AND operation, and storing the result of a logical OR operation.

5.2.3.3 Integer16 variable type model

5.2.3.3.1 Formal model

This integer type is a two's complement binary number with a length of two octets.

FAL ASE: VARIABLE ASE

CLASS: INTEGER16 VARIABLE TYPE

CLASS ID: 4

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

- | | | | |
|---|-----|-------------|-----|
| 1 | (m) | OpsService: | And |
| 2 | (m) | OpsService: | Or |

5.2.3.3.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

- | | | |
|---|----------------|-------------|
| 2 | VariableTypeId | = Integer16 |
| 3 | Octet Length | = 2 |

5.2.3.3.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation.

5.2.3.4 Integer32 variable type model

5.2.3.4.1 Formal model

This integer type is a two's complement binary number with a length of four octets.

FAL ASE: VARIABLE ASE

CLASS: INTEGER32 VARIABLE TYPE

CLASS ID: 5

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

1 (m) OpsService: And

2 (m) OpsService: Or

5.2.3.4.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

2 VariableTypeIdentifier = Integer32

3 Octet Length = 4

5.2.3.4.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation.

5.2.3.5 Unsigned8 variable type model

5.2.3.5.1 Formal model

This integer type is a binary number with a length of one octet. The most significant bit is always used as the most significant bit of the binary number; no sign bit is included.

FAL ASE: VARIABLE ASE

CLASS: UNSIGNED8 VARIABLE TYPE

CLASS ID: 6

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

1 (m) OpsService: And

2 (m) OpsService: Or

3 (m) OpsService: Test-And-Set

5.2.3.5.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

2 VariableTypeIdentifier = Unsigned8

3 Octet Length = 1

5.2.3.5.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation.

3) Test-And-Set

This service is used to read and update the data value of the Variable Object, by returning the result of a logical AND operation, and storing the result of a logical OR operation.

5.2.3.6 Unsigned16 variable type model

5.2.3.6.1 Formal model

This integer type is a binary number with a length of two octets. The most significant bit of the most significant octet is always used as the most significant bit of the binary number; no sign bit is included.

FAL ASE: VARIABLE ASE

CLASS: UNSIGNED16 VARIABLE TYPE

CLASS ID: 7

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

1 (m) OpsService: And

2 (m) OpsService: Or

5.2.3.6.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

2 VariableTypeIdentifier = Unsigned16

3 Octet Length = 2

5.2.3.6.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation.

5.2.3.7 Float32 variable type model

5.2.3.7.1 Formal model

This type has a length of four octets. The format for Float32 is that defined by ISO/IEC/IEEE 60559 as single precision.

FAL ASE: VARIABLE ASE

CLASS: FLOAT32 VARIABLE TYPE

CLASS ID: 8

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

5.2.3.7.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

2 VariableTypeIdentifier = Float32

3 Octet Length = 4

5.2.3.8 Float64 variable type model

5.2.3.8.1 Formal model

This type has a length of eight octets. The format for Float64 is that defined by ISO/IEC/IEEE 60559 as double precision.

FAL ASE: VARIABLE ASE

CLASS: FLOAT64 VARIABLE TYPE

CLASS ID: 9

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

5.2.3.8.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

2 VariableTypeIdentifier = Float64

3 Octet Length = 8

5.2.3.9 UNICODE char variable type model

5.2.3.9.1 Formal model

This type has a length of two octets. It is defined as a single UNICODE character.

FAL ASE: VARIABLE ASE

CLASS: UNICODE CHAR VARIABLE TYPE

CLASS ID: 10

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

5.2.3.9.2 Attributes

Variable Objects of this class will have the following constant values of the following (parent class) attributes:

2 VariableTypeIdentifier = UNICODE Char

3 Octet Length = 2

5.2.4 Constructed variable type specifications

5.2.4.1 Complex variable type model

5.2.4.1.1 Formal model

A Complex Variable is an Array or a Structure.

An Array is composed of an ordered set of homogeneously typed elements. This document places no restriction on the type of array elements, but it does require that each element be of the same type. Once defined, the number of elements in an Array may not be changed.

A Structure is made of an ordered set of heterogeneously typed elements called fields. Like Arrays, this document does not restrict the type of fields. However, the fields within a Structure can be of different types.

FAL ASE: VARIABLE ASE

CLASS: COMPLEX VARIABLE TYPE

CLASS ID: 11

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

- | | | | |
|---|-----|-------------|--------------|
| 1 | (m) | OpsService: | And |
| 2 | (m) | OpsService: | Or |
| 3 | (m) | OpsService: | Test-And-Set |

5.2.4.1.2 Attributes

Variable Objects of this class will have the following constant value of the following (parent class) attribute:

- | | |
|---|----------------------------------|
| 2 | VariableTypeIdentifier = Complex |
|---|----------------------------------|

5.2.4.1.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation. The operation is legal on subelements of integer or boolean type only.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation. The operation is legal on subelements of integer or boolean type only.

3) Test-And-Set

This service is used to read and update the data value of the Variable Object, by returning the result of a logical AND operation, and storing the result of a logical OR operation. The operation is legal on subelements of Integer8, Unsigned8 or boolean type only.

5.2.4.2 String variable type model

5.2.4.2.1 Formal model

A String is composed of an ordered set of an Actual Number of Elements field and a number of homogeneously typed elements. Once defined, the maximum number of elements in a String may not be changed.

FAL ASE:

VARIABLE ASE

CLASS: STRING VARIABLE TYPE

CLASS ID: 12

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

- | | | | |
|---|-----|-------------|--------------|
| 1 | (m) | OpsService: | And |
| 2 | (m) | OpsService: | Or |
| 3 | (m) | OpsService: | Test-And-Set |

5.2.4.2.2 Attributes

Variable Objects of this class will have the following constant value of the following (parent class) attribute:

- | | |
|---|---------------------------------|
| 2 | VariableTypeIdentifier = String |
|---|---------------------------------|

5.2.4.2.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation. The operation is legal on subelements of integer or boolean type only.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation. The operation is legal on subelements of integer or boolean type only.

3) Test-And-Set

This service is used to read and update the data value of the Variable Object, by returning the result of a logical AND operation, and storing the result of a logical OR operation. The operation is legal on subelements of Integer8, Unsigned8 or boolean type only.

5.2.4.3 BitString variable type model

5.2.4.3.1 Formal model

A BitString is defined as a series of bits. Once defined, the number of bits in a BitString may not be changed. The octet length of a BitString is the integral part of ((the number of bits + 7) divided by 8).

FAL ASE: VARIABLE ASE

CLASS: BITSTRING VARIABLE TYPE

CLASS ID: 13

PARENT CLASS: VARIABLE

ATTRIBUTES:

SERVICES:

- | | | | |
|---|-----|------------|--------------|
| 1 | (m) | OpService: | And |
| 2 | (m) | OpService: | Or |
| 3 | (m) | OpService: | Test-And-Set |

5.2.4.3.2 Attributes

Variable Objects of this class will have the following constant value of the following (parent class) attribute:

- 2 VariableTypeIdentifier = BitString

5.2.4.3.3 Services

1) And

This service is used to update the data value of the Variable Object, by storing the result of a logical AND operation. The operation is legal on a subelement (which is a bit) only.

2) Or

This service is used to update the data value of the Variable Object, by storing the result of a logical OR operation. The operation is legal on a subelement (which is a bit) only.

3) Test-And-Set

This service is used to read and update the data value of the Variable Object, by returning the result of a logical AND operation, and storing the result of a logical OR operation. The operation is legal on a subelement (which is a bit) only.

5.2.4.4 FIFO variable type model

5.2.4.4.1 Formal model

A FIFO queue is composed of a set of homogeneously typed elements. This document places no restriction on the type of FIFO elements, but it does require that each element be of the same type. The first written element will be the first element that can be read. On the fieldbus only one, complete element can be transferred as a result of one service invocation.

FAL ASE: VARIABLE ASE

CLASS: FIFO VARIABLE TYPE

CLASS ID: 14

PARENT CLASS: VARIABLE

ATTRIBUTES:

- | | | | |
|---|-----|------------|------------------|
| 1 | (m) | Attribute: | Next Element In |
| 2 | (m) | Attribute: | Next Element Out |
| 3 | (m) | Attribute: | Free elements |

- | | | | |
|---|-----|------------|---------------|
| 4 | (m) | Attribute: | Used elements |
| 5 | (o) | Attribute: | ReRead |
| 6 | (o) | Attribute: | ReWrite |

5.2.4.4.2 Attributes

Variable Objects of this class will have the following constant value of the following (parent class) attribute:

2 VariableTypeIdentifier = FIFO

1) Next element in

Next Element In is an Integer16, which holds the index number for the next element to be written to the FIFO.

2) Next element out

Next Element Out is an Integer16, which holds the index number for the next element to be read from the FIFO.

3) Free elements

This attribute is an Integer16 which holds the current number of free elements in the FIFO (= 0 if full).

4) Used elements

This attribute is an Integer16 which holds the current number of used elements in the FIFO (= 0 if empty).

5) Reread

Reread is a Boolean. When the value of Reread is TRUE, a Read will return the previously read element, instead of returning and removing the element indexed by Next Element Out. This facility can be used if a transmission error resulted in a faulty read of an element.

6) Rewrite

Rewrite is a Boolean. When the value of Rewrite is TRUE, a Write will overwrite the previously written element, instead of inserting a new element. This facility can be used if a transmission error resulted in a faulty write of an element.

5.2.4.4.3 Services

5.2.4.4.3.1 Overview

The services defined in the Variable ASE provide access to attributes and data of Variable Objects. The services are invoked by a REP ASE REQUEST Service invocation. The REP ASE REQUEST Service conveys the Variable ASE Service parameters. Refer to 5.3.3 for the documentation of these parameters.

5.2.4.4.3.2 Method

This service is used to activate a method that is related to the specified variable. Data passed with the request specifies the parameters and the specific ID of the method to activate for the FAL User. Data passed in the response is the result of the activated method.

5.2.4.4.3.3 Read

This service is used to read (part of) the specified variable. No data is passed with the request. The value of the specified variable is returned in the response.

5.2.4.4.3.4 Write

This service is used to update (part of) the specified variable. The data passed with the request is written into (part of) the specified variable. No data is returned in the response.

5.2.4.4.3.5 And

This service performs a logical AND of (part of) the specified variable and the data passed with the request. The result is stored in (part of) the variable. The service is used to clear individual bits in a variable without first reading the variable and afterwards writing the result back to the variable. No data is returned in the response.

5.2.4.4.3.6 Or

This service performs a logical OR of (part of) the specified variable and the data passed with the request. The result is stored in (part of) the variable. The service is used to set individual bits in a variable without first reading the variable and afterwards writing the result back to the variable. No data is returned in the response.

5.2.4.4.3.7 Test-And-Set

This service performs a logical AND of (part of) the specified variable and the data passed in the request. The result of the AND operation is returned in the response. Then a logical OR operation of (part of) the specified variable and the data passed in the request is performed. The result of the OR operation is stored in (part of) the variable. The service is used to set individual bits in a variable, and in the same transmission read their state prior to the operation.

5.2.4.4.3.8 Get variable attribute

This service is used to read an attribute of the specified Variable Object. The attribute is specified by the offset parameter.

5.2.4.4.3.9 Set variable attribute

This service is used to update an attribute of the specified Variable Object. The attribute is specified by the offset parameter.

5.2.5 Route endpoint ASE

5.2.5.1 Overview

In the fieldbus environment, application processes contain data that remote applications are able to read and write. The data is accessed by means of the REP ASE. This ASE offers services to user applications in clients. The services REQUEST and RESPONSE give the access to real Variable Objects (VAOs) located in a server. In the server the REP ASE conveys data to / from the real Variable Object and returns responses. The services Get REP Attribute, Set REP Attribute, Reserve REP and Free REP are all for local use.

5.2.5.1.1 Route endpoint Description

The Route Endpoint class is defined to support the on-demand exchange of confirmed and unconfirmed services between two application processes. It uses AR ASE services for conveying APDUs.

An REP is an object container, containing Variable Objects of a variable type. It performs the access to variable objects. The Variable Object ID is unique within an REP. The request service addresses a Variable Object within the REP. The Variable Object ID is one of the request service parameters.

An REP in the proxy container role represents a remote REP in a Server. The remote REP is in the real container role. The Destination Route attribute of the REP in the client holds the Route to the real container REP, which it represents.

The REP ASE handles the segmentation when the data length exceeds the MaxDataSize.

When data is segmented, the order of segments is indicated by the offset part of the APDU.

To initiate access of a proxy Variable Object, the user application uses Reserve REP to get a REP currently not in use.

The attributes of the REP are set, including the Destination Route to the remote REP. This is done by the Set REP Attribute service. The requesting user then issues a REQUEST primitive with the REP ID and a Variable Object ID as parameters. The REP ASE builds a request APDU, and passes that along with Route Info in an AR Send request.

Following a successful transmission, if the REQUEST was confirmed, the AREP receives a response APDU and conveys that to the requesting REP by an AR Send indication. The user application can now read the result by issuing a RESPONSE primitive, with the REP ID as a parameter.

5.2.5.2 Route endpoint model

Formal Model

FAL ASE: **Route Endpoint ASE**

CLASS: Route Endpoint

CLASS ID: 1

PARENT CLASS: TOP

ATTRIBUTES:

1. (m) Key Attribute: Endpoint Address
2. (m) Attribute: Role (Proxy object / Real object)
3. (m) Attribute: REP State
4. (m) Attribute: Priority
5. (m) Attribute: Confirmation
6. (m) Attribute: Destination Route
7. (m) Attribute: Source route
8. (m) Attribute: Progress
9. (m) Attribute: Capabilities
10. (m) Attribute: Flat addressing

SERVICES:

1. (m) OpsService: REQUEST
2. (m) OpsService: RESPONSE
3. (m) OpsService: Reserve REP
4. (m) OpsService: Free REP
5. (m) OpsService: Get REP Attribute
6. (m) OpsService: Set REP Attribute

5.2.5.2.1 Attributes

5.2.5.2.1.1 Endpoint address

This key attribute holds the Endpoint address identifying the REP.

5.2.5.2.1.2 ROLE

This attribute specifies the role of the REP. The valid values are as follows.

Proxy container	Endpoints of this type are used for sending requests to servers and receive responses from them. The objects contained in REPs of this role are proxy objects for the real objects in the server.
Real container	Endpoints of this type are used for receiving confirmed and unconfirmed requests from clients and sending responses to them. The objects contained in REPs of this role are the real Variable Objects.

5.2.5.2.1.3 REP State

This attribute indicates the state of the REP. The values for this attribute are: IDLE, RESERVED, WAITING FOR RESPONSE, RESPONSE RECEIVED or NOT IN USE.

5.2.5.2.1.4 Priority

The DLL may provide the possibility to send high priority APDUs before APDUs of lower priority. The priority only refers to the request on the local link, not requests passing gateways and not the response.

5.2.5.2.1.5 Confirmation

This attribute indicates whether the request has to be confirmed or unconfirmed. The response is always returned unconfirmed. If the Destination Route contains one or more broadcast addresses (126) this attribute shall be set to unconfirmed.

5.2.5.2.1.6 Destination route

The Destination Route describes the Route to the destination REP. It is a sequence of Endpoint addresses and DL-addresses. On its way to the destination, the first part always indicates the address of the next DLE, AREP or REP to receive the APDU. In a request, the Destination Route holds the Route to the REP to respond. In a response, the Destination Route holds the Route to the requesting REP.

5.2.5.2.1.7 Source route

The Source Route describes the Route to the source REP. It is a sequence of endpoint addresses and DL-addresses. On its way to the destination, the first element always indicates the address of the DLE, AREP or REP endpoint from where the APDU was conveyed. In a request, the Source Route holds the Route to the requesting REP. In a response, the Source Route holds the Route to the responding REP.

5.2.5.2.1.8 Progress

This attribute is only relevant in proxy container REPs. It indicates the progress of a request. It indicates number of segments that has been delivered divided with the total number of segments. This means for non-segmented requests the value is zero while waiting for the response, and one when the response is received. For segmented requests, the value will start from zero and gradually increase till it reaches the value of one.

5.2.5.2.1.9 Capabilities

This attribute defines the capabilities of the REP addressed by the Destination Route. It is a local attribute, which shall be set up by the user application, to reflect the capabilities of the REP containing the real Variable Objects. The value of Capabilities is used by the requesting REP to build the APDU. The attribute indicates, whether the responding REP is capable of handling bit addressing or not.

5.2.5.2.1.10 Flat addressing

This attribute indicates, whether the REP should be seen as a container of individual Variable Objects, or as a container of one, flat memory area. If Flat addressing is selected, the Variable Object ID parameter of the REQUEST service indicates the offset in octets from the beginning of the memory area.

5.2.6 Route endpoint ASE service specification

5.2.6.1 REQUEST service

5.2.6.1.1 Overview

This service is used to initiate access of the value of a Variable Object. It may be used for as well reading as updating the value. The result of the operation (if any) is retrieved by the RESPONSE service.

5.2.6.1.2 Service primitives

The service parameters for this service are shown in Table 1. The Indication parameters are indicating the parameters in the APDU received by the remote REP. These parameters are for local use within the remote REP and its variable objects.

Table 1 – REQUEST service parameters

Parameter name	Req	Ind	Cnf
Argument	M	M	
REP	M	M	
Variable object ID	M	M(=)	
Variable Service	M	M(=)	
Data length	M	M(=)	
Offset/Attribute	C	C(=)	
Bit-no	C	C(=)	
Data	C	C(=)	
Result			
Status			M

- Argument
The argument carries the parameters of the REQUEST service invocation.
- REP
This parameter is the EP address of the REP holding the route information.
- Variable ID
This parameter identifies the Variable Object. The Variable ID indicates the Variable Object on which the service is to be performed.
- Variable service
This parameter holds the Variable service to be performed. (Method, Read, Write, And, Or, Test-And-Set, Get attribute and Set Attribute).
- Data length
This parameter indicates the number of octets of data to be transferred.
- Offset/attribute
This parameter is used when accessing only part of a structured variable or an Attribute of the variable. When accessing part of a structured variable, it indicates the offset in octets

to the starting octet of the data block to be transferred, relative to the first octet of the variable. When accessing attributes, it identifies the attribute to be accessed.

- Bit-no

This parameter is used to select a bit within a BitString. It indicates the bit number (1-8) within an octet. The Offset/Attribute parameter is used to select the octet.

- Data

This parameter holds the data to be transferred.

- Status

As a result of the request, Status is returned indicating OK or FAILURE.

5.2.6.2 RESPONSE service

5.2.6.2.1 Overview

This service is used to return the result of a confirmed REQUEST to the requesting user application in a requester.

5.2.6.2.2 Service primitives

The service parameters for this service are shown in Table 2. The response parameters are for local use within the responding REP and its variable object.

Table 2 – RESPONSE service parameters

Parameter name	Rsp	Cnf
Argument	M	M
REP	M	M
Result		
Variable Service	M	M
Data length	M	M(=)
Error status	M	M(=)
Data	C	C(=)

- Argument

The argument carries the parameters of the service request.

- REP

This parameter holds the ID of the REP holding the route information.

- Variable service

This parameter holds the Variable service that has been performed. (Method, Read, Write, And, Or, Test and Set, Get attribute and Set Attribute).

- Data length

This parameter indicates the number of octets of data that have been transferred.

- Error status

This parameter holds error information for errors occurred in any layer local or remote. For details, see Table 3.

The error code can be generated anywhere on the route between client and server, or by the responding Variable Object.

Table 3 – Error codes by source

Error description	Client	Gateway	Server
User Application:			
Instruction Error	X		X
Info length error	X		X
FIFO full or empty			X
Write protection			X
Data format error			X
Variable Object ID error			X
Time Out	X		
Actual data error			X
System result			X
Historical data error			X
FAL:			
Route error	X	X	X
Signature error	X		X
DL-layer:			
No Response	X	X	
WAIT TOO LONG	X	X	
Out of sync	X	X	
CRC ERROR	X	X	
DLE not Client	X	X	
Physical Layer:			
NET SHORTCIRCUIT	X	X	
OVERRUN/FRAMING ERROR	X	X	
RS-232 HANDSHAKE ERROR	X	X	X

– Data

This parameter holds the data that has been transferred.

5.2.6.3 Reserve REP service

5.2.6.3.1 Overview

This service is used by the user application to reserve an REP currently not in use, and to get the ID of the reserved REP.

5.2.6.3.2 Service primitives

The service parameters for this service are shown in Table 4.

Table 4 – Reserve REP service parameters

Parameter name	Req	Cnf
Result		
REP		M

– REP

This parameter holds the ID of the reserved REP. If no REP is available, zero is returned.

5.2.6.4 Free REP Service

5.2.6.4.1 Overview

This service is used by the user application to free an REP by changing the state of the REP to “not in use”.

5.2.6.4.2 Service primitives

The service parameters for this service are shown in Table 5.

Table 5 – Free AREP service parameters

Parameter name	Req
Argument	M
REP	M

– Argument

The argument carries the parameters of the service request.

– REP

This parameter holds the EP address of the reserved REP to free.

5.2.6.5 Get REP attribute service

5.2.6.5.1 Overview

This service is used by the user application to read an attribute of a REP locally.

5.2.6.5.2 Service Primitives

The service parameters for this service are shown in Table 6.

Table 6 – Get REP attribute service parameters

Parameter name	Req	Cnf
Argument	M	
REP	M	
Attribute index	M	
Result (+)		
Value		C
Result (-)		
Status		C

– Argument

The argument carries the parameters of the service request.

– REP

This parameter specifies the REP.

– Attribute index

This parameter identifies the attribute to read.

Value

This parameter returns the value of the specified attribute.

– Status

This parameter returns error information if the service fails. The possible values are: Illegal attribute index, Illegal REP address.

5.2.6.6 Set REP attribute service

5.2.6.6.1 Overview

This service is used by the user application to write a value into an attribute of a REP locally.

5.2.6.6.2 Service primitives

The service parameters for this service are shown in Table 7.

Table 7 – Set REP attribute service parameters

Parameter name	Req	Cnf
Argument	M	
REP	M	
Attribute index	M	
Result		
Status		M

– Argument

The argument carries the parameters of the service request.

– REP

This parameter specifies the REP.

– Attribute index

This parameter identifies the attribute to update within the specified REP.

– Value

This parameter holds the value to be written to the specified attribute.

– Status

As a result of the request, Status is returned indicating OK or the reason for failure. The possible values are: OK, Illegal attribute index, Illegal value, Illegal REP address.

5.3 Application relationship ASE

5.3.1 Overview

To support access to the remote AP, the Application Relationship ASE is defined. It provides services to the AP for accessing communication-related parameters, and it provides services to the REP ASE for conveying service requests and responses.

The AR ASE provides services at the endpoints of ARs (AREPs).

5.3.2 Application relationship class specification

5.3.2.1 Application relationship formal model

The functionality of the AR ASE is described in 5.1.

The application ASE defines one class, the AREP class.

FAL ASE: Application Relationship ASE

CLASS: AREP

CLASS ID: 1
PARENT CLASS: TOP

ATTRIBUTES:

1. (m) Key Attribute: Endpoint Address
2. (m) Attribute: Role (Client, Server, Peer)
3. (m) Attribute: DLL Reference
4. (m) Attribute: MaxPDUSize
5. (m) Attribute: MaxDataSize
6. (m) Attribute: Acknowledgement
7. (m) Attribute: MaxIndicationDelay
8. (m) Attribute: Local DLE address
9. (o) Attribute: MaxRetryTime
10. (o) Attribute: MaxRetries
11. (o) Attribute: MaxOutstandingRequests
12. (o) Attribute: BaudRate
13. (o) Attribute: NumberOfClientDLEs

5.3.2.1.1.1 SERVICES:

- 1 (m) OpService: AR-Get Attribute
- 2 (m) OpService: AR-Set Attribute
- 3 (m) OpService: AR-Send
- 4 (m) OpService: AR-Acknowledge

5.3.2.1.1.2 Endpoint address

This attribute specifies the numeric identifier of the AREP. It is used by the FAL to select the AREP, and implicitly the DLE for a request.

5.3.2.1.1.3 Role

This attribute specifies the role of the AREP. The valid values are as follows.

Client Endpoints of this type send confirmed and unconfirmed Request APDUs to servers and receive Response APDUs.

Server Endpoints of this type receive confirmed and unconfirmed Request APDUs from clients and send unconfirmed Response APDUs.

Peer Endpoints of this type act as both Clients and Servers.

5.3.2.1.1.4 MaxPDUSize

This attribute specifies the maximum PDU size that can be sent by the DLL.

5.3.2.1.1.5 MaxDataSize

This attribute specifies the maximum data size that can be sent by the DLL. If the data length exceeds MaxDataSize, the VARIABLE ASE shall segment the request.

5.3.2.1.1.6 DLL reference

This attribute contains the necessary context to convey the DLL relations.

5.3.2.1.1.7 Acknowledgement

This attribute describes the type of Acknowledgement to be used by DLL: Acknowledged or Unacknowledged transfer of Confirmed APDUs, and Acknowledged or Unacknowledged transfer of Unconfirmed APDUs.

5.3.2.1.1.8 MaxIndicationDelay

This attribute indicates to the user application, how long time a Variable Object can use to prepare a response after receiving an indication requiring that. If the Variable Object is unable to prepare a response within MaxIndicationDelay, it shall issue an AR-Acknowledge. The value of MaxIndicationDelay is calculated by the DLE.

5.3.2.1.1.9 Local DLE address

This attribute reflects the DL address of the related DLE. In some situations it may be a read-only attribute.

5.3.2.1.1.10 MaxRetryTime

This attribute indicates the maximum time the DLE should try to re-transmit a request as a result of Acknowledge responses from the remote Variable Object.

5.3.2.1.1.11 MaxRetries

This attribute indicates the maximum number of re-transmissions carried out by the DLE as a result of transmission errors.

5.3.2.1.1.12 MaxOutstandingRequests

This attribute indicates the maximum number of requests that the AREP may initiate without receiving the related responses.

5.3.2.1.1.13 BaudRate

This attribute specifies the baud rate used by the physical layer. It is conveyed to/from the physical layers by the DLEs.

5.3.2.1.1.14 NumberOfClientDLEs

This attribute only relates to a DLE using the P-NET protocol in the client role. It specifies the number of participants in a token round.

5.3.3 Application relationship ASE service specifications

5.3.3.1 Overview

Subclause 5.3.3 contains the definition of the services that are unique to this ASE. The services are the following:

AR Send
AR Acknowledge
AR Get Attribute
AR Set Attribute

5.3.3.2 Common parameter definition

Parameters used in more AR ASE services are defined below:

5.3.3.2.1.1 Route info

The complete DL Route contains the following elements:

5.3.3.2.1.2 Destination route

The Destination-Route describes how to reach the destination REP. It is a sequence of Endpoint addresses and DL-addresses. On its way to the destination, the first part always indicates the address of the next DLE, AREP or REP to receive the APDU.

5.3.3.2.1.3 Source route

The Source Route in the same way describes how to find the way back to the endpoint that initiated the request. It is a sequence of endpoint addresses and DL-addresses. On its way to the destination, the first element always indicates the address of the DLE, AREP or REP endpoint from where the APDU was sent.

5.3.3.2.1.4 Priority

The underlying layer may provide the possibility to send high-priority APDUs before APDUs of lower priority. This priority only refers to the request on the local link, not requests passing gateways and not the response.

5.3.3.2.1.5 Confirmation

This parameter indicates whether the request has to be confirmed or unconfirmed. A response is always returned unconfirmed. If the destination route contains one or more broadcast addresses (126) this attribute shall be set to unconfirmed.

5.3.3.2.1.6 APDU header

The APDU Header parameter holds a Control/Status subfield indicating the Variable Service, an APDU format subfield, indicating whether the APDU holds an offset, and finally an APDU length subfield, indicating the octet length of the APDU.

5.3.3.2.1.7 APDU body

This parameter holds the APDU Body to send or receive.

5.3.3.3 AR send service

5.3.3.3.1 Overview

The AR Send service is used to send confirmed or unconfirmed APDUs from one AREP to another.

It is the task of the receiving AREP to convey the APDU to the Endpoint specified by the first element in the destination route. In the gateway situation the AR is using this AR Send service to convey the APDU to an AREP.

5.3.3.3.2 Service primitives

The service parameters for this service are shown in Table 8.

Table 8 – AR send service parameters

Parameter name	Req	Ind	Cnf
Argument	M	M	
Route info	M	M	
APDU Header	M	M(=)	
APDU Body	C	C(=)	
Result			
Status			M

– Argument

The argument carries the parameters of the service request.

– Status

As a result of the request, Status is returned indicating OK or the locally detected reason for failure. Status only refers to local conditions. The possible values are: OK, Route Error.

5.3.3.4 AR acknowledge service

5.3.3.4.1 Overview

When the Variable ASE in a confirmed request is not able to process the indication and respond within the time limit, "MaxIndicationDelay", it shall submit an AR Send Acknowledge request primitive to the local AREP, and in this way free the Token. "MaxIndicationDelay" is an attribute of the AREP.

5.3.3.4.2 Service Primitives

The service parameters for this service are shown in Table 9.

Table 9 – AR acknowledge service parameters

Parameter name	Req
Argument	M
Route info	M

– Argument

The argument carries the parameters of the service request.

5.3.3.5 AR get attribute service

5.3.3.5.1 Overview

This confirmed service is used to read the value of attributes of an AREP locally.

5.3.3.5.2 Service parameters

The service parameters for the AR Get Attribute Service are shown in Table 10.

Table 10 – AR get attributes service parameters

Parameter name	Req	Cnf
Argument	M	
AREP	M	
Attribute index	M	
Result (+)		S
Value		C
Result (-)		S
Status		C

- Argument
The argument carries the parameters of the service request.
- AREP
This parameter identifies the AREP by its endpoint address.
- Attribute index
This parameter identifies the attribute.
- Result (+)
This selection type parameter indicates that the request succeeded.
- Value
This parameter is returned with the requested attribute value if the request succeeded.
- Result (-)
This selection type parameter indicates that the request failed.
- Status
If the request failed, Status is returned indicating the reason for failure. The possible values are: Illegal attribute index, Illegal AREP address.

5.3.3.6 AR set attributes service

This confirmed service is used to set the current value of attributes of an AREP locally.

5.3.3.6.1 Service parameters

The service parameters for the AR Set Attribute Service are shown in Table 11.

Table 11 – AR set attributes service parameters

Parameter name	Req	Cnf
Argument	M	
AREP	M	
Attribute index	M	
Value	M	
Result		
Status		M

- Argument
The argument carries the parameters of the service request.
- AREP
This parameter identifies the AREP by its endpoint address. The legal values are 1 to 16 inclusive.
- Attribute index
This parameter identifies the attribute to be updated.
- Value
This parameter holds the new attribute value.
- Status
As a result of the request, Status is returned indicating OK or the reason for failure. The possible values are: OK, Illegal attribute index, Illegal value, Illegal AREP address.

IECNORM.COM : Click to view the full PDF of IEC 61158-5-4:2019

Bibliography

IEC 61158-1:2019, *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

IEC 61158-2, *Industrial communication networks – Fieldbus specifications – Part 2: Physical layer specification and service definition*

IEC 61784-1:2019, *Industrial communication networks – Profiles – Part 1: Fieldbus profiles*

IEC 61784-2:2019, *Industrial communication networks – Profiles – Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC/IEEE 8802-3*

IECNORM.COM : Click to view the full PDF of IEC 61158-5-4:2019

SOMMAIRE

AVANT-PROPOS	75
INTRODUCTION	77
1 Domaine d'application	78
1.1 Généralités	78
1.2 Spécifications	79
1.3 Conformité	79
2 Références normatives	79
3 Termes, définitions, symboles, abréviations et conventions	80
3.1 Termes de l'ISO/IEC 7498-1	80
3.2 Termes de l'ISO/IEC 8822	81
3.3 Termes de l'ISO/IEC 9545	81
3.4 Termes de l'ISO/IEC 8824-1	81
3.5 Termes relatifs à la couche Liaison de données de bus de terrain	81
3.6 Définitions relatives à la couche application de bus de terrain	82
3.7 Abréviations et symboles	88
3.8 Conventions	89
3.8.1 Vue d'ensemble	89
3.8.2 Conventions générales	89
3.8.3 Conventions pour les définitions de classe	90
3.8.4 Conventions pour les définitions de service	91
4 Concepts	93
4.1 Vue d'ensemble	93
4.2 Relations de l'architecture	93
4.2.1 Relation à la couche Application du modèle de référence de base OSI	93
4.2.2 Relations avec les autres entités du bus de terrain	94
4.3 Structure de la couche Application de bus de terrain	96
4.3.1 Vue d'ensemble	96
4.3.2 Concepts fondamentaux	96
4.3.3 Procédés d'application de bus de terrain	97
4.3.4 Objets de processus d'application (APO)	101
4.3.5 Entités d'application	104
4.3.6 Éléments de service d'application de bus de terrain	104
4.3.7 Relations entre applications	108
4.4 Désignation et adressage de la couche Application de bus de terrain	111
4.4.1 Généralités	111
4.4.2 Identification des objets accessibles par l'intermédiaire de la couche FAL	111
4.4.3 Adressage des AP accessibles par l'intermédiaire de la couche FAL	112
4.5 Résumé de l'architecture	112
4.6 Procédure de service FAL	113
4.6.1 Procédures de service confirmé FAL	113
4.6.2 Procédures de service non confirmé FAL	113
4.7 Attributs FAL courants	114
4.8 Paramètres communs aux services de la FAL	114
4.9 Taille APDU	115

5	Spécification du modèle de communication de type 4	115
5.1	Concepts	115
5.1.1	Vue d'ensemble	115
5.1.2	Entités d'application	115
5.1.3	Passerelle et routage.....	117
5.1.4	Résumé de l'architecture	119
5.1.5	Procédures de service FAL et diagrammes de séquence temporelle	119
5.2	Elément ASE de variable	123
5.2.1	Types de variable	123
5.2.2	Spécification de la classe de modèle de variable	124
5.2.3	Spécifications du type de variable de base	125
5.2.4	Spécifications du type de variable construite	130
5.2.5	Point d'extrémité de chemin ASE	134
5.2.6	Spécification du service Route endpoint ASE	137
5.3	ASE de relations entre applications.....	142
5.3.1	Vue d'ensemble	142
5.3.2	Spécification de la classe de relation d'applications.....	142
5.3.3	Spécifications de service de l'ASE de relations entre applications	144
	Bibliographie.....	148
	Figure 1 – Relation avec le modèle de référence de base OSI	94
	Figure 2 – Positionnement architectural de la couche Application de bus de terrain	95
	Figure 3 – Interactions client/serveur	98
	Figure 4 – Interactions du modèle tireur.....	99
	Figure 5 – Interactions du modèle pousseur.....	100
	Figure 6 – Services APO transmis par la couche FAL	102
	Figure 7 – Structure d'entité d'application	104
	Figure 8 – Exemple de FAL ASE.....	106
	Figure 9 – Gestion FAL des objets	107
	Figure 10 – Transmission des services d'ASE.....	108
	Figure 11 – AREP définis et établis.....	111
	Figure 12 – Composants d'architecture de la couche FAL	112
	Figure 13 – FAL AE	116
	Figure 14 – Résumé de l'architecture FAL	119
	Figure 15 – Présentation de la procédure de service FAL	120
	Figure 16 – Diagramme de séquence temporelle des services confirmés	121
	Figure 17 – Diagramme de séquence temporelle des services non confirmés	122
	Tableau 1 – Paramètres du service REQUEST	137
	Tableau 2 – Paramètres du service REPONSE	138
	Tableau 3 – Codes d'erreur par source	139
	Tableau 4 – Paramètre du service Reserve REP.....	140

Tableau 5 – Paramètres du service Free AREP	140
Tableau 6 – Paramètres du service de l'attribut Get REP	141
Tableau 7 – Paramètres du service de l'attribut Set REP	141
Tableau 8 – Paramètres du service AR send	145
Tableau 9 – Paramètres du service AR acknowledge.....	146
Tableau 10 – Paramètres du service AR get attributes.....	146
Tableau 11 – Paramètres du service AR set attributes	147

IECNORM.COM : Click to view the full PDF of IEC 61158-5-4:2019

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

**RÉSEAUX DE COMMUNICATION INDUSTRIELS –
SPÉCIFICATIONS DES BUS DE TERRAIN –****Partie 5-4: Définition des services de la couche application –
Éléments de type 4**

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

L'attention est attirée sur le fait que l'utilisation du type de protocole associé est restreinte par les détenteurs des droits de propriété intellectuelle. En tout état de cause, l'engagement de renonciation partielle aux droits de propriété intellectuelle pris par les détenteurs de ces droits autorise l'utilisation d'un type de protocole de couche avec les autres protocoles de couche du même type, ou dans des combinaisons avec d'autres types autorisés explicitement par les détenteurs des droits de propriété intellectuelle pour ce type.

NOTE Les combinaisons de types de protocoles sont spécifiées dans les normes IEC 61784-1 et IEC 61784-2.

La Norme internationale IEC 61158-5-4 a été établie par le sous-comité 65C: Réseaux industriels, du comité d'études 65 de l'IEC: Mesure, commande et automation dans les processus industriels.

Cette troisième édition annule et remplace la deuxième édition parue en 2014. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- a) paramètres d'utilisateur supplémentaires pour les services;
- b) services supplémentaires pour prendre en charge les objets distribués;
- c) services de sécurité supplémentaires;

La présente version bilingue (2021-02) correspond à la version anglaise monolingue publiée en 2019-04.

La version française de cette norme n'a pas été soumise au vote.

Cette publication a été rédigée selon les Directives ISO/IEC, Partie 2.

Une liste de toutes les parties de la série IEC 61158, publiées sous le titre général *Réseaux de communication industriels – Spécifications des bus de terrain* peut être consultée sur le site web de l'IEC.

Le comité a décidé que le contenu de cette publication ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

IMPORTANT – Le logo "colour inside" qui se trouve sur la page de couverture de cette publication indique qu'elle contient des couleurs qui sont considérées comme utiles à une bonne compréhension de son contenu. Les utilisateurs devraient, par conséquent, imprimer cette publication en utilisant une imprimante couleur.

INTRODUCTION

La présente partie de l'IEC 61158 est l'une d'une série produite pour faciliter l'interconnexion des composants d'un système d'automatisation. Elle est liée aux autres normes de la série telle que définie par le modèle de référence de bus de terrain "à trois couches" décrits dans l'IEC 61158-1.

Le service d'application est fourni par le protocole d'application, qui utilise les services disponibles dans la couche liaison de données ou toute autre couche immédiatement inférieure. Le présent document définit les caractéristiques des services d'application que les applications à bus de terrain et/ou la gestion de systèmes peuvent exploiter.

Dans cet ensemble de normes relatives aux bus de terrain, le terme "service" désigne la capacité abstraite fournie par une couche du modèle de référence de base OSI à la couche située juste au-dessus. Le service de couche application défini dans le présent document est donc un service architectural conceptuel, indépendant des divisions administratives et de mise en œuvre.

IECNORM.COM : Click to view the full PDF of IEC 61158-5-4:2019

RÉSEAUX DE COMMUNICATION INDUSTRIELS – SPÉCIFICATIONS DES BUS DE TERRAIN –

Partie 5-4: Définition des services de la couche application – Éléments de type 4

1 Domaine d'application

1.1 Généralités

La couche application de bus de terrain (FAL – fieldbus application layer) donne aux programmes d'utilisateur le moyen d'accéder à l'environnement de communication des bus de terrain. A cet égard, la FAL peut être vue comme une "fenêtre entre des programmes d'application correspondants".

La présente partie de l'IEC 61158 fournit des éléments communs pour les communications de messagerie prioritaires et non prioritaires élémentaires entre les programmes d'application des environnements d'automatisation et le matériel spécifique au bus de terrain de type 4. On utilise le terme "prioritaire" pour traduire la présence d'une fenêtre temporelle, à l'intérieur de laquelle il est exigé qu'une ou plusieurs actions spécifiées soient terminées avec un niveau de certitude défini. Si les actions spécifiées ne sont pas réalisées dans la fenêtre temporelle, les applications demandant les actions risquent de connaître une défaillance, avec les risques que cela comporte pour les équipements, les installations et éventuellement la vie humaine.

La présente norme définit de manière abstraite le service visible de l'extérieur fourni par la couche application de bus de terrain de type 4 en termes

- a) d'un modèle abstrait pour la définition des ressources d'application (objets) qui peuvent être manipulées par les utilisateurs par l'intermédiaire de l'utilisation du service FAL,
- b) des actions primitives et des événements du service;
- c) des paramètres associés à chaque action et événement primitif, et de la forme qu'ils peuvent prendre; et
- d) des interrelations entre ces actions et événements, et de leurs séquences valides.

Le but du présent document est de définir les services fournis à

- 1) l'utilisateur de FAL à la frontière entre l'utilisateur et la couche application du modèle de référence de bus de terrain, et
- 2) la gestion des systèmes au niveau de la frontière entre la couche application et la gestion des systèmes selon le modèle de référence de bus de terrain.

Le présent document spécifie la structure et les services de la couche application de bus de terrain de type 4, en conformité avec le modèle de référence de base de l'OSI (ISO/IEC 7498-1) et la structure de la couche application de l'OSI (ISO/IEC 9545).

Les services et protocoles de la FAL sont fournis par des entités d'application (AE, "Application Entity") de la FAL contenues dans les processus application. L'AE de la FAL se compose d'un jeu d'éléments de service application (ASE) orientés objet et d'une entité de gestion de couche (LME) qui gère l'AE. Les ASE fournissent des services de communication qui fonctionnent sur un jeu de classes d'objets de processus application (APO, "Application process object") connexes. L'un des ASE de la FAL est un ASE de gestion qui fournit un ensemble commun de services pour la gestion des instances des classes FAL.

Bien que ces services spécifient, du point de vue des applications, la manière dont la demande et les réponses sont émises et délivrées, ils n'incluent pas une spécification de ce que les applications qui demandent et qui répondent sont supposées en faire. Autrement dit, les aspects comportementaux des applications ne sont pas spécifiés; seules sont définies les demandes et les réponses que ces applications peuvent envoyer/recevoir. Cela offre aux utilisateurs de la FAL une plus grande flexibilité pour normaliser le comportement de ces objets. En plus de ces services, certains services d'appui sont également définis dans le présent document pour fournir l'accès à la FAL afin de maîtriser certains aspects de son fonctionnement.

1.2 Spécifications

L'objectif principal du présent document est de spécifier les caractéristiques des services conceptuels d'une couche application qui sont adaptées à des communications prioritaires et donc complètent le Modèle de référence de base de l'OSI en guidant le développement des protocoles de couche application pour les communications prioritaires.

Un objectif secondaire est de fournir des trajets de migration à partir de protocoles de communication industriels préexistants. Ce dernier objectif explique la diversité des services normalisés sous la forme des différents Types donnés par l'IEC 61158, ainsi que les protocoles correspondants, normalisés dans l'IEC 61158-6 (toutes les sous-parties).

La présente spécification peut être utilisée comme la base pour les interfaces formelles de programmation d'applications ("Application Programming Interfaces"). Néanmoins, il ne s'agit pas d'une interface de programmation formelle, et toute interface de ce type devra résoudre les problèmes de mise en œuvre non traités par la présente spécification, notamment:

- a) les tailles et l'ordre des octets de divers paramètres de service multioctets, et
- b) la corrélation des primitives appariées demande et confirmation, ou indication et réponse.

1.3 Conformité

Le présent document ne spécifie ni ne définit des mises en œuvre individuelles ou de produits individuels ni ne contraint les mises en œuvre d'entités de la couche application au sein des systèmes d'automatisation industriels.

Il n'y a pas de conformité des équipements à la présente norme de définition des services de couche application. Au contraire, la conformité est obtenue par une mise en œuvre de protocoles conformes de couche application qui satisfont aux services de couche application de type 2 définis dans le présent document.

2 Références normatives

Les documents suivants sont cités dans le texte de sorte qu'ils constituent, pour tout ou partie de leur contenu, des exigences du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

NOTE Toutes les parties de la série IEC 61158, ainsi que l'IEC 61784-1 et l'IEC 61784-2 font l'objet d'une maintenance simultanée. Les références croisées à ces documents dans le texte se rapportent par conséquent aux éditions datées dans la présente liste de références normatives.

IEC 61158-3-4:2019, *Réseaux de communication industriels – Spécifications des bus de terrain – Partie 3-4: Définition du service de la couche liaison de données – Éléments de type 4*

IEC 61158-4-4:2019, *Réseaux de communication industriels – Spécifications des bus de terrain – Partie 4-4: Spécification du protocole de la couche liaison de données – Éléments de type 4*

IEC 61158-6-4:2019, *Réseaux de communication industriels – Spécifications des bus de terrain – Partie 6-4: Spécification de protocole de la couche application – Eléments de type 4*

IEC 61158-6 (toutes les sous-parties), *Réseaux de communication industriels – Spécifications des bus de terrain – Partie 6: Spécification de protocoles de la couche application*

ISO/IEC 7498-1, *Technologies de l'information — Interconnexion de systèmes ouverts (OSI) — Modèle de référence de base – Partie 1: Le modèle de base*

ISO/IEC 7498-3, *Technologies de l'information — Interconnexion de systèmes ouverts (OSI) — Modèle de référence de base – Partie 3: Dénomination et adressage*

ISO/IEC 8822, *Technologies de l'information – Interconnexion de systèmes ouverts – Définition du service de présentation*

ISO/IEC 88241, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation (disponible en anglais seulement)*

ISO/IEC 9545, *Technologies de l'information – Interconnexion de systèmes ouverts (OSI) – Structure de la couche Application*

ISO/IEC 10731, *Technologies de l'information – Interconnexion de systèmes ouverts – Modèle de référence de base – Conventions pour la définition des services OSI*

ISO/IEC/IEEE 60559, *Information technology – Microprocessor Systems – Floating-Point arithmetic (disponible en anglais seulement)*

3 Termes, définitions, symboles, abréviations et conventions

Pour les besoins du présent document, les termes, définitions, symboles, abréviations et conventions suivants s'appliquent.

L'ISO et l'IEC tiennent à jour des bases de données terminologiques destinées à être utilisées en normalisation, consultables aux adresses suivantes:

- IEC Electropedia: disponible à l'adresse <http://www.electropedia.org/>
- ISO Online browsing platform: disponible à l'adresse <http://www.iso.org/obp>

3.1 Termes de l'ISO/IEC 7498-1

Pour les besoins du présent document, les termes suivants définis dans l'ISO/IEC 7498-1 s'appliquent:

- a) entité d'application
- b) processus d'application
- c) unité de données de protocole d'application
- d) élément de service d'application
- e) appel d'entité d'application
- f) appel de processus d'application
- g) transaction d'application
- h) système ouvert réel
- i) syntaxe de transfert

3.2 Termes de l'ISO/IEC 8822

Pour les besoins du présent document, les termes suivants tels que définis dans l'ISO/IEC 8822 s'appliquent:

- a) syntaxe abstraite
- b) contexte de présentation

3.3 Termes de l'ISO/IEC 9545

Pour les besoins du présent document, les termes suivants, définis dans l'ISO/IEC 9545, s'appliquent:

- a) association d'application
- b) contexte d'application
- c) nom de contexte d'application
- d) appel d'entité d'application
- e) type d'entité d'application
- f) appel de processus d'application
- g) type de processus d'application
- h) élément de service application
- i) élément de service de commande d'application

3.4 Termes de l'ISO/IEC 8824-1

Pour les besoins du présent document, les termes suivants, définis dans l'ISO/IEC 8824-1, s'appliquent:

- a) identificateur d'objet
- b) type

3.5 Termes relatifs à la couche Liaison de données de bus de terrain

Pour les besoins du présent document, les termes suivants s'appliquent.

- a) délai DL
- b) politique de planification DL
- c) DLCEP
- d) DLC
- e) DLPDU
- f) DLSDU
- g) DLSAP
- h) indicateur fixe
- i) indicateur générique
- j) liaison
- k) adresse réseau
- l) adresse de nœud
- m) nœud
- n) étiquette
- o) planifié
- p) non planifié

3.6 Définitions relatives à la couche application de bus de terrain

Pour les besoins du présent document, les termes et définitions suivants s'appliquent:

3.6.1

application

fonction ou structure de données pour laquelle des données sont consommées ou produites

3.6.2

objets d'application

classes contenant plusieurs objets permettant de gérer et d'assurer l'échange dynamique des messages sur le réseau et au sein de l'appareil de réseau

3.6.3

processus application

partie d'une application distribuée sur un réseau, qui est située sur un dispositif et qui est adressée sans ambiguïté

3.6.4

identificateur de processus d'application

valeur qui différencie un processus d'application parmi plusieurs processus d'application utilisés dans un appareil

3.6.5

objet de processus d'application

composant d'un processus d'application qui est identifiable et accessible par la relation d'application de la FAL

Note 1 à l'article: Les définitions d'objets de processus d'application se composent d'un ensemble de valeurs destinées aux attributs de leur classe (voir la définition "classe d'objets de processus d'application"). L'accès aux définitions d'objet de processus d'application peut se faire à distance à l'aide des services de l'ASE de gestion d'objet FAL. Les services de gestion des objets FAL peuvent être utilisés pour charger ou mettre à jour des définitions d'objets, pour lire des définitions d'objets, ainsi que pour créer et supprimer de manière dynamique des objets d'application et les définitions correspondantes.

3.6.6

classe d'objet de processus d'application

classe d'objets de processus d'application définis par rapport à l'ensemble des attributs et services accessibles en réseau qu'ils possèdent

3.6.7

relation d'application

association coopérative entre deux appels d'entité d'application ou plus, destinée à l'échange d'informations et à la coordination de leur association fonctionnelle

Note 1 à l'article: Cette relation est activée soit par l'échange d'unités de données de protocole d'application (application-protocol-data-unit), soit à la suite d'activités de préconfiguration.

3.6.8

élément de service d'application de relation d'applications

élément de service d'application qui fournit le moyen exclusif d'établir et de terminer toutes les relations d'application

3.6.9

point final de relation d'application

contexte et comportement d'une relation d'application, vus et maintenus par l'un des processus d'application impliqués dans la relation d'application

Note 1 à l'article: Chaque processus d'application impliqué dans la relation d'applications maintient son propre point d'extrémité de relation d'applications.

3.6.10**attribut**

description d'une caractéristique ou d'une particularité, visible de l'extérieur, d'un objet

Note 1 à l'article: Les attributs d'un objet contiennent des informations relatives aux portions variables d'un objet. Ils servent habituellement à fournir des informations de statut ou à régir le fonctionnement d'un objet. Les attributs peuvent également avoir un effet sur le fonctionnement d'un objet. Les attributs se répartissent en attributs de classe et en attributs d'instance.

3.6.11**comportement**

indication de la manière dont un objet réagit à des événements particuliers

3.6.12**n° de bit**

désigne le numéro d'un bit dans une chaîne de bits ou un octet

3.6.13**canal**

liaison physique ou logique unique d'un objet d'application d'entrée ou de sortie d'un serveur avec le processus

3.6.14**classe**

ensemble d'objets, chacun d'eux représentant la même sorte de composant de système

Note 1 à l'article: Une classe est une généralisation d'un objet, un modèle qui permet de définir des variables et des méthodes. Tous les objets d'une classe possèdent une forme et un comportement identiques, mais leurs attributs contiennent généralement des données différentes.

3.6.15**attribut de classe**

attribut qui est partagé par tous les objets de la même classe

3.6.16**code de classe**

identificateur unique affecté à chaque classe d'objet

3.6.17**service spécifique à une classe**

service défini par une classe d'objets particulière pour l'exécution d'une fonction exigée qui n'est pas exécutée par un service commun

Note 1 à l'article: Tout objet spécifique à une classe est réservé à l'usage exclusif de la classe d'objets qui le définit.

3.6.18**client**

<objet> objet qui utilise les services d'un autre objet (serveur) pour exécuter une tâche

3.6.19**client**

<message> émetteur d'un message auquel un serveur réagit

3.6.20**objets de communication**

composants qui gèrent et assurent un échange de messages pendant le mode exécution à travers le réseau

EXEMPLES: objet Connection Manager (gestionnaire de connexion), objet Unconnected Message Manager (UCMM, gestionnaire de messages non connectés) et objet Message Router (routeur de message).

3.6.21

connexion

liaison logique entre deux objets d'application qui peuvent se trouver au sein du même appareil ou dans des appareils différents

Note 1 à l'article: Les connexions peuvent être soit point à point, soit multipoints.

3.6.22

chemin de transmission

flux unidirectionnel d'APDU sur l'ensemble d'une relation d'application

3.6.23

AR dédiée

AR directement utilisée par l'utilisateur FAL

Note 1 à l'article: Dans les AR dédiées, seuls l'en-tête FAL et les données d'utilisateur sont transférés.

3.6.24

adresse DL par défaut

la valeur 126 en tant que valeur initiale de l'adresse DL, devant être changée (par exemple par l'affectation d'une adresse DL via le bus de terrain) avant utilisation avec un DP-maître (classe 1)

3.6.25

appareil

matériel physique connecté à la liaison

Note 1 à l'article: Un appareil peut contenir plus d'un nœud.

3.6.26

AR dynamique

AR qui exige l'utilisation de procédures d'établissement d'AR pour pouvoir être placée dans un état établi

3.6.27

point final

l'une des entités communicantes impliquées dans une connexion

3.6.28

erreur

écart ou discordance entre une valeur ou une condition calculée, observée ou mesurée et la valeur ou la condition spécifiée ou théoriquement correcte

3.6.29

classe d'erreur

groupement général des définitions d'erreur connexes et des codes d'erreur correspondants

3.6.30

code d'erreur

identification d'un type d'erreur spécifique dans une classe d'erreur

3.6.31

événement

instance d'un changement des conditions

3.6.32**sous-réseau FAL**

sous-réseaux composés d'un ou plusieurs segments de liaison de données, identifiés par un sous-ensemble de l'adresse de réseau

Note 1 à l'article: les sous-réseaux FAL peuvent contenir des ponts, mais pas de routeurs.

3.6.33**variable FIFO**

classe d'objets de variable composée d'un ensemble d'éléments saisis de manière homogène dans laquelle le premier élément écrit constitue le premier élément qui peut être lu

Note 1 à l'article: Dans un bus de terrain, seul un élément complet peut être transféré à la suite d'une invocation de services.

3.6.34**trame**

synonyme déconseillé de DLPDU

3.6.35**interface**

<unité fonctionnelle> frontière commune entre deux unités fonctionnelles, définie par des caractéristiques fonctionnelles, des caractéristiques de signal ou d'autres caractéristiques, suivant le cas

3.6.36**interface**

<protocole de communication> ensemble d'attributs et de services de classe FAL représentant une vue spécifique de la classe FAL

3.6.37**invocation**

acte d'utiliser un service ou une autre ressource d'un processus d'application

Note 1 à l'article: Chaque invocation représente un fil de commande distinct qui peut être décrit par son contexte. Une fois le service terminé ou la ressource libérée, l'invocation cesse d'exister. Dans le cas des invocations de services, un service lancé, mais pas encore terminé est considéré comme une invocation de services en cours. Dans le cas des invocations de services, un ID d'invocation (Invoke ID) peut être utilisé pour identifier une invocation de services de manière non ambiguë et la différencier des autres invocations de services en cours.

3.6.38**index**

adresse d'un objet au sein d'un processus application

3.6.39**instance**

occurrence physique permettant d'identifier un objet parmi d'autres au sein d'une même classe d'objets

EXEMPLE Californie est une instance de l'état de la classe d'objets.

Note 1 à l'article: Les termes objet, instance et instance d'objet font référence à une instance particulière.

3.6.40**attributs d'instance**

attribut unique d'une instance d'objet, qui n'est pas partagé par la classe d'objets

3.6.41**instancié**

objet créé dans un appareil

3.6.42

dispositif logique

classe FAL particulière qui extrait un composant logiciel ou de microprogramme sous la forme d'un dispositif intégré et autonome au sein d'un appareil d'automatisation

3.6.43

ID fabricant

identification de chaque fabricant de produits par un numéro unique

3.6.44

information de gestion

information accessible en réseau utilisée pour gérer le fonctionnement du système de bus de terrain, y compris la couche application

Note 1 à l'article: La gestion inclut des fonctions telles que la commande, la surveillance et le diagnostic.

3.6.45

membre

élément d'un attribut qui est structuré comme une partie d'une matrice

3.6.46

méthode

<objet> synonyme d'un service de fonctionnement délivré par l'élément ASE serveur et appelé par un client

3.6.47

module

composant matériel ou logique d'un appareil physique

3.6.48

réseau

ensemble de nœuds connectés par un certain type de support de communication, y compris les répéteurs intercalés, les ponts, les routeurs et les passerelles de couche inférieure

3.6.49

objet

représentation abstraite d'un composant particulier dans un appareil; il s'agit généralement d'un ensemble de données (sous la forme de variables) et de méthodes (procédures) associées, destiné à l'exploitation des données dont l'interface et le comportement sont clairement définis

3.6.50

service spécifique à un objet

service réservé à l'usage exclusif de la classe d'objets qui le définit

3.6.51

pair

rôle d'un point final d'AR consistant à être capable d'agir à la fois comme client et comme serveur

3.6.52

appareil physique

appareil d'automation ou autre appareil de réseau

3.6.53

propriété

terme général désignant toute information descriptive concernant un objet

3.6.54**fournisseur**

source d'une connexion de données

3.6.55**publicateur**

rôle d'un point d'extrémité d'AR qui transmet les unités APDU sur le bus de terrain afin qu'elles soient consommées par un ou plusieurs abonnés

Note 1 à l'article: Un publicateur peut ne pas connaître l'identité des abonnés ou leur nombre; il peut publier ses unités APDU au moyen d'une AR dédiée.

3.6.56**gestionnaire de publication**

rôle d'un point d'extrémité d'AR dans lequel il envoie une ou plusieurs unités APDU de demande de service confirmé à un publicateur pour demander l'édition d'un objet spécifié

Note 1 à l'article: Deux types de gestionnaires de publication sont définis dans le présent document: les gestionnaires de publication tireurs et les gestionnaires de publication pousseurs, chacun étant défini individuellement.

3.6.57**abonné tireur**

type d'abonné qui reconnaît les APDU de réponse de service confirmé reçues en tant que données d'objet fournies

3.6.58**ressource**

capacité de traitement ou d'information d'un sous-système

3.6.59**point d'extrémité de chemin**

conteneur d'objet contenant les objets de variable d'une classe de variables

3.6.60**serveur**

<protocole de communication> rôle joué par un AREP consistant à renvoyer une APDU de réponse de service confirmé au client qui a initié la demande

3.6.61**serveur**

<objet> objet qui fournit des services à un autre objet (client)

3.6.62**service**

opération ou fonction qu'un objet et/ou une classe d'objets exécute à la demande d'un autre objet et/ou une autre classe d'objets

3.6.63**abonné**

rôle joué par un AREP consistant à recevoir des APDU produites par un publicateur

3.7 Abréviations et symboles

AE	Application Entity (Entité d'application)
AL	Application Layer (Couche application)
ALME	Application Layer Management Entity (Entité de gestion de couche application)
ALP	Application Layer Protocol (Protocole de couche application)
APO	Application Object (Objet d'application)
AP	Application Process (Processus d'application)
APDU	Application Protocol Data Unit (Unité de données de protocole d'application)
API	Application Process Identifier (Identificateur de processus d'application)
AR	Application Relationship (Relation d'application)
AREP	Application Relationship End Point (point final de relation d'application)
ASCII	American Standard Code for Information Interchange (Code normalisé américain pour l'échange d'informations)
ASE	Application Service Element (Elément de service d'application)
Cnf	Confirmation (Confirmation)
CR	Communication Relationship (Relation de communication)
CREP	Communication Relationship End Point (Point d'extrémité de relation de communication)
DL-	(préfixe) Data Link- (Liaison de données)
DLC	Data Link Connection (Connexion de liaison de données)
DLCEP	Data Link Connection End Point (Point final de connexion de liaison de données)
DLL	Data Link Layer (Couche liaison de données)
DLM	Data Link-management (Gestion de liaison de données)
DLSAP	Data Link Service Access Point (Point d'accès au service de liaison de données)
DLSDU	DL-service-data-unit (Unité de données de service de liaison de données)
DNS	Domain Name Service (Service de noms de domaine)
DP	Decentralised Peripherals (Périphériques décentralisés)
FAL	Fieldbus Application Layer (Couche application de bus de terrain)
FIFO	First In First Out (Premier entré premier sorti)
HMI	Human-Machine Interface (Interface Homme/Machine)
ID	Identifier (Identificateur)
IDL	Interface Definition Language (Langage de définition d'interface)
IEC	International Electrotechnical Commission (Commission Electrotechnique Internationale)
Ind	(Indication (Indication))
IP	Internet Protocol (Protocole Internet)
ISO	International Organization for Standardization (Organisation Internationale de Normalisation)
LDev	Logical Device (Dispositif logique)
LME	Layer Management Entity (Entité de gestion de couche)

OSI	Open Systems Interconnection (Interconnexion de systèmes ouverts)
PDev	Physical Device (Appareil physique)
PDU	Protocol Data Unit (Unité de données de protocole)
PL	Physical Layer (Couche physique)
QoS	Quality of Service (Qualité de service)
REP	Route Endpoint (Point d'extrémité de chemin)
Req	Request (Demande)
Rsp	Response (Réponse)
RT	RunTime (Exécution)
SAP	Service Access Point (Point d'accès au service)
SCL	SeCurity Level (Niveau de sécurité)
SDU	Service Data Unit (Unité de données de service)
SEM	State Event Matrix (Matrice d'événements d'états)
SMIB	System Management Information Base (Base d'information de gestion de système)
SMK	System Management Kernel (Noyau de gestion de système)
STD	State Transition Diagram (Diagramme de transition d'états, utilisé pour décrire le comportement de l'objet)
VAO	VARiable Object (Objet de variable)

3.8 Conventions

3.8.1 Vue d'ensemble

La FAL est définie comme étant un ensemble d'ASE orientés objet. Chaque ASE est spécifiée dans un paragraphe distinct. Chaque spécification d'ASE comprend deux parties: la spécification de classe et la spécification de service.

La spécification de classe définit les attributs de la classe. Les attributs sont accessibles dans les instances de la classe au moyen des services ASE de gestion d'objets spécifiés à l'Article 5 du présent document. La spécification de service définit les services qui sont fournis par l'ASE.

3.8.2 Conventions générales

Le présent document utilise les conventions descriptives données dans l'ISO/IEC 10731.

3.8.3 Conventions pour les définitions de classe

Les définitions de classe sont décrites au moyen de modèles. Chaque modèle consiste en une liste d'attributs destinés à la classe. La forme générale du modèle est représentée ci-dessous:

ASE de FAL:		Nom de l'ASE
CLASSE:		Nom de la classe
ID DE CLASSE:		#
CLASSE PARENTE:		Nom de la classe parente
ATTRIBUTS:		
1	(o) Attribut clé:	Identifiant numérique
2	(o) Attribut clé:	nom
3	(m) Attribut:	nom de l'attribut(valeurs)
4	(m) Attribut:	nom de l'attribut(valeurs)
4.1	(s) Attribut:	nom de l'attribut(valeurs)
4.2	(s) Attribut:	nom de l'attribut(valeurs)
4.3	(s) Attribut:	nom de l'attribut(valeurs)
5.	(c) Contrainte:	expression de la contrainte
5.1	(m) Attribut:	nom de l'attribut(valeurs)
5.2	(o) Attribut:	nom de l'attribut(valeurs)
6	(m) Attribut:	nom de l'attribut(valeurs)
6.1	(s) Attribut:	nom de l'attribut(valeurs)
6.2	(s) Attribut:	nom de l'attribut(valeurs)
SERVICES:		
1	(o) OpService:	nom du service
2.	(c) Contrainte:	expression de la contrainte
2.1	(o) OpService:	nom du service
3	(m) MgtService:	nom du service

- (1) L'entrée "ASE de FAL:" est le nom de l'ASE de FAL qui fournit les services correspondant à la classe qui est en train d'être spécifiée.
- (2) L'entrée "CLASSE:" est le nom de la classe qui est en train d'être spécifiée. Tout objet défini au moyen de ce modèle constitue une instance de cette classe. La classe peut être spécifiée au moyen du présent document ou par un utilisateur du présent document.
- (3) L'entrée "ID CLASSE:" est le numéro qui identifie la classe qui est en train d'être spécifiée. Ce numéro est unique au sein de l'ASE de FAL qui fournit les services correspondant à cette classe. Lorsqu'on lui adjoint l'identité de son ASE de FAL, il identifie sans ambiguïté la classe dans le domaine d'application de la FAL. La valeur "NULL" indique que la classe ne peut pas être instanciée. Les ID de classe compris entre 1 et 255 sont réservés par le présent document pour l'identification des classes normalisées. Ils ont été définis ainsi pour maintenir la compatibilité avec les normes nationales existantes. Les ID de classe compris entre 256 et 2048 sont alloués pour l'identification des classes définies par les utilisateurs.
- (4) L'entrée "CLASSE PARENTE:" est le nom de la classe parente de la classe qui est en train d'être spécifiée. Tous les attributs définis pour la classe parente et hérités par celle-ci sont hérités pour la classe définie, et ils n'ont donc pas à être redéfinis dans le modèle pour cette classe.

NOTE La classe parente "TOP" indique que la classe en train d'être définie est une définition de classe initiale. La classe parente TOP est utilisée comme point de départ à partir duquel toutes les autres classes sont définies. L'utilisation de TOP est réservée aux classes définies par le présent document.

(5) L'étiquette "ATTRIBUTS" indique que les entrées suivantes sont des attributs définis pour la classe.

- a) Chacune des entrées d'attribut est composée d'un numéro de ligne dans la colonne 1, d'un indicateur obligatoire (mandatory) (m) / optionnel (o) / conditionnel (c) / sélecteur (s) dans la colonne 2, d'une étiquette de type d'attribut dans la colonne 3, d'un nom ou d'une expression conditionnelle dans la colonne 4 et, en option, d'une liste de valeurs énumérées dans la colonne 5. Dans la colonne qui suit la liste de valeurs, on peut spécifier la valeur par défaut de l'attribut.
- b) Les objets sont normalement identifiés par un identificateur numérique ou par un nom d'objet, ou les deux. Dans les modèles de classe, ces attributs clés sont définis sous l'attribut clé.
- c) Le numéro de ligne identifie la séquence et le niveau d'emboîtement de la ligne. Chaque niveau d'emboîtement est identifié par période. L'imbrication est utilisée pour spécifier
 - i) les champs d'un attribut structuré (4.1, 4.2, 4.3),
 - ii) les attributs dépendant d'une déclaration de contrainte (5). Les attributs peuvent être obligatoires (5.1) ou optionnels (5.2) si la contrainte est vraie. Contrairement à l'attribut défini en (5.2), les attributs facultatifs n'exigent pas systématiquement de déclaration de contrainte.
 - iii) les champs de sélection d'un attribut de type de choix (6.1 et 6.2).

(6) L'étiquette "SERVICES" indique que les entrées suivantes sont des services définis pour la classe.

- a) Un (m) dans la colonne 2 indique le service est obligatoire (mandatory) pour la classe, le (o) indiquant qu'il est optionnel. Un (c) dans cette colonne indique que le service est conditionnel. Lorsque tous les services définis pour une classe le sont comme étant facultatifs, il faut en sélectionner au moins un quand une instance de la classe est définie.
- b) L'étiquette "OpsService" désigne un service opérationnel (1).
- c) L'étiquette "MgtService" désigne un service de gestion (2).
- d) Le numéro de ligne identifie la séquence et le niveau d'emboîtement de la ligne. Chaque niveau d'emboîtement est identifié par période. L'imbrication dans la liste de services sert à spécifier des services conditionnés à un énoncé de contrainte.

3.8.4 Conventions pour les définitions de service

3.8.4.1 Généralités

Le modèle de service, les primitives de service et les schémas de séquence de temps utilisés sont des descriptions entièrement abstraites; elles ne correspondent pas à une spécification de mise en œuvre.

3.8.4.2 Paramètres de service

Les primitives de service sont utilisées pour représenter les interactions entre utilisateur de service et fournisseur de service (ISO/IEC 10731). Elles transmettent des paramètres qui indiquent les informations disponibles dans l'interaction utilisateur/fournisseur. Dans une interface particulière, il n'est pas nécessaire de déclarer explicitement tous les paramètres.

Les spécifications de service du présent document décrivent les paramètres qui composent les primitives de service ASE au moyen d'un format tabulaire. Les paramètres qui s'appliquent à chaque groupe des primitives de service sont présentés dans des tableaux. Chaque tableau comprend jusqu'à cinq colonnes donnant:

- 1) nom de paramètre,
- 2) la primitive de demande,
- 3) la primitive d'indication,
- 4) la primitive de réponse et
- 5) la primitive de confirmation.

Un paramètre (ou un composant de celui-ci) est répertorié sur chaque ligne de chacun des tableaux. Dans les colonnes appropriées de la primitive de service, un code est utilisé pour spécifier le type d'usage du paramètre sur la primitive spécifiée dans la colonne:

- M Paramètre obligatoire pour la primitive.
- U Option de l'utilisateur; ce paramètre peut ou non être indiqué, en fonction de l'utilisation dynamique par l'utilisateur du service. Si ce paramètre n'est pas indiqué, il peut prendre une valeur par défaut.
- C Paramètre dépendant d'autres paramètres ou de l'environnement de l'utilisateur du service.
- (vide) Paramètre jamais spécifié.
- S Paramètre qui correspond à un élément sélectionné.

Certaines entrées sont également qualifiées par des éléments entre parenthèses. Il peut s'agir

- a) d'une contrainte spécifique à un paramètre:
 "(=)" indique que le paramètre équivaut sur le plan sémantique au paramètre de la primitive de service se trouvant immédiatement à sa gauche dans le tableau.
- b) d'une indication qu'une note s'applique à l'entrée:
 "(n)" indique que la note "n" qui suit contient des informations supplémentaires concernant le paramètre et son utilisation.

3.8.4.3 Procédures de service

Les procédures sont définies en termes

- interactions entre entités d'application via l'échange d'unités de données de protocole d'application de bus de terrain, et
- interactions entre un fournisseur de service de couche application et un utilisateur de service de couche application dans le même système via l'invocation de primitives de service de couche application.

Ces procédures sont applicables aux instances de communication entre systèmes supportant les services de communication à contrainte de temps propres à la couche application de bus de terrain.

4 Concepts

4.1 Vue d'ensemble

Le bus de terrain est destiné à être utilisé dans les usines et les installations de traitement pour interconnecter les appareils primaires d'automatisation (par exemple, capteurs, organes de commande, dispositifs d'affichage locaux, organes de signalisation, automates programmables, petits régulateurs en boucle unique et contrôles de champ autonomes) avec des équipements de commande et de surveillance situés dans des centres de contrôle.

Les appareils primaires d'automatisation sont associés aux niveaux les plus faibles de la hiérarchie d'automatisation industrielle et effectuent un ensemble limité de fonctions dans une fenêtre temporelle définie. Certaines de ces fonctions incluent les diagnostics, la validation des données et la gestion de plusieurs entrées et sorties.

Ces appareils primaires d'automatisation, également appelés dispositifs de terrain, sont situés à proximité des fluides de traitement, de la pièce fabriquée, de la machine, de l'opérateur et de l'environnement. Cette utilisation positionne le bus de terrain aux niveaux les plus bas de l'architecture CIM (Computer Integrated Manufacturing).

Certains des avantages attendus de l'utilisation de bus de terrain sont la réduction du câblage, l'augmentation de la quantité des données échangées, la distribution plus large du contrôle entre les appareils primaires d'automatisation et l'équipement du centre de contrôle, et le respect des contraintes temporelles critiques.


L'Article 4 décrit les principes de la couche FAL. Des informations descriptives détaillées relatives aux éléments ASE de couche FAL peuvent être trouvées dans le paragraphe "Présentation" de chacune des spécifications de modèle de communication.

4.2 Relations de l'architecture

4.2.1 Relation à la couche Application du modèle de référence de base OSI

Les fonctions de la couche FAL ont été décrites conformément aux principes des couches OSI. Toutefois, sa relation d'architecture aux couches inférieures est différente, comme représenté à la Figure 1.

- La couche FAL inclut les fonctions OSI avec des extensions pour faire face aux exigences temporelles critiques. La norme relative à la structure de la couche Application OSI (ISO/IEC 9545) a servi de base pour la spécification de la couche FAL.
- La couche FAL utilise directement les services de la couche sous-jacente. La couche sous-jacente peut être la couche DLL ou n'importe quelle autre couche intermédiaire. Lorsqu'elle utilise la couche sous-jacente, la couche FAL peut fournir des fonctions normalement associées aux couches OSI intermédiaires pour le mapping correct sur la couche sous-jacente.



Anglais	Français
OSI AP	Processus d'application OSI
Fieldbus User Layer	Couche utilisateur de bus de terrain
OSI Application Layer	Couche d'application OSI
Fieldbus Application Layer	Couche d'application de bus de terrain
OSI Middle Layers	Couches intermédiaire OSI
(possibly non-existent)	(peut-être inexistant)
OSI Data Link Layer	Couche de liaison OSI
Data Link Layer	Couche de liaison de données
OSI Physical Layer	Couche physique OSI
Physical Layer	Couche physique
Physical Medium	Support physique

Figure 1 – Relation avec le modèle de référence de base OSI


4.2.2 Relations avec les autres entités du bus de terrain

4.2.2.1 Généralités

Les relations d'architecture de la couche Application de bus de terrain (FAL), représentées à la Figure 2, ont été conçues pour faire face aux besoins d'interopérabilité des systèmes à temps critique distribués au sein de l'environnement du bus de terrain.

Au sein de cet environnement, la couche FAL fournit des services de communications aux applications en temps critique ou non situées dans les appareils de bus de terrain.

En outre, la couche FAL utilise directement la couche DLL pour transférer ses unités de données de protocole de couche application. Elle le fait en utilisant un ensemble de services de transfert de données et un ensemble de services de soutien qui permettent de contrôler les aspects opérationnels de la couche DLL.



Anglais	Français
System Mgt	Gestion système
Fieldbus User	Utilisateur de bus de terrain
ALME	Application Layer Management Entity (Entité de gestion de couche application)
Fieldbus Application Layer	Couche d'application de bus de terrain
Fieldbus Data Link Layer	Couche de liaison de données de bus de terrain

Figure 2 – Positionnement architectural de la couche Application de bus de terrain

4.2.2.2 Utilisation de la couche Liaison de données de bus de terrain

La couche Application de bus de terrain (FAL) assure l'accès réseau aux AP de bus de terrain. Elle s'interface directement à la couche Liaison de données de bus de terrain pour le transfert de ses APDU.

La couche DLL offre différents types de services à la couche FAL pour le transfert des données entre les points d'extrémité de liaison de données (par exemple DLSAP, DLCEP).

4.2.2.3 Support pour les applications de bus de terrain

Les applications de bus de terrain sont représentées sur le réseau en tant que procédés d'application (AP). Les AP sont les composants d'un système distribué qui peuvent être individuellement identifiés et adressés.

Chaque AP contient une entité d'application (AE) FAL qui assure l'accès réseau à l'AP. C'est-à-dire que chaque AP communique avec les autres par l'intermédiaire de son AE. Dans ce sens, l'AE fournit une fenêtre de visibilité dans l'AP.

Les AP contiennent des composants identifiables qui sont également visibles sur le réseau. Ces composants sont représentés sur le réseau en tant qu'objets de processus d'application (APO). Ils peuvent être identifiés par un ou plusieurs attributs clés. Ils se trouvent à l'adresse du processus d'application qui les contient.

Les services utilisés pour y accéder sont fournis par les éléments de service application (ASE) spécifiques de l'APO contenus au sein de la couche FAL. Ces ASE sont conçus pour prendre en charge les applications utilisateur, de bloc de fonction et de gestion.

4.2.2.4 Prise en charge de la gestion du système

Les services de la couche FAL peuvent être utilisés pour prendre en charge diverses opérations de gestion, y compris la gestion des systèmes de bus de terrain, des applications et du réseau de bus de terrain.

4.2.2.5 Accès aux entités de gestion de couche de la couche FAL

Une entité de gestion de couche (LME) peut être présente dans chaque entité FAL du réseau. Les FALME donnent accès à la couche FAL pour les besoins de gestion du système.

L'ensemble des données accessibles par le gestionnaire du système s'appelle Base d'informations de gestion du système (SMIB). Chaque entité de gestion de couche Application de bus de terrain (FALME) fournit la partie FAL de la SMIB. Le mode d'implémentation de la SMIB ne relève pas du domaine d'application de la présente norme.

4.3 Structure de la couche Application de bus de terrain

4.3.1 Vue d'ensemble

La structure de la couche FAL est un affinement de la structure de la couche Application OSI (ISO/IEC 9545). Par conséquent, l'organisation de 4.3 est similaire à celle de l'ISO/IEC 9545. Certains concepts présentés ici ont été développés à partir de l'ISO/IEC 9545 pour l'environnement de bus de terrain.

La couche FAL diffère des autres couches OSI par deux aspects principaux.

- OSI définit un type unique de voie de communication de la couche application, l'association, pour connecter les APPAREILS PORTABLES les uns aux autres. La couche FAL définit la relation entre applications (AR), dont il existe plusieurs types, pour permettre aux procédés d'application (AP) de communiquer.
- La couche FAL utilise la DLL pour transférer ses PDU mais pas la couche de présentation. Par conséquent, il n'existe pas de contexte de présentation explicite à la disposition de la couche FAL. Entre la même paire (ou ensemble) de points d'accès de service de liaison de données, le protocole de la couche FAL ne peut pas être utilisé simultanément avec d'autres protocoles de couche application.

4.3.2 Concepts fondamentaux

Le fonctionnement des systèmes ouverts réels à temps critiques est modélisé en termes d'interactions entre les AP à temps critiques. La couche FAL permet à ces AP de transmettre des commandes et des données entre elles.

La coopération entre AP exige qu'elles partagent des informations suffisantes pour interagir et réaliser les activités de traitement de façon coordonnée. Leurs activités peuvent être restreintes à un segment unique de bus de terrain ou s'étendre sur plusieurs segments. La couche FAL a été conçue en utilisant une architecture modulaire pour prendre en charge les exigences de messagerie de ces applications.

En outre, la coopération entre AP exige parfois qu'elles partagent le même sens de la durée. La couche FAL ou la couche DLL (IEC 61158-3-4 et IEC 61158-4-4) peut assurer la distribution du temps sur tous les appareils. Elles peuvent également définir des services d'appareil locaux qui peuvent être utilisés par les AP pour accéder au temps distribué.

Le reste de 4.3 décrit chacun des composants modulaires de l'architecture ainsi que leurs relations les uns aux autres. Les composants de la couche FAL sont modélisés en tant qu'objets, chacun d'entre eux fournissant un ensemble de services de communications FAL utilisables par les applications. Les objets FAL et leurs relations sont décrits ci-dessous. Les spécifications détaillées des objets FAL et leurs services sont fournis dans les articles suivants de la présente norme. L'IEC 61158-6-4 spécifie les protocoles nécessaires pour acheminer ces services d'objets entre les applications.

4.3.3 Procédés d'application de bus de terrain

4.3.3.1 Définition de l'AP de bus de terrain

Dans l'environnement du bus de terrain, une application peut être fractionnée en un ensemble de composants et distribuée sur plusieurs appareils du réseau. Chacun de ces composants est appelé procédé d'application (AP) de bus de terrain. Un AP de bus de terrain est une variante du procédé d'application tel qu'il est défini dans le modèle de référence OSI ISO (ISO/IEC 7498). Les AP de bus de terrain peuvent être adressés sans ambiguïté par au moins une adresse individuelle de point d'accès au service de couche de liaison de données. Adressé sans ambiguïté, dans ce contexte, signifie qu'aucun autre AP ne peut être localisé simultanément par la même adresse. Cette définition n'interdit pas qu'un AP soit localisé par une ou plusieurs adresses individuelles (ou groupe) de point d'accès au service de couche liaison de données.

4.3.3.2 Services de communication

Les AP de bus de terrain communiquent entre eux en utilisant des services confirmés ou non confirmés (ISO/IEC 10731). Les services définis dans cette norme pour la couche FAL spécifient la sémantique des services vus par les AP demandeuse et répondeuse. La syntaxe des messages utilisés pour acheminer les demandes de service et les réponses est définie dans l'IEC 61158-6-4. Le comportement d'AP associé aux services est spécifié par l'AP.

Les services confirmés sont utilisés pour définir les échanges de demande/réponse entre les AP.

En revanche, les services non confirmés sont utilisés pour définir le transfert unidirectionnel des messages d'une AP vers un ou plusieurs AP distants. Du point de vue des communications, il n'existe pas de relation entre appels séparés de service non confirmé, comme il en existe entre la demande et la réponse d'un service confirmé.

4.3.3.3 Interactions entre AP

4.3.3.3.1 Généralités


Au sein de l'environnement du bus de terrain, les AP peuvent interagir avec d'autres AP selon les besoins pour atteindre leurs objectifs fonctionnels. Aucune contrainte n'est imposée par la présente norme quant à l'organisation de ces interactions ou quant aux possibles relations qui peuvent exister entre elles.

Par exemple, dans l'environnement du bus de terrain, les interactions peuvent être basées sur des messages de demande/réponse envoyés directement entre les AP, ou sur des données/événements envoyés par un AP pour être utilisés par d'autres. Ces deux modèles d'interactions entre AP sont nommés interactions client/serveur et publicateur/abonné.

Les services supportés par un modèle d'interaction sont transmis par des points finaux de relation d'application (des AREP) associés aux AP communicants. Le rôle joué par l'AREP dans l'interaction (client, serveur, pair, publicateur, abonné) est défini en tant qu'attribut de l'AREP.

4.3.3.3.2 Interactions client/serveur

Les interactions client/serveur sont caractérisées par un flot unidirectionnel des données entre un AP client et un ou plusieurs AP serveurs. La Figure 3 représente l'interaction entre un client seul et un serveur seul. Dans ce type d'interaction, le client peut émettre une demande confirmée ou non confirmée au serveur pour réaliser une tâche. Si le service est confirmé, le serveur retourne toujours une réponse. Si le service n'est pas confirmé, le serveur peut retourner une réponse en utilisant un service non confirmé défini à cette fin.



Anglais	Français
Unconfirmed and confirmed service requests	Demandes de service non confirmées et confirmées
Client (requester	Client (demandeur)
Server responder)	Serveur (répondeur)
Unconfirmed service replies and confirmed service responses	Réponses des services non confirmés et confirmés

Figure 3 – Interactions client/serveur

4.3.3.3.3 Interactions entre publicateur et abonné

4.3.3.3.3.1 Généralités

Les interactions publicateur/abonné, quant à elles, impliquent un seul AP publicateur, et un groupe d'un ou plusieurs AP abonnés. Ce type d'interaction a été défini pour supporter des variations des deux modèles d'interaction entre AP, le modèle "tireur" et le modèle "pousseeur". Dans ces deux modèles, la configuration de l'AP assurant la publication est effectuée par des actions de gestion et ne fait pas partie du domaine d'application de la présente norme.


4.3.3.3.3.2 Interactions du modèle tireur

Dans le modèle "pull", le publicateur reçoit une demande de publication provenant d'un *gestionnaire* de publication distant et diffuse (ou multidiffuse) sa réponse sur le réseau. Le gestionnaire de publication a pour seule responsabilité celle d'initier la publication en envoyant une demande au publicateur.

Les abonnés souhaitant recevoir les données publiées écoutent les réponses émises par le publicateur. C'est ainsi que les données sont "tirées" au publicateur par des demandes émanant du gestionnaire de publication.

Les services de FAL confirmés sont utilisés pour supporter ce type d'interaction. Ce type d'interaction se distingue des autres types d'interaction par deux caractéristiques. Premièrement, un échange demande/réponse confirmé type a lieu entre le gestionnaire de publication et le publicateur. Cependant, le mécanisme de transmission sous-jacent fourni par la FAL renvoie la réponse non seulement au gestionnaire de publication, mais aussi à tous les abonnés souhaitant recevoir les informations publiées. On accomplit cela en faisant en sorte que la couche liaison de données émette la réponse à un groupe d'adresses plutôt qu'à l'adresse individuelle du gestionnaire de publication. Par conséquent, la réponse envoyée par le publicateur contient les données publiées et est multidiffusée au gestionnaire de publication et à tous les abonnés.

La deuxième différence concerne le comportement des abonnés. Les abonnés du modèle tireur, appelés abonnés tireurs, sont capables d'accepter les données publiées contenues dans les réponses de service confirmé sans avoir émis la demande correspondante. La Figure 4 représente ces concepts.



Anglais	Français
confirmed service request for published information	demande de service confirmée pour les informations publiées
Pull Publishing Manager	Gestionnaire d'abonnement par extraction
Pull Publisher	Editeur par extraction
Pull Subscriber	Abonné par extraction
confirmed service response containing published information	réponse de service confirmée contenant des informations publiées


Figure 4 – Interactions du modèle tireur

4.3.3.3.3 Interactions du modèle pousseur

Dans le modèle "pousseur", deux services peuvent être utilisés, le service confirmé et le service non confirmé. L'abonné utilise le service confirmé pour demander à joindre la publication. La réponse à cette demande est renvoyée à l'abonné en suivant le modèle d'interaction client/serveur. Cet échange est seulement nécessaire lorsque l'abonné et le publicateur sont situés dans des AP différents.

Le service non confirmé utilisé dans le modèle pousseur est celui qu'utilise le publicateur pour distribuer ses informations aux abonnés. Dans ce cas, le publicateur a la responsabilité d'appeler le service non confirmé correct au moment approprié et de fournir les informations appropriées. Dans ce mode, il est configuré pour "pousser" ses données sur le réseau.

Les abonnés du modèle pousseur reçoivent les services non confirmés fournis, distribués par les publicateurs. La Figure 5 représente le concept de modèle pousseur.



Anglais	Français
confirmed service request to subscribe to publishing	demande de service confirmée pour s'abonner à la publication
confirmed service response to indicate capability to publish	demande de service confirmée pour indiquer la capacité à publier
unconfirmed service request containing published information	demande de service non confirmée contenant des informations publiées
Push Subscriber	Abonné par émission
Push Publisher	Editeur par émission

Figure 5 – Interactions du modèle pousseur

4.3.3.3.4 Ponctualité des informations publiées

Pour prendre en charge la nature périssable des informations publiées, la couche FAL peut prendre en charge quatre types de ponctualités définies pour les interactions publicateur/abonné. Chaque type permet aux abonnés des données publiées de déterminer si les données qu'ils reçoivent sont à jour ou "dépassées". Ces types sont réalisés par l'intermédiaire de mécanismes au sein de la couche DLL. Chacun d'eux est brièvement décrit ci-dessous. Pour une description plus détaillée, se reporter à l'IEC 61158-3-4 et à l'IEC 61158-4-4.

Type	Description
Transparent	Ce type de ponctualité permet au processus application utilisateur de déterminer la qualité des données de ponctualité qu'il génère et de faire que la qualité de ponctualité accompagne les informations lors de leur transfert sur le réseau. Dans ce type de ponctualité, le réseau n'effectue ni calcul ni mesure de ponctualité. Il se contente de transmettre la qualité de ponctualité fournie avec les données par le processus application utilisateur.
Résidence	Lorsque la couche FAL présente des données de l'AP assurant la publication à la couche DLL pour les transmettre, la couche DLL démarre un temporisateur. Si le temporisateur expire avant que les données n'aient été transmises, la couche DLL marque le tampon comme "non opportun" et transmet ces informations de ponctualité avec les données.

Type	Description
Synchronisé	Ce type de ponctualité exige la coordination de deux informations publiées. Les unes sont les données à publier les autres sont une "marque de synchronisation" spéciale. Lorsque la marque de synchronisation est reçue du réseau un temporisateur démarre dans chacune des stations participantes. Par la suite, lorsque les données sont reçues pour être transmises par la couche DLL à la station de publication, ou lorsque les données transmises sont reçues du réseau à la station de l'abonné, l'attribut de ponctualité de la couche DLL pour les données est défini sur TRUE. Il reste défini sur TRUE jusqu'à la réception de la marque de synchronisation suivante ou jusqu'à l'expiration du temporisateur. Les données reçues après l'expiration du temporisateur mais avant la marque de synchronisation suivante ne provoquent pas la réinitialisation de l'attribut de ponctualité sur TRUE. Il n'est réinitialisé sur TRUE que si les données sont reçues dans la fenêtre temporelle après réception de la marque de synchronisation. Les données transmises par la station du publicateur avec l'attribut de ponctualité défini sur FALSE conservent le paramètre FALSE à chacun des abonnés, quel que soit le fonctionnement de leur temporisateur.
Mise à jour	Ce type de ponctualité exige la coordination de deux mêmes informations publiées définies pour la ponctualité <i>synchronisée</i> . Dans ce type, la marque de synchronisation démarre également un temporisateur dans chacune des stations participantes. De même que la ponctualité <i>synchronisée</i> , l'expiration du temporisateur provoque toujours la définition de l'attribut de ponctualité sur FALSE. Contrairement à la ponctualité <i>synchronisée</i> , la réception de nouvelles données à tout moment (pas seulement dans la fenêtre temporelle démarrée après réception de la marque de synchronisation) provoque toujours la définition de l'attribut de ponctualité sur TRUE.

4.3.3.4 Structure des AP

La structure des AP peut être représentée par un ou plusieurs objets de processus d'application (APO) et accessible par une ou plusieurs entités d'application (AE). Les AE fournissent les capacités de communication de l'AP. Pour chaque AP de bus de terrain, il n'existe qu'une seule entité AE de couche FAL. Les APO sont la représentation en réseau des capacités propres à l'application (objets de processus d'application utilisateur) d'un AP qui sont accessibles par l'intermédiaire de son entité AE de couche FAL.

4.3.3.5 Classe AP

Une classe AP est une définition des attributs et des services d'un AP. La définition de classe standard des AP est définie dans le présent document. Des classes définies par l'utilisateur peuvent également être spécifiées. Les identificateurs de classe (décrits en 3.8.2) sont attribués à partir d'un ensemble réservé à cette fin.

4.3.3.6 Type AP


Comme décrit ci-dessus dans les paragraphes précédents, les AP sont définis en instanciant une classe AP. Chaque définition d'AP est composée des attributs et des services sélectionnés pour l'AP à partir de ceux définis par sa classe AP. En outre, une définition d'AP contient des valeurs pour un ou plusieurs des attributs sélectionnés pour celui-ci. Lorsque deux AP partagent la même définition, la définition en question est appelée "type d'AP". Ainsi, un type AP est une spécification générique d'un AP qui peut être utilisé pour définir un ou plusieurs AP.

4.3.4 Objets de processus d'application (APO)

4.3.4.1 Définition d'un APO

Un objet de processus d'application (APO) est une représentation en réseau d'un aspect particulier d'un AP. Chaque APO représente un ensemble spécifique d'informations et de capacités de traitement d'un AP, qui sont accessibles par les services de la FAL. On utilise les APO pour représenter ces capacités pour d'autres AP d'un système de bus de terrain.

Vu de la FAL, un APO est modélisé sous forme d'objet accessible en réseau contenu dans un AP ou dans un autre APO (les APO pouvant contenir d'autres APO). Les APO fournissent la définition réseau des objets contenus dans un AP qui sont accessibles à distance. La définition d'un APO comprend une identification des services de la FAL qui peuvent être utilisés par des AP distants pour l'accès distant. Les services de la FAL, tels que représentés à la Figure 6, sont fournis par l'entité de communications de FAL de l'AP, appelée entité d'application de la FAL (FAL AE).



Anglais	Français
services for remote access to APO	services pour accéder à distance à APO
User Request and Response Data	Données de demande et de réponse utilisateur
requester	demandeur
FAL AE	Entité d'application de couche de bus de terrain (AE de FAL)
FAL APDUs	Fieldbus Application Layer Application Protocol Data Units (Unités de données de protocole d'application relative à la couche application de bus de terrain) (APDU de FAL)
APO services	Services APO
Real object	Objet réel
responder	répondeur
APO provides network view of real object	APO fournit une vue réseau d'un objet réel

Figure 6 – Services APO transmis par la couche FAL

Sur la Figure 6, les AP distants agissant comme clients peuvent accéder à l'objet réel en envoyant des demandes par l'intermédiaire de l'APO qui représente l'objet réel. Les aspects locaux de l'AP font la conversion entre la vue réseau (l'APO) de l'objet réel et la vue d'AP interne de l'objet réel.

Pour prendre en charge le modèle d'interaction publicateur/abonné, les informations concernant l'objet réel peuvent être publiées par l'intermédiaire de son APO. Les AP distants agissant en tant qu'abonnés voient la vue APO des informations publiées au lieu de devoir connaître les détails spécifiques de l'objet réel.

4.3.4.2 Classes APO

Une classe APO est spécification générique pour un ensemble d'APO, chacun étant décrit par le même ensemble d'attributs et accessible en utilisant le même ensemble de services.

Les classes APO fournissent le mécanisme permettant la normalisation des aspects réseau visibles des AP. Chaque définition de classe APO standard spécifie un ensemble particulier d'attributs et de services AP accessible sur le réseau. L'IEC 61158-6-4 spécifie la syntaxe et les procédures utilisées par le protocole de la couche FAL pour fournir un accès distant aux attributs et aux services d'une classe APO.

Les classes standard APO sont spécifiées par la présente norme dans le but de normaliser l'accès distant aux AP. Des classes définies par l'utilisateur peuvent également être spécifiées.

Les classes définies par l'utilisateur sont définies en tant que sous-classes des classes APO normalisées ou d'autres classes définies par l'utilisateur. Elles peuvent être définies en identifiant de nouveaux attributs ou en indiquant que les attributs facultatifs pour la classe parente sont obligatoires pour la sous-classe. Les conventions de définition des classes définies en 3.8.2 peuvent être utilisées à cette fin. La méthode permettant d'enregistrer ou de mettre ces nouvelles définitions de classe à la disposition du public ne relève pas du domaine d'application de la présente norme.

4.3.4.3 APO en tant qu'instances des classes APO

Les classes APO sont définies dans le présent document en utilisant des modèles. Ces modèles sont utilisés non seulement pour définir les classes APO, mais également pour spécifier les instances d'une classe.

Chaque APO défini pour un AP est une instance d'une classe APO. Chaque APO fournit la vue réseau d'un objet réel contenu dans un AP. Un APO est défini par

- (1) la sélection des attributs à partir de son modèle de classe APO, censés être accessibles à partir de l'objet réel;
- (2) l'attribution de valeurs à un ou plusieurs attributs indiqués comme clé dans le modèle. Des attributs clés sont utilisés pour identifier l'APO;
- (3) l'attribution de valeurs à zéro, un ou plusieurs attributs non cruciaux pour l'APO. Des attributs non cruciaux sont utilisés pour caractériser l'APO;
- (4) la sélection des services à partir du modèle qui peuvent être utilisés par des AP distants pour accéder à l'objet réel.

Le paragraphe 3.8.2 du présent document spécifie les conventions des modèles de classe. Ces conventions fournissent la définition des attributs et des services obligatoires, facultatifs et conditionnels.

Il est exigé que les attributs et les services obligatoires soient présents dans tous les APO de la classe. Les attributs et les services facultatifs peuvent être sélectionnés, sur un APO par base APO, pour inclusion dans un APO. Les attributs et les services conditionnels sont définis avec un énoncé de contrainte qui les accompagne. Les énoncés de contrainte spécifient les conditions qui indiquent si l'attribut est tenu d'être présent ou non dans un APO.

4.3.4.4 Types APO


Les types APO fournissent le mécanisme permettant la définition des APO standard.

Comme décrit ci-dessus dans les paragraphes précédents, les APO sont définis en instanciant une classe APO. Chaque définition d'APO est composée des attributs et des services sélectionnés pour l'APO à partir de ceux définis par sa classe APO. En outre, une définition d'APO contient des valeurs pour un ou plusieurs des attributs sélectionnés pour celui-ci. Lorsque deux APO partagent la même définition à l'exception des positionnements des attributs clés, la définition en question est appelée "type d'APO". Ainsi, un type APO est une spécification générique d'un APO qui peut être utilisé pour définir un ou plusieurs APO.

4.3.5 Entités d'application

4.3.5.1 Définition de FAL AE

Une entité d'application fournit les capacités de communication d'un AP unique. Un FAL AE fournit un ensemble de services ainsi que les protocoles de prise en charge qui permettent les communications entre AP dans un environnement du bus de terrain. Les services fournis par les AE de FAL sont regroupés dans des éléments de service d'application (ASE), de sorte que les services FAL fournis à un AP soient définis par les ASE que contient son AE de FAL. La Figure 7 représente ce concept.



Anglais	Français
service primitives	primitives de service
FAL AE	Entité d'application de couche de bus de terrain (AE de FAL)
FAL Service	Service FAL
FAL ASE	Elément de service d'application de la couche application de bus de terrain (ASE de FAL)
service conveyance to remote AEs	transport de service vers AE à distance

Figure 7 – Structure d'entité d'application

4.3.5.2 Type AE

Les entités d'application qui fournissent le même ensemble d'ASE sont du même type AE. Deux AE partageant un ensemble commun d'ASE sont capables de communiquer ensemble.

4.3.6 Éléments de service d'application de bus de terrain

4.3.6.1 Généralités

Un élément de service d'application (ASE), tel que défini dans l'ISO/IEC 9545, est un ensemble de fonctions d'application qui offrent une capacité d'interfonctionnement des invocations d'entités d'application à des fins particulières. Les ASE fournissent un ensemble de services pour transmettre des demandes et des réponses vers et à partir des processus d'application et de leurs objets. Les AE, tels que définis ci-dessus, sont représentés par un ensemble d'invocations ASE au sein de l'AE.

4.3.6.2 Services de la FAL

Les services de la FAL transmettent les demandes/réponses fonctionnelles entre les AP. Chaque service de la FAL est défini pour transmettre les demandes et les réponses pour accéder à un objet réel modélisé en tant qu'objet FAL accessible.

La couche FAL définit les services confirmés et non confirmés. Les demandes de service confirmé sont envoyées à l'AP contenant l'objet réel. Une invocation d'une demande de service confirmé peut être identifiée par l'ID d'invocation fourni par l'utilisateur. Cet ID d'invocation est retourné dans la réponse par l'AP contenant l'objet réel. Lorsqu'il est présent, il est utilisé par l'AP demandeur et son FAL AE pour associer la réponse avec la demande appropriée.

Les services non confirmés peuvent être envoyés à partir de l'AP contenant l'objet réel pour envoyer des informations concernant l'objet. Ils peuvent également être envoyés à l'AP contenant l'objet réel pour accéder à l'objet réel. Les deux types de services non confirmés peuvent être définis pour la couche FAL.

4.3.6.3 Définition des FAL ASE


4.3.6.3.1 Généralités

La définition des FAL ASE suit une approche modulaire. Les ASE définis pour la FAL sont également orientés objet. En général, les ASE fournissent un ensemble de services conçu pour une classe d'objets spécifique ou pour un ensemble de classes associé. Les ASE de gestion d'objets communs, lorsqu'ils sont présents, fournissent un ensemble commun de services de gestion applicable à toutes les classes d'objets.

Pour supporter l'accès distant à l'AP, on définit l'ASE de relation d'application. Il fournit des services à l'AP pour définir et établir des relations de communication avec les autres AP, et il fournit des services aux autres ASE pour transmettre leurs demandes de service et leurs réponses.

Chaque ASE de FAL définit un ensemble de services, les APDU, et les procédures qui fonctionnent sur les classes qu'il représente. Seul un sous-ensemble des services ASE peut être fourni pour satisfaire aux besoins d'une application. Des profils peuvent être utilisés pour définir de tels sous-ensembles. La définition des profils ne relève pas du domaine d'application du présent document.

Les APDU sont envoyés et reçus entre les ASE de FAL qui supportent les mêmes services. Chaque AE de FAL contient au minimum l'ASE d'AR et au moins un autre ASE. La Figure 8 représente un exemple d'ASE de FAL et leurs relations architecturales. Tous les APO ASE suivent cet exemple.




Anglais	Français
FAL AP	Processus d'application de la couche application de bus de terrain (AP de FAL)
ASE Requests and Responses	Demandes et réponses ASE
AP ASE	ASE d'AP
Mgt ASE	Gérer ASE
Variable ASE	Elément ASE de variable
Event ASE	Elément ASE d'événement
Fnc Inv ASE	Fnc Inv ASE
Load Reg ASE	Charger ASE enregistré
AR ASE Service Primitives	Primitives de service AR ASE
AR ASE	ASE d'AR
Example FAL AE	Exemple de FAL AE
Conveyance of APDUs by the AR ASE	Acheminement d'unités de données de protocole application par l'AR ASE

Figure 8 – Exemple de FAL ASE

4.3.6.3.2 ASE Object Management (gestion d'objets)

Un ASE de gestion d'objets spécial peut être spécifié pour la couche FAL pour fournir des services pour la gestion des objets. Ses services sont utilisés pour accéder aux attributs d'objet, et créer et supprimer des instances d'objets. Ces services sont utilisés pour gérer les objets AP visibles du réseau accessibles par l'intermédiaire de la couche FAL. Les services opérationnels spécifiques qui s'appliquent à chaque type d'objet sont spécifiés dans la définition de l'ASE pour le type d'objet. La Figure 9 représente l'intégration des services de gestion et des services opérationnels pour un objet au sein d'un AP.



Anglais	Français
Application Process	Processus d'application
MGT ASE	Elément de service d'application de gestion
FAL AE	Entité d'application de couche de bus de terrain (AE de FAL)
APO ASE	Elément de service d'application d'objet de processus application
mgt services	services mgt
ops services	services ops
Target Object Attributes	Attributs d'objet cible
describe	décrire
Target Object	Objet cible

Figure 9 – Gestion FAL des objets

4.3.6.3.3 Elément de service application d'un processus d'application (ASE d'AP)

Un AP ASE peut être spécifié pour l'identification et le contrôle des FAL AP. Les attributs définis par l'AP ASE spécifient les caractéristiques de l'AP concernant son fabricant et énumèrent son contenu et ses capacités.

4.3.6.3.4 Eléments de service application d'un objet de processus d'application (ASE d'APO)

La couche FAL spécifie un ensemble d'ASE avec les services définis pour accéder aux APO d'un AP. Les APO ASE définis pour la couche FAL sont définis par chaque modèle de communication.

4.3.6.3.5 Elément de service application d'une relation d'applications (ASE d'AR)


Un AR ASE est spécifié pour établir et gérer les relations entre applications (AR) qui sont utilisées pour transmettre les FAL APDU entre/parmi les AP. Les AR représentent les canaux de communication de la couche application entre les AP. Les AR ASE sont responsables de fournir les services aux points d'extrémité des AR. Les services AR ASE peuvent être définis pour établir, rompre et abandonner les AR, pour transmettre les APDU pour l'AE, et pour indiquer l'état local de l'AR à l'utilisateur. De plus, des services locaux peuvent être définis pour accéder à certains aspects des points d'extrémité des AR.

4.3.6.4 Transport des services FAL

Les FAL APO ASE fournissent des services pour transmettre les demandes et les réponses entre les utilisateurs du service et les objets réels.

Pour accomplir la tâche de transmettre des demandes et des réponses de service, trois types d'activités pour l'utilisateur expéditeur et trois types correspondants pour l'utilisateur récepteur sont définis. Du côté de l'utilisateur expéditeur, ils acceptent les demandes et les réponses de service à transmettre. Ensuite, ils sélectionnent le type de FAL APDU qui sera utilisé pour transmettre la demande ou la réponse et coder les paramètres de service sans sa portion du corps. Puis, ils soumettent de corps APDU codé à l'AR ASE pour le transport.

Du côté de l'utilisateur récepteur, ils reçoivent les corps APDU codés à partir de l'AR ASE. Ils décodent les corps APDU et extraient les paramètres de service qu'ils ont transmis. Pour conclure le transport, ils fournissent la demande ou la réponse de service à l'utilisateur. La Figure 10 représente ces concepts.



Anglais	Français
Service Parameters	Paramètres de service
service primitives	primitives de service
service user	utilisateur service
real object	objet réel
FAL ADPU Body	Corps FAL ADPU
FAL AE	Entité d'application de couche de bus de terrain (AE de FAL)
FAL APO ASE	ASE d'APO de la FAL
FAL AR ASE	ASE d'AR de la FAL
FAL	ASE
APDU's	de FAL

Figure 10 – Transmission des services d'ASE

4.3.6.5 Contexte de présentation de la couche FAL

Le contexte de présentation de l'environnement OSI permet de distinguer les APDU d'un ASE et d'un autre, et d'identifier les règles de syntaxe de transfert utilisées pour coder chaque APDU. Toutefois, l'architecture de communication des bus de terrain n'inclut pas la couche de présentation. Par conséquent, un autre mécanisme est fourni par la couche FAL par chacun des types particuliers de modèles de communication.

4.3.7 Relations entre applications

4.3.7.1 Définition de AR

Les AR représentent les canaux de communication entre les AP. Ils définissent la manière dont les informations sont communiquées entre les AP. Chaque AR est caractérisé par la manière dont il transmet les demandes et les réponses de service ASE d'un AP à un autre. Ces caractéristiques sont décrites ci-dessous.

4.3.7.2 Points d'extrémité AR

Les AR sont définis en tant qu'ensemble d'AP coopérant. L'AR ASE de chaque AP gère un point d'extrémité de l'AR, et gère son contexte local. Le contexte local d'un point d'extrémité de l'AR est utilisé par l'AR ASE pour contrôler le transport des APDU sur l'AR.

4.3.7.3 Classes de points d'extrémité AR

Les AR sont composés d'un ensemble de points d'extrémité de classes compatibles. Les classes de points d'extrémité AR sont utilisées pour représenter des points d'extrémité AR qui acheminent des APDU de la même manière. Par l'intermédiaire de la normalisation des classes de points d'extrémité, des AR pour différents modèles d'interaction peuvent être définis.

4.3.7.4 Cardinalité d'AR

Les AR caractérisent les canaux communications entre les AP. L'une des caractéristiques d'un AR est le nombre de points d'extrémité de l'AR. Les AR qui transmettent des services entre deux AP ont une cardinalité de 1:1. Ceux qui transmettent des services d'un AP à un certain nombre d'AP ont une cardinalité de 1:many (c'est-à-dire: un à plusieurs). Ceux qui transmettent des services de ou vers plusieurs AP ont une cardinalité de many-to-many (c'est-à-dire: plusieurs à plusieurs).

4.3.7.5 Accès aux objets par l'intermédiaire des AR

Les AR donnent accès aux AP et aux objets qu'ils contiennent par l'intermédiaire des services d'un ou plusieurs ASE. Par conséquent, une caractéristique est l'ensemble des services ASE qui peuvent être transmis vers et à partir de ces objets par l'AR. Les services qui peuvent être transmis par l'AR sont sélectionnés à partir de ceux définis pour l'AE.

4.3.7.6 Chemins de transport entre AR

Les AR sont modélisés en tant qu'un ou deux chemins de transport entre points d'extrémité des AR. Chaque chemin de transport transmet des APDU dans une direction entre un ou plusieurs points d'extrémité des AR. Chaque point d'extrémité de l'AR récepteur pour un chemin de transport reçoit tous les APDU émettant sur l'AR par le point d'extrémité de l'AR expéditeur.

4.3.7.7 Rôles AREP

Du fait que les AP interagissent les uns avec les autres par l'intermédiaire des points d'extrémité, un déterminant de base de leur compatibilité est le rôle qu'ils jouent dans l'AR. Le rôle définit comment un AREP interagit avec les autres AREP dans l'AR.

Par exemple, un AREP peut fonctionner en tant que client, serveur, publicateur ou abonné. Lorsqu'un AREP interagit avec un autre AREP sur un AR unique à la fois en tant que client et serveur, il est défini comme ayant le rôle d'un "homologue".

Certains rôles peuvent être capables de démarrer des demandes de service, tandis que d'autres peuvent limiter leur capacité à la simple réponse aux demandes de service. Cette partie de la définition d'un rôle identifie les exigences d'un AR pour qu'il soit capable de transmettre les demandes dans les deux directions, ou seulement dans une seule.

4.3.7.8 Tampons et files d'attente d'AREP

Les AREP peuvent être modélisés en tant que file d'attente ou de tampon. Les APDU transférés sur un AREP mis en file d'attente sont fournis dans l'ordre reçu pour le transport. Le transfert des APDU sur un AREP mis en mémoire tampon est différent. Dans ce cas, un APDU à transmettre par l'AR ASE est placé dans une mémoire tampon pour le transfert. Lorsque la couche DLL a accès au réseau, elle transmet le contenu de la mémoire tampon.

Lorsque l'AR ASE reçoit une autre demande de transport, il remplace le contenu précédent de la mémoire tampon qu'il ait été transmis ou non. Lorsqu'un APDU est écrit dans une mémoire tampon pour être transféré, il est conservé dans la mémoire tampon jusqu'à ce que l'APDU suivant à transmettre le remplace. Lorsqu'il se trouve en mémoire tampon, un APDU peut être lu plusieurs fois sans le supprimer de la mémoire tampon ou sans en changer le contenu.

A l'extrémité de réception, l'opération est similaire. Le point d'extrémité de réception place un APDU reçu dans une mémoire tampon pour que l'AR ASE puisse y accéder. Lorsqu'un APDU suivant est reçu, il remplace l'APDU précédent dans la mémoire tampon qu'il ait été lu ou non. La lecture de l'APDU à partir de la mémoire tampon n'est pas destructive — elle ne détruit pas ou ne change pas le contenu de la mémoire tampon, ce qui permet au contenu d'être lu à partir de la mémoire tampon une ou plusieurs fois.

4.3.7.9 Transport déclenché par l'utilisateur et planifié

Une autre caractéristique d'un AREP apparaît lorsqu'ils transmettent les demandes et les réponses de service. Les AREP qui les transmettent lors de la soumission par l'utilisateur sont nommés déclenchés par l'utilisateur. Leur transport est asynchrone par rapport au fonctionnement du réseau.

Les AREP qui transmettent les demandes et les réponses selon des intervalles prédéfinis, quel que soit le moment où ils sont reçus pour être transférés sont nommés planifiés. Les AREP planifiés peuvent être capables d'indiquer quand des données transférées ont été soumises en retard pour la transmission, ou lorsqu'elles ont été soumises dans les délais, mais transmises en retard.

4.3.7.10 Ponctualité des AREP

Les AREP transmettent les APDU entre applications à l'aide des services de la couche DLL. Lorsque les capacités de ponctualité sont définies pour un AREP et prises en charge par la couche DLL, l'AREP fait suivre les indicateurs de ponctualité fournis par la couche DLL. Ces indicateurs de ponctualité permettent aux abonnés des données publiées de déterminer si les données qu'ils reçoivent sont à jour ou "dépassées".


Pour prendre en charge ces types de ponctualité, l'AREP d'édition établit une connexion de la liaison de données du publicateur reflétant le type de ponctualité configuré pour lui par la gestion. Après l'établissement de la connexion, l'AREP reçoit les données de l'utilisateur et les envoie à la couche DLL pour transmission, où des procédures de ponctualité sont effectuées. Lorsque la couche DLL a la possibilité de transmettre les données, elle transmet l'état actuel de la ponctualité avec les données.

A l'AREP abonné, une connexion de liaison de données est ouverte pour recevoir les données publiées qui reflètent le type de ponctualité configuré pour lui par la gestion. La couche DLL calcule la ponctualité des données reçues, puis les fournit à l'AREP. Les données sont ensuite fournies à l'AP de l'utilisateur par l'intermédiaire de l'ASE approprié.

4.3.7.11 Définition et création des AREP

Les définitions d'AREP spécifient les instances des classes AREP. Les AREP peuvent être prédéfinis ou ils peuvent être définis en utilisant un service "create" si leur AE prend en charge cette capacité.

Les AREP peuvent être prédéfinis et préétablis ou peuvent être prédéfinis et établis en dynamique. La Figure 11 représente ces deux cas. Les AREP peuvent également exiger à la fois la définition et l'établissement dynamiques, ou être définis de façon dynamique de telle sorte qu'ils puissent être utilisés sans aucun établissement (ils sont définis dans un état établi).



Anglais	Français
defined, but not established	défini, mais pas établi
Established AR	AR établi

Figure 11 – AREP définis et établis

4.3.7.12 Etablissement et arrêt des AR

Les AR peuvent être établis soit avant la phase opérationnelle de l'AP ou pendant son fonctionnement. Lorsqu'il est établi lors du fonctionnement d'un AP, l'AR est établi par l'intermédiaire de l'échange des AR APDU.

Lorsqu'un AR a été établi, il peut être arrêté normalement ou être abandonné, selon les capacités de l'AR.

4.4 Désignation et adressage de la couche Application de bus de terrain

4.4.1 Généralités

Les principes définis dans l'ISO 7498-3 qui implique l'identification (désignation) et l'emplacement (adressage) APO référencés par l'intermédiaire de la couche Application de bus de terrain sont détaillés en 4.4.

La manière dont les noms et les identificateurs numériques sont utilisés pour identifier les APO accessibles par l'intermédiaire de la couche FAL est détaillée en 4.4. Le paragraphe 4.4 indique également comment les adresses des couches sous-jacentes sont utilisées pour localiser les AP dans l'environnement du bus de terrain.

4.4.2 Identification des objets accessibles par l'intermédiaire de la couche FAL

4.4.2.1 Généralités

Les APO accessibles par l'intermédiaire de la couche FAL sont identifiés indépendamment de leur emplacement. C'est-à-dire que si l'emplacement de l'AP qui contient l'APO change, l'APO peut toujours être référencé en utilisant le même ensemble d'identificateurs.

Les identificateurs pour les AP et les APO au sein de la couche FAL sont définis comme les attributs clés dans les définitions de classe pour les APO. Au sein de ces définitions d'APO, deux types d'attributs clés sont couramment utilisés, les noms et les identificateurs numériques.

La Figure 12 représente un AP qui communique par l'intermédiaire du FAL AE. L'AP représente ses objets réels internes comme des APO pour un accès distant à ceux-ci. Deux ASE sont représentés, qui fournissent à leurs APO connexes les services d'accès à distance. L'AR ASE contient un AREP unique qui transmet les demandes et les réponses de service pour les ASE à un ou plusieurs AREP distants situés dans des AP distants.

4.6 Procédure de service FAL

4.6.1 Procédures de service confirmé FAL

L'utilisateur demandeur soumet une primitive de demande de service confirmé à sa couche FAL. L'élément ASE de la couche FAL génère le corps APDU de la demande de service confirmé associée et la transmet sur l'AR spécifié.

A la réception du corps APDU de la demande de service confirmé, l'ASE qui répond le décode. Si aucune erreur de protocole ne s'est produite, l'ASE envoie une primitive indication de service confirmé à son utilisateur.

Si l'utilisateur qui répond est capable de traiter la demande avec succès, il retourne une primitive (+) de réponse de service confirmé.

Si l'utilisateur qui répond n'est pas capable de traiter la demande avec succès, le service échoue et l'utilisateur émet une primitive (-) de réponse de service confirmé qui en indique le motif.

L'ASE qui répond génère un corps APDU de réponse de service confirmé pour une primitive (+) de réponse de service confirmé ou un corps APDU d'erreur de service confirmé pour une primitive (-) de réponse de service confirmé et le transmet sur l'AR spécifié.

A la réception du corps APDU retourné, l'ASE initiateur fournit une primitive de confirmation de service confirmé à son utilisateur qui indique le succès ou l'échec, ainsi que le motif de l'échec le cas échéant.

4.6.2 Procédures de service non confirmé FAL

L'utilisateur demandeur soumet une primitive de demande de service non confirmé à l'entité AE de sa couche FAL. L'élément ASE de la couche FAL génère le corps APDU de la demande de service non confirmé associée et la transmet sur l'AR spécifié.

A la réception d'un corps APDU de demande de service non confirmé, les ASE récepteurs qui participent à l'AR fournissent la primitive d'indication de service non confirmé appropriée à son utilisateur. Les paramètres de ponctualité sont inclus dans la primitive d'indication si l'AR qui a transmis le corps APDU prend en charge la ponctualité.

4.7 Attributs FAL courants

Dans les spécifications des classes FAL qui suivent, un grand nombre de classes utilisent les attributs suivants. Par conséquent, ces attributs sont définis ici au lieu de l'être avec les autres attributs pour chacune des classes, excepté pour la classe du type de données.

ATTRIBUTS:

- 1 (o) Attribut clé: Identificateur numérique
- 2 (o) Attribut clé: Name (Nom)
- 3 (o) Attribut: Description d'utilisateur
- 4 (o) Attribut: Révision de l'objet

1) Identificateur numérique

Cet attribut clé facultatif spécifie l'identificateur numérique de l'objet. Il est utilisé comme une référence abrégée par le protocole de la couche FAL pour identifier l'objet. Il existe trois possibilités pour les besoins de l'identification: l'identificateur numérique, le nom ou les deux. Cet attribut est exigé pour le modèle de type de données.

2) Name (Nom)

Cet attribut clé facultatif spécifie le nom de l'objet. Il existe trois possibilités pour l'identification: un identificateur numérique ou un nom ou les deux.

3) Description d'utilisateur

Cet attribut facultatif contient des informations descriptives fournies par l'utilisateur concernant l'objet.

4) Révision de l'objet

Cet attribut facultatif spécifie le niveau de révision de l'objet. C'est un attribut structuré composé des numéros des révisions majeures et mineures. Si la révision de l'objet est prise en charge, il contient à la fois une révision majeure et une révision mineure avec une plage de valeurs de 0 à 15 pour chacune. L'utilisation des champs majeur/mineur est destinée à fournir les fonctions suivantes:

– Major revision

Le champ révision majeure contient la valeur de révision majeure de l'objet. Un changement de révision majeure indique que l'interopérabilité est affectée par le changement.

– Minor revision

Le champ révision mineure contient la valeur de révision mineure de l'objet. Un changement de révision mineure indique que l'interopérabilité n'a pas été affectée par le changement -- c'est-à-dire que les utilisateurs de l'objet seront toujours en mesure d'interopérer avec l'objet lorsque sa révision mineure aura changé, dans la mesure où la révision majeure reste la même.

4.8 Paramètres communs aux services de la FAL

Dans les spécifications des services FAL qui suivent, un grand nombre de services utilisent les paramètres suivants. Par conséquent, ils sont définis ici au lieu de l'être avec les autres paramètres pour chacun des services.

– Point d'extrémité d'une relation d'applications

Ce paramètre contient des informations suffisantes pour identifier localement l'AREP devant être utilisé pour acheminer le service: Ce paramètre peut utiliser un attribut clé de l'AREP pour identifier la relation entre applications. Lorsqu'un AREP prend en charge plusieurs contextes (établis en utilisant le service de lancement) en même temps, le paramètre AREP est étendu pour identifier le contexte ainsi que l'AREP.

– ID appel

Ce paramètre identifie cette invocation du service. Il est utilisé pour associer des demandes à des réponses. Par conséquent, deux quelconques invocations de services en cours ne peuvent pas être identifiées par la même valeur d'ID d'invocation.

– Classe FAL ASE/FAL

Ce paramètre spécifie l'élément ASE de la couche FAL (par exemple AP, AR, Variable, Type de données, Événement, Invocation de fonctions, Région de charge) et la classe FAL au sein de l'ASE (par exemple AREP, Liste de variables, Notificateur, Action).

– ID numérique

Ce paramètre est l'identificateur numérique de l'objet.

– Info. erreur

Ce paramètre donne des informations d'erreur pour les erreurs de service. Il est renvoyé dans les primitives (-) de réponse de service confirmé. Il se compose des éléments suivants:

- Classe d'erreurs

Ce paramètre indique la classe générale d'erreur. Les valeurs valides sont spécifiées dans la définition du paramètre Code d'erreur, ci-dessous.

- Code d'erreur

Ce paramètre identifie l'erreur de service spécifique.

- Code supplémentaire

Ce paramètre facultatif identifie l'erreur qui s'est produite lors du traitement de la demande spécifique à l'objet auquel l'accès est effectué. Lorsqu'il est utilisé, la valeur présentée dans la primitive "response" est délivrée inchangée dans la primitive "confirmation".

- Informations supplémentaires

Ce paramètre facultatif contient les données d'utilisateur qui accompagnent la réponse négative. Lorsqu'il est utilisé, la valeur présentée dans la primitive "response" est délivrée inchangée dans la primitive "confirmation".

4.9 Taille APDU

La taille APDU dépend du modèle de communication.

5 Spécification du modèle de communication de type 4

5.1 Concepts

5.1.1 Vue d'ensemble

Les principes de ce modèle reposent essentiellement sur les concepts communs avec quelques exceptions. Le principe de base décrit du paragraphe 4.2.2.1 au paragraphe 4.2.2.3 s'applique à l'Article 5. Ce type prend en charge la fonctionnalité de passerelle au sein de la couche application. Une partie peut également être reconnue à partir des concepts communs. Toutefois, pour encourager la lisibilité, certains éléments de l'Article 4 sont répétés dans l'Article 5.

5.1.2 Entités d'application

5.1.2.1 Définition de FAL AE

Un FAL AE fournit un ensemble de services qui permettent les communications entre AP dans un environnement du bus de terrain. Ces services permettent à une application utilisateur d'un client d'accéder aux objets utilisateur d'un serveur.

La fonctionnalité du FAL AE peut être répartie en deux groupes.

Relation d'application (AR). La fonctionnalité AR est responsable de l'organisation du transport des APDU via le réseau.


Accès variable (VA). La fonctionnalité d'accès variable est responsable du codage et de l'encodage des APDU. Dans un serveur le VA transporte également les données directement vers / à partir des objets utilisateur. Cette opération est réalisée en local et est en dehors du domaine d'application de la présente norme.

5.1.2.2 Services de la FAL

Les services offerts par le FAL AE à l'application utilisateur sont appelés Services de la FAL. Les services pour l'AR sont appelés services AR ASE et les services pour l'accès variable sont nommés services de point d'extrémité de chemin ASE (services REP ASE).

Les services de la FAL donnent accès aux objets AR locaux et assurent le transport des demandes et des réponses pour accéder aux objets réels modélisés en tant qu'objets FAL accessibles. La couche FAL fournit à la fois des services confirmés et non confirmés. Les demandes de service sont transmises à l'AP qui contient l'objet réel.

La Figure 13 représente le FAL AE et les relations d'architecture.



Anglais	Français
User Application	Application utilisateur
ASE Service Primitives	Primitives de service ASE
REP ASE Service Primitives	Primitives de service REP ASE
AR ASE Service Primitives	Primitives de service AR ASE
Conveyance of APDUs by the AR ASE	Acheminement d'unités de données de protocole application par l'AR ASE
DL layer.	Couche DL.

Figure 13 – FAL AE

5.1.2.3 Elément de service application d'une relation d'applications (ASE d'AR)

Pour prendre en charge l'accès à l'AP distant, l'ASE de relations entre applications est défini. Il fournit des services à l'AP pour accéder aux paramètres associés à la communication, ainsi que des services au REP ASE pour transmettre des demandes et des réponses de service.

L'AR ASE fournit les services aux points d'extrémité des AR (AREP).

5.1.2.4 REP ASE

Le REP ASE fournit un ensemble de services utilisés pour lire et écrire les attributs visibles du réseau des objets de variable et leurs données d'application. Dans la mesure où un seul type ASE est utilisé à distance, le type est implicite et non transféré.

5.1.2.5 Transport et passerelle des services FAL

Les FAL AE fournissent des services pour transmettre les demandes et les réponses entre les applications utilisateur et les objets de variable incluant la fonctionnalité de passerelle.

Dans un système distribué, les procédés d'application communiquent les uns avec les autres en échangeant des messages de couche application. L'AR est défini pour prendre en charge l'échange à la demande des services confirmés et non confirmés entre deux procédés d'application. Les services de liaison de données sans connexion sont utilisés pour les échanges. Les transferts de la couche DLL peuvent être acquittés ou non acquittés.

5.1.2.6 Relations entre applications

5.1.2.6.1 Définition de AR

L'AR est responsable de transmettre des messages entre applications. Les messages qui sont acheminés sont des demandes et des réponses de services de la couche FAL. Chaque demande et réponse de service est soumise à l'AR ASE pour le transfert. Au sein de l'AR il n'existe qu'un type d'objet, le point d'extrémité AR (AREP).

5.1.2.6.2 Points d'extrémité AR

Un point d'extrémité AR (AREP) représente un point d'accès de service à un DLE au sein de l'AE. Le service d'envoi AR transmet les APDU et les informations relatives au chemin vers l'AREP et implicitement au DLE. L'AREP est un objet de gestion de système présentant les paramètres configurables de l'utilisateur au DLE associé.

Ce type n'a pas de services de gestion de système spéciaux, car les attributs des objets AREP sont déclarés en tant qu'objets de variable par l'application utilisateur. Cela rend le réseau d'attributs visible. Les services AR Get Attribute et AR Set Attribute sont utilisés par ces objets de variable pour accéder aux valeurs des attributs.

Lorsqu'un AREP reçoit un APDU à partir de son DLE (déclenché par l'utilisateur) il transmet l'APDU au REP ASE ou à un AREP (passerelle).

5.1.3 Passerelle et routage

5.1.3.1 Vue d'ensemble

Ce type prend en charge la fonctionnalité de passerelle. Pour identifier la destination d'une demande, une description de chemin est utilisée. Cette description de chemin contenant une liste complète de points à transmettre est envoyée avec la demande. Sur son itinéraire de destination, le chemin évolue de manière à toujours contenir le chemin de retour vers le demandeur et le chemin vers la destination. Les éléments du chemin sont les adresses de point d'extrémité et de DL.

5.1.3.2 Point d'extrémité de chemin (Route End Point)

Au sein du REP ASE, les objets point d'extrémité de chemin (REP) représentent des points d'extrémité, contenant une description de chemin. Un REP représente le point de départ pour transmettre un message. Un REP représente également la destination de l'APDU.

5.1.3.3 Identification des points d'extrémité

Les points d'extrémité sont identifiés par des adresses de point d'extrémité. Ces adresses EP sont des adresses numériques, prises au sein d'un AE à partir du même espace de nom de nombres, pour obtenir une identification unique. Ces adresses EP sont utilisées pour identifier les AREP et les REP.

5.1.3.4 Adresses DL

Le DLE est identifié à partir de la liaison par une adresse DL. Les adresses DL sont définies dans l'IEC 61158-4-4, mais comme elles font partie du chemin, elles sont mentionnées ici. Il existe une relation bi-univoque entre l'adresse DL d'un DLE et l'adresse de point d'extrémité de l'AREP correspondant.

5.1.3.5 Chemin

Le chemin complet contient un chemin de destination et un chemin de départ

Le chemin de destination décrit comment atteindre le REP de destination. C'est une séquence d'adresses de point d'extrémité et d'adresses DL. Sur son itinéraire de destination, le premier élément indique toujours l'adresse du DLE, de l'AREP ou du REP de réception.

De la même manière, le chemin de départ décrit comment retrouver le chemin vers le point d'extrémité qui est à l'origine de la demande. C'est une séquence d'adresses de point d'extrémité et d'adresses DL. Sur son itinéraire de destination, le premier élément indique toujours l'adresse du DLE, de l'AREP ou du REP d'émission.

5.1.3.6 Conversion de chemin Destination / départ

Un chemin de destination transmis par un REP démarre par l'adresse de point d'extrémité de l'AREP local. L'élément suivant est l'adresse DL du DLE de réception. Si le chemin traverse des passerelles, une paire d'adresses doit être ajoutée pour chaque passerelle: une adresse DL et une adresse AREP. L'adresse finale est l'adresse de point d'extrémité du REP de destination. L'adresse de départ est l'adresse de point d'extrémité du REP de départ.

Le service d'envoi AR supprime le premier élément du chemin de destination. Le DLE insère sa propre adresse DL avant le chemin de départ actuel avant de transmettre la demande à la liaison.


Lorsqu'un DLE reçoit une indication à partir de la liaison, il supprime le premier élément du chemin de destination (sa propre adresse DL). L'AREP correspondant insère sa propre adresse AREP avant le chemin de départ actuel avant de transmettre la demande à un REP ou un AREP.

Au REP de destination, le chemin de destination contient l'adresse de point d'extrémité du REP, et le chemin de départ contient le chemin complet de retour vers le REP demandeur.

Si des erreurs apparaissent lorsqu'une demande est en route vers la destination, le chemin de départ actuel peut être utilisé pour retourner une réponse d'erreur.

5.1.4 Résumé de l'architecture

Un résumé de l'architecture FAL est donné à la Figure 14, qui représente les principaux composants de l'architecture FAL et la manière dont ils se relient les uns aux autres.



Anglais	Français
Client	Client
Gateway	Passerelle
Server	Serveur
User Request	Demande utilisateur
EP (address)	EP (adresse)
DL address	Adresse DL
Gateway	Passerelle

Figure 14 – Résumé de l'architecture FAL

5.1.5 Procédures de service FAL et diagrammes de séquence temporelle

5.1.5.1 Vue d'ensemble

Le paragraphe 5.1.5 décrit les procédures de service pour les services FAL confirmés et non confirmés. Une présentation des procédures de service FAL est donnée à la Figure 15.