

# INTERNATIONAL STANDARD



Fibre optic communication subsystem test procedures –  
Part 1-3: General communication subsystems – ~~Central wavelength and spectral  
width measurement~~ Measurement of central wavelength, spectral width and  
additional spectral characteristics

IECNORM.COM : Click to view the full PDF of IEC 61280-1-3:2021 RLV



**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2021 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

**About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

**About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

**IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)**

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

**IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)**

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

**IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)**

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

**IEC online collection - [oc.iec.ch](http://oc.iec.ch)**

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

**Electropedia - [www.electropedia.org](http://www.electropedia.org)**

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IECNORM.COM : Click to view the full PDF of IEC 61281-3:2021 PLV

# INTERNATIONAL STANDARD



Fibre optic communication subsystem test procedures –  
Part 1-3: General communication subsystems – ~~Central wavelength and spectral  
width measurement~~ Measurement of central wavelength, spectral width and  
additional spectral characteristics

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

ICS 33.180.01

ISBN 978-2-8322-1000-5

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD	4
1 Scope	6
2 Normative references	6
3 Terms, definitions and abbreviated terms	6
3.1 Wavelength	6
3.2 Spectral width	7
3.3 Additional spectral characteristics	7
3.4 Abbreviated terms	8
4 Apparatus	8
4.1 Calibrated optical spectrum analyzer (OSA)	8
4.2 Calibrated optical wavelength meter (OWM)	8
4.3 Power supplies	9
4.4 Input signal source or modulator	9
4.5 Test cord	9
5 Test sample	9
6 Procedure (method A)	9
6.1 General	9
6.2 Setup	10
6.3 Adjustment of spectrum analyzer controls	10
6.4 Setting of optical wavelength meter	11
7 Procedure (method B)	11
7.1 Setup	11
7.2 Adjustment of spectrum analyzer controls	11
7.3 Setting of optical wavelength meter	12
7.4 Continuous LED and SLM spectra	12
7.5 Discrete MLM spectra	12
7.6 <del>Continuous</del> SLM spectra	13
8 Calculation	13
8.1 General	13
8.2 Centre wavelength	13
8.2.1 Continuous LED spectra	13
8.2.2 Discrete MLM spectra	13
8.3 Centroidal wavelength	13
8.4 Peak wavelength	14
8.4.1 Continuous LED and SLM spectra	14
8.4.2 Discrete MLM spectra	14
8.5 RMS spectral width ( $\Delta\lambda_{\text{RMS}}$ )	14
8.6 $n$ -dB-down spectral width ( $\Delta\lambda_{n\text{-dB}}$ )	14
8.7 Full-width at half-maximum spectral width ( $\Delta\lambda_{\text{fwhm}}$ )	15
8.7.1 Continuous LED spectra	15
8.7.2 Discrete MLM spectra	15
8.8 Side-mode suppression ratio (SMSR)	15
8.9 Signal-to-source spontaneous emission ratio (SSER)	15
9 Test results	15
9.1 Required information	15

9.2 Information to be available on request ..... 16

10 Examples of results ..... 16

Bibliography..... 21

Figure 1 – Example of a LED optical spectrum..... 16

Figure 2 – Typical spectrum analyzer output for MLM laser..... 18

Figure 3 –  $\Delta\lambda_{\text{fwhm}}$  spectral width measurement for MLM laser..... 18

Figure 4 –  $\Delta\lambda_{\text{fwhm}}$  spectral width calculation for MLM laser ..... 19

Figure 5 – Peak emission wavelength and  $\Delta\lambda_{30\text{-dB}}$  measurement for SLM laser..... 19

Figure 6 – Resolution bandwidth (RBW) dependence of SMSR for SLM laser ..... 20

Figure 7 – Signal-to-source spontaneous emission ratio measurement for SLM laser..... 20

Table 1 – Measurement points for LED spectrum from Figure 1 ..... 17

Table 2 – RMS spectral characterization..... 17

IECNORM.COM : Click to view the full PDF of IEC 61280-1-3:2021 RLV

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## FIBRE OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

**Part 1-3: General communication subsystems – ~~Central wavelength and spectral width measurement~~ Measurement of central wavelength, spectral width and additional spectral characteristics**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 61280-1-3:2010. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.**

IEC 61280-1-3 has been prepared by subcommittee 86C: Fibre optic systems and active devices, of IEC technical committee 86: Fibre optics. It is an International Standard.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) addition of measurement of signal-to-source spontaneous emission ratio in 8.9;
- b) change of document title to reflect the additional measurement;
- c) additional information on the resolution bandwidth used in the measurement of the side-mode suppression ratio in 8.8;
- d) use of a calibrated optical wavelength meter for accurate wavelength measurements of single-longitudinal mode lasers.

The text of this International Standard is based on the following documents:

Draft	Report on voting
86C/1701/CDV	86C/1717/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

A list of all parts in the IEC 61280 series, published under the general title *Fibre optic communication subsystem test procedures*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## FIBRE OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

### Part 1-3: General communication subsystems – ~~Central wavelength and spectral width measurement~~ Measurement of central wavelength, spectral width and additional spectral characteristics

#### 1 Scope

This part of IEC 61280 provides definitions and measurement procedures for several wavelength and spectral width properties of an optical spectrum associated with a fibre optic communication subsystem, an optical transmitter, or other light sources used in the operation or test of communication subsystems. This document also provides definitions and measurement procedures for side-mode suppression ratio and signal-to-source spontaneous emission ratio.

The measurement is done for the purpose of system construction and/or maintenance. In the case of communication subsystem signals, the optical transmitter is typically under modulation.

NOTE Different properties ~~may~~ can be appropriate to different spectral types, such as continuous spectra characteristics of light-emitting diodes (LEDs), as well as multilongitudinal-mode (MLM), multitransverse-mode (MTM) and single-longitudinal mode (SLM) spectra, which are characteristic of laser diodes (LDs).

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60825-1, *Safety of laser products – Part 1: Equipment classification and requirements*

IEC 62129-1, *Calibration of wavelength/optical frequency measurement instruments – Part 1: Optical spectrum analyzers*

IEC 62129-2, *Calibration of wavelength/optical frequency measurement instruments – Part 2: Michelson interferometer single wavelength meters*

#### 3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms, definitions and abbreviated terms apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

##### 3.1 Wavelength

NOTE The following wavelength terms provide quantitative definitions for the description of the central wavelength of a spectrum. In this document, "central wavelength" is a general category label for these terms.

### 3.1.1 centre wavelength

 $\lambda_0$ 

mean of the closest spaced half-power wavelengths in an optical spectrum, one above and one below the peak wavelength

Note 1 to entry: Centre wavelength is also called “half-power mid-point”.

### 3.1.2 half-power wavelength

 $\lambda_{3dB}$ 

wavelength corresponding to a half-peak power value of the optical spectrum

### 3.1.3 peak wavelength

 $\lambda_p$ 

wavelength corresponding to the maximum power value of the optical spectrum

### 3.1.4 centroidal wavelength

 $\lambda_c$ 

mean or average wavelength of an optical spectrum

## 3.2 Spectral width

### 3.2.1 RMS spectral width

 $\Delta\lambda_{rms}$ 

square root of the second moment of the power distribution about the centroidal wavelength

### 3.2.2 $n$ -dB-down spectral width

 $\Delta\lambda_{n-dB}$ 

positive difference of the closest spaced wavelengths, one above and one below the peak wavelength  $\lambda_p$ , at which the spectral power density determined in a specified resolution bandwidth is  $n$  dB down from its peak value

### 3.2.3 full-width at half-maximum

 $\Delta\lambda_{fwhm}$ 

~~a special case of  $n$ -dB-down width with  $n = 3$~~

positive difference of the closest spaced wavelengths, one above and one below the peak wavelength  $\lambda_p$ , at which the spectral power density determined in a specified resolution bandwidth is 3 dB down from its peak value

## 3.3 Additional spectral characteristics

### 3.3.1 side-mode suppression ratio SMSR

ratio of the largest peak of the optical spectrum to the second largest peak under non-modulated (continuous wave) operating condition, which is determined in a specified wavelength resolution bandwidth (RBW), for a nominally single-longitudinal mode (SLM) spectrum

Note 1 to entry: See 8.8.

**3.3.2****signal-to-source spontaneous emission ratio****SSER**

ratio between the signal power and maximum source spontaneous emission (SSE) power under the non-modulated (CW) condition which is determined in a specified bandwidth

**3.4 Abbreviated terms**

CW	continuous wave
DFB	distributed feedback
ESD	electrostatic discharge
InGaAsP	indium gallium arsenide phosphide
LD	laser diode
LED	light-emitting diode
MLM	multi-longitudinal mode
MTM	multi-transverse mode
OSA	optical spectrum analyzer
OWM	optical wavelength meter
RBW	resolution bandwidth
RMS	root-mean-square
SLM	single-longitudinal mode
SMSR	side-mode suppression ratio
SSE	source spontaneous emission
SSER	signal-to-source spontaneous emission ratio
TLA	tuneable laser assembly
VCSEL	vertical cavity surface emitting lasers
WDM	wavelength-division multiplexing

**4 Apparatus****4.1 Calibrated optical spectrum analyzer (OSA)**

This special-purpose test equipment uses a dispersive spectrophotometric method to resolve and record the optical spectral distribution. The required wavelength resolution **bandwidth** and range depend on the type and variety of signals to be measured. Generally, LED sources have wide spectra with little structure, so a range of at least 200 nm and resolution **bandwidth** of 1 nm or narrower are recommended. Laser sources have much narrower spectra and **may** can be used in wavelength-**domain** division multiplexing (WDM) applications, where more accurate determination of the wavelength is required. A **wavelength** resolution bandwidth of 0,1 nm or narrower is recommended, and the actual requirement is determined by the application. In any case, the sensitivity and wavelength range of the spectrum analyzer shall be sufficient to measure all of the spectrum within at least –20 dB from the peak power. For measurement of SMSR, a larger dynamic range is typically required.

OSA equipment shall be calibrated for vacuum wavelengths in **accordance** order to be consistent with the calibration processes and results of IEC 62129-1. The equipment used shall have a valid calibration certificate, in accordance with the applicable quality system for the period over which the testing is done.

**4.2 Calibrated optical wavelength meter (OWM)**

For central wavelength measurements of SLM lasers, such as distributed feedback (DFB) lasers or tuneable laser assemblies (TLAs) for dense WDM applications, sufficient

measurement accuracy is required. In this case, an optical wavelength meter based on interferometric spectroscopy can be used. The accuracy of the central wavelength measurement is generally specified for non-modulated (CW) lasers. When the SLM laser is modulated, the uncertainty of the central wavelength measurement increases with the increasing modulation frequency or symbol rate.

OWM equipment shall be calibrated in accordance with IEC 62129-2. The equipment used shall have a valid calibration certificate, in accordance with the applicable quality system for the period over which the testing is done.

#### 4.3 Power supplies

As required for the device under test.

#### 4.4 Input signal source or modulator

The input signal source is a signal generator or modulator with the appropriate digital or analogue signal of the system.

#### 4.5 Test cord

Unless otherwise specified, the physical and optical properties of the test cords shall match the cable plant with which the equipment is intended to operate. The cords shall be 2 m to 5 m long and shall contain fibres with coatings which remove cladding light. Appropriate connectors shall be used. Single-mode cords shall be deployed with two 90 mm diameter loops or otherwise assure rejection of cladding modes. If the equipment is intended for multimode operation and the intended cable plant is unknown, the fibre size shall be 50/125 µm.

### 5 Test sample

The test sample shall be a specified fibre optic subsystem, transmitter, or light source. The system inputs and outputs shall be those normally seen by the user. The spectral width parameters are typically used for characterizing MLM and LED transmitters. The widths of MTM and SLM lasers without modulation are normally too narrow to measure with the dispersive spectral instruments used with this method. Modulated SLM transmitters have broadened linewidths for high data rates (above about 2,5 Gb/s) caused by chirp that ~~may~~ can be measurable by this method.

~~**WARNING** – Exercise care to avoid possible eye damage from looking into the end of an energized fibre from any light source. Most importantly, avoid looking into any energized fibre using any type of magnification device.~~

~~The requirements in IEC 60825-1 shall be followed.~~

Because of the potential for hazardous radiation, conditions of laser safety shall be established and maintained. Refer to IEC 60825-1.

### 6 Procedure (method A)

#### 6.1 General

Method A is designed for the use of typical commercial optical spectrum analyzer instruments that allow quick measurement of spectra with 1 000 wavelength samples or more and allow for the analysis of such spectra based on all of the samples, rather than selecting for example only the samples at the peaks of mode wavelengths. The previous method using a smaller number of discrete wavelength points is included in Clause 7 as method B, for compatibility with the first edition of this document. Method A has the advantage of easier, simpler

automated analysis and better representation of complex but narrow spectra, such as multi-transverse-mode vertical cavity surface emitting lasers (VCSELs). Due to its convenience and prevalence in the industry, method A is considered the reference test method.

For measurements of the central wavelength of SLM lasers, a commercial optical wavelength meter can also be used. These instruments typically allow the user to specify whether the optical signal is a continuous wave (CW) signal or a modulated communication signal. An appropriate mode should be selected according to the condition of the light signal under test. In the case of modulated SLM lasers, the uncertainty of the central wavelength measurement typically increases with increasing modulation frequency or symbol rate.

## 6.2 Setup

**6.2.1** Use appropriate handling procedures to prevent damage from electrostatic discharge (ESD), which can cause opto-electronic devices to fail.

**6.2.2** With the exception of ambient temperature, standard ambient conditions shall be used, unless otherwise specified. The ambient or reference point temperature shall be  $23\text{ °C} \pm 2\text{ °C}$ , unless otherwise specified.

**6.2.3** Unless otherwise specified, apply a modulated input signal to the optical source. Allow sufficient time (according to the manufacturer's recommendation or as specified in the detail specification) for the optical source/transmitter to reach a steady-state temperature.

**6.2.4** Turn the optical spectrum-analyzer measuring instruments, such as the OSA or the OWM, on and allow the recommended warm-up and settling time to achieve the rated measurement performance level.

**6.2.5** Connect the optical output of the optical source under test to the optical input connector of the optical spectrum-analyzer measuring instrument. If the transmitter under test does not include isolation from back-reflections, as often the case at 850 nm, these reflections can cause the spectrum to be unstable and should be reduced with high return-loss connections and possibly external isolation or attenuation at the transmitter output.

## 6.3 Adjustment of spectrum analyzer controls

**6.3.1** Using the resolution bandwidth control, select an appropriate resolution bandwidth (see 4.1). Typically, less than 1/10 of the spectral width to be measured or the finest available resolution bandwidth (0,1 nm or narrower) should be used. Set the number of data points in the acquired signal to be sure to adequately sample the detail of the optical spectrum. Typically, this is set to at least four times the sample resolution times the total measured width. For example, a 10 nm measurement span using 0,1 nm resolution bandwidth requires a minimum of 400 points in the measurement, which is given by four times the total measurement span divided by the resolution bandwidth.

**6.3.2** Using the span control, select an appropriate span of wavelength range on the display section of the spectrum analyzer. Initially, select a sufficiently wide span to determine the appropriate position of the peak wavelength; then reduce and adjust the span again to fit all of the source spectrum or at least all that is within at least 20 dB of the peak power. For SLM lasers, the span may need to be changed, typically from 2 nm to 20 nm full scale, to determine the spectral width and SMSR.

**6.3.3** Using the gain or reference level control, select a gain or reference level so that the amplitude of the peak output extends over the entire screen vertical scale.

**6.3.4** If available, use the spectrum analyzer log-scale for amplitude measurement to achieve the maximum dynamic range

**6.3.5** For OSAs that are not capable of performing the subsequent calculations in Clause 8 internally, download the measured optical spectra data to a computer for further analysis in a format that contains both the wavelength and amplitude of all points in the measurement.

## **6.4 Setting of optical wavelength meter**

**6.4.1** The optical wavelength meter is implemented with a longitudinal mode detecting function. The appropriate parameters should be set, such as threshold from the peak and excursion from the peak.

**6.4.2** Generally, the optical wavelength meter is also implemented with a light signal condition setting function. The appropriate condition should be set, such as continuous wave (CW) or modulated signal.

## **7 Procedure (method B)**

### **7.1 Setup**

**7.1.1** Use appropriate handling procedures to prevent damage from electrostatic discharge (ESD), which can cause opto-electronic devices to fail.

**7.1.2** With the exception of ambient temperature, standard ambient conditions shall be used, unless otherwise specified. The ambient or reference point temperature shall be  $23\text{ °C} \pm 2\text{ °C}$ , unless otherwise specified.

**7.1.3** Unless otherwise specified, apply a modulated input signal to the optical source. Allow sufficient time (according to the manufacturer's recommendation or as specified in the detail specification) for the optical source/transmitter to reach a steady-state temperature.

**7.1.4** Turn the optical spectrum ~~analyzer~~ measuring instruments, such as the OSA or the OWM, on and allow the recommended warm-up and settling time to achieve the rated measurement performance level.

**7.1.5** Connect the optical output of the optical source under test to the optical input connector of the optical spectrum ~~analyzer~~ measuring instrument. If the transmitter under test does not include isolation from back-reflections, as is often the case at 850 nm, these reflections can cause the spectrum to be unstable and should be reduced with high return-loss connections and possibly external isolation or attenuation at the transmitter output.

### **7.2 Adjustment of spectrum analyzer controls**

**7.2.1** Using the resolution **bandwidth** control, select an appropriate resolution **bandwidth** (see 4.1).

**7.2.2** Using the span control, select an appropriate span of wavelength range on the display section of the spectrum analyzer. Initially, select the maximum span to obtain the appropriate position of the peak wavelength; then adjust the span again so that, at the selected gain, the smallest detectable output power level occupies the extreme edges of the screen horizontal scale. For SLM lasers, the span may need to be changed, typically from 2 nm to 20 nm full scale, to determine the spectral width and SMSR.

**7.2.3** Using the gain or reference level control, select a gain or reference level so that the amplitude of the peak output extends over the entire screen vertical scale. If available, use the spectrum analyzer log-scale for amplitude measurement to achieve the maximum dynamic range.

### 7.3 Setting of optical wavelength meter

**7.3.1** The optical wavelength meter is implemented with a longitudinal mode detecting function, and appropriate parameters should be set, such as threshold from the peak and excursion from the peak.

**7.3.2** Generally, the optical wavelength meter is also implemented with a light signal condition setting function, and the appropriate conditions should be set, such as continuous wave (CW) or modulated signal.

### 7.4 Continuous LED and SLM spectra

#### 7.4.1 General

**7.4.1** Refer to Figure 1 and Figure 5 for samples of LED and SLM-LD spectrum analyzer outputs. At the end of several single measurement sweeps, ensure that the output spectrum is stable (power variation at any wavelength is  $\leq 10\%$  or  $\sim 0,5$  dB between sweeps).

**7.4.2** Determine the peak wavelength,  $\lambda_p$ . (Most optical spectrum analyzers have a peak-search button that automatically performs this function.)

**7.4.3** For LEDs, record the two half-power wavelengths on both sides of the peak wavelength that are 3 dB down from the peak amplitude. Determine the number of points to record (minimum 11), the wavelength  $\lambda_i$ , and the amplitude  $p_i$  for each point  $i$  in the displayed spectrum as follows.

**7.4.4** On both sides of the peak, find the wavelengths closest to the peak, corresponding to the two points  $n$  dB down from the peak (see example in Figure 1), where  $n$  is typically 20.

**7.4.5** To find 11 equally spaced points, subtract these two wavelengths and divide the result by 10. This gives the spacing between points.

**7.4.6** Starting with the minimum wavelength as the first point, add the wavelength spacing to find the next point. Continue until 11 points are found (the 11<sup>th</sup> point should correspond to the maximum wavelength from 7.4.4). Record the wavelengths in Table 2, column 2.

**7.4.7** Find the output power (in dBm) corresponding to each wavelength point and record in Table 2, column 3.

**7.4.8** Convert the power in dBm to nanowatts (nW) using  $P(\text{nW}) = 10^{[0,1 P(\text{dBm}) + 6]}$  and record in Table 2, column 4.

### 7.5 Discrete MLM spectra

**7.5.1** At the end of a single measurement sweep, measure and record the wavelength and the amplitude, for all the modes displayed, in Table 2. The display at the end of the measurement sweep will determine the number of modes and the reference nominal wavelength for each mode. Refer to Figure 2 for a sample spectrum analyzer output.

**7.5.2** Measure and record the wavelength and the amplitude for each mode displayed for each of the 10 single measurement sweeps. Include modes at least  $n$  dB below the peak mode, where  $n$  is typically 20 to 25. For each mode at nominal wavelengths measured and recorded in 7.5.1, calculate the average of the 10 measured wavelengths and the corresponding average of the 10 amplitude readings. Record these average values in Table 2.

**7.5.3** Compare the readings of 7.5.1 and 7.5.2 for each mode. For any mode, if the difference in wavelength readings is more than 0,2 nm, or the difference in amplitude readings is more than 10 %, this indicates mode instability, and the calculations may not be accurate.

## 7.6 Continuous SLM spectra

**7.6.1** Measure and record the ~~amplitude~~ power ( $M_1$ ) at the peak wavelength and the ~~amplitude~~ power ( $M_2$ ) of the strongest side-mode under the non-modulated (CW) condition.

**7.6.2** Measure and record the two wavelengths on both sides of the peak wavelength that are  $n$  dB down from the peak amplitude, where  $n$  is typically 20 or 30.

**7.6.3** Measure and record the optical signal power ( $P_1$ ) and the maximum value ( $P_2$ ) of the optical power level of source spontaneous emission (SSE) under non-modulated (CW) operating condition. The SSE power level shall be determined over the entire wavelength range where the laser (TLA) can oscillate, with the exclusion of typically  $\pm 1$  nm around the optical signal wavelength (see Figure 7). The resolution bandwidth of OSA is usually set to 0,1 nm. The actual resolution bandwidth ( $B_r$ ) should be calibrated.

## 8 Calculation

### 8.1 General

Many optical spectrum analyzers calculate some or all the following parameters internally. Note that for method A, there will be  $N$  points corresponding to all the data points taken. Before beginning calculations, it is recommended that any power data points that are more than 20 dB (or another chosen and documented range) below the maximum power reading not be used in the calculations. This will especially prevent the user from overestimating the RMS spectral width. For method B, the total number of data points  $N$  will be the number of recorded mode peaks.

### 8.2 Centre wavelength

#### 8.2.1 Continuous LED spectra

This is the average of the half-power wavelengths determined from the result of 6.3.5 for method A or 7.4.3 for method B.

#### 8.2.2 Discrete MLM spectra

This is the average of the half-power wavelengths that can be determined as follows by interpolation, since the laser may not have modes at these wavelengths.

Connect the tip of each mode to the tips of adjacent modes as shown in Figure 3; draw a horizontal line 3 dB down from the peak power point. The two or more intersection points of the horizontal line with the tip-connecting lines define the half-power wavelengths. The average of the half-power wavelengths that are furthest separated is  $\lambda_0$ .

### 8.3 Centroidal wavelength

Using the wavelengths and corresponding linear power (nW) in Table 2 for method B or the result of 6.3.5 for method A, calculate the centroidal wavelength as follows:

$$\lambda_c = \left( \frac{1}{P_0} \right) \sum_{i=1}^N P_i \lambda_i \quad (1)$$

where

$\lambda_i$  is the wavelength of the  $i^{\text{th}}$  point;

$P_i$  is the power of the  $i^{\text{th}}$  point;

$P_0$  is the total power summed for all points: 
$$P_0 = \sum_{i=1}^N P_i$$

$N$  is the number of points.

Refer to Table 1 for a calculation example.

## 8.4 Peak wavelength

### 8.4.1 Continuous LED and SLM spectra

Use the value measured in 7.4.2 for method B or the wavelength of the maximum power in the spectrum of 6.3.5 for method A as the peak wavelength.

### 8.4.2 Discrete MLM spectra

The peak wavelength can be obtained directly from the wavelength corresponding to maximum power in the spectrum from 6.3.5 for method A or from Table 2 (log or linear scale), representing the average of 10 readings, by reading the wavelength corresponding to the peak power level for method B. If the maximum power occurs in more than one mode, take the average of the wavelength of all modes with the maximum power. Use the average value as the peak wavelength.

## 8.5 RMS spectral width ( $\Delta\lambda_{\text{rms}}$ )

Using the wavelengths and corresponding linear power (nW), in the spectrum from 6.3.5 for method A or from Table 2 (single or average values) for method B, calculate the RMS spectral width as:

$$\Delta\lambda_{\text{rms}} = \left[ \frac{1}{P_0} \sum_{i=1}^N P_i (\lambda_i - \lambda_c)^2 \right]^{\frac{1}{2}} \quad (2)$$

Refer to Table 1 for a calculation example. Note that  $\Delta\lambda_{\text{rms}}$  does not apply to SLM sources. As mentioned at the beginning of Clause 8, a documented method for limiting the range of the data points should be used, such as a cutoff of 20 dB from the peak power.

## 8.6 $n$ -dB-down spectral width ( $\Delta\lambda_{n\text{-dB}}$ )

The difference in wavelengths recorded in 7.5.2 for method B, or which are  $n$  dB below the peak in the spectrum from 6.3.5 from method A, is  $\Delta\lambda_{n\text{-dB}}$  (see Figure 5). This  $\Delta\lambda_{n\text{-dB}}$  applies to SLM lasers but does not apply to MLM lasers or to LEDs.

$n$ -dB-down spectral width depends on the resolution bandwidth of the OSA, because the main mode of SLM lasers, such as DFB-LDs and TLAs, is substantially narrower than the resolution bandwidth of an OSA. Therefore, information on the resolution bandwidth of the OSA that was used to measure the signal spectrum should be noted together with  $n$ -dB-down spectral width test result.

## 8.7 Full-width at half-maximum spectral width ( $\Delta\lambda_{\text{fwhm}}$ )

### 8.7.1 Continuous LED spectra

The difference of the half-power wavelengths recorded in 7.4.3 from method B or determined from the spectra of 6.3.5 for method A is  $\Delta\lambda_{\text{fwhm}}$ .

### 8.7.2 Discrete MLM spectra

This is the difference of the half-power wavelengths that can be determined as follows by interpolation, since the laser may not have modes at these wavelengths.

Connect the tip of each mode to the tips of adjacent modes, as shown in the examples of Figure 3 and Figure 4, and draw a horizontal line 3 dB down from the peak power point. The two or more intersection points between these lines define the half-power wavelengths. The maximum difference in half-power wavelengths is  $\Delta\lambda_{\text{fwhm}}$ .

NOTE The procedure of 8.7.2 uses interpolation based on a segmented linear fit. In many cases, the spectrum can also be well represented by a Gaussian fit. In this case, the FWHM spectral width can also be calculated on the basis of the RMS spectral width. For a Gaussian distribution,  $\Delta\lambda_{\text{fwhm}} = 2,355 \times \Delta\lambda_{\text{rms}}$ .

## 8.8 Side-mode suppression ratio (SMSR)

From the power of the highest signal peak of an SLM,  $M_1$ , and the power of the highest side-mode,  $M_2$ , as determined in 7.6.1 from method B or from the spectrum of 6.3.5 from method A, calculate the side-mode suppression ratio ( $R_{\text{SMS}}$  in dB) as:

$$R_{\text{SMS}} = 10 \log_{10} \left( \frac{M_1}{M_2} \right) \quad (3)$$

Typically, the side modes of non-modulated (CW) SLM lasers, such as DFB-LDs and TLAs, exhibit a linewidth that is substantially narrower than the resolution bandwidth of an OSA. However, due to the influence of spontaneous light emission and narrow mode spacing, the power of the highest side mode,  $M_2$ , depends on the resolution bandwidth of the OSA that is used when the spectra are measured. Therefore, the side-mode suppression ratios measured with different resolution bandwidths can differ significantly (see Figure 6). Information on the resolution bandwidth of the OSA, which was used to measure the signal spectrum, should be noted together with SMSR test results.

## 8.9 Signal-to-source spontaneous emission ratio (SSER)

From the optical signal power of a non-modulated (CW) SLM laser,  $P_1$ , and the maximum optical power level,  $P_2$ , of the spontaneous emission as determined in 7.6.3 from method B, calculate the signal-to-source spontaneous emission ratio ( $R_{\text{SSE}}$  in dB/nm) as:

$$R_{\text{SSE}} = -10 \log_{10} \left( \frac{P_2/B_r}{P_1} \right) \quad (4)$$

## 9 Test results

### 9.1 Required information

The required information shall include:

- a) date, title of test, and procedures used;
- b) identification of the fibre optic transmitter (terminal device) or the optical source to be tested, together with applicable data;
- c) reference point temperature;
- d) results of the examination.


**9.2 Information to be available on request**

Information to be available on request is as follows:

- a) test equipment used and latest date of calibration;
- b) names of test personnel;
- c) measurement uncertainty due to measurement inaccuracy and display resolution;
- d) data rate and input signal characteristics, including modulation depth and pulse shape;
- e) supply voltage(s) and/or current(s);
- f) bias circuit configuration for discrete optical source;
- g) optical output measurement conditions, including details of fibre test cords, pigtail and standard coupling means, where applicable;
- ~~h) Optical output measurement conditions, including details of fibre test cords, pigtail and standard coupling means, where applicable~~
- h) recommended warm-up time for temperature stabilization;
- i) setting resolution bandwidth of OSA for SMSR test.

**10 Examples of results**

The output power spectrum (in dBm) of a single-mode fibre coupled, high power, InGaAsP edge-emitting LED is shown in Figure 1. Columns 1 to 3 in Table 1 show the 11 points selected from the spectrum according to 7.4. Column 4 shows the power converted from logarithmic to linear units. The products shown in columns 5 and 6, and the summations shown in the row labeled "SUM", are used to calculate the centroidal wavelength  $\lambda_c$ , and RMS spectral width,  $\Delta\lambda_{rms}$ , according to 8.3 and 8.5, respectively. The bottom two rows show the calculated centroidal wavelength and RMS spectral width for this LED.



**Figure 1 – Example of a LED optical spectrum**

**Table 1 – Measurement points for LED spectrum from Figure 1**

<i>i</i>	Wavelength $\lambda_i$ nm	Power (log) dBm	Power (linear) $P_i$ nW	$P_i \lambda_i$	$P_i (\lambda_i - \lambda_c)^2$
1	1 226	-44	40	49 040	256 000
2	1 243	-39	126	156 618	500 094
3	1 260	-33	501	631 260	1 060 116
4	1 277	-28	1 585	2 024 045	1 332 985
5	1 294	-24	3 981	5 151 414	573 264
6	1 311	-24	3 981	5 219 091	99 525
7	1 328	-27	1 995	2 649 360	965 580
8	1 345	-31	794	1 067 930	1 207 674
9	1 362	-35	316	430 392	990 976
10	1 379	-39	126	173 754	671 454
11	1 396	-44	40	55 840	324 000
<b>SUM</b>	–	–	13 485	17 608 744	7 981 668
$\lambda_c$	1 306	–	–	–	–
$\Delta\lambda_{rms}$	24	–	–	–	–

**Table 2 – RMS spectral characterization**

<i>i</i>	Wavelength $\lambda_i$ nm	Power (log) dBm	Power (linear) $P_i$ nW	$P_i \lambda_i$	$P_i (\lambda_i - \lambda_c)^2$
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
<b>SUM</b>	–	–			
$\lambda_c$		–	–	–	–
$\Delta\lambda_{rms}$		–	–	–	–

**NOTE** The entries to Table 2 are the average wavelength and power readings for each point *i*, where *i* corresponds to the mode number for discrete MLM spectra and to the wavelength point for continuous LED and SLM spectra.




Figure 2 – Typical spectrum analyzer output for MLM laser




Figure 3 –  $\Delta\lambda_{fwhm}$  spectral width measurement for MLM laser




Figure 4 –  $\Delta\lambda_{fwhm}$  spectral width calculation for MLM laser




Figure 5 – Peak emission wavelength and  $\Delta\lambda_{30-dB}$  measurement for SLM laser




Figure 6 – Resolution bandwidth (RBW) dependence of SMSR for SLM laser




Figure 7 – Signal-to-source spontaneous emission ratio measurement for SLM laser

## Bibliography

IEC 62522, *Calibration of tuneable laser sources*

---

IECNORM.COM : Click to view the full PDF of IEC 61280-1-3:2021 RLV

[IECNORM.COM](https://www.iecnorm.com) : Click to view the full PDF of IEC 61280-1-3:2021 RLV

# INTERNATIONAL STANDARD



**Fibre optic communication subsystem test procedures –  
Part 1-3: General communication subsystems – Measurement of central  
wavelength, spectral width and additional spectral characteristics**

IECNORM.COM : Click to view the full PDF of IEC 61280-1-3:2021 RLV

## CONTENTS

FOREWORD .....	4
1 Scope .....	6
2 Normative references .....	6
3 Terms, definitions and abbreviated terms .....	6
3.1 Wavelength .....	6
3.2 Spectral width .....	7
3.3 Additional spectral characteristics .....	7
3.4 Abbreviated terms .....	8
4 Apparatus .....	8
4.1 Calibrated optical spectrum analyzer (OSA) .....	8
4.2 Calibrated optical wavelength meter (OWM) .....	8
4.3 Power supplies .....	9
4.4 Input signal source or modulator .....	9
4.5 Test cord .....	9
5 Test sample .....	9
6 Procedure (method A) .....	9
6.1 General .....	9
6.2 Setup .....	10
6.3 Adjustment of spectrum analyzer controls .....	10
6.4 Setting of optical wavelength meter .....	11
7 Procedure (method B) .....	11
7.1 Setup .....	11
7.2 Adjustment of spectrum analyzer controls .....	11
7.3 Setting of optical wavelength meter .....	11
7.4 Continuous LED and SLM spectra .....	12
7.5 Discrete MLM spectra .....	12
7.6 SLM spectra .....	12
8 Calculation .....	13
8.1 General .....	13
8.2 Centre wavelength .....	13
8.2.1 Continuous LED spectra .....	13
8.2.2 Discrete MLM spectra .....	13
8.3 Centroidal wavelength .....	13
8.4 Peak wavelength .....	14
8.4.1 Continuous LED and SLM spectra .....	14
8.4.2 Discrete MLM spectra .....	14
8.5 RMS spectral width ( $\Delta\lambda_{\text{RMS}}$ ) .....	14
8.6 $n$ -dB-down spectral width ( $\Delta\lambda_{n\text{-dB}}$ ) .....	14
8.7 Full-width at half-maximum spectral width ( $\Delta\lambda_{\text{fwhm}}$ ) .....	14
8.7.1 Continuous LED spectra .....	14
8.7.2 Discrete MLM spectra .....	15
8.8 Side-mode suppression ratio (SMSR) .....	15
8.9 Signal-to-source spontaneous emission ratio (SSER) .....	15
9 Test results .....	15
9.1 Required information .....	15

9.2	Information to be available on request .....	16
10	Examples of results .....	16
	Bibliography.....	21
	Figure 1 – Example of a LED optical spectrum.....	16
	Figure 2 – Typical spectrum analyzer output for MLM laser.....	18
	Figure 3 – $\Delta\lambda_{\text{fwhm}}$ spectral width measurement for MLM laser.....	18
	Figure 4 – $\Delta\lambda_{\text{fwhm}}$ spectral width calculation for MLM laser.....	19
	Figure 5 – Peak emission wavelength and $\Delta\lambda_{30\text{-dB}}$ measurement for SLM laser.....	19
	Figure 6 – Resolution bandwidth (RBW) dependence of SMSR for SLM laser .....	20
	Figure 7 – Signal-to-source spontaneous emission ratio measurement for SLM laser.....	20
	Table 1 – Measurement points for LED spectrum from Figure 1 .....	17
	Table 2 – RMS spectral characterization.....	17

IECNORM.COM : Click to view the full PDF of IEC 61280-1-3:2021 RLV

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

### FIBRE OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

#### Part 1-3: General communication subsystems – Measurement of central wavelength, spectral width and additional spectral characteristics

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61280-1-3 has been prepared by subcommittee 86C: Fibre optic systems and active devices, of IEC technical committee 86: Fibre optics. It is an International Standard.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) addition of measurement of signal-to-source spontaneous emission ratio in 8.9;
- b) change of document title to reflect the additional measurement;
- c) additional information on the resolution bandwidth used in the measurement of the side-mode suppression ratio in 8.8;
- d) use of a calibrated optical wavelength meter for accurate wavelength measurements of single-longitudinal mode lasers.

The text of this International Standard is based on the following documents:

Draft	Report on voting
86C/1701/CDV	86C/1717/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

A list of all parts in the IEC 61280 series, published under the general title *Fibre optic communication subsystem test procedures*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## FIBRE OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

### Part 1-3: General communication subsystems – Measurement of central wavelength, spectral width and additional spectral characteristics

#### 1 Scope

This part of IEC 61280 provides definitions and measurement procedures for several wavelength and spectral width properties of an optical spectrum associated with a fibre optic communication subsystem, an optical transmitter, or other light sources used in the operation or test of communication subsystems. This document also provides definitions and measurement procedures for side-mode suppression ratio and signal-to-source spontaneous emission ratio.

The measurement is done for the purpose of system construction and/or maintenance. In the case of communication subsystem signals, the optical transmitter is typically under modulation.

NOTE Different properties can be appropriate to different spectral types, such as continuous spectra characteristics of light-emitting diodes (LEDs), as well as multilongitudinal-mode (MLM), multitransverse-mode (MTM) and single-longitudinal mode (SLM) spectra, which are characteristic of laser diodes (LDs).

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60825-1, *Safety of laser products – Part 1: Equipment classification and requirements*

IEC 62129-1, *Calibration of wavelength/optical frequency measurement instruments – Part 1: Optical spectrum analyzers*

IEC 62129-2, *Calibration of wavelength/optical frequency measurement instruments – Part 2: Michelson interferometer single wavelength meters*

#### 3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms, definitions and abbreviated terms apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

##### 3.1 Wavelength

NOTE The following wavelength terms provide quantitative definitions for the description of the central wavelength of a spectrum. In this document, "central wavelength" is a general category label for these terms.

### 3.1.1 centre wavelength

 $\lambda_0$ 

mean of the closest spaced half-power wavelengths in an optical spectrum, one above and one below the peak wavelength

Note 1 to entry: Centre wavelength is also called “half-power mid-point”.

### 3.1.2 half-power wavelength

 $\lambda_{3dB}$ 

wavelength corresponding to a half-peak power value of the optical spectrum

### 3.1.3 peak wavelength

 $\lambda_p$ 

wavelength corresponding to the maximum power value of the optical spectrum

### 3.1.4 centroidal wavelength

 $\lambda_c$ 

mean or average wavelength of an optical spectrum

## 3.2 Spectral width

### 3.2.1 RMS spectral width

 $\Delta\lambda_{rms}$ 

square root of the second moment of the power distribution about the centroidal wavelength

### 3.2.2 $n$ -dB-down spectral width

 $\Delta\lambda_{n-dB}$ 

positive difference of the closest spaced wavelengths, one above and one below the peak wavelength  $\lambda_p$ , at which the spectral power density determined in a specified resolution bandwidth is  $n$  dB down from its peak value

### 3.2.3 full-width at half-maximum

 $\Delta\lambda_{fwhm}$ 

positive difference of the closest spaced wavelengths, one above and one below the peak wavelength  $\lambda_p$ , at which the spectral power density determined in a specified resolution bandwidth is 3 dB down from its peak value

## 3.3 Additional spectral characteristics

### 3.3.1 side-mode suppression ratio SMSR

ratio of the largest peak of the optical spectrum to the second largest peak under non-modulated (continuous wave) operating condition, which is determined in a specified wavelength resolution bandwidth (RBW), for a nominally single-longitudinal mode (SLM) spectrum

Note 1 to entry: See 8.8.

**3.3.2****signal-to-source spontaneous emission ratio****SSER**

ratio between the signal power and maximum source spontaneous emission (SSE) power under the non-modulated (CW) condition which is determined in a specified bandwidth

**3.4 Abbreviated terms**

CW	continuous wave
DFB	distributed feedback
ESD	electrostatic discharge
InGaAsP	indium gallium arsenide phosphide
LD	laser diode
LED	light-emitting diode
MLM	multi-longitudinal mode
MTM	multi-transverse mode
OSA	optical spectrum analyzer
OWM	optical wavelength meter
RBW	resolution bandwidth
RMS	root-mean-square
SLM	single-longitudinal mode
SMSR	side-mode suppression ratio
SSE	source spontaneous emission
SSER	signal-to-source spontaneous emission ratio
TLA	tuneable laser assembly
VCSEL	vertical cavity surface emitting lasers
WDM	wavelength-division multiplexing

**4 Apparatus****4.1 Calibrated optical spectrum analyzer (OSA)**

This special-purpose test equipment uses a dispersive spectrophotometric method to resolve and record the optical spectral distribution. The required wavelength resolution bandwidth and range depend on the type and variety of signals to be measured. Generally, LED sources have wide spectra with little structure, so a range of at least 200 nm and resolution bandwidth of 1 nm or narrower are recommended. Laser sources have much narrower spectra and can be used in wavelength-division multiplexing (WDM) applications, where more accurate determination of the wavelength is required. A resolution bandwidth of 0,1 nm or narrower is recommended, and the actual requirement is determined by the application. In any case, the sensitivity and wavelength range of the spectrum analyzer shall be sufficient to measure all of the spectrum within at least –20 dB from the peak power. For measurement of SMSR, a larger dynamic range is typically required.

OSA equipment shall be calibrated for vacuum wavelengths in order to be consistent with the calibration processes and results of IEC 62129-1. The equipment used shall have a valid calibration certificate, in accordance with the applicable quality system for the period over which the testing is done.

**4.2 Calibrated optical wavelength meter (OWM)**

For central wavelength measurements of SLM lasers, such as distributed feedback (DFB) lasers or tuneable laser assemblies (TLAs) for dense WDM applications, sufficient

measurement accuracy is required. In this case, an optical wavelength meter based on interferometric spectroscopy can be used. The accuracy of the central wavelength measurement is generally specified for non-modulated (CW) lasers. When the SLM laser is modulated, the uncertainty of the central wavelength measurement increases with the increasing modulation frequency or symbol rate.

OWM equipment shall be calibrated in accordance with IEC 62129-2. The equipment used shall have a valid calibration certificate, in accordance with the applicable quality system for the period over which the testing is done.

#### **4.3 Power supplies**

As required for the device under test.

#### **4.4 Input signal source or modulator**

The input signal source is a signal generator or modulator with the appropriate digital or analogue signal of the system.

#### **4.5 Test cord**

Unless otherwise specified, the physical and optical properties of the test cords shall match the cable plant with which the equipment is intended to operate. The cords shall be 2 m to 5 m long and shall contain fibres with coatings which remove cladding light. Appropriate connectors shall be used. Single-mode cords shall be deployed with two 90 mm diameter loops or otherwise assure rejection of cladding modes. If the equipment is intended for multimode operation and the intended cable plant is unknown, the fibre size shall be 50/125  $\mu\text{m}$ .

### **5 Test sample**

The test sample shall be a specified fibre optic subsystem, transmitter, or light source. The system inputs and outputs shall be those normally seen by the user. The spectral width parameters are typically used for characterizing MLM and LED transmitters. The widths of MTM and SLM lasers without modulation are normally too narrow to measure with the dispersive spectral instruments used with this method. Modulated SLM transmitters have broadened linewidths for high data rates (above about 2,5 Gb/s) caused by chirp that can be measurable by this method.

Because of the potential for hazardous radiation, conditions of laser safety shall be established and maintained. Refer to IEC 60825-1.

## **6 Procedure (method A)**

### **6.1 General**

Method A is designed for the use of typical commercial optical spectrum analyzer instruments that allow quick measurement of spectra with 1 000 wavelength samples or more and allow for the analysis of such spectra based on all of the samples, rather than selecting for example only the samples at the peaks of mode wavelengths. The previous method using a smaller number of discrete wavelength points is included in Clause 7 as method B, for compatibility with the first edition of this document. Method A has the advantage of easier, simpler automated analysis and better representation of complex but narrow spectra, such as multi-transverse-mode vertical cavity surface emitting lasers (VCSELs). Due to its convenience and prevalence in the industry, method A is considered the reference test method.

For measurements of the central wavelength of SLM lasers, a commercial optical wavelength meter can also be used. These instruments typically allow the user to specify whether the

optical signal is a continuous wave (CW) signal or a modulated communication signal. An appropriate mode should be selected according to the condition of the light signal under test. In the case of modulated SLM lasers, the uncertainty of the central wavelength measurement typically increases with increasing modulation frequency or symbol rate.

## 6.2 Setup

**6.2.1** Use appropriate handling procedures to prevent damage from electrostatic discharge (ESD), which can cause opto-electronic devices to fail.

**6.2.2** With the exception of ambient temperature, standard ambient conditions shall be used, unless otherwise specified. The ambient or reference point temperature shall be  $23\text{ °C} \pm 2\text{ °C}$ , unless otherwise specified.

**6.2.3** Unless otherwise specified, apply a modulated input signal to the optical source. Allow sufficient time (according to the manufacturer's recommendation or as specified in the detail specification) for the optical source/transmitter to reach a steady-state temperature.

**6.2.4** Turn the optical spectrum measuring instruments, such as the OSA or the OWM, on and allow the recommended warm-up and settling time to achieve the rated measurement performance level.

**6.2.5** Connect the optical output of the optical source under test to the optical input connector of the optical spectrum measuring instrument. If the transmitter under test does not include isolation from back-reflections, as often the case at 850 nm, these reflections can cause the spectrum to be unstable and should be reduced with high return-loss connections and possibly external isolation or attenuation at the transmitter output.

## 6.3 Adjustment of spectrum analyzer controls

**6.3.1** Using the resolution bandwidth control, select an appropriate resolution bandwidth (see 4.1). Typically, less than 1/10 of the spectral width to be measured or the finest available resolution bandwidth (0,1 nm or narrower) should be used. Set the number of data points in the acquired signal to be sure to adequately sample the detail of the optical spectrum. Typically, this is set to at least four times the sample resolution times the total measured width. For example, a 10 nm measurement span using 0,1 nm resolution bandwidth requires a minimum of 400 points in the measurement, which is given by four times the total measurement span divided by the resolution bandwidth.

**6.3.2** Using the span control, select an appropriate span of wavelength range on the display section of the spectrum analyzer. Initially, select a sufficiently wide span to determine the appropriate position of the peak wavelength; then reduce and adjust the span again to fit all of the source spectrum or at least all that is within at least 20 dB of the peak power. For SLM lasers, the span may need to be changed, typically from 2 nm to 20 nm full scale, to determine the spectral width and SMSR.

**6.3.3** Using the gain or reference level control, select a gain or reference level so that the amplitude of the peak output extends over the entire screen vertical scale.

**6.3.4** If available, use the spectrum analyzer log-scale for amplitude measurement to achieve the maximum dynamic range

**6.3.5** For OSAs that are not capable of performing the subsequent calculations in Clause 8 internally, download the measured optical spectra data to a computer for further analysis in a format that contains both the wavelength and amplitude of all points in the measurement.

## 6.4 Setting of optical wavelength meter

**6.4.1** The optical wavelength meter is implemented with a longitudinal mode detecting function. The appropriate parameters should be set, such as threshold from the peak and excursion from the peak.

**6.4.2** Generally, the optical wavelength meter is also implemented with a light signal condition setting function. The appropriate condition should be set, such as continuous wave (CW) or modulated signal.

## 7 Procedure (method B)

### 7.1 Setup

**7.1.1** Use appropriate handling procedures to prevent damage from electrostatic discharge (ESD), which can cause opto-electronic devices to fail.

**7.1.2** With the exception of ambient temperature, standard ambient conditions shall be used, unless otherwise specified. The ambient or reference point temperature shall be  $23\text{ °C} \pm 2\text{ °C}$ , unless otherwise specified.

**7.1.3** Unless otherwise specified, apply a modulated input signal to the optical source. Allow sufficient time (according to the manufacturer's recommendation or as specified in the detail specification) for the optical source/transmitter to reach a steady-state temperature.

**7.1.4** Turn the optical spectrum measuring instruments, such as the OSA or the OWM, on and allow the recommended warm-up and settling time to achieve the rated measurement performance level.

**7.1.5** Connect the optical output of the optical source under test to the optical input connector of the optical spectrum measuring instrument. If the transmitter under test does not include isolation from back-reflections, as is often the case at 850 nm, these reflections can cause the spectrum to be unstable and should be reduced with high return-loss connections and possibly external isolation or attenuation at the transmitter output.

### 7.2 Adjustment of spectrum analyzer controls

**7.2.1** Using the resolution bandwidth control, select an appropriate resolution bandwidth (see 4.1).

**7.2.2** Using the span control, select an appropriate span of wavelength range on the display section of the spectrum analyzer. Initially, select the maximum span to obtain the appropriate position of the peak wavelength; then adjust the span again so that, at the selected gain, the smallest detectable output power level occupies the extreme edges of the screen horizontal scale. For SLM lasers, the span may need to be changed, typically from 2 nm to 20 nm full scale, to determine the spectral width and SMSR.

**7.2.3** Using the gain or reference level control, select a gain or reference level so that the amplitude of the peak output extends over the entire screen vertical scale. If available, use the spectrum analyzer log-scale for amplitude measurement to achieve the maximum dynamic range.

### 7.3 Setting of optical wavelength meter

**7.3.1** The optical wavelength meter is implemented with a longitudinal mode detecting function, and appropriate parameters should be set, such as threshold from the peak and excursion from the peak.

**7.3.2** Generally, the optical wavelength meter is also implemented with a light signal condition setting function, and the appropriate conditions should be set, such as continuous wave (CW) or modulated signal.

#### **7.4 Continuous LED and SLM spectra**

**7.4.1** Refer to Figure 1 and Figure 5 for samples of LED and SLM-LD spectrum analyzer outputs. At the end of several single measurement sweeps, ensure that the output spectrum is stable (power variation at any wavelength is  $\leq 10\%$  or  $\sim 0,5$  dB between sweeps).

**7.4.2** Determine the peak wavelength,  $\lambda_p$ . (Most optical spectrum analyzers have a peak-search button that automatically performs this function.)

**7.4.3** For LEDs, record the two half-power wavelengths on both sides of the peak wavelength that are 3 dB down from the peak amplitude. Determine the number of points to record (minimum 11), the wavelength  $\lambda_i$ , and the amplitude  $p_i$  for each point  $i$  in the displayed spectrum as follows.

**7.4.4** On both sides of the peak, find the wavelengths closest to the peak, corresponding to the two points  $n$  dB down from the peak (see example in Figure 1), where  $n$  is typically 20.

**7.4.5** To find 11 equally spaced points, subtract these two wavelengths and divide the result by 10. This gives the spacing between points.

**7.4.6** Starting with the minimum wavelength as the first point, add the wavelength spacing to find the next point. Continue until 11 points are found (the 11<sup>th</sup> point should correspond to the maximum wavelength from 7.4.4). Record the wavelengths in Table 2, column 2.

**7.4.7** Find the output power (in dBm) corresponding to each wavelength point and record in Table 2, column 3.

**7.4.8** Convert the power in dBm to nanowatts (nW) using  $P(\text{nW}) = 10^{[0,1 P(\text{dBm}) + 6]}$  and record in Table 2, column 4.

#### **7.5 Discrete MLM spectra**

**7.5.1** At the end of a single measurement sweep, measure and record the wavelength and the amplitude, for all the modes displayed, in Table 2. The display at the end of the measurement sweep will determine the number of modes and the reference nominal wavelength for each mode. Refer to Figure 2 for a sample spectrum analyzer output.

**7.5.2** Measure and record the wavelength and the amplitude for each mode displayed for each of the 10 single measurement sweeps. Include modes at least  $n$  dB below the peak mode, where  $n$  is typically 20 to 25. For each mode at nominal wavelengths measured and recorded in 7.5.1, calculate the average of the 10 measured wavelengths and the corresponding average of the 10 amplitude readings. Record these average values in Table 2.

**7.5.3** Compare the readings of 7.5.1 and 7.5.2 for each mode. For any mode, if the difference in wavelength readings is more than 0,2 nm, or the difference in amplitude readings is more than 10 %, this indicates mode instability, and the calculations may not be accurate.

#### **7.6 SLM spectra**

**7.6.1** Measure and record the power ( $M_1$ ) at the peak wavelength and the power ( $M_2$ ) of the strongest side-mode under the non-modulated (CW) condition.

**7.6.2** Measure and record the two wavelengths on both sides of the peak wavelength that are  $n$  dB down from the peak amplitude, where  $n$  is typically 20 or 30.

**7.6.3** Measure and record the optical signal power ( $P_1$ ) and the maximum value ( $P_2$ ) of the optical power level of source spontaneous emission (SSE) under non-modulated (CW) operating condition. The SSE power level shall be determined over the entire wavelength range where the laser (TLA) can oscillate, with the exclusion of typically  $\pm 1$  nm around the optical signal wavelength (see Figure 7). The resolution bandwidth of OSA is usually set to 0,1 nm. The actual resolution bandwidth ( $B_r$ ) should be calibrated.

## 8 Calculation

### 8.1 General

Many optical spectrum analyzers calculate some or all the following parameters internally. Note that for method A, there will be  $N$  points corresponding to all the data points taken. Before beginning calculations, it is recommended that any power data points that are more than 20 dB (or another chosen and documented range) below the maximum power reading not be used in the calculations. This will especially prevent the user from overestimating the RMS spectral width. For method B, the total number of data points  $N$  will be the number of recorded mode peaks.

### 8.2 Centre wavelength

#### 8.2.1 Continuous LED spectra

This is the average of the half-power wavelengths determined from the result of 6.3.5 for method A or 7.4.3 for method B.

#### 8.2.2 Discrete MLM spectra

This is the average of the half-power wavelengths that can be determined as follows by interpolation, since the laser may not have modes at these wavelengths.

Connect the tip of each mode to the tips of adjacent modes as shown in Figure 3; draw a horizontal line 3 dB down from the peak power point. The two or more intersection points of the horizontal line with the tip-connecting lines define the half-power wavelengths. The average of the half-power wavelengths that are furthest separated is  $\lambda_0$ .

### 8.3 Centroidal wavelength

Using the wavelengths and corresponding linear power (nW) in Table 2 for method B or the result of 6.3.5 for method A, calculate the centroidal wavelength as follows:

$$\lambda_c = \left( \frac{1}{P_0} \right) \sum_{i=1}^N P_i \lambda_i \quad (1)$$

where

$\lambda_i$  is the wavelength of the  $i^{\text{th}}$  point;

$P_i$  is the power of the  $i^{\text{th}}$  point;

$P_0$  is the total power summed for all points:  $P_0 = \sum_{i=1}^N P_i$

$N$  is the number of points.

Refer to Table 1 for a calculation example.

## 8.4 Peak wavelength

### 8.4.1 Continuous LED and SLM spectra

Use the value measured in 7.4.2 for method B or the wavelength of the maximum power in the spectrum of 6.3.5 for method A as the peak wavelength.

### 8.4.2 Discrete MLM spectra

The peak wavelength can be obtained directly from the wavelength corresponding to maximum power in the spectrum from 6.3.5 for method A or from Table 2 (log or linear scale), representing the average of 10 readings, by reading the wavelength corresponding to the peak power level for method B. If the maximum power occurs in more than one mode, take the average of the wavelength of all modes with the maximum power. Use the average value as the peak wavelength.

## 8.5 RMS spectral width ( $\Delta\lambda_{\text{rms}}$ )

Using the wavelengths and corresponding linear power (nW), in the spectrum from 6.3.5 for method A or from Table 2 (single or average values) for method B, calculate the RMS spectral width as:

$$\Delta\lambda_{\text{rms}} = \left[ \frac{1}{P_0} \sum_{i=1}^N P_i (\lambda_i - \lambda_c)^2 \right]^{\frac{1}{2}} \quad (2)$$

Refer to Table 1 for a calculation example. Note that  $\Delta\lambda_{\text{rms}}$  does not apply to SLM sources. As mentioned at the beginning of Clause 8, a documented method for limiting the range of the data points should be used, such as a cutoff of 20 dB from the peak power.

## 8.6 $n$ -dB-down spectral width ( $\Delta\lambda_{n\text{-dB}}$ )

The difference in wavelengths recorded in 7.5.2 for method B, or which are  $n$  dB below the peak in the spectrum from 6.3.5 from method A, is  $\Delta\lambda_{n\text{-dB}}$  (see Figure 5). This  $\Delta\lambda_{n\text{-dB}}$  applies to SLM lasers but does not apply to MLM lasers or to LEDs.

$n$ -dB-down spectral width depends on the resolution bandwidth of the OSA, because the main mode of SLM lasers, such as DFB-LDs and TLAs, is substantially narrower than the resolution bandwidth of an OSA. Therefore, information on the resolution bandwidth of the OSA that was used to measure the signal spectrum should be noted together with  $n$ -dB-down spectral width test result.

## 8.7 Full-width at half-maximum spectral width ( $\Delta\lambda_{\text{fwhm}}$ )

### 8.7.1 Continuous LED spectra

The difference of the half-power wavelengths recorded in 7.4.3 from method B or determined from the spectra of 6.3.5 for method A is  $\Delta\lambda_{\text{fwhm}}$ .