

INTERNATIONAL STANDARD

IEC 61822

First edition
2002-06

Electrical installations for lighting and beaconing of aerodromes – Constant current regulators

*Installations électriques pour l'éclairage
et le balisage des aérodromes –
Régulateurs du courant constant*



Reference number
IEC 61822:2002(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/catlg-e.htm) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/JP.htm) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC 61822

First edition
2002-06

Electrical installations for lighting and beaconing of aerodromes – Constant current regulators

*Installations électriques pour l'éclairage
et le balisage des aérodromes –
Régulateurs de courant constant*

© IEC 2002 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

S

For price, see current catalogue

CONTENTS

FOREWORD.....	3
1 Scope.....	4
2 Normative references.....	4
3 Definitions	4
4 Classification	5
4.1 Output current	5
4.2 Current steps.....	5
4.3 Ratings.....	6
5 Requirements	6
5.1 General	6
5.2 Environmental requirements	6
5.3 Performance requirements.....	6
5.4 Electromagnetic compatibility (EMC).....	10
5.5 Design requirements.....	10
5.6 Protection against electric shock.....	13
5.7 Optional accessories	13
6 Qualification and test requirements.....	15
6.1 Type tests	15
6.2 Routine tests	15
7 Tests description for type tests.....	16
7.1 Visual inspection	16
7.2 Protection against electric shock.....	16
7.3 Dielectric test.....	17
7.4 Enclosure temperature test.....	17
7.5 Leakage test.....	18
7.6 Test of protective devices	18
7.7 Operation test.....	18
7.8 Performance test.....	19
7.9 Environmental tests	21
7.10 Optional accessories	22

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL INSTALLATIONS FOR LIGHTING
AND BEACONING OF AERODROMES –
CONSTANT CURRENT REGULATORS**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61822 has been prepared by IEC Technical Committee 97: Electrical installations for lighting and beaconing of aerodromes.

The text of this standard is based on the following documents:

FDIS	Report on voting
97/86/FDIS	97/90/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 3.

The committee has decided that the contents of this publication will remain unchanged until 2006. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

ELECTRICAL INSTALLATIONS FOR LIGHTING AND BEACONING OF AERODROMES – CONSTANT CURRENT REGULATORS

1 Scope

This International Standard specifies the requirements for a Constant Current Regulator (CCR) having a nominal output of 6,6 A for use in an aeronautical ground lighting constant current series circuit. However CCRs may be manufactured which have a different power rating (kVA) and current steps than those specified in this standard in order to be used on existing circuits. This standard shall be applied where appropriate for these CCRs.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60439-1:1991, *Low-voltage switchgear and controlgear assemblies – Part 1: Type-tested and partially type-tested assemblies*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 61000-6-2, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity for industrial environments*

IEC 61000-6-4, *Electromagnetic compatibility (EMC) – Part 6: Generic standards – Section 4: Emission standard for industrial environments*

IEC/TS 61000-6-5, *Electromagnetic compatibility (EMC) – Part 6-5: Generic standards – Immunity for power station and substation environments*

IEC 61140, *Protection against electric shock – Common aspects for installation of equipment*

CISPR 11, *Industrial, scientific and medical (ISM) radio-frequency equipment – Electromagnetic disturbance characteristics – Limits and methods of measurement*

CISPR 22, *Information technology equipment – Radio disturbance characteristics – Limits and methods of measurement*

3 Terms and definitions

For the purposes of this International Standard, the following definitions developed to be included in international standards relating to airport/aerodrome visual aids apply

3.1

aeronautical ground lighting (AGL) constant current series circuit

apparatus configured as an electrical circuit designed to produce and operate with a constant current, independent of variations in the load, in order to provide a specified light for aeronautical purposes

3.2

constant current regulator (CCR)

apparatus which produces a current output at a constant r.m.s. value independent of variations in the constant current series circuit load, input voltage and service conditions as specified

3.3

contractor

organisation or person(s) given a written order to provide a service or undertake specified work

3.4

earthed

connected to the ground in such a manner as to ensure at all times an immediate discharge of electrical energy to reduce the danger of equipment damage or personnel injury

3.5

electrical equipment

anything used, intended to be used or installed for use, to generate, provide, transmit, transform, rectify, convert, conduct, distribute, control, store, measure or use electrical energy

3.6

injury

death or personnel injury from electric shock, electric burn, electrical explosion or arcing, or from fire or explosion initiated by electrical energy, where any such death or injury is associated with the generation, provision, transmission, transformation, rectification, conversion, conduction, distribution, control, storage, measurement or use of electrical energy

3.7

isolate

to disconnect and separate electrical equipment from the normal source(s) of electrical energy in such a way that the disconnection and separation is secure

3.8

live

electrically connected to a source of electricity or having acquired a charge by other means

3.9

work/working (on electrical equipment)

installing, dismantling, assembling, maintaining or repairing of electrical equipment

4 Classification

4.1 Output current

The CCR shall produce a maximum rated r.m.s. current output of 6,6 A and a minimum rated r.m.s. current output of 1,8 A.

4.2 Current steps

CCRs shall be classified according to the number of output current steps available, as follows:

style 1 3 current steps;

style 2 5 current steps.

Each step shall have a single adjustment over the full range specified in 4.1.

NOTE An additional low current step(s) for non-illumination purposes may be offered as an option (see 5.7.6). Each style CCR can be configured to operate with a reduced number of current steps.

4.3 Ratings

CCRs shall be manufactured in the following output power ratings:

1; 2,5; 5; 7,5; 10; 15; 20; 25; and 30 kVA.

NOTE 1 There may be situations where greater power rating is required than that specified in this International Standard to meet existing circuit requirements. In this case, the CCR should meet the applicable performance, qualification and safety requirements contained in this International Standard.

The standard input voltage to the CCR (see 5.3.5) shall be a single-phase or three-phase value in accordance with IEC 60038.

NOTE 2 Input voltage configured between two phases of a three-phase system is defined as single-phase.

The operating frequency shall be 50 Hz \pm 7,5 % or 60 Hz \pm 7,5 %.

NOTE 3 The CCR may be designed to operate from a d.c. power source.

5 Requirements

5.1 General

The following requirements are grouped into six categories: environmental, performance, EMC, design, protection against electric shock and optional accessories.

5.2 Environmental requirements

The equipment shall be designed for continuous indoor operation without derating, under the following conditions:

- temperature range from 0 °C to +50 °C;
- relative humidity from 10 % to 95 % without dewing;
- altitude from sea-level to 1 000 m;
- electromagnetic compatibility – as per IEC 61000-6-2.

5.3 Performance requirements

5.3.1 Regulation – resistive loading

The CCR shall maintain the output current within the limits of table 1 while powering any resistive load between no load (short circuit) and full load. CCRs shall provide regulation over the full range of environmental conditions specified in 5.2 and the input voltage range of 90 % to 110 %.

When current steps different than those shown below are used, the tolerances (\pm 0,1 A) used in table 1 shall be maintained.

Table 1 – Nominal CCR output current range

Style	Current step	Nominal output (A r.m.s.)	Allowable range (A r.m.s.)
1	3	6,60	6,50 – 6,70
	2	5,50	5,40 – 5,60
	1	4,80	4,70 – 4,90
2	5	6,60	6,50 – 6,70
	4	5,20	5,10 – 5,30
	3	4,10	4,00 – 4,20
	2	3,40	3,30 – 3,50
	1	2,80	2,70 – 2,90

5.3.2 Regulation – reactive loading

The CCR shall maintain the current within the limits of table 1 for all current steps when the load has an inductive power factor of 0,60.

5.3.3 Efficiency

At all current steps, the average efficiency of the CCR, operating at rated input voltage into a full nominal resistive load shall not be less than 80 %.

5.3.4 Power factor

The power factor of the CCR, operating at rated input voltage into a full nominal resistive load shall not be less than 0,90.

5.3.5 Input voltage

Input voltage shall be as stated in 4.3. The CCR shall operate as required in 5.3.1 when the input voltage is anywhere between 90 % and 110 % of the nominal input.

The CCR shall be designed to withstand momentary increases of voltage up to 120 % and momentary decreases of voltage down to 80 % of the nominal input voltage without being de-energized or damaged by such voltages. The CCR shall withstand such voltage excursions for up to 50 ms within a period of 1 min. The CCR shall automatically resume normal operation (table 1) when the input voltage returns to 90 % to 110 % of the nominal value.

5.3.6 Load matching

CCRs shall match connected loads from 50 % to 100 % of the rated load.

For resistive loads in the range of 50 % to 100 % of the rated load, at the rated input voltage, and with an output current at 100 %, the efficiency and power factor shall not be less than the values specified in 5.3.3 and 5.3.4. If required, additional output load taps may be provided to allow a more precise adjustment.

5.3.7 Operation

The CCR shall stabilize the output current at any selected current step within 500 ms, and shall hold the output current stable within the limits of table 1. There shall not be any interruption of output current to the series circuit when switching from one current step to another.

5.3.8 Control/Monitoring System

5.3.8.1 Functions

The CCR shall be capable of being controlled locally and from a remote location. Information on the selected current step and remote/local status shall be provided at the CCR regardless of whether the CCR is in local or remote control.

The local control system shall be integral to the CCR and shall not be supplied from a source located outside the CCR package. The CCR shall be capable of being controlled remotely for any current level by parallel wiring or serial interface. The design of the remote control interface shall provide, at least, the inputs and outputs described in table 2:

Table 2 – CCR remote control/monitoring functions

Remote control			Remote monitoring				
	Standard	Option	Standard		Option		
a	On/Off selection		a	CCR on			
			b	Local/Remote			
b	Current step selection		c	Step 1 selected	c1	Step 1 obtained	
			d	Step 2 selected	d1	Step 2 obtained	
			e	Step 3 selected	e1	Step 3 obtained	
			f	Step 4 selected	f1	Step 4 obtained	
			g	Step 5 selected	g1	Step 5 obtained	
					h	CCR out of range	
					i	Open circuit trip	
		j	Over current trip				
c		CCR Non-illumination step		k	CCR non-illumination step		
d		Circuit Selector Switch		l	Circuit selector fault		
				m	Lamp fault warning		
				n	Lamp fault alarm		
				o	Earth fault warning		
				p	Earth fault alarm		

NOTE For the monitoring section, if (c1) to (g1) is implemented, (c) to (g) can be omitted

5.3.8.2 Control interface

The standard source voltage for controlling and monitoring the CCR shall be +48 V d.c., +24 V d.c. or +60 V d.c. nominal, with the negative pole being common. Remote control power shall be provided from a source either external or internal to the CCR. If internal, a dedicated power supply shall be for remote control only.

Relays or other isolating devices shall be provided for switching on and setting the current steps of the CCR.

Monitoring of the CCR data output shall be provided by relay contacts or another isolating device rated at minimum 60 V d.c. and 50 mA. Where a common pole is used, it shall be negative.

Terminal blocks or connectors having a minimum voltage rating of 300 V shall be installed in the control cabinet for connection of external wiring associated with monitoring and remote control. Terminal blocks or connectors shall accommodate 0,250 mm² to 2,500 mm² cable with a minimum insulation rating of 300 V. Space for spare positions shall be provided to accommodate optional devices.

5.3.8.3 Monitoring terminals

One terminal for each of the functions listed in 5.3.8.1 shall be provided.

5.3.8.4 Serial wiring

All controls and output functions may be optionally available using a serial interface. Output functions may alone be optionally available through a serial interface using a protocol that allows the use of at least layers one and two of the ISO/OSI reference model.

5.3.9 Output current surge limitation

The CCR shall be designed with a controlled feature, so that switching the CCR on and off, changing current steps, or shorting the load, shall not damage the CCR, trip a protective device, nor produce output current surges (transients) that will damage series incandescent lamps. Changes of intensity due to switching of current steps in local or remote control shall occur without over-shoots exceeding 6,7 A r.m.s.

5.3.10 Dynamic response

For sudden load variations exceeding 10 % of the load, the duration of the possible over current condition shall be limited to one half-cycle. If the peak current reaches twice the maximum peak current while in normal operation, (i.e. peak current in short circuit at maximum current and maximum input voltage) or the current reaches 125 % of the maximum r.m.s. value, the current shall be limited under 2,0 A r.m.s. after the half sine wave in progress. The suppression shall remain for one to four cycles and then the current limits of table 1 shall be achieved in 500 ms or less.

5.3.11 Output voltage limitation

With the open circuit protection disabled, the peak output voltage of an open-circuited CCR shall not exceed twice the rated r.m.s. output kVA divided by the rated r.m.s. output current.

5.3.12 Protective devices

5.3.12.1 Open circuit protection

The CCR shall include an open-circuit protective device to de-energize the CCR output within 1 s after an open circuit condition (less than 1,5 A r.m.s.) occurs in the primary series circuit. The protective device shall be reset manually from the local position only. The CCR shall not trip out due to the switching of load circuits or other transients.

5.3.12.2 Overcurrent protection

The CCR shall include an overcurrent protective device to de-energize the CCR output between 3 s and 5 s when the output current exceeds 6,75 A r.m.s. The CCR shall de-energize the output within 300 ms when the output current exceeds 8,30 A r.m.s. The protective device shall be reset manually from the local position only.

5.3.12.3 Primary switching

The CCR shall have an electro-mechanical isolating device that interrupts the input power before it reaches the main power transformer and shall not interrupt internal control power.

5.3.12.4 Short circuit protection

The CCR shall have short-circuit protection on the primary side of the power transformer appropriate to the fault current level.

5.3.12.5 Input power loss

In the event of an input power loss for up to 1 min, the CCR shall resume operation on the selected current setting within 500 ms after the restoration of input power.

5.3.12.6 Output series circuit switching

When the CCR is used with a circuit selector, the CCR shall not lock-out or produce surges that would damage the connected series circuits.

Means shall be provided for interlocking the CCR and circuit selector switch. A breaking switch in the circuit selector switch shall force the CCR output current to zero while the circuit selector switch is operating.

5.4 Electromagnetic compatibility (EMC)

5.4.1 Limits for emission

CCRs shall comply with IEC 61000-6-4, the EMC generic emission standard for industrial environments. Radiated emission limits shall be in accordance with CISPR 11, class B.

5.4.2 Output current waveform

The CCR shall provide an output current waveform with a crest factor of less than 3,2 at all current steps at the nominal input voltage and with 10 % resistive load.

5.4.3 Limits for immunity

CCRs shall comply with the generic immunity standards for industrial environments IEC 61000-6-2, supplemented by applicable parts of IEC/TS 61000-6-5 containing EMC immunity requirements for power station and substation environments (locations where apparatus for electricity utilities are installed). CCRs shall comply with requirements for apparatus installed in type G locations (power stations and medium voltage substations) as defined in IEC/TS 61000-6-5.

5.5 Design requirements

5.5.1 Local control and indication

The CCR shall be capable of being locally controlled to provide the following functions:

- on/off;
- local/remote control;
- current steps.

The CCR shall indicate the following conditions on the front of the unit:

- an alarm indication that an open-circuit trip-out has occurred;
- an alarm indication that an over current trip-out has occurred;
- an indication that the CCR input voltage is present;
- an indication of local/remote control;
- the selected current step;
- an indication that the output current is present.

5.5.2 Output current indication

An indication of output current shall be installed on the front panel of the CCR.

5.5.3 Power transformer

The temperature rise of the power transformer windings shall remain within the limits of the class of insulation utilized, taking into consideration an elevated ambient temperature of 50 °C resulting in an 80 % derating factor for components.

5.5.4 Wiring diagram

A wiring diagram showing all customer connection points shall be permanently readable, and located in a visible place in the CCR.

5.5.5 Mechanical design

The CCR shall be constructed only of materials capable of withstanding the mechanical, electrical, and thermal stresses as well as the effects of humidity, which are likely to be encountered in normal service.

Protection against corrosion shall be ensured by the use of suitable materials or by the application of equivalent protective coatings to the exposed surface, taking account of the intended conditions of use and maintenance.

All enclosures and partitions shall be of a mechanical strength sufficient to withstand the stresses to which they may be subjected in normal service.

The CCR cabinet shall be designed for ease of installation movement of the unit (e.g. rollers, lifting rings, etc.).

The apparatus and circuits in the CCR shall be so arranged as to facilitate their operation and maintenance and at the same time to ensure the necessary degree of safety.

The CCR shall be designed and arranged in such a way that certain operations, according to agreement between manufacturer and user, can be performed when the CCR is connected to the mains.

Such operations may be:

- visual inspection of
 - switching devices and other apparatus,
 - settings and indicators,
 - conductor connections and markings;
- adjusting and resetting of relays, releases and electronic devices;
- certain fault location operations.

Necessary measures shall be taken to enable maintenance of the CCR, with adjacent functional units or groups energized. Such measures may be:

- sufficient space between subassemblies;
- use of barrier protected sub-sections for each subassembly;
- use of compartments for each subassembly;
- insertion of additional protective means provided or specified by the manufacturer.

5.5.6 Electrical design

All components used in the design of the CCR shall be suitable for their function and shall not operate in excess of 80 % of the component manufacturer's recommended rating. In order to maximize reliability it is recommended that no forced heating or cooling be utilized. If either is used it shall be monitored with an alarm given upon failure. Upon failure of the cooling or heating element, the CCR shall continue to operate normally for a period of time specified by the manufacturer.

All cabling and small wiring shall be securely placed in systematic runs and coded where terminated. Power cabling shall be terminated with lugs or eyes and terminals shall be clearly and appropriately coded. Wiring identification shall be in agreement with the indicators on wiring diagrams and drawings. Bushings, glands, or grommets shall protect cabling and wiring passing through metal work.

The protective earth conductor shall be readily distinguishable by twin coloured green and yellow markings. When the protective conductor is an insulated single core cable, this colour identification shall be used throughout the entire length.

Insulated conductors shall be rated for at least the maximum voltage of the circuit concerned.

Cables between two connecting devices shall have no intermediate splices or soldered joints. Connections shall be made at fixed terminals. The connection of two or more conductors to one terminal is permissible only in those cases where the terminals are designed for this purpose.

5.5.7 Nameplate

A permanently readable nameplate (figure 1) with the information listed below shall be securely attached to a visible location on the exterior of the CCR enclosure. If the nameplate is attached to a readily removable surface, such as a cover, the serial number shall be duplicated in a permanent conspicuous place elsewhere on the CCR.

Constant current regulator Manufacturer's name and part number: _____ Number of current steps: _____ Input: Volts Hertz Remote control voltage: _____ Volts d.c. or serial physical layer: Output: kVA at 6,6 Amperes. Maximum output voltage: _ Volts. Serial number: _____ Year of manufacture: _____
--

IEC 1609/02

Figure 1 – Nameplate

5.5.8 Instruction manual

The manufacturer shall specify in its instruction manuals the conditions for the installation, operation and maintenance of the CCR and the equipment contained herein.

The instructions for the transport, installation and operation of the CCR shall indicate the measures that are of particular importance for the proper and correct installation, commissioning and operation of the CCR.

The instruction manual shall include the following:

- theory of operation;
- wiring and control diagrams;
- general operation;
- installation instructions;
- preventive maintenance;
- parts list;
- troubleshooting;
- revision information including firmware (if applicable);
- options.

5.6 Protection against electric shock

CCRs shall be provided with protection against electric shock in accordance with the fundamental rules outlined in IEC 61140.

For provision of equipotential bonding and connection of protective conductors refer to IEC 60439-1.

The degree of protection provided by the cabinet containing a CCR assembly against contact with live parts or ingress of solid bodies and liquid shall be indicated by the IP designation, according to IEC 60529.

For CCR assemblies for indoor use where there is no requirement for protection against ingress of water, the degree of protection shall be at least IP2X after installation in accordance with the manufacturer's instructions.

For assemblies for outdoor use having no supplementary protection, the second numeral shall be at least 3.

High voltage equipment (1 000 V or greater), including the power transformer, shall be isolated from the low voltage equipment either by construction when they are in the same assembly, or by inclusion in a separate switchgear assembly.

The internal access plates shall be fitted with the appropriate IEC warning label.

5.7 Optional accessories

5.7.1 Earth fault monitor

An earth fault indicator may be built into the CCR for monitoring its own output circuit and shall be designed in one of the following ways.

- When the CCR is in a brightness step, it shall be designed to apply a d.c. voltage of 500 V maximum on the output series circuit relative to ground or earth potential.
- When the CCR is disconnected, it shall be designed to apply a d.c. voltage of 1 000 V maximum on the output series circuit relative to ground or earth potential.

The earth fault indicator shall be able to detect an insulation resistance with a minimum range of 10 k Ω to 50 M Ω .

The insulation resistance reading shall be independent of the current step setting, and of the location of the fault. The fault shall be measured permanently as soon as the local switch is on "remote control" position or on a current step setting. If operated at voltages exceeding 70 V d.c., when the CCR is in local-off, this control device shall be automatically switched off.

At least two thresholds (warning and alarm), determined in relation to the local operational requirement of the airport, shall be offered with information available locally and remotely.

5.7.2 Load indicator

A load indicator may be installed in the CCR in order to indicate the amount of load on the CCR.

5.7.3 Lamp fault indicator

A lamp fault detector may be installed in the CCR to detect a pre-determined number of burnt out lamps on the series circuit. The resolution shall be 2 % of total number of lamps where the total number of lamps exceeds 100. Where the total number of lamps is less than 100, the resolution shall be 1 lamp. Detection shall operate, at a minimum, the top two steps of both CCR types and for all loads between 25 % and 100 % of the nominal load.

At least two thresholds (warning and alarm) for the number of lamps out of service shall be available. These thresholds shall be adjustable from two times the actual accuracy. Local visual indication shall be provided as well as remote indication when a lamp out warning or alarm has occurred.

5.7.4 Output lightning arrestors

The CCR may be fitted with output lightning arrestors. Where fitted, lightning arrestors of the size necessary to protect the CCR shall be installed across the CCR output terminals. The ground side of the arrestors shall be connected to the earth terminal of the enclosure or other suitable earth ground location. The lightning arrestors shall have the capability to withstand a pulse on the output circuit consisting of a 10 μ s by 20 μ s current surge of 15 000 A with a subsequent power-follow current and a voltage surge of 10 000 V/ μ s minimum without damaging the CCR.

5.7.5 Field circuit isolator

The CCR may contain an integral isolating device to allow the isolation of the outgoing field cables for the purpose of load disconnection, cable insulation resistance testing, and ground search capability. When operated, the device shall short out the CCR output terminals and provide access for instrument connection to both of the load side terminals. Facility shall be provided for earthing the primary series circuit.

5.7.6 Non-illumination current step

A non-illumination current step may be offered to allow the use of accessory devices on the series circuit. The minimum nominal current value shall be 1,8 A r.m.s. The accuracy of this option need not meet the intentions of table 1.

5.7.7 Out of range indicator

The CCR may contain an out of range indicator for the series circuit. This indicator shall be installed on the CCR front panel that displays a warning when the current measured for the selected current step is not within the limits of table 1.

5.7.8 Output ammeter

An r.m.s. reading ammeter may be installed on the front panel of the CCR to indicate output current. The accuracy shall be better than or equal to ± 1 % of the full range (i.e. 6,6 A).

6 Qualification and test requirements

6.1 Type tests

The type tests shown in table 3 aim at ensuring that the design of the CCR is able to comply with this specification. Any certification report shall mention compliance to this specification and to any applicable standard.

Each CCR design type shall be tested with the largest power rating for each enclosure size. All tests shall be performed with all optional accessories offered by the manufacturer, which are defined in 5.7.

The ambient temperature shall be measured during the last quarter of the test period by means of at least two thermometers or thermocouples equally distributed around the CCR assembly. The ambient temperature may be in the range from +10 °C to +40 °C. For the temperature rise test (see 7.8.10) the upper limit may be reduced to +20 °C.

In case the CCR is made of several subassemblies, the type test shall be run on a complete assembly containing subassemblies wired per the manufacturer's instruction manual. The test results for the CCR and each subassembly shall be recorded.

6.2 Routine tests

The following tests, shown in table 3, shall be carried out at the factory on every CCR assembly when it is assembled in accordance with a previously accepted type or through the exclusive use of parts and accessories specified or supplied by the manufacturer for this purpose and already approved.

The following minimum routine tests shall be undertaken at an ambient temperature in the range from +10 °C to +40 °C. Additionally, the CCR shall be checked for compliance with the particular requirements of the purchase order/contract. This check shall at least comprise, but not be limited to, specific controls, signalling and/or marking.

The results of the routine tests shall be recorded in the test protocol. A copy of these results shall be included with each CCR.

NOTE The performance of the routine tests at the factory does not relieve the contractor installing the CCR from the duty of checking it after transport and installation.

Table 3 – Type and routine tests

Test	Type test	Routine test	reference
Visual inspection	X	X	7.1
Safety	X	X	7.2
Operation	X	X	7.7
Regulation (resistive load)	X	X	7.8.1.1
Regulation (reactive load)	X		7.8.1.2
Efficiency	X		7.8.2
Power factor	X	X	7.8.3
Output current surge	X		7.8.4
Dynamic response	X		7.8.5
Power supply interruptions	X		7.8.6
Output waveforms	X		5.4.2
Mechanical operation	X	X	7.8.7
EMC	X		7.8.8
BIL	X		7.3.2
Lightning arrestors	X		7.8.9
Temperature rise	X		7.8.10
Low temperature	X		7.9.1
High temperature	X		7.9.2

7 Tests description for type tests

Calibrated r.m.s. measuring equipment with an accuracy class at least twice the specified accuracy for the parameter to be measured shall be used. Calibration shall be traceable. When a variation from a following test description is applicable in the corresponding re-qualification or routine production tests, the variation is explicitly recorded.

7.1 Visual inspection

The equipment shall be visually inspected for compliance with:

- manufacturer's data sheet;
- manufacturer's drawings;
- manufacturer's instruction manual;
- this standard regarding name plate position and content;
- presence of the safety warnings;
- presence and size of power, earthing and control terminals;
- presence of equipment (rolling castors, lifting rings, etc.) specified in this International Standard.

7.2 Protection against electric shock

7.2.1 Verification of protection by enclosures

The specified degree of protection provided by enclosures shall be verified in accordance with procedures specified in IEC 60529.

7.2.2 Verification of clearances and creepage distances

It shall be verified that the clearances and creepage distances comply with values which are consistent with the rated insulation voltages. Tables 14 and 16 included in IEC 60439-1 contain minimum values for clearances and creepage distances for low voltage circuits. If necessary, the clearances and creepage distances have to be verified by measurements, taking account of possible deformation of parts of the enclosure or of the internal screens, including possible changes in the event of a short-circuit.

NOTE The rated insulation voltage is a voltage value to which dielectric test voltages and creepage distances are referred. It is assumed that the maximum rated operational voltage of any circuit of the CCR will not, even temporarily, exceed 110 % of its rated insulation voltage.

7.3 Dielectric test

7.3.1 Power frequency and d.c. tests

The dielectric strength shall be checked as follows:

- between output terminals and earth in accordance with 8.3.2.1 and 8.2.3.1a) of IEC 60439-1, with the test voltage being twice the rated insulation voltage plus 2 500 V r.m.s., with the rated insulation voltage being 1,1 times the maximum operating voltage (when the CCR is operating at maximum rated output current). During this test the control terminals and low voltage circuitry shall be earthed;
- low voltage input terminals and earth (output and control terminals being earthed) in accordance with 8.3.2.1 and 8.2.3.1a) of IEC 60439-1.

7.3.2 Basic impulse insulation level (BIL) test for power transformer

Basic lightning impulse insulation level (BIL) testing of the CCR's power transformer shall be performed on both the primary and secondary windings. The terminals of each winding shall be connected together to the high impulse generator. All other terminals and the core shall be grounded. Testing shall be performed with a 1,2 μ s rise time x 50 μ s fall time wave shape at the nominal peak levels shown below (table 4) with a negative polarity. One reduced, two chopped and one full impulse wave shall be applied.

Table 4 – BIL test

Transformer size	Primary BIL			Secondary BIL		
	Reduced wave	Chopped wave	Full wave	Reduced wave	Chopped wave	Full wave
	kV Peak	kV Peak	kV Peak	kV Peak	kV Peak	kV Peak
Under 10 kVA	7	10	10	7	10	10
10 kVA & 15 kVA	7	10	10	12	20	20
20 kVA, 25 kVA & 30 kVA	7	10	10	18	30	30

7.4 Enclosure temperature test

The CCR shall be installed and wired per manufacturer's instruction manual. The clearances around the CCR shall be at the minimum specified by the instruction manual.

The enclosure temperature test shall be carried out as follows.

- Connect the CCR to a nominal power source and a nominal resistive load.
- Adjust the CCR for supplying a nominal output current until the temperature has stabilized (no variation in excess of 1 °C for a period of 1 h). Record the highest temperature spot on the enclosure. Verify that the temperature on the enclosure does not exceed 15 °C above the ambient temperature. Record the temperature.

7.5 Leakage test

A leakage test shall be carried out as follows.

- a) Connect the CCR to a nominal power source and a nominal resistive load.
- b) Connect a milliamperemeter having impedance of less than $1\ \Omega$ in the earthing connection.
- c) Vary the CCR output current level and record the maximum milliamperemeter reading for any current step. Verify that the reading is less than 10 mA.

7.6 Test of protective devices

7.6.1 Open circuit test

An open circuit test (see 5.3.12.1) shall be carried out as follows.

- a) Force or adjust the CCR output current to between 1,30 A and 1,50 A. Check that the power to the output transformer is switched off within 1 s.
- b) De-energize the CCR. Remove the load circuit from the output of the CCR.
- c) Re-energize the CCR into the highest current step. Check that the power to the output transformer is switched off within 1 s and record the maximum output voltage.

The open circuit peak voltage before operation of the protective circuitry should not exceed twice the nominal r.m.s. output voltage (rated r.m.s. output kVA divided by the r.m.s. output current).

7.6.2 Overcurrent test

See 5.3.12.2.

- a) Force or adjust the CCR output current to more than 6,75 A and check that the power to the output transformer is cut off within 3 - 5 s.
- b) Force or adjust the CCR output current to more than 8,30 A. Check that the power to the output transformer is cut off within 300 ms.

7.7 Operation test

By applying a nominal supply voltage and control signals insulated from earth, check that the CCR is fully responding to the signals and that local and remote signalling follows the actual operation (see 5.3.7).

In order of precedence, reference shall be made to this specification, then to the CCR data sheet, then to the instruction manual.

The following procedures shall be carried out.

- a) Circuit breakers, fuses, safety switches, etc. shall be checked.
- b) Local ON/OFF and current step selection shall be checked.
- c) Remote ON/OFF and current step selection of the CCR shall be verified at all current steps by inserting a $215\ \Omega$ resistor (+48 V d.c. control) in series with all lines of the remote control circuitry except for the common lead of the control power line. Operate the CCR remotely on all current steps at the rated output load to verify compliance.
- d) Verify that when the control switch is in the local position, changes in the remote control status shall have no effect.