

# INTERNATIONAL STANDARD

**IEC**  
**61892-5**

First edition  
2000-08

---

---

## **Mobile and fixed offshore units – Electrical installations –**

### **Part 5: Mobile units**

*Unités mobiles et fixes en mer –  
Installations électriques –*

*Partie 5:  
Unités mobiles*



Reference number  
IEC 61892-5:2000(E)

## Numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series.

## Consolidated publications

Consolidated versions of some IEC publications including amendments are available. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

## Validity of this publication

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology.

Information relating to the date of the reconfirmation of the publication is available in the IEC catalogue.

Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is to be found at the following IEC sources:

- **IEC web site\***
- **Catalogue of IEC publications**  
Published yearly with regular updates  
(On-line catalogue)\*
- **IEC Bulletin**  
Available both at the IEC web site\* and as a printed periodical

## Terminology, graphical and letter symbols

For general terminology, readers are referred to IEC 60050: *International Electrotechnical Vocabulary (IEV)*.

For graphical symbols, and letter symbols and signs approved by the IEC for general use, readers are referred to publications IEC 60027: *Letter symbols to be used in electrical technology*, IEC 60417: *Graphical symbols for use on equipment. Index, survey and compilation of the single sheets* and IEC 60617: *Graphical symbols for diagrams*.

\* See web site address on title page.

# INTERNATIONAL STANDARD

# IEC 61892-5

First edition  
2000-08

---

---

## Mobile and fixed offshore units – Electrical installations –

### Part 5: Mobile units

*Unités mobiles et fixes en mer –  
Installations électriques –*

*Partie 5:  
Unités mobiles*

© IEC 2000 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission  
Telefax: +41 22 919 0300

3, rue de Varembé Geneva, Switzerland  
e-mail: [inmail@iec.ch](mailto:inmail@iec.ch)

IEC web site <http://www.iec.ch>



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

PRICE CODE

U

*For price, see current catalogue*

## CONTENTS

	Page
FOREWORD .....	3
INTRODUCTION .....	5
Clause	
1 Scope .....	6
2 Normative references .....	6
3 Definitions .....	7
4 General requirements .....	8
5 Limits of inclination of the unit .....	9
6 Bilge pumps .....	9
7 Navigation lights .....	10
8 Steering gear .....	10
9 Electric propulsion .....	13
10 Dynamic positioning .....	22
11 Ballast systems .....	22
12 Jacking systems .....	24
13 Anchoring systems .....	26
Bibliography .....	28

IECNORM.COM: Click to view the full PDF of IEC 61892-5:2000

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MOBILE AND FIXED OFFSHORE UNITS –  
ELECTRICAL INSTALLATIONS –**

**Part 5: Mobile units**

**FOREWORD**

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61892-5 has been prepared by IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units.

The text of this standard is based on the following documents:

FDIS	Report on voting
18/885/FDIS	18/886/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

Upon authorization by national maritime administrations, classification societies carry out statutory work on their behalf. Relevant rules of a classification society need to be approved by the national maritime administration, and may differ worldwide

The requirements specified in this International Standard are based on the Code for the Construction and Equipment of Mobile Offshore Drilling Units (1989 MODU CODE) published by the International Maritime Organization (IMO), and might include additional provisions.

This part of IEC 61892 supersedes IEC publication 60092-505, third edition (1984) and its amendment 1 (1993).

This publication has been drafted in accordance with the ISO/IEC Directives, Part 3.

A bilingual version of this standard may be issued at a later date.

IEC 61892 consists of the following parts, under the general title: *Mobile and fixed offshore units – Electrical installations*:

Part 1: General requirements and conditions

Part 2: System design

Part 3: Equipment

Part 4: Cables

Part 5: Mobile units

Part 6: Installation

Part 7: Hazardous areas

The committee has decided that the contents of this publication will remain unchanged until 2005-12. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

IECNORM.COM: Click to view the full PDF of IEC 61892-5:2000  
Withdrawn

## INTRODUCTION

IEC 61892 forms a series of International Standards intended to ensure safety in the design, selection, installation, maintenance and use of electrical equipment for the generation, storage, distribution and utilization of electrical energy for all purposes in offshore units used for exploration or exploitation of petroleum resources.

This standard is based on equipment and practices which are in current use, but it is not intended in any way to impede development of new or improved techniques.

The ultimate aim has been to produce a set of International Standards exclusively for the offshore petroleum industry.

In this part of IEC 61892, reference is made to other parts of the standard, which are still in preparation. Footnotes are attached to such references. A footnote indicates which current standard should be used until the part in preparation is published.

IECNORM.COM: Click to view the full PDF of IEC 61892-5:2000

Withdram

# MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

## Part 5: Mobile units

### 1 Scope

This part of IEC 61892 specifies the characteristics for electrical installations in floating units, for use during transfer from one location to another and for use during the exploration and exploitation of petroleum resources.

NOTE Attention is drawn to further requirements concerning electrical installations on such mobile offshore units contained in the MODU CODE of the International Maritime Organization (IMO).

### 2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of IEC 61892. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of IEC 61892 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 60034-1:1996, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-6:1991, *Rotating electrical machines – Part 6: Methods of cooling (IC Code)*

IEC 60092-201, *Electrical installations in ships – Part 201: System design – General*

IEC 60092-401:1980, *Electrical installations in ships – Part 401: Installation and test of completed installation*  
Amendment 1 (1987)  
Amendment 2 (1997)

IEC 60332-1:1993, *Tests on electric cables under fire conditions – Part 1: Test on a single vertical insulated wire or cable*

IEC 61892-3:1999, *Mobile and fixed offshore units – Electrical installations – Part 3: Equipment*

IEC 61892-6:1999, *Mobile and fixed offshore units – Electrical installations – Part 6: Installation*

*IMO Guidelines for vessels with dynamic positioning systems* – see IMO/Circ. 645, Annex, International Maritime Organization

IMO 904E, *Convention on the International Regulations for Preventing Collisions at Sea*, International Maritime Organization

### 3 Definitions

For the purposes of this part of IEC 61892, the following definitions apply.

#### 3.1

##### **auxiliary steering gear**

equipment, other than any part of the main steering gear, necessary to steer the unit in the event of failure of the main steering gear but not including the tiller, quadrant or components serving the same purpose

#### 3.2

##### **dynamic positioning (DP) system**

equipment necessary to provide means of controlling the position and heading of a mobile unit within predetermined limits by means of resultant vectored thrust

#### 3.3

##### **electrical coupling**

coupling in which the torque is transmitted by the interaction of the magnetic field produced by magnetic poles on one rotating member and induced current in the other rotating member

NOTE 1 The magnetic field may be produced by direct current excitation, permanent magnet excitation, or alternating current excitation. The induced current may be carried in a cage or insulated winding or may be present as eddy current.

NOTE 2 Couplings utilizing a wound secondary winding or a cage winding are known as slip or magnetic couplings. Couplings utilizing eddy-current effects are known as eddy-current couplings.

#### 3.4

##### **electric steering gear**

power operated steering gear where an electric motor applies torque to the rudder stock through mechanical means only

#### 3.5

##### **electrohydraulic steering gear**

power operated steering gear where a hydraulic pump, driven by an electric motor, applies torque to the rudder stock through hydraulic and mechanical means

#### 3.6

##### **main steering gear**

machinery, rudder actuators, steering gear power units and ancillary equipment and the means of applying torque to the rudder stock (for example tiller or quadrant) necessary for effecting movement of the rudder for the purpose of steering the unit under normal service conditions

#### 3.7

##### **petroleum**

complex mixture of hydrocarbons that occurs in the earth in liquid, gaseous or solid forms

#### 3.8

##### **propulsion machine (electric)**

rotating machine normally intended to provide propulsive power

#### 3.9

##### **redundancy**

in an item, the existence of more than one means for performing a required function

### 3.10

#### **semiconductor convertor**

static device using semiconducting elements to convert electric energy from one state to another

### 3.11

#### **steering gear control system**

equipment by which orders are transmitted from the navigating bridge to the steering gear power units

NOTE Steering gear control systems comprise transmitters, receivers, hydraulic control pumps and their associated motors, motor controllers, piping and cables, etc.

### 3.12

#### **steering gear power unit (electric steering gear)**

electric motor and its associated electrical equipment used to operate the steering gear

### 3.13

#### **steering gear power unit (electrohydraulic steering gear)**

electric motor and its associated electrical equipment and connected pump used to operate the steering gear

## 4 General requirements

4.1 In every mobile unit in which electric power is used for the services necessary for the safety of the unit, the generators, switchgear, motors and associated control gear for such services, with the exception of machinery in the platform of semi-submersibles, shall be so situated or arranged that they continue to operate satisfactorily in the event of partial flooding by bilge water above the tank top in the space in which they are situated. The design criterion for partial flooding shall be assumed to be a depth of water  $1/12^{\text{th}}$  beam but not exceeding a depth of 1,5 m except where this requirement is impracticable for horizontally mounted propulsion generators and motors. In such circumstances the machine enclosures shall, at least, be watertight to the underside of the shaft.

4.2 Rotating machines shall be installed to minimise the effects of motion. The design of bearings of all machines and the arrangement for their lubrication shall be adequate to withstand the motions encountered in heavy weather and operation for prolonged periods at the list and trim specified in clause 5 without the spillage of oil.

4.3 Conductors and equipment shall be placed at such a distance from each magnetic compass or shall be so disposed that the interfering external magnetic field is negligible; that is, the total singular deviation shall not exceed 30 minutes when any combination of circuits is switched on and off.

4.4 Where the total installed electrical power of the main generators exceeds 3 MW the busbars of the main switchboard shall be subdivided into at least two parts. The subdivision may be effected by removable links, circuit-breakers or other suitable means so that the main generators and any supplies to duplicated services which are directly connected to the busbars are, as far as is practicable, equally divided between the sections.

## 5 Limits of inclination of the unit

**5.1** Dependent upon the outcome of all studies relevant to the intact and damaged stability of the unit, the appropriate authority may require or permit deviations from the angles stated in 5.2, 5.3 and 5.4.

**5.2** All machines and apparatus shall operate satisfactorily under all conditions with the unit upright and when inclined up to the following angles from the normal:

- for column stabilized units, 15° in any direction;
- for self-elevating units, 10° in any direction;
- for surface units, 15° either way in list and simultaneously trimmed 5° by the bow or stern.

**5.3** Main propulsion machinery and all auxiliary machinery essential to the propulsion and safety of the mobile unit shall be capable of operating under the static conditions specified in 5.2 and the following dynamic conditions:

- for column stabilized units, 22° 30' in any direction;
- for self-elevating units, 15° in any direction;
- for surface units, 22° 30' rolling and simultaneously pitching 7° 30' by the bow or stern.

**5.4** Emergency machines and apparatus fitted in accordance with requirements from the appropriate authority for emergency plant shall operate satisfactorily under all conditions with the unit upright and when inclined up to the following maximum angles from the normal:

- for column stabilized units, 25° in any direction;
- for self-elevating units, 15° in any direction;
- for surface units, 22° 30' about the longitudinal axis and/or when inclined 10° about the transverse axis.

**5.5** Where required by the appropriate authority, dynamic condition limits shall apply as follows:

- rotation about fore-and-aft axis (rolling),  $\pm 22^{\circ} 30'$
- rotation about athwartship (pitching),  $\pm 7^{\circ} 30'$

NOTE These motions may occur simultaneously.

## 6 Bilge pumps

**6.1** Motors of permanently installed emergency bilge pumps, if any, shall be connected to an emergency switchboard.

**6.2** Cables and their connections to submersible pumps shall be capable of operating under a head of water equal to their distance below the worst damaged condition waterline. The cables shall either be armoured or mechanically protected by other means and shall not be installed within the assumed extent of damage. They shall be installed in continuous lengths from above the worst damaged condition waterline to the motor terminals, entering the air-bell from its underside.

**6.3** Under all circumstances it shall be possible to start the motor of a permanently installed bilge pump from a convenient point above the worst damaged condition waterline and in a space not within the assumed extent of damage.

NOTE The worst damaged condition waterline and the spaces within the assumed extent of damage shall be in accordance with IMO requirements.

## 7 Navigation lights

**7.1** Except when a unit is stationary and engaged in operations, attention is drawn to IMO 904E, the Convention on the International Regulations for Preventing Collisions at Sea.

**7.2** When a unit is stationary and engaged in operations, attention is drawn to the requirements for the safety of navigation of the coastal state in whose territorial sea or on whose continental shelf the unit is operating.

**7.3** All units shall be provided with "steaming lights" which comprise masthead, side, stern, anchor, not-under-command and, if applicable, special-purpose lights. The construction and installation of navigation lights shall be to the satisfaction of the appropriate authority.

**7.4** Attention is drawn to the Collision Regulations in relation to the provision of primary and alternative lanterns for each of the navigation lights.

**7.5** The following electrical arrangements relate only to the navigation lights referred to in 7.3 and 7.4.

- Each light shall be connected by a separate cable to a distribution board reserved solely for navigation lights, fitted in an accessible place under the control of watchkeeping personnel.
- There shall be two separate power supply systems to the distribution board, one being from the main switchboard and one from the emergency switchboard. Where a transitional source of emergency power is required by the Safety of Life at Sea (SOLAS) Convention, the arrangements shall enable the lights to be supplied from this source in addition to the emergency switchboard.
- So far as is practicable, the arrangements should be such that a fire, a fault or mechanical damage at any one point will not render both systems inoperative. It is, however, accepted that the systems must come together at some point where the changeover can be effected. This should, preferably, be at or near to the distribution board.
- Each light shall be controlled and protected in each insulated pole by a switch and fuse or by a circuit-breaker mounted in the distribution board.
- Each light shall be provided with an automatic indicator to give an acoustic and/or optical alarm in the event of a lamp failure. If an optical signal is used, which is connected in series with the steaming light, means to prevent failure of the indicator extinguishing the steaming light shall be provided. If an acoustic device alone is used it shall be connected to an independent source of supply, for example a battery, and provision shall be made for testing this supply.

## 8 Steering gear

### 8.1 Power operated steering gear

**8.1.1** Electric and/or electrohydraulic steering gear shall be used for the power-operated main and auxiliary steering gear required by the appropriate authorities.

**8.1.2** The electrical systems of the main steering gear and auxiliary steering gear shall be so arranged that any failure in one of the steering gears will not render inoperative the electrical systems of the other steering gear.

When an auxiliary steering gear is not required by the appropriate authorities and the main steering gear comprises two or more power units, the electrical system for each power unit shall be so arranged that the failure of one of them will not render the other units inoperative.

## 8.2 Motors

**8.2.1** To determine the required characteristics of the electric motors for power units, the breakaway torque and maximum working torque of the steering gear under all operating conditions shall be used. The ratio of pull-out torque to rated torque shall be at least 1,6.

**8.2.2** The rating shall be determined on the basis of the steering gear characteristics of the subject unit as specified in 8.2.2.1 and 8.2.2.2.

NOTE Motors for steering gear power units may be rated for intermittent power demand.

**8.2.2.1** For motors of electric steering gear power units the rating shall be as follows:

S3 – 40 % in accordance with IEC 60034-1.

**8.2.2.2** For motors of electrohydraulic steering gear power units and for converters the rating shall be as follows:

S6 – 25 % in accordance with IEC 60034-1.

## 8.3 Motor starters

Each electric motor of a main or auxiliary steering gear power unit shall be provided with its own separate motor starter gear either located within the steering gear compartment or in the supply switchboard rooms (see 8.1.2).

## 8.4 Power circuits supply

**8.4.1** Each electric or electrohydraulic steering gear comprising one or more power units should, except as otherwise permitted by the appropriate authorities, be served by at least two exclusive circuits, one fed directly from the main switchboard and one of the circuits shall be supplied through the emergency switchboard.

NOTE An auxiliary electric or electrohydraulic steering gear associated with a main electric or electrohydraulic steering gear may be connected to one of the circuits supplying the main steering gear.

**8.4.2** The circuits supplying an electric or electrohydraulic steering gear shall have a continuous rating for supplying all electric motors and devices which can be simultaneously connected to them and may be required to operate simultaneously.

**8.4.3** For certain units specified by the appropriate authorities, an alternative power supply from the emergency source of electrical power or from an independent source of power located within the steering gear compartment, is required.

This power supply shall be activated automatically, within 45 s, in the event of power failure of the main source(s) of electrical power and shall meet the requirements of the appropriate authorities.

## 8.5 Supply of control circuits and control systems

**8.5.1** Each control for starting and stopping of motors for power units shall be served by its own control circuit supplied from its respective power circuit.

**8.5.2** Any electrical main and auxiliary steering gear control system shall be served by its own separate circuit supplied from a steering gear power circuit from a point within the steering gear compartment, or directly from switchboard busbars supplying that steering gear power circuit at a point on the switchboard adjacent to the supply to the steering gear power circuit.

## 8.6 Circuit protection

**8.6.1** Short-circuit protection shall be provided for each control circuit and each power circuit of electric or electrohydraulic main and auxiliary steering gear.

**8.6.2** No protection other than short-circuit protection shall be provided for steering gear control system supply circuits.

**8.6.3** Protection against excess current, if provided for power circuits, shall be for not less than twice the full load current of the motor or circuit so protected, and shall be arranged to permit the passage of the appropriate starting currents.

## 8.7 Starting and stopping of motors for steering gear power units

**8.7.1** Motors for power units shall be capable of being started and stopped from a position on the navigating bridge and from a point within the steering gear compartment.

Means shall be provided at the position of the motor starters for isolating any remote controlled starting and stopping devices.

**8.7.2** Main and auxiliary steering gear power units shall be arranged to restart automatically when power is restored after a power failure.

## 8.8 Steering gear control systems

**8.8.1** For the main steering gear, control for the steering gear shall be provided both on the navigating bridge and in the steering gear compartment.

**8.8.2** For the power operated auxiliary steering gear, control for steering gear shall be provided in the steering gear compartment and it shall also be operable from the navigating bridge and shall be independent of the control system for the main steering gear.

**8.8.3** When, in accordance with the appropriate authorities, an auxiliary steering gear is not installed and the main steering gear comprises two or more identical power units, two independent control systems shall be provided, both operable from the navigating bridge and the steering gear compartment.

NOTE This does not require duplication of the steering wheel or steering lever.

Where the control system includes a hydraulic telemotor, a second independent control system need not be fitted, except where specified by the appropriate authorities.

**8.8.4** The steering gear control system provided in accordance with 8.8.1, 8.8.2 and 8.8.3 shall be capable of being brought into operation from a position on the navigating bridge.

**8.8.5** Means shall be provided in the steering gear compartment for isolating any steering gear control system operable from the navigating bridge from the steering gear it serves.

## 8.9 Alarms and indications

**8.9.1** Means for indicating that the motors of electric and electrohydraulic steering gear are running shall be installed on the navigating bridge and at a suitable main machinery control position.

**8.9.2** Overload alarms shall be provided for motors of power units for all main and auxiliary steering gear.

**8.9.3** Where a three-phase power supply is used, an alarm shall be provided that will indicate failure of any one of the supply phases.

**8.9.4** In the event of a power failure to any one of the steering gear power units, an alarm shall be given.

**8.9.5** In the event of a power failure of electrical power supply to the control system, an alarm shall be given.

**8.9.6** A low level alarm for each hydraulic fluid reservoir shall be provided to give the earliest practicable indication of hydraulic fluid leakage.

**8.9.7** The alarms specified in 8.9.2 to 8.9.6 shall be both audible and visual and should be located as indicated in 8.9.1 and as specified by the appropriate authorities.

### **8.10 Rudder angle indication**

The angular position of the rudder shall be indicated on the navigating bridge. The rudder angle indication system shall be independent of the steering gear power and control systems and be supplied either through the emergency switchboard or by an alternative independent source of electric power.

NOTE The angular position of the rudder should be recognizable, in accordance with the appropriate authorities, in the steering gear compartment. The indication need not be electrical.

### **8.11 Separation of circuits**

Duplicated electric power circuits and their steering gear control systems with their associated components should be separated as far as practicable.

The corresponding cables should follow different routes, which should be separated both vertically and horizontally, as far as practicable, throughout their entire length.

### **8.12 Communication between navigating bridge and steering gear compartment**

A means of communication shall be provided between the navigating bridge and the steering gear compartment.

If electrical, it shall be fed through the emergency switchboard; if not, it shall be sound-powered.

## **9 Electric propulsion**

### **9.1 General**

Clause 9 is applicable to electric propulsion machinery and plants and deals with propulsion motors, propulsion generators and their prime movers, electrical couplings, excitation systems, semiconductor convertors, control monitoring, instrumentation and protection equipment and systems and wires and cables.

NOTE 1 Requirements applicable to propulsion systems may also be applicable to other consumers directly connected to the main electric propulsion system, the functioning of which may influence the propulsion or manoeuvrability of the unit.

NOTE 2 For semiconductor convertors, reference is made to IEC 61892-3 and IEC 61892-6

## 9.2 General requirements

### 9.2.1 Torque and critical speeds

**9.2.1.1** The normal torque available in the propulsion motors for manoeuvring shall be such as to enable the unit to be stopped or reversed, when the unit is travelling at its maximum service speed, in a time to be agreed between the builder and the manufacturers of the electrical propulsion equipment. This time shall be based on the estimated torque-speed characteristics of the propeller during manoeuvring and on other necessary characteristics supplied to the manufacturers of the electrical systems.

NOTE This subclause contains requirements that have to be agreed between manufacturer and purchaser.

**9.2.1.2** Adequate torque margin shall be provided in a.c. propulsion systems to guard against the motor pulling out of synchronism during rough weather, and on a multiple screw unit when turning, based on the information provided regarding propeller and unit characteristics.

**9.2.1.3** In order to prevent excessive torsional stresses and torsional vibrations of excessive magnitude, careful consideration shall be given to co-ordination of the mass constants and the elasticity constants of the entire propulsion system, and electrical characteristics in the system.

**9.2.1.4** The entire system, *inter alia*, includes prime movers, generators, convertors, exciters, motors, slip couplings, gearing, shafting and propeller.

**9.2.1.5** The electrical system shall be stable under all operating conditions, due regard being paid to switching transients, system recovery after fault and/or maloperation. Operation of the protection equipment shall also be reviewed under these conditions.

NOTE 1 Where generating sets also supply power to services other than propulsion, consideration should be given to the starting requirements of a.c. propulsion machines, such that this should be achieved within the limits of voltage and frequency transient values.

NOTE 2 Where generating sets also supply power to services other than propulsion, consideration should be paid to the priority of the consumers. Power management systems should be taken into consideration.

### 9.2.2 Lubrication

The lubrication of the bearings of propulsion motors, gearing and shafting shall be effective at all normal speeds from creep speeds upwards either ahead or astern.

The shafts and bearings shall not be damaged by slow rotation, whether or not electrical power is applied to the motor or whether or not such rotation is induced by the propeller, and under all predictable oil temperature conditions.

NOTE Where propeller motors can generate voltage due to rotation induced by the propeller, measures should be taken to avoid disturbances or damage of components and systems.

### 9.2.3 Prime movers

**9.2.3.1** Prime movers of any type shall be provided with a governor capable of maintaining the pre-set steady speed within a range not exceeding 5 % of the rated full-load speed for load changes from full-load to no-load.

Where the speed control of the propeller requires speed variation of the prime mover, the governor shall be provided with means for local manual control as well as for remote control.

In case of parallel operation of generators, the governing system shall permit stable operation to be maintained over the entire operational speed range of the prime movers.

**9.2.3.2** The prime mover rated power in conjunction with its overloading and load build-up capabilities shall supply the power needed during transitional changes in operating conditions of the electrical equipment due to manoeuvring and sea and weather conditions.

NOTE With respect to the above, special attention should be paid to diesel engines equipped with an exhaust gas-driven turbine blower for supercharging.

**9.2.3.3** When manoeuvring from full propeller speed ahead to full propeller speed astern with the unit making full way ahead, the prime mover shall be capable of absorbing a portion of the regenerated power without tripping due to overspeed.

The setting of the overspeed trip device shall be in accordance with the requirements of the appropriate authority and the amount of the regenerated power to be absorbed agreed to by the electrical and mechanical machinery manufacturers.

Means external to the mechanical and electrical rotating machinery should be provided in the form of phantom or dynamic braking resistors, or ballast consumers to absorb excess amounts of regenerated energy and to retard the speed of rotation of the propulsion motor.

NOTE 1 Alternatively, the amount of regenerated power may be limited by the action of the control system.

NOTE 2 This subclause contains requirements that have to be agreed between manufacturer and purchaser.

### **9.3 Generators, motors, semiconductor convertors and electric slip-couplings**

#### **9.3.1 Machine and equipment temperature and ventilation**

**9.3.1.1** When generators, motors or slip-couplings are fitted with an integral fan (see IEC 60034-6) and are operated at speeds below the rated speed with full-load torque, full-load current, full-load excitation, etc., temperature limits in accordance with table 2 of IEC 61892-3, shall not be exceeded.

**9.3.1.2** The temperature of the cooling air of machines provided with forced air ventilation, air ducts or air filters shall be continuously monitored by means of direct reading thermometers which are readable from outside the machine and by a remote audible alarm actuated by suitable temperature detectors.

For machines with a closed circuit cooling method with a heat exchanger, the flow of primary and secondary coolants shall be monitored.

Consideration shall be given to the necessity of providing equipment for detecting leakage of cooling liquid in a machine enclosure and operating an associated alarm.

NOTE Alternatively, monitoring of the winding temperature plus alarm may be accepted in lieu of flow alarm.

**9.3.1.3** If semiconductor convertors are fitted with forced-ventilation, monitoring means for the cooling system shall be provided.

In case of failure of the cooling system, an alarm shall be given and the current shall be reduced automatically. The alarm signal can be generated by the flow of the coolant, by the electrical supply to the ventilator or by the temperature of the diodes and thyristors.

NOTE Override of the automatic reduction, if necessary, can be considered.

**9.3.1.4** Stator windings of a.c. machines and interpole windings of d.c. machines, rated above 500 kW, shall be provided with temperature sensors.

### 9.3.2 Accessibility and facilities for repair *in situ*

**9.3.2.1** For the purposes of inspection and repair, provision shall be made for access to the stator and rotor coils and for the withdrawal and replacement of field coils.

**9.3.2.2** Facilities shall be provided for supporting the shaft to permit inspection and withdrawal of bearings.

**9.3.2.3** Adequate access shall be provided to permit the resurfacing of commutators and slip-rings, as well as the renewal and bedding of brushes.

**9.3.2.4** Slip-couplings shall be designed to permit removal as a unit without axial displacement of the driving and driven shaft, and without removing the poles.

**9.3.2.5** Convertors shall be easily accessible and arranged for quick repair and exchange of components.

### 9.3.3 Protection against moisture and condensate

Effective means shall be provided in propulsion machines and convertors to prevent accumulation of moisture and condensate, even if they are idle for appreciable periods (for example by means of space heaters).

### 9.3.4 Sudden short circuits

AC machines shall be capable of withstanding a short circuit at their terminals under rated conditions without suffering damage.

### 9.3.5 Overspeed of propulsion motors

The rotor of propulsion motors shall be capable of withstanding overspeeding up to the limit reached in accordance with the characteristics of the overspeed protection device at its normal operational setting.

### 9.3.6 Exciter sets

The obtainable current and voltage of exciters and their supply shall be suitable for the output required during manoeuvring and overcurrent conditions including short circuit.

For this reason, attention shall be paid to the strength of shafts and couplings of rotating sets and the power of their driving machines.

### 9.3.7 Semiconductor convertor design data

**9.3.7.1** The following limiting repetitive peak voltages shall be used as a base for the semiconductor valve:

- when connected to a supply specifically for propeller drives,  $U_{RM} = 1,5 U_P$ ;
- when connected to a common main supply,  $U_{RM} = 1,8 U_P$

( $U_P$  is the peak value of the rated voltage at the input of the semiconductor convertor.)

If the semiconductors are connected in series, the value mentioned above shall be increased by 10 %. Equal voltage distribution shall be ensured.

**9.3.7.2** When semiconductor convertors are used, means shall be taken, where necessary, to limit the effect of disturbances, both to the system and to other semiconductor convertors. The following are example of items that should be considered in relation to limiting the effect of disturbances:

- convertors when connected to the same busbar system;
- commutation reactance which, if insufficient, may result in voltage distortion adversely affecting other consumers on the system;
- the relation between the system subtransient reactance and the convertor;
- commutation reactance: unsuitable matching may result in the production of voltage harmonics which could cause overheating of other consumers;
- any adverse effect of convertors on the commutation of d.c. machines;
- any adverse effect, in the regenerating mode, if voltage drops on inverter operation;
- interference from high frequency noise.

When filter circuits and capacitors are used for reactive current compensation, the following items should be considered:

- any adverse effect of frequency variation on the r.m.s. and peak values of the system voltage;
- any adverse effect on the voltage regulation of generators.

**9.3.7.3** The following protection of convertors shall be provided:

- overvoltage in a supply system to which convertors are connected shall be limited by suitable devices to prevent damage. Protective fuses for these devices shall be monitored. A suitable control shall ensure that the permissible current of semiconductor elements cannot be exceeded during normal operation;
- short circuit currents shall be limited by specially adapted fuses. These semiconductor protective fuses shall be monitored. In case of fuse operation, the respective part of the plant shall be taken out of operation;
- fuses in filter circuits shall be monitored.

NOTE Consideration should be given to include excessive current ripple in the scheme of protection.

## **9.4 Controlgear**

### **9.4.1 Location of manoeuvring controls**

The main propulsion manoeuvring controls shall be located at a convenient place.

Whenever control outside the engine room is applied, an arrangement shall be provided whereby the propulsion plant can also be controlled from the engine room, or control room.

NOTE In systems equipped with variable pitch propellers, pitch indication should be integrated in the main control station.

### **9.4.2 Engine order systems**

Engine order systems shall be provided on self-propelled units.

NOTE Engine order telegraph systems or other means of engine order systems in accordance with the appropriate authorities can be considered.

### 9.4.3 Operation of manoeuvring controls

Either manual operation or operation with the aid of power or a combination of both shall be used.

In the case of manual operation, all manoeuvring switches, field-regulators and controllers shall be operable without undue effort.

If failure of power supply occurs in systems with power-aided control (e.g. with electric, pneumatic or hydraulic aid), it shall be possible to restore control in a short time.

When two or more control stations are provided outside the engine room, a selector switch or other means shall be provided for transferring the manoeuvring controls to the designated station.

Indication of which control station is in command shall be provided at the selector switch and at each control station. Simultaneous control from more than one control station shall not be possible.

Except for systems in which the control levers are electrically or mechanically interconnected in such a manner that each lever will be set to the same position, the changing of the control station shall be possible only when the control levers of the station in command and the incoming station are in the same position or when an acceptance signal set by the desired station is received. The control equipment shall be so arranged that in case of damage to the equipment outside the engine room, control can always be executed from the engine room or the engine control room manoeuvring control stations.

NOTE It is recommended that failure of power aid, when used, shall if possible not result in an interruption of the power to the propulsion shaft, but be indicated by an alarm.

### 9.4.4 Interlocking of the means of control

All control means for operating prime movers, set-up switches, contactors, field switches, etc., shall be interlocked to prevent their incorrect operation.

Access doors for switchgear and controlgear shall be locked to prevent access while equipment is energised, and shall be provided with a key available only to competent personnel.

## 9.5 Cables and wiring

### 9.5.1 Construction

9.5.1.1 The conductors of cables external to the components of the propulsion plant, other than cables and interconnecting wiring for computers, data loggers or other automation equipment requiring currents of very small value, shall consist of not less than seven strands and have a cross-sectional area of not less than 1,5 mm<sup>2</sup>.

9.5.1.2 The insulation of internal wiring in main control gear, including switchboard wiring, shall be of flame retardant quality in accordance with IEC 60332-1.

## 9.6 Main and control circuits

### 9.6.1 Circuitry and components

9.6.1.1 Systems having two or more propulsion generators, two or more semiconductor convertors or two or more motors on one propeller shaft shall be so arranged that any unit can be taken out of service and disconnected electrically.

**9.6.1.2** If a propulsion system contains only one generator and one motor and cannot be connected to another propulsion system, more than one exciter set should be provided for each machine. However, this is not necessary for self-excited generators or for multi-propeller propulsion units where any additional exciter set can be common for the unit.

**9.6.1.3** Every exciter set shall be supplied by a separate feeder.

**9.6.1.4** Field circuits shall be provided with means for suppressing voltage rise when a field switch is opened.

**9.6.1.5** For Ward-Leonard systems, arrangements for the generator excitation shall be such that if the motor excitation circuit is opened by a switch or contactor, the generator excitation circuit shall be simultaneously opened or the generator voltage shall be immediately reduced to zero.

In constant voltage systems with two or more independently controlled motors in parallel on the same generator(s), the armature circuit-breaker shall be tripped when an excitation circuit is opened by a switch or contactor.

When using semiconductor exciter sets, and when diodes or thyristors are necessary to protect the field coils against transient overvoltage or when they are used as free-wheeling diodes, the arrangement of the semiconductor fuses shall prevent opening of the excitation circuit.

Where fuses are used for excitation circuit protection, it is essential that they do not interrupt the field discharge resistor circuit upon rupturing.

**9.6.1.6** If a service generator is also used for propulsion purposes, other than for boosting the propulsion power, the components then being part of the propulsion circuit shall conform to the requirements of this standard.

**9.6.1.7** In regulation systems with feedback control special consideration shall be given to ensure a high degree of reliability.

**9.6.1.8** The design of the circuitry and components shall be such that failure of a control signal shall not cause an excessive increase in propeller speed.

The reference value transmitter in the control equipment shall be so designed that any defect in the desired value transmitters or in the cables between the control station and the propulsion system shall not cause a substantial increase in the propeller speed.

**9.6.1.9** It shall only be possible to start the engines when the control lever is in zero position and the plant is ready for operation.

NOTE Changing of manoeuvring responsibility should be possible without substantial change in propeller speed or direction or pitch as appropriate.

**9.6.1.10** Each control station shall have an emergency stop device which is independent of the control lever.

## **9.7 Protection of the system**

### **9.7.1 Protection**

**9.7.1.1** Overcurrent protection devices, if any, in the main circuits shall be set sufficiently high so that there is no possibility of their operating due to the overcurrent caused by manoeuvring or normal operation in heavy seas or in floating broken ice.

**9.7.1.2** For d.c. systems in which excessive overspeeding of the propulsion motor may occur, for example, at light loads or loss of a propeller, suitable overspeed protection shall be provided.

**9.7.1.3** Where separately driven d.c. generators are connected electrically in series, means shall be provided to prevent reversal of the rotation of a generator upon failure of the driving power of its prime mover.

**9.7.1.4** In excitation circuits, no overload protection shall cause the opening of the circuit.

**9.7.1.5** Means shall be provided for selective tripping or rapid reduction of the magnetic fluxes of the generators and motors to ensure that overcurrents do not reach values which may endanger the plant.

**9.7.1.6** Means for earth leakage detection shall be provided for main propulsion circuits, and shall be arranged to operate an alarm upon the occurrence of an earth fault. When the fault current flowing is liable to cause damage, tripping arrangements shall be provided.

NOTE Means should be provided for earth leakage detection in the excitation circuits of propulsion machines but may be omitted in circuits of brushless excitation systems and of machines rated up to 500 kW

**9.7.1.7** Consideration shall be given in the design of d.c. machines and their protective systems to the measures necessary to minimize damage in the event of short circuit.

**9.7.1.8** Semiconductor elements in semiconductor converters shall have fuse protection.

**9.7.1.9** If there is a possibility of blocking the propeller (for example during ice-breaking conditions) a protection against damage of the propulsion plant shall be provided.

## **9.7.2 Instrumentation**

At least the following instruments, in addition to those required in IEC 61892-3, shall be provided and mounted in the main control assembly or any other suitable location.

NOTE Attention should be paid to the effect of regenerated power on wattmeters and ammeters as the value may exceed those assumed in IEC 61892-3.

### **9.7.2.1 AC propulsion systems**

For each propulsion generator the following instrumentation shall be provided:

- ammeter for measuring each phase;
- voltmeter for measuring each phase;
- three-phase wattmeter;
- tachometer or frequency meter.

NOTE 1 When the rated power of semiconductors is a substantial part of the rated power of the generators, the voltmeters of the generator(s) should display the arithmetical mean value of the voltage.

NOTE 2 Alternatively for multi-generator systems, switched voltmeters and frequency meters may be used. A power factor meter or a kilovarmeter or a field ammeter will also be required if generators are to be operated in parallel.

For propulsion generators rated above 500 kW the following instrumentation shall be provided:

- a temperature indicator for reading directly the temperature of the stator windings.

For propulsion motors fed from the main electrical system the following instrumentation shall be provided:

- an ammeter for the main current of each motor and an ammeter for the field current of each synchronous motor.

For propulsion motors rated above 500 kW the following instrumentation shall be provided:

- a temperature indicator for reading directly the temperature of the motor windings.

For each propeller shaft the following instrumentation shall be provided:

- a speed indicator.

For semiconductor convertors the following instrumentation shall be provided:

- an ammeter for each bridge connection of semiconductors.

### 9.7.2.2 DC propulsion systems

For each propulsion generator the following instrumentation shall be provided:

- an ammeter;
- a voltmeter;
- a field ammeter.

For each propulsion motor the following instrumentation shall be provided:

- a field ammeter.

For propulsion motors fed from the main electrical system the following instrumentation shall be provided:

- an ammeter for the armature current of each motor.

For propulsion motors fed from semiconductor convertors the following instrumentation shall be provided:

- an ammeter for the armature current of each motor;
- a voltmeter for the armature voltage of each motor;
- an ammeter in the input of each parallel bridge circuitry of the convertor.

For propulsion motors rated above 500 kW the following instrumentation shall be provided:

- a warning for excessive temperature of the interpole windings.

For each propeller shaft the following instrumentation shall be provided:

- a speed indicator.

**9.7.2.3** When two or more control stations are provided for variable speed propellers, a propeller speed indicator shall be provided at each control station.

**9.7.2.4** Where control outside the engine room is used, instruments giving the necessary information on the main electric propulsion system shall be installed at the convenient location near such a station.

**9.7.2.5** The control station of the propulsion system shall have at least the following indications for each propeller:

- ready for operation – power circuits and necessary auxiliaries are in operation;
- faulty – propeller is not controllable;
- power limitation – in case of disturbance, for example, in the ventilators for propulsion motors, in the convertors, cooling water supply or load limitation of the generators.

NOTE See also 9.2.

## 9.8 Testing

The standard tests for individual items of equipment shall be carried out as specified in IEC 61892-6.

NOTE 1 As far as practicable, all standard acceptance tests should be carried out at the manufacturer's works.

NOTE 2 The dock and sea trial test should be carried out including duration runs and manoeuvring tests. These should include a reversal of the unit from full speed ahead to full speed astern, tests for operation of all protective devices and stability tests for control. All tests necessary to demonstrate that each item of plant and the system as a whole are satisfactory for duty should be performed. Immediately prior to and after trials the insulation resistance should be measured and recorded.

## 10 Dynamic positioning

### 10.1 General

**10.1.1** Attention is drawn to the provisions in the IMO Guidelines for vessels with dynamic positioning systems (see IMO/Circ. 645, Annex).

NOTE IMO has established guidelines for equipment levels and redundancy on DP-vessels. There are three equipment levels, denoted as equipment classes 1, 2 and 3. The class of vessel required for a particular operation should be determined on the basis of a risk analysis into the consequences of a loss of position:

- equipment class 1: loss of position may occur in the event of a single fault;
- equipment class 2: loss of position is not to occur in the event of a single fault in any active component or system;
- equipment class 3: redundancy of all components and physical separation of the components against compartment fire or flood.

## 11 Ballast systems

### 11.1 General

Units shall be provided with an efficient pumping system capable of ballasting and deballasting any ballast tank under normal operating and transit conditions.

NOTE On jack-up units, ballast systems may not be required.

### 11.2 Ballast pumps

**11.2.1** Motors of ballast pumps shall be capable of connection to an emergency switchboard.

**11.2.2** The ballast system shall be capable of operation after the loss of any single component in the power supply system.

**11.2.3** The ballast system shall still be capable of operation when the unit is:

- under the inclination expected in the operational condition as stated in clause 5; and
- powered via the emergency switchboard, with the unit in the “damaged condition” specified by the appropriate authority.

### 11.3 Control and indicating systems

**11.3.1** A central ballast control station shall be provided. It shall be located above the worst damage waterline and adequately protected from the weather. It shall be provided with the following control and indicating system where applicable:

- a) ballast pump control system;
- b) ballast pump status-indicating system;
- c) ballast valve control system;
- d) ballast valve position-indicating system;
- e) tank level indicating system;
- f) draught indicating system;
- g) heel and trim indicators;
- h) power availability-indicating system (main and emergency);
- i) ballast system hydraulic/pneumatic pressure-indicating system.

**11.3.2** In addition to remote control of the ballast pumps and valves from the central ballast control station, all ballast pumps and valves shall be fitted with independent local control operable in the event of remote control failure. The independent local control of each ballast pump and of its associated ballast tank valves shall be in the same location.

**11.3.3** The control and indicating systems listed in 11.3.1 shall function independently of one another, or have sufficient redundancy, such that a failure in one system does not jeopardize the operation of any of the other systems.

**11.3.4** Each power-actuated ballast valve shall fail to the closed position upon loss of control power. Upon the reactivation of control power, each such valve shall remain closed until the ballast control operator assumes control of the reactivated system. The appropriate authority may accept ballast valve arrangements that do not fail to the closed position upon loss of power, provided the appropriate authority is satisfied that the safety of the unit is not impaired.

**11.3.5** The tank level-indicating system specified in 11.3.1e) shall provide means to:

- a) indicate liquid levels in all ballast tanks. A secondary means of determining levels in ballast tanks, which may be a sounding pipe, shall be provided. Tank level sensors shall not be situated in the tank suction lines;
- b) indicate liquid level in other tanks, such as fuel oil, fresh water, drilling water or liquid storage tanks, the filling or emptying of which, in the view of the appropriate authority, can affect the stability of the unit. Tank level sensors shall not be situated in the tank suction lines.

**11.3.6** The draught-indicating system specified in 11.3.1f) shall indicate the draught either at each corner of the unit or at a representative position as required by the appropriate authority.

Enclosures housing ballast system electrical components, the failure of which may cause unsafe operation of the ballast system upon liquid entry into the enclosure, shall have a minimum degree of protection as specified in IEC 61892-2<sup>1)</sup>.

<sup>1)</sup> Under consideration. Until future IEC 61892-2, *System design* is published, reference is made to table 5 in IEC 60092-201.