

**Uninterruptible power systems (UPS) –  
Part 1-1: General and safety requirements for UPS  
used in operator access areas**

**CORRIGENDUM 1**

Page 8

**2 Normative references**

*Replace “IEC 2040-1-2” by “IEC 62040-1-2”.*

Page 18

**5.1.4 Backfeed protection**

*Replace, in item b), the second and third sentences by the following:*

For example, circuits with voltage less than 150 V r.m.s. require 0,7 mm for **basic insulation** and circuits with voltage greater than 150 V r.m.s. but less than 300 V r.m.s. require 1,4 mm for **basic insulation**. For a **UPS** with floating outputs, opening all phases and the neutral using the required **clearance** for **basic insulation** is considered acceptable.

Page 27

**7.7 Temperature rise**

*Replace, in the first sentence, “...4.5.2./RD...” by “...4.5.1./RD...”.*

Page 33

**Annex L**

**Figure L.1**

*Delete, in the upper sketch, the brackets round “L1” and “L2”. Replace, in the lower sketch, “Ø1, Ø2, Ø3” by “L1, L2, L3”.*