

TECHNICAL REPORT

IEC TR 61131-4

Second edition
2004-07

Programmable controllers –

**Part 4:
User guidelines**

IECNORM.COM : Click to view the full PDF of IEC TR 61131-4:2004



Reference number
IEC/TR 61131-4:2004(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

TECHNICAL REPORT

IEC TR 61131-4

Second edition
2004-07

Programmable controllers –

Part 4: User guidelines

IECNORM.COM : Click to view the full PDF of IEC TR 61131-4:2004

© IEC 2004 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XF**

For price, see current catalogue

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 General	8
1.1 Scope and object.....	8
1.2 Normative references	9
1.3 Use of this report.....	9
2 Terms and definitions	10
3 General recommendations for installation	11
3.1 Environmental conditions	11
3.2 Field wiring.....	11
3.3 Electromagnetic compatibility	12
3.4 User system markings	13
4 PLC in functional safety applications	13
4.1 Functional safety and safety-related-system concept.....	13
4.2 Using a PLC in a safety-related application	15
4.3 Requirements on PLCs in a safety-related system.....	16
4.4 Integration of PLC into a safety-related system	16
Annex A (informative) Overview of normative parts of IEC 61131	19
A.1 Overview of IEC 61131-1.....	19
A.2 Overview of IEC 61131-2.....	26
A.3 Overview of IEC 61131-3.....	59
A.4 (blank).....	88
A.5 Overview of IEC 61131-5.....	88
A.6 (blank).....	100
A.7 Overview of IEC61131-7.....	100
A.8 (blank).....	107
Annex B (informative) Conformity to IEC 61131 and product certification	108
B.1 General	108
B.2 Conformity to standards	108
B.3 Declaration of conformity and certification	109
B.4 The inter-relation of standards to laws in European Community.....	109
B.5 CE-marking of PLCs in the European Union	111
B.6 Transition periods.....	113
B.7 Other jurisdictions	114
B.8 Reference documents.....	115
Annex C (informative) Use of PLC programming languages and examples.....	116
C.1 Preamble.....	116
C.2 Advance planning.....	116
C.3 Structure and organization	117
C.4 Use of PLC languages.....	120

C.5 User Defined Function Block (DFB)	127
C.6 Language implementation.....	130
Figure 1 – Object of user guidelines.....	8
Figure 2 – SRS in risk reduction concept	14
Figure 3 – Event tree analysis for deployment of SRS.....	18
Figure A.1 – Basic functional structure of a PLC system	21
Figure A.2 – PLC hardware model	22
Figure A.3 – Typical interface/port diagram of a PLC system	23
Figure A.4 – Type test EUT configuration.....	32
Figure A.5 – Digital I/O parameters.....	35
Figure A.6 – Immunity zones.....	46
Figure A.7 – Programmable Controller System (PLC system).....	59
Figure A.8 – Software model.....	62
Figure A.9 – Combination of programmable controller language elements	64
Figure A.10 – Examples of function usage	69
Figure A.11 – Function block instantiation examples	70
Figure A.12 – Sequential function chart	71
Figure A.13 – Function block and program declarations for configuration example.....	79
Figure A.14 – The four programming languages.....	82
Figure A.15 – Boolean OR examples	86
Figure A.16 – Programming elements of Function Block Diagram language	87
Figure A.17 – Top-down and bottom-up programming.....	88
Figure A.18 – Scope of IEC 61131-5.....	88
Figure A.19 – Relationship of the communication model to IEC 61131-2 and IEC 61131-3	90
Figure A.20 – Programmable controller communication model	91
Figure A.21 – Example of communication control in FBD language	99
Figure A.22 – Example of a fuzzy control in FBD program.....	101
Figure A.23 – Example of ramp curve membership functions	102
Figure A.24 – Defuzzification program block	102
Figure A.25 – Example of singleton terms.....	102
Figure C.1 – Program structure overview	118
Figure C.2 – Program structure with detail	119
Figure C.3 – The structured program plan for brewing process automation with various languages.....	121
Figure C.4 – Example of a program in IL language.....	122
Figure C.5 – Example of a program in ST language	123
Figure C.6 – Example of a control program in LD language.....	124
Figure C.7 – An example of a control program in FBD language	125
Figure C.8 – A control program in SFC	126
Figure C.9 – A DFB for valve control.....	127
Figure C.10 – DFB for valve actuation	128
Figure C.11 – DFB for alarm actuation	129

Table 1 – Environmental conditions	11
Table 2 – Installation rules: earthing measures	12
Table 3 – Installation rules: EMC	12
Table 4 – SIL of demand mode safety functions	14
Table 5 – SIL of continuous mode safety functions	14
Table A.1 – Summary of programmable functions	24
Table A.2 – General conditions for tests	32
Table A.3 – Operating ambient air temperature of PLC systems	33
Table A.4 – Emission limits	45
Table A.5 – Criteria to prove the performance of a PLC-system against EMC disturbances	47
Table A.6 – Voltage drops and interruptions	47
Table A.7 – Shock protection requirements for open and enclosed equipment	50
Table A.8 – Temperature limits	52
Table A.9 – Data type declaration features	67
Table A.10 – Location and size prefix features for directly represented variables	67
Table A.11 – Variable usage	68
Table A.12 – Examples of function block I/O variable usage	70
Table A.13 – Step features	72
Table A.14 – Transition and transition conditions	73
Table A.15 – Declaration of action	75
Table A.16 – Step/action association	77
Table A.17 – Action block features	78
Table A.18 – Configuration and resource declaration features	79
Table A.19 – Examples of configuration and resource declaration features	80
Table A.20 – Operators of Instruction List language	83
Table A.21 – Operators of the ST language	84
Table A.22 – ST language statements:	84
Table A.23 – Status presenting entities	92
Table A.24 – PLC summary status	93
Table A.25 – Status of I/O subsystem	94
Table A.26 – Status of processing unit	94
Table A.27 – PLC application functions	95
Table A.28 – Meaning of value of I/O state	97
Table A.29 – List of communication function blocks	98
Table A.30 – Semantic of communication function block parameters	98
Table A.31 – Defuzzification methods	103
Table A.32 – Priority of rule block operators	103
Table A.33 – Fuzzy logic control basic level language elements	105
Table A.34 – Fuzzy logic control extension level language elements (optional)	105
Table A.35 – Fuzzy logic control data check list	106

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROGRAMMABLE CONTROLLERS –**Part 4 – User guidelines**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

This part of the International Standard IEC 61131 has been prepared by subcommittee 65B: Devices, of IEC Technical Committee 65: Industrial-process measurement and control.

This second edition cancels and replaces the first edition published in 1995. It constitutes a technical revision.

This second edition of IEC 61131-4 differs extensively from the first edition. The first edition, IEC 61131-4:1995, initiated some twenty years ago, was mainly tutorial in nature. The present revision aims to provide an engineering overview of the IEC 61131 series for the end-user of PLC equipment who may not be expected to delve into the details of the extensive product standard that is IEC 61131.

The purpose of this revision is therefore to assist the end-users of PLCs to make efficient and effective use of the IEC 61131 series, and to realise the benefit of IEC standard compliant programmable controllers. This revised Technical Report serves as a quick reference and roadmap. Many of the IEC 61131 parts have gone through their maintenance cycle revisions. This revision of IEC 61131-4 is based on the latest revisions available.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
65B/508A/DTR	65B/527/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61131 consists of the following parts, under the general title: *Programmable controllers*

Part 1: General information

Part 2: Equipment requirements and tests

Part 3: Programming languages

Part 4: User guidelines

Part 5: Communications

Part 7: Fuzzy control programming

Part 8: Guidelines for the application and implementation of programming languages

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this Technical Report may be issued at a later date.

INTRODUCTION

This part of IEC 61131 constitutes the fourth part of a series of standards on programmable controllers and the associated peripherals and should be read in conjunction with the other parts of the series.

Where a conflict exists between this and other IEC standards (except basic safety standards), the provisions of this standard should be considered to govern in the area of programmable controllers and their associated peripherals.

Terms of general use are defined in IEC 61131-1. More specific terms are defined in each part.

IECNORM.COM : Click to view the full PDF of IEC TR 61131-4:2004

PROGRAMMABLE CONTROLLERS –

Part 4: User guidelines


1 General

1.1 Scope and object

The object of this Technical report is to introduce the end-users of Programmable Controller (PLC) to the IEC 61131 series, and to assist the end-users in their selection and specification of their PLC equipment according to the IEC 61131 series. This user guideline has as its main audience PLC end-users.

PLCs, their application program and their associated peripherals are considered as components of a control system. Therefore, PLC users should take note that this standard does not deal with the automated system in which the PLC and PLC system is but one component. However, when applying this user guideline, an overall system architecture evaluation is recommended. Functional safety of the overall automated system is beyond the scope of this standard.

An objective of this user guideline is to facilitate communication between the PLC user and PLC supplier according to the specifications of the IEC 61131 series that applies to PLCs and their associated peripherals. This information exchange is illustrated in Figure 1.



IEC 1025/04

Figure 1 – Object of user guidelines

As depicted in Figure 1, the users consist of system integrators and end-users. The manufacturer of PLC is required by the IEC 61131 series to furnish appropriate product information to the user. Optionally, the user supplies operational requirements and specifications to the manufacturer in order to receive suitable products and services from the manufacturer. One objective of this Technical Report is therefore to assist in this communication, especially from the end-user's perspective. Accordingly, this Technical Report does not detail all the requirements of each and every part of the IEC 61131 series, such as conformance tests. The user should refer to the individual parts of the standard when needed.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61131-1: *Programmable controllers – Part 1: General information*

IEC 61131-2: *Programmable controllers – Part 2: Equipment requirements and tests*

IEC 61131-3: *Programmable controllers – Part 3: Programming languages*

IEC 61131-5: *Programmable controllers – Part 5: Communications*

IEC 61131-7: *Programmable controllers – Part 7: Fuzzy control programming*

IEC 61131-8: *Programmable controllers – Part 8: Guidelines for the application and implementation of programming languages*

1.3 Use of this report

A PLC application starts with the user's system analysis and specification. Inquiries and discussions (and suggestions/recommendations) with the manufacturer necessitate the use of a mutually agreed language for interactive information exchange as in Figure 1. The user can use this report as a basis and/or to supplement any in-house system design rules. The user can then specify the equipment and software requirements according to the relevant parts in the IEC 61131 series. In this user guideline, introductions and briefings of various parts of the IEC 61131 series are presented in Annex A according to the divisions in the IEC 61131 series. For example, Clause A.1 covers IEC 61131-1, Clause A.2 covers IEC 61131-2, etc.

This Technical Report presents only those specifications for which the user may have an immediate need for reference. It is not a complete summary of the whole IEC 61131 series.

2 Terms and definitions

For the purposes of this part of IEC 61131, the following terms and definitions, as well as those given in IEC 61131-1, apply.

2.1

application program (user program)

logical assembly of all the programming language elements and constructs necessary for the intended signal processing required for the control of a machine or process by a PLC system

2.2

automated system

control system beyond the scope of IEC 61131 in which PLC systems are incorporated by or for the user, but which also contains other components including their application programs

2.3

operator (human)

person commanding and monitoring a machine or process through an HMI connected to the PLC. The operator does not change the PLC hardware configuration, software or the application program. A PLC is not intended for use by untrained personnel. The operator is assumed to be aware of the general hazards in an industrial environment.

2.4

programmable controller

digitally operating electronic system, designed for use in an industrial environment, which uses a programmable memory for the internal storage of user-oriented instructions to implement specific functions (such as logic, sequencing, timing, counting and arithmetic) to control, through digital or analogue inputs and outputs, various types of machines or processes.

NOTE In the first edition of the IEC 61131 series, the acronym "PC" was used for Programmable Controller. However, usage of the earlier acronym PLC has been persisted with the majority of industries. After consultation, IEC Subcommittee 65B WG7 recommended that the more widely accepted acronym PLC be used, starting with all new editions of the IEC 61131 standard.

2.5

programmable controller system

user-assembled configuration, consisting of a programmable controller and associated peripherals that is necessary for the intended automated system. It consists of units interconnected by cables or plug-in connections for permanent installation and by cables or other means for portable and transportable peripherals.

2.6

service personnel

person changing or repairing the PLC hardware configuration or the application programme.

The service person may also install software updates provided by the manufacturer. They are assumed to be trained in the programming and operation of the PLC equipment and its use.

They are persons having the appropriate technical training and experience necessary to be aware of hazards – in particular, electrical hazards – to which they are exposed in performing a task and of measures to minimize danger to themselves or to other persons or to the equipment.

3 General recommendations for installation

The installation procedure should fulfil the requirements given by documents, which are prepared during the system selection/engineering/application phase. Not all site conditions can be recognized at the PLC selection phase. During installation, it is important to update all engineering and application documents according to how the PLC equipment is assembled or modified on site.

3.1 Environmental conditions

The user should ensure that care is taken concerning temperature, contaminants, shock, vibration and electromagnetic influence. Refer to IEC 61131-2 for specific environmental requirements. Table 1 describes environmental conditions to be evaluated during installation.

Table 1 – Environmental conditions

Criteria	Comments and considerations
Temperature	Check for possible influence of steady or temporary heat sources: <ul style="list-style-type: none"> - space heater - solar heat - hot goods passing by
Contaminants	Moisture, corrosive gases, liquids and conductive dust can affect the function of a PLC system. Therefore, check: <ul style="list-style-type: none"> - use of adequate enclosures in compliance with international/national codes - compliance with manufacturer's installation instructions - degradation of thermal efficiency caused by dust
Shock and vibration	Check for possible effects on site: <ul style="list-style-type: none"> - engines - compressors - transfer lines - presses, hammers - vehicles
Electromagnetic interference	Check electromagnetic interference from various sources on site: <ul style="list-style-type: none"> - motors - switch gears, thyristors - radio-controlled equipment - welding equipment - electrical arcs - switched power supplies - power converters/inverters

3.2 Field wiring

Proper field wiring practices are of prime importance to the application of PLCs. The installer needs to follow the manufacturer's wiring instructions and applicable local regulations.

Two earthing/grounding requirements need to be fulfilled during installation: protective earth (safety grounding) and functional earth (signal ground reference).

Protective earthing requires the solid connection (e.g., low impedance connection, including star washers, welding, soldering, etc.) of inactive metal parts to an equipotential metallic grid (frames, chassis, cabinets). The grid needs to be connected to protective earth in accordance with local and national codes.

Functional earthing needs to be installed as the low impedance network of signal ground reference lines. It should be a network separate from protective earthing.

Protective and functional earth networks may be interconnected via wires or other low impedance paths. Such interconnections or lack thereof may be required by applicable local/national codes, or due to noise reduction requirements, depending on the type of controlled process/equipment. Table 2 describes installation rules of earthing measures.

Table 2 – Installation rules: earthing measures

Criteria	Reference	Comments and considerations
Protective earthing		<ul style="list-style-type: none"> - Provide sufficient conductor cross-section for connections to earth. - Doors should have electrical connections according to local and national codes. - Verify connections are tight and resistant to vibration and corrosion.
Functional earthing		<ul style="list-style-type: none"> - Usually functional ground reference is connected only at a single point to earth. When more than one connection to earth is made, care should be taken to avoid ground loop interference. Such multipoint earth connections must be made to an equipotential grid. - Protective earth conductors may be suitable for functional grounding. Such practice can be determined on site by measurement at 50 Hz/60 Hz and at frequencies above signal frequency. Such quality may be improved by specially installed electrodes or, possibly, earthed conductive building structures. - If a direct connection of the signal ground reference conductor of the PLC to earth is not possible, the connection may be made via a suitable capacitor. The capacitor should correspond to the rated insulation voltage of the PLC circuit, and should have good high-frequency properties. Static charging can be prevented by the use of a high ohm value resistor for discharge. - There should be no discontinuities on ground circuits, such as could be introduced by terminals and sockets.
<p>Caution – protective earthing is intended to reduce the risk of electric shock hazard. Under no circumstances should the protective earth be disconnected from the PLC. Functional earth connections may be temporarily disconnected for servicing and/or maintenance as required.</p>		

3.3 Electromagnetic compatibility

A number of common installation practices have been found to minimise EMC related problems. Some of these are listed in Table 3

Table 3 – Installation rules: EMC

Criteria	Reference	Comments and considerations
Mains		<ul style="list-style-type: none"> - Mains conductors should be separately installed from other PLC wiring, i.e., cable spacings of 10 cm or more from signal cables. - Unavoidable crossing should be at right angles. - Use of mains' filters on the cabinet feed-ins may be required. - Transient suppressor at mains' entrance may be required.
Input/output		<ul style="list-style-type: none"> - Separation of the field wiring from internal I/O cabling and from bus lines. - Care must be taken not to compromise isolation of circuits (e.g., by optical separation) between I/O field wiring and internal PLC system. - Filtering of susceptible I/O cables may be required. - Use of shielded cables with low inductance cable shields (low-level signals). - Earthing measurement in each individual case must be determined on site. - Shield may be connected to functional ground or protective earth. - Electrical contacts in series with inductive loads require special attention for voltage surge and stored energy.
Noise sources		<p>Noise damping at emission sources with noise suppressers such as:</p> <ul style="list-style-type: none"> - Separate cables for input, outputs, and power circuits. - Minimise the total length of wiring. - Use of manufacturer recommended cables and leads.
Analogue and other noise-sensitive circuits		<ul style="list-style-type: none"> - Use of shielded wires. - Use of twisted-pair wiring.
Routing		<p>Interference voltage or current noise can enter PLCs where connections are made, as well as the power supply connections. The wiring which extends between the PLC and these control devices should be properly routed to minimize induced noise on these wires.</p>

3.4 User system markings

User system markings of components (sensors, actuators, cables, distribution-boards, enclosures, modules, etc.) should be done in accordance with the installation drawings and applicable codes.

Special care needs to be taken on markings of wiring. Each and every field wire should be identified with a marking corresponding to drawing. Alteration from the drawing should be noted on the same drawing immediately.

Care needs to be taken to ensure the following:

- markings need to be indelible;
- adequate sizes of letters and signs;
- fuse location, type, rating need to be clearly marked;
- visibility of markings; and
- conformity with installation drawings according to revision of final documents.

4 PLC in functional safety applications

When PLCs are required to perform safety functions, it is necessary that special measures be taken to avoid and limit dangerous failures of the functional-safety-related system. Detailed requirements for Safety-Related System (SRS) are contained in IEC 61508 and in emerging sector implementation standards such as the IEC 61511 series. The purpose of this Clause is to provide an overview of some of the functional safety issues that will need to be addressed. It is not intended to provide definitive or detailed guidance for implementation.

4.1 Functional safety and safety-related-system concept

Functional safety, as defined in IEC 61508, refers to the ability of a SRS to carry out the functions necessary to achieve a safe state for the Equipment Under Control (EUC) or to maintain a safe state for the EUC. In this definition, the main subject is focused on the ability of a safety-related system to do what it is required to do.


“Safety” refers to freedom from unacceptable risk. It follows that there are acceptable risks. The level of risks may be categorized as “broadly acceptable”, “tolerable” where further risk reduction is impracticable (the As Low As Reasonably Practical, ALARP, principle) and, the “intolerable” where risks cannot be justified, except in extraordinary circumstances. Risk level is assessed as a combination of “Consequence of hazardous event” and “Frequency of hazardous event”.

The task of a SRS is to reduce the risk to a tolerable level or lower as prescribed by the control system designer. This risk-reduction model is depicted in Figure 2.

NOTE 1 The IEC 61131 series does not deal with the functional safety or other safety aspects of the overall automated system. Safety considerations for the overall automated system are beyond the scope of this standard.

NOTE 2 The IEC 61131 series does not contain a part on functional safety. At the preparation of this part of IEC 61131, a sector standard for PLC and similar equipment is under consideration.

NOTE 3 Safety, as covered in IEC 61131-2, refers to prevention of electric shock and fire hazards.



IEC 1026/04

Figure 2 – SRS in risk reduction concept

Each SRS is assigned Safety Functions and is to fulfil the safety functions with a prescribed Safety Integrity Level (SIL) requirement. IEC 61508 categorises SIL in four levels as listed in Table 4 for Demand Mode and in Table 5 for Continuous Mode.

Table 4 – SIL of demand mode safety functions

SIL	Average probability of failure to perform the safety function on demand (PFD)
4	$\geq 10^{-5}$ to $< 10^{-4}$
3	$\geq 10^{-4}$ to $< 10^{-3}$
2	$\geq 10^{-3}$ to $< 10^{-2}$
1	$\geq 10^{-2}$ to $< 10^{-1}$

Table 5 – SIL of continuous mode safety functions

SIL	Probability of a dangerous failure of the safety function (per hour)
4	$\geq 10^{-9}$ to $< 10^{-8}$
3	$\geq 10^{-8}$ to $< 10^{-7}$
2	$\geq 10^{-7}$ to $< 10^{-6}$
1	$\geq 10^{-6}$ to $< 10^{-5}$

Note that Table 5 can also be used for Demand Mode safety functions when the demand rate is high compared with the proof test frequency of the safety function. Typically, when the demand rate is higher than twice the proof test frequency, then it is reasonable to specify the safety function in terms of probability of failure per hour using Table 5.

The international standard for safety instrumented system for the process industry is the IEC 61511 series. In the IEC 61511 series, the safety instrumented system (SIS) includes all components and subsystems necessary to carry out the safety instrumented function, from sensor(s) to actuator(s).

For the machine sector, IEC 62061 is in preparation. This standard is being harmonized with international standard ISO 13849-1 (EN 954-1). The Safety-Related Part (SRP) which carries out safety functions is viewed as a component of the total control system. The ability of SRP to fulfil a safety function is described as Performance Levels (PL). Performance Levels PL-a, PL-b, PL-c, PL-d, and PL-e correspond to the “average probability of a dangerous failure per hour” ranging from 10^{-4} to 10^{-8} . The required PL (for a SRP) is determined on risk parameters of “Severity of injury”, “Frequency and/or exposure time to the hazard” and “Probability of avoiding the hazard”. Each of these parameters is categorized as high or low. PL-a describes risks lower than SIL1. PL-b and c approximately correspond to SIL1. PL-d corresponds to SIL2 and PL-e corresponds to SIL3. A SRP is then specified as one of five categories: Basic, 1, 2, 3, and 4.

4.2 Using a PLC in a safety-related application

When applying a PLC in a safety-related application (that is, an application where a failure of the SRS to carry out its intended safety function could lead to injury, loss of life or damage to health), then it will be necessary to take into account the likelihood of dangerous failure due to random hardware faults. It will also be necessary to address the possibility of systematic faults in hardware and software.

Notice that safety-related applications should not be confused with basic control applications where there are other measures, such as safety interlocks, which provide protection in the event of such failure.

In safety-related applications, a PLC will usually form only one part of a programmable electronic safety-related system. The other parts, or subsystems, of the SRS include switches and/or sensors as input devices and contactors and/or valves as output actuators.

4.2.1 Safety functions

In order to determine the particular requirements for a PLC used in a safety-related application, it is first necessary to specify the entire safety requirements of the safety-related system.

The safety requirements of a programmable electronic SRS are assigned safety functions. Each safety function required to be carried out by the SRS is specified in terms of Safety Function and Safety Integrity Level (SIL). The safety functional specification is a description of the required function in terms of the action of the safety-related system under a specific set of circumstances.

It is very important that the safety functional specification also needs to include a description of any states of the system which should be avoided in order to prevent hazardous situations. For example, in the case of a system used for an emergency stop safety function on a machine tool, it is necessary to ensure that the machine does not restart when the emergency stop actuator is reset. The machine restarts only when all faults are cleared and a start command is given.

4.2.2 Safety Integrity Level (SIL)

The Safety Integrity Level (SIL) part of the safety functions specification is a measure of the target acceptable probability of failure of the safety function. To determine the SIL level for a safety function, it is necessary to take into account the hazards and risks associated with the application together with the tolerable risk target, and any contribution to risk reduction provided by other safety measures. Generic methods for SIL determination are given in IEC 61508-5. Sector functional safety standards provide guidance relevant to particular applications (see, for example, IEC 61511-3 for the process sector or IEC 62061 for the machinery sector).

Experts in the industry have found that in order to achieve the required reduction of dangerous failure rates required for higher levels of safety integrity (e.g. SIL3 and above), it may be necessary to employ redundant architectures (e.g. 2 out of 3 voting), even taking into account the high levels of diagnostic coverage (e.g. >99 %) typically seen in such PLCs.

4.3 Requirements on PLCs in a safety-related system

In order for a safety-related system to meet the requirements of IEC 61508 or associated sector standards, it is necessary that the following characteristics of a PLC used in the safety-related system be taken account of when designing a safety-related system to carry out a safety function with a specified SIL:

- hardware reliability;
- diagnostic test coverage and test interval;
- periodic testing/maintenance requirements;
- hardware fault tolerance; and
- SIL capability.

This information should be obtained from the PLC manufacturer.

Notice that the 'SIL capability' is the highest SIL which can be claimed for a safety function which uses the PLC, taking into account the measures and techniques used for the avoidance and control of systematic faults in the PLC hardware and software (including system software and firmware) according to IEC 61508. Note also that in order to determine the actual SIL that can be claimed for a safety function in a particular application, it is necessary to consider all of the above characteristics for all of the subsystems which contribute to the safety function.

4.4 Integration of PLC into a safety-related system

The process for deployment of protective features may be illustrated in the event analysis diagram in Figure 3.

The activities undertaken to integrate a PLC into a safety-related system include the development of application software safety requirements. Application programming or configuration and testing should be carried out and verified according to the requirements of IEC 61508 or associated sector standards. It will be necessary to determine how frequently it is required to undertake proof tests in order to detect any dangerous faults which are not revealed by the automatic diagnostic tests. Proof tests are particularly important when PLCs are applied in redundant configurations, or when there are components (such as batteries) whose failure may not be apparent during normal operation.

If previously developed application software library functions are to be used, their suitability in satisfying the software safety requirements specifications need to be verified. Suitability may be based on evidence of satisfactory operation in a similar application which has been demonstrated to have similar functionality or having been subject to the same verification and validation procedures as would be expected for newly developed software. Any constraints from the previous software environment (for example operating system and compiler dependencies, order of execution of library functions, etc.) need to be evaluated.

Application programs should be well documented, including at the least the following information:

- legal entity (e.g.: company, author(s), etc.);
- description;
- tractability to application functional requirements;
- logic conventions used;
- standard library functions used (and associated justifications, see above);

- inputs and outputs; and
- configuration management including a history of changes.


All integration (including hardware, software, mechanical assembly and wiring, use of tools and programming languages, interfacing of inputs and outputs) need to be in accordance with instructions of the PLC manufacturer.

Note that extreme caution should be exercised when combining PLCs in redundant architectures in order to meet hardware reliability requirements. Such architectures could introduce the possibility of systematic failure modes associated with timing synchronization and voting which may outweigh the benefits to be gained from redundancy.

Integration should take into account the possibility of reasonably foreseeable fault conditions, such as open circuits on inputs or power supply failure, so as to ensure that such fault conditions do not lead to hazardous situations.

Care should be taken to ensure that it is not possible, during use of the PLC, for a previous version of an application program (e.g. stored in NVRAM) to over-write an application program which may have been changed to remove faults. Such over-writing could lead to software faults being re-introduced.

IECNORM.COM : Click to view the full PDF of IEC TR 61131-4:2004



IEC 1027/04

Figure 3 – Event tree analysis for deployment of SRS

Annex A (informative) **Overview of normative parts of IEC 61131**

This Annex presents overviews of all normative parts of the IEC 61131 series. Not presented are IEC 61131-4, which is this Technical Report, IEC 61131-8 which is itself a guideline Technical Report and IEC 61131-6 which is reserved for future use.

This Annex is divided into Clauses: Clause A.1 to Clause A.7. Each Clause's number and title (but not Subclause numbers) correspond directly with the part number of the IEC 61131 series, viz:

- Clause A.1: Overview of IEC 61131-1;
- Clause A.2: Overview of IEC 61131-2;
- Clause A.3: Overview of IEC 61131-3;
- Clause A.4: (blank);
- Clause A.5: Overview of IEC 61131-5;
- Clause A.6: (blank);
- Clause A.7: Overview of IEC 61131-7;
- Clause A.8: (blank).

The purpose of this Annex is to provide the user with a window and a bridge to the IEC 61131 series. It is not intended as a definitive specifications on PLCs, nor does it intend to substitute for any part of the IEC 61131 series. This Annex is prepared to provide information and selective guidance on IEC 61131 in its entirety, more related to the user point of view.

Some key specifications in IEC 61131-1, IEC 61131-2 and IEC 61131-3 that are especially germane to the user's specification and selection of PLCs are reflected directly from those parts.

A.1 Overview of IEC 61131-1

A.1.1 General

The scope of IEC 61131-1 is to deal with the framework for the overall IEC 61131 series. It applies to PLCs and their associated peripherals which have as their intended use the control and command of machines and industrial processes. IEC 61131-1 defines the terms and principal functional characteristics of programmable controller system.

PLCs and their associated peripherals are intended to be used in an industrial environment. If a PLC or its associated peripherals are used in other environments, then the specific requirements, standards and installation practices for those other environments must be additionally applied to the PLC and its associated peripherals.

The IEC 61131 series does not deal with the functional safety or other aspects of the overall automated system. Safety considerations for the overall automated system is beyond the scope of this standard.

PLC safety as related to electric shock and fire hazards, electrical interference immunity and error detecting of the PLC system operation are addressed in the IEC 61131 series. For installation IEC 60364 and applicable national/local regulations should be referred to. IEC 61131-1 was prepared with normative referencing to IEC 61131-2 and IEC 61131-3.

A.1.2 Terms and definitions

Some of the terms and definitions used in IEC 61131-1 are as follows:

a) Field devices

catalogued part to provide input and/or output interface or to provide data pre-conditioning.

NOTE The abbreviation “PLC” is used in this standard to stand for “programmable controllers”, as is the common practice in the automation industry. The use of “PC” as abbreviation to “programmable controllers” leads to confusion with personal computers.

b) Programmable Controller system (PLC system)

user-built configuration, consisting of a programmable controller and associated peripherals, that is necessary for the intended automated system. It consists of units interconnected by cables or plug-in connections for permanent installation and by cables or other means for portable and transportable peripherals.

c) Programming And Debugging Tool (PADT)

catalogued peripheral to assist in programming, testing, commissioning and trouble-shooting the PLC system application, program storage and documentation. PADTs may be used as Human-Machine-Interface (HMI). PADTs are said to be pluggable when they may be plugged or unplugged into their associated interface at any time without any risk to the operator and the application. In all other cases, PADTs are said to be fixed.


d) Remote Input/Output Station (RIOS)

manufacturer's catalogued part of a PLC system, including input and/or output interfaces allowed to operate only under the hierarchy of the main processing unit (CPU) for I/O multiplexing/de-multiplexing and dated pre-processing/post-processing. The RIOS is the only peripheral permitted to have limited autonomous operation, for example, under emergency conditions such as breakdown of the communication link to the CPU, or when maintenance and trouble-shooting operations are to be performed.

A.1.3 Functional characteristics


A.1.3.1 Basic functional structure of a PLC system

The structure of a PLC system and communication interfaces are illustrated in Figure A.1, Figure A.2 and Figure A.3. These models are the basis of IEC 61131-2 on hardware, IEC 61131-3 on programming, IEC 61131-5 on communication and IEC 61131-7 on fuzzy programming.



IEC 1028/04

Figure A.1 – Basic functional structure of a PLC system



IEC 1029/04

Figure A.2 – PLC hardware model

The CPU function consists of the application program storage, the data storage, the operating system, the execution of the application program function and processes signals obtained from sensors as well as internal data storage and generates signals to actuators as well as internal data storage in accordance with the application program. These include:

- Interface function to sensors and actuators converts I/O signals including pre-processed signal from special modules such as PID, fuzzy control module, high speed counter module, and motion module.
- Communication function provides the data exchange with other systems (third party devices) such as other PLC systems, robot controllers, computers, etc.
- Human-Machine Interface (HMI) function provides for interaction between the operator, the signal processing function and the machine/process.
- Programming, debugging, testing and documentation functions provide for application program generation and loading, monitoring, testing and debugging as well as for application program documentation and archiving.
- Power supply functions.




Figure A.3 – Typical interface/port diagram of a PLC system

A.1.3.2 Characteristics of the CPU function

A.1.3.2.1 Programmable functions

Capabilities of a PLC are determined by programmable functions of the CPU, summarised in Table A.1.

Table A.1 – Summary of programmable functions

Function group	Examples
Logic control – Logic – Timers – Counters	Programming language elements AND, OR, NOT, XOR, bi-stable elements On-delay, off-delay Up and/or down counting (of pulses)
Signal/data processing – Mathematical functions – Data handling – Analogue data processing	Basic arithmetic: ADD, SUB, MUL, DIV Extended arithmetic: SQRT, trigonometric functions Comparisons: greater, smaller, equal Selecting, formatting, moving PID, integration, filtering (not as standard elements) Fuzzy control
Interfacing functions – Input/output – Other systems – HMI – Printers – Mass memory	Analogue, digital I/O modules BCD conversion, Communication protocols Display, commands Messages, reports Logging
Execution control periodic	Periodic, event-driven execution
System configuration	Status checking

A.1.3.2.2 Operating system and re-start of PLC

The operating system is responsible for the management of internal PLC system functions. According to the controlled system application, the user needs to ascertain how the PLC system is to re-start after interruption of operation. Re-start is classified into Cold restart, Hot restart, and Warm restart.

1) Cold restart

Restart of the PLC system and its application program after all dynamic data (variables such as I/O image, internal registers, timers, counters, etc., and program contexts) are reset to a predetermined state. A cold restart may be automatic (e.g. after a power failure, a loss of information in the dynamic portion(s) of the memory(ies), etc.) or manual (e.g. push-button reset, etc.).

2) Hot restart

Restart after power failure, within the maximum interruption time allowed, for the PLC system to recover as if there had been no power failure. All I/O information and other dynamic data as well as the application program context are restored or unchanged.

Hot restart capability requires a separately powered real time clock or timer to determine elapsed time since the power failure was detected and a user accessible means to program the process dependent maximum interruption time allowed.

3) Warm restart

Restart after a power failure with a user programmed predetermined set of dynamic data and a system predetermined application program context. A warm restart is identified by a status flag or equivalent means made available to the application program indicating that the power failure shut down of the PLC system was detected in the run mode. At warm restart, usually only the MPU is supplied with Un-interruptible Power Supply (UPS) power source.

A.1.4 Languages and documentation of program

For programming of the PLC application, four types of languages are defined in IEC 61131-3. These languages are: Instruction List (IL), Structured Text (ST), Function Block Diagram (FBD) and Ladder Diagram (LD). Although one type of language may be more widely used in a particular region, the collection encompasses the whole spectrum of software technology and complement each other in many instances. The user may note that IEC 61131-3 specifies PLC language elements and does not describe any particular language in practical use. Such practical language would necessarily include proprietary information or copyright issues that are outside the scope of this standard.

Application program(s) should be documented in a package that may consist of description(s) of the hardware configuration(s) with project-dependent notations. Program documentation should include the following:

- program listing with mnemonics for signal and data;
- cross-reference tables for all data processed;
- comments;
- description of modifications;
- maintenance manual.

Application program archiving in non-volatile media enables rapid repair and minimizes down-time.

A.1.5 Availability and reliability

Every automated system requires a certain level of availability and reliability of its control system. It is the user's responsibility to ensure that the architecture of the overall automated system, the characteristics of the PLC system and its application program will jointly satisfy the intended application requirements. Factors governing availability and reliability include:

a) Architecture of the automated system

Techniques such as redundancy, fault tolerance and automatic error checking, as well as machine/process diagnostic functions can provide enhancements in the area of availability of the automated system.

b) Architecture of the programmable controller system

A modular construction in conjunction with suitable internal self-tests allowing rapid fault identification may provide enhancements in the area of maintainability of the PLC system and therefore of the availability of the automated system. Techniques such as redundancy and fault tolerance may also be considered for special applications. Evaluation of availability and reliability of a PLC system with a particular architecture may be carried out with the help of related IEC standards such as IEC 61508-6 for the process industry.

c) Design, testing and maintenance of the application program

Most programmable controllers provide enough computing power to permit implementation of diagnostic functions in addition to the minimum control function. Machine/process behaviour modelling and subsequent identification of faulty conditions should be considered.

Adequate testing of the application program is mandatory. The extent of testing, such as point-to-point, loop back or full simulation of process, should be specified. Every modification requires proper design and testing such that the overall availability and reliability are not impaired. The program documentation needs to be maintained and annotated accordingly.

d) Installation and service conditions

PLC systems are typically of rugged design and construction intended for general purpose service. The more stressful the service conditions are, the more degradation is possible for availability and reliability. Conversely, improvements in availability and reliability may be expected when actual service conditions are less stressful than the normal service conditions specified in IEC 61131-2.

Some applications may require consideration of special enclosure, cooling, electrical noise protection, etc., for reliable operation.

A.2 Overview of IEC 61131-2

A.2.1 General

A.2.1.1 Scope and objectives

IEC 61131-2 establishes the functional, electrical safety, electromagnetic compatibility (EMC) and electrical, mechanical, environmental and construction requirements for the PLC and specifies testing methods accordingly. This standard covers PLCs and any products performing the function of PLCs and their associated peripherals. Only equipment intended for use in an industrial environment for control and command of machines and industrial processes are covered.

This standard also applies to any products performing the function of PLCs and/or their peripherals.

Equipment covered in IEC 61131-2 are intended for use in Overvoltage Category II as per IEC 60664-1 in low-voltage installations where the rated mains supply does not exceed 1 000 V r.m.s. or 1 500 V DC.

The object of IEC 61131-2 is to establish the definitions and identify the principle characteristics relevant to the selection and application of PLCs and their associated peripherals. It specifies the minimum requirements for functional, electrical, mechanical, environmental and construction characteristics, service conditions, safety, EMC, user programming and tests applicable to PLCs and the associated peripherals.

A.2.1.2 Compliance with this standard

When compliance with IEC 61131-2 is indicated without qualification, compliance with all clauses, including all tests and verifications required in IEC 61131-2, must be verified. Moreover, the manufacturer's obligations expressed in IEC 61131-2 are not waived if no type test is required, or if the test conditions are restricted for practical reasons.

When compliance with some portion of IEC 61131-2 is indicated, it is only necessary to verify compliance with those clauses against which the compliance claim is made. The manufacturer's obligations as indicated above are still applicable. The smallest unit of IEC 61131-2 for compliance purposes is a Clause, such as Functional Requirements, Immunity Requirements, Safety Requirements, etc.

All requirements not tested according to Tests and Verifications Clauses need to be verifiable under a procedure to be agreed upon by the manufacturer and the user. The manufacturer needs to provide, on request, compliance verification information for all requirements referenced in the claims of compliance with all or a portion of this standard.

A.2.1.3 Normative references

IEC 61131-2 lists some 28 normative references, including:

IEC 60068-2-1, *Environmental testing - Part 2: Tests. Tests A: Cold*

IEC 60364-4-443, *Electrical installations of buildings – Part 4: Protection for safety – Chapter 44: Protection against overvoltages – Section 443: Protection against overvoltages of atmospheric origin or due to switching*

IEC 60417-DB:2002¹, *Graphical symbols for use on equipment*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60664-1:1992, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3:1992, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coatings to achieve insulation coordination of printed board assemblies*

IEC 60695-2-1, *Fire hazard testing – Part 2: Test methods – Section 1: Glow-wire test and methods*

IEC 60707, *Flammability of solid non-metallic materials when exposed to flame sources – List of test methods*

IEC 60947, *Low-voltage switchgear and controlgear*

IEC 60950, *Safety of information technology equipment, including electrical business equipment*

IEC 60947-5-1:1997, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 60947-7-1:2002, *Low-voltage switchgear and controlgear – Part 7-1: Ancillary equipment – Terminal blocks for copper conductors*

IEC 60950-1:2001, *Information technology equipment–Safety – Part 1: General requirements*

IEC 61000-4-2:1995, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:2002, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated radio-frequency electromagnetic field immunity test*

IEC 61000-4-4:1995, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 4: Electrical fast transient/burst immunity test*

IEC 61000-4-5:1995, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6:1996, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances induced by radio-frequency fields*

¹ "DB" refers to the IEC on-line database.

IEC 61000-4-8:1993, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-12:1995, *Electromagnetic compatibility (EMC) – Part 4-12: Testing and measurement techniques – Oscillatory waves immunity test*

IEC 61010-1:2001, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

CISPR 11:1999, *Industrial, scientific and medical (ISM) radio-frequency equipment – electromagnetic disturbance characteristics – limits and methods of measurement*

CISPR 16-1:1999, *Specification for radio disturbance and immunity measuring apparatus and methods. – Part 1: Radio disturbance and immunity measuring apparatus*

CISPR 16-2:1999, *Specification for radio disturbance and immunity measuring apparatus and methods. – Part 2: Methods of measurement of disturbances and immunity*

A.2.2 Terms and definitions

Some basic PLC equipment related definitions are listed in this Clause.

a) clearance

Shortest distance in air between two conductive parts.

b) creepage distance

shortest distance along the surface of the insulating material between two conductive parts.

c) digital input types

- Type 1 Digital Input
senses signal from mechanical contacts such as pushbuttons.
- Type 2 Digital Input
senses signals from solid state switching devices such as 2-wire proximity switches.
This class could also be used for type 1 or type 3 applications.
- Type 3 Digital Input
senses signals from solid state switching devices only.

d) earth, functional earth, protective earth

- Earth refers to part of the earth globe considered as conductive, the electrical potential of which is conventionally taken as zero.
- Functional Earth is a conductor that is in electrical contact with earth for purposes of interference immunity improvement.
- Protective Earth is a conductor in electrical contact with earth for purposes of safety.

e) Electro-Magnetic Compatibility (EMC)

The ability of an equipment or system to function satisfactorily in its electromagnetic environment without introducing intolerable electromagnetic disturbances to anything in that environment.

NOTE 1 According to IECV 161-01-07.

f) equipment class

Equipment classes, or Protection classes, designate the means by which electric shock protection is maintained in normal use and single fault conditions:

- Class I Equipment
are those with protection against electric shock which does not only rely on basic insulation, but also include means by which accessible conductive parts cannot become live in the event of a failure of the basic insulation.
- Class II Equipment
are those with protection against electric shock which does not rely on basic insulation only but also include additional safety precautions such as double insulation or reinforced insulation.
- Class III Equipment
are which protection against electric shock is provided by circuits supplied by Safety Extra-Low Voltage (SELV, 30 V r.m.s., 42,4 V peak or 60 V DC) and where voltages generated do not exceed the limits for SELV.

g) functional earthing conductor

A conductor that is in electrical contact with earth or earth equal-potential, for example those used for purposes of interference immunity improvement.

h) hazardous live

Capable of rendering an electric shock or electric burn in normal conditions or single fault conditions.

i) hazardous voltage

Hazardous voltage is which under normal conditions exceeds either 30 V r.m.s., or 42,4 V peak.

j) immunity (to a disturbance)

The ability of a device, equipment or system to perform without degradation in the presence of an electromagnetic disturbance.

NOTE 2 Definition according to IEC 161-01-20.

NOTE 3 Immunity may also refer to no degradation of performance in the presence of vibration, humidity, etc.

k) insulation

NOTE 4 Insulation can be a solid, a liquid, a gas (e.g. air), or any combination. According to IEC 151-03-30.

— Basic Insulation

Insulation of hazardous live parts, which provides basic protection against electric shock under fault free conditions.

NOTE 5 According to IEC 195-06-06 and IEC 195-06-01. This concept does not apply to insulation used exclusively for functional purposes. Such insulation is referred to as functional insulation.

— Double Insulation

Insulation comprising both basic insulation and supplementary insulation.

Note 6 According to IEC 195-06-08.

— Reinforced Insulation

Insulation of hazardous live parts which provides a degree of protection against electric shock equivalent to double insulation.

NOTE 7 According to IEC 195-06-09. Reinforced insulation may comprise several layers which cannot be tested singly as basic or supplementary insulation.

— Supplementary Insulation

Independent insulation applied in addition to basic insulation, for fault protection.

NOTE 8 According to IEC 195-06-07.

l) live part

A conductor or conductive part intended to be energized in normal use, including a neutral conductor, but by convention not a PEN conductor or PEM conductor or PEL conductor.

NOTE 9 According to IEC 195-02-19. This concept does not necessarily imply a risk of electric shock. (IEC 195-02-19).

— PEN conductor

A conductor combining the functions of both a protective earthing conductor and a neutral conductor. (IEV 195-02-12).

— PEM conductor

A conductor combining the functions of a protective earthing conductor and a mid-point conductor. (IEV 195-02-13).

— PEL conductor

A conductor combining the functions of both a protective earthing conductor and a line conductor. (IEV 195-02-14).

m) normal condition

Condition in which all means for protection against hazards are intact, that is, a fault-free condition.

n) normal use

Operation, including stand-by, according to the instructions for use or for the obvious intended purpose.

NOTE 10 Normal service conditions are stated in IEC 61131-2.

o) operator

Person commanding and monitoring a machine or process through an HMI connected to the PLC. The operator does not change the PLC hardware configuration, software or the application program. A PLC is not intended for use by untrained personnel. The operator is assumed to be aware of the general hazards in an industrial environment.

p) overvoltage category (of a circuit or within an electrical system)

A classification based on limiting (or controlling) the values of prospective transient overvoltages occurring in a circuit (or within an electrical system having different nominal voltages) and depending upon the means employed to influence the overvoltages.

NOTE 11 Equipment covered in IEC 61134-2 is intended for use in overvoltage category II.

q) pollution degree (in the micro-environment)

For the purpose of evaluating clearances and creepage distances, three degrees of pollution in the micro-environment are established.

NOTE 12 The conductivity of a polluted insulation is due to the deposition of foreign matter and moisture. The minimum clearances given for pollution degrees 2 and 3 are based on experience rather than on fundamental data.

— Pollution Degree 1

No pollution or only dry, non-conductive pollution occurs. The pollution has no influence.

— Pollution Degree 2

Normally, only non-conductive pollution occurs. Occasionally, however, a temporary conductivity caused by condensation must be expected.

— Pollution Degree 3

Conductive pollution occurs, or dry, non-conductive pollution occurs which becomes conductive due to condensation, which is expected.

r) protective conductor

A conductor provided for purposes of safety, for example protection against electric shock.

NOTE 13 According to IEC 195-02-09.

s) Protective Extra-Low Voltage (PELV) circuit

An electrical circuit in which the voltage cannot exceed AC 30 V r.m.s., 42,4 V peak or DC 60 V under normal condition and under single fault conditions, excepting earth faults in other circuits.

A PELV circuit is similar to an SELV circuit that is connected to protective earth.

t) Safety Extra-Low Voltage Circuit (SELV circuit)

An electrical circuit in which the voltage cannot exceed AC 30 V r.m.s., 42,4 V peak or DC 60 V under normal and under single fault conditions, including earth faults in other circuits.

An SELV circuit is not connected to protective earth.

u) service personnel

The person changing or repairing the PLC hardware configuration or the application program.

The service personnel may also install software updates provided by the manufacturer. They are assumed to be trained in the programming and operation of the PLC equipment and its use.

They are persons with the appropriate technical training and experience necessary to be aware of hazards – in particular, electrical hazards – to which they are exposed in performing a task and of measures to minimize danger to themselves or to other persons or to the equipment.

v) type of test

The following ways of testing may be used by PLC manufacturers to evaluate and confirm specified quality. IEC 61131-2 extensively specifies test methods and requirements. That information is not presented in this Technical Report since the user is normally not expected to delve into the details of the PLC manufacturing process.

— Routine Test

is applied to each individual catalogued device during or after its manufacturing process to ascertain compliance with certain criteria.

— Type Test

is applied to one or several basic PLC systems or samples of catalogue devices subjected to in order to ascertain compliance with required criteria.

— Withstand Type Test (Withstand Test)

Verifies that the application of more severe influencing quantities to the basic PLC system does not impair its ability to assume its intended mission. During this test, the basic PLC system is not energised.

A.2.3 Type tests to verify conformity


A Type Test is a conformity test on one or more items representative of the production.

Type tests are used to verify compliance of the PLC and the associated peripherals with the requirements given in IEC 61131-2. This compliance verification also includes visual inspection or/and measurement. In addition, routine tests are specified in IEC 61131-2. A routine test is a conformity test made on each individual item during or after manufacture.

The tests specified in IEC 61131-2 are qualification tests, and not tests related to the ways PLCs are employed. According to the scope of IEC 61131-2, the compliance verification may not cover the verification of the ability of the PLC system to satisfy the intended automated system requirements. Where special tests (not covered by IEC 61131-2) are required, those tests need to be agreed to between the manufacturer and the user.

Examples of Equipment Under Test (EUT) for noise immunity and EMC tests are shown in Figure A.4 in which each subpart of the PLC system as shown may constitute an EUT represented in Figure A.3 as EUT A, B, C, D, E and/or F. To exercise the different ports of each EUT, the manufacturer may define subsystems and the different EUTs are tested in turn.

Interfaces/Ports shown are meant to represent major/example links, not all links. Most EUTs will have multiple interface/ports active during testing.



IEC 1031/04

Figure A.4 – Type test EUT configuration

A.2.3.1 Withstand test conditions

A Withstand Test is a Type Test which verifies that the application of more severe influencing quantities to the basic PLC system does not impair its ability to assume its intended mission. In general, the manufacturer's catalogued module needs to be tested alone during the Withstand Test.

A.2.3.2 General conditions for tests

Tests are carried out under the general test conditions given in IEC 61131-2, unless otherwise specified. No sequence is imposed for type tests, unless otherwise specified.

Table A.2 – General conditions for tests

	Test conditions
Mains power supply	Rated voltage and frequency
Temperature	15 °C to 35 °C
Relative humidity	≤75 %
Barometric pressure	86 kPa to 106 kPa (650 mm Hg to 800 mm Hg)
Output loads	Outputs loaded to rated load
Pollution	Pollution degree 2

A.2.4 Normal service conditions and requirements

It is the user's responsibility to ensure that the equipment service conditions are not exceeded. The PLC and PLC system is intended to be used in an industrial environment.

The user must ensure the installation conditions match the environmental conditions given in IEC 61131-2.

A.2.4.1 Climatic conditions and requirements

A.2.4.1.1 Operating ambient air temperature

The equipment needs to be suitable for the operating temperature ranges given by Table A.3.

Table A.3 – Operating ambient air temperature of PLC systems

		Enclosed equipment (ventilated/non-ventilated)		Open equipment
Temperature range	Type of limit	Permanent installation	Non-permanent installation	Permanent installation
	Max.	40 °C	40 °C	55 °C
	Min.	5 °C	5 °C	5 °C
Average temperature over 24 h	Max.	35 °C	35 °C	50 °C
Notes		1 m away for non-ventilated. Temperature of incoming air for ventilated.		Temperature of incoming air immediately below the equipment.

No forced external cooling is assumed. Open peripherals, which are intended to be permanently installed as part of the PLC system, need to meet the operating temperature range of the PLC.

A.2.4.1.2 Relative Humidity

The equipment needs to be suitable for a relative humidity level from 10 % to 95 %, non-condensing.

A.2.4.1.3 Altitude

The equipment needs to be suitable for operation up to 2 000 m. No test required.

A.2.4.1.4 Pollution degree

Where not otherwise specified by the manufacturer, the equipment is designed for use in Pollution Degree 2.

A.2.4.2 Mechanical service conditions and requirements

Vibration, shock and free fall conditions vary widely depending on the installation and environment and are very difficult to specify.

The service conditions listed in IEC 61131-2 are indirectly defined by the following requirements which apply to fixed equipment as well as to unpackaged portable and hand-held equipment. Experience shows that equipment meeting these requirements is suitable for industrial use on stationary installations.

Conditions are also prescribed for transportation and storage, including temperature, altitude, free fall in manufacturer's original packaging and other conditions.

A.2.4.3 Electrical service conditions and requirements

Electrical service conditions prescribed in IEC 61131-2 include: AC and DC mains power supply, overvoltage category, control of transient overvoltages, transient overvoltages at the point of connection to the mains power supply, non-periodic overvoltages.

The user needs to take the necessary steps to prevent damage to the PLC system (e.g. by interposing a transformer) under overvoltage conditions, in particular the very damaging nature of non-periodical overvoltage (spike) at the mains resulting from power interruption of high-energy circuit/equipment.

When the service conditions are more severe than those given in IEC 61131-2, or other adverse environmental conditions exist, (e.g. air pollution by dust, smoke, corrosive or radioactive particles, vapours or salts, attack by fungi, insects or small animals), the manufacturer should be consulted to determine suitability of the equipment or the steps to be taken.

A.2.5 Functional requirements

A.2.5.1 Functional power supply and memory power back-up requirements

a) Rated value and operating range

Incoming power supplies to the PLC system and to the externally powered I/O modules are specified as:

- Rated DC voltages are: 24 V, 48 V and 125 V with tolerance (min./max.) of –15 %/+20 %.
- Rated AC r.m.s. voltages are: 24 V, 48 V, 100 V, 110 V, 120 V, 200 V, 230 V, 240 V, and 400 V with voltage tolerance of –15 %/+10 %. The specified frequencies are 50 Hz or 60 Hz. with tolerance (min./max.) of –6 %/+4 %.
- AC voltage is in terms of the total r.m.s. voltage values measured at the point of entry to the equipment.
- Total r.m.s. content of true harmonics (integral multiple of nominal frequency) less than 10 times nominal frequency may reach 10 % of the total voltage. Harmonic and other frequency content for higher frequencies may reach 2 % of the total voltage. However, to provide constant comparative results, the equipment needs to be tested at the third harmonic only (10 % at 0° and at 180° phase angle).

b) Memory power back-up

Power back-up for volatile memories needs to be capable of maintaining stored information for at least 300 h under normal use, and 1 000 h at a temperature not greater than 25 °C when the energy source is at rated capacity. (For power back-up needing replacement, the rated capacity is the value used to designate the procedure and time interval for replacement.)

The manufacturer is to specify storage time information relative to volatile memory if different from stated durations.

It should be possible to change or refresh power back-up without loss of data in the backed-up portions of memory. If a memory back-up battery is provided, a warning of “Low Battery Voltage” needs to be provided.


A.2.5.2 Digital inputs/outputs

Some digital I/O parameters are illustrated in Figure A.5.

Other types of outputs include: protected outputs, short-circuit-proof outputs, and non-protected output fitted with an external protective device recommended by the manufacturer. With protected outputs, the PLC system is specified to return to normal operation after re-setting or replacement of the protective device alone.

Electromechanical relay outputs are to be capable of performing at least 0,3 million operations at specified load.

Current sourcing digital output for direct current has rated value of 0,1 A to 2 A with maximum range for state 1 of 0,12 A to 2,4 A.



IEC 1032/04

Key:

C: Output.

Mechanical or static contact (e.g. dry relay contact, triac, transistor or equivalent).

E: Earthings.

The earths shown are optional.

Earthing is dependent on national regulations and/or application needs.

Z: Input.

Input impedance.

PS: External power supplies.

NOTE Some applications may use only one PS common to inputs, outputs and PLC system.

Figure A.5 – Digital I/O parameters

A.2.5.3 Analogue I/Os

Analogue input voltage signals are rated ± 10 V, (0 to 10) V and (1 to 5) V with input impedance limit of ≥ 1 k Ω , ≥ 1 k Ω and ≥ 500 Ω respectively. The rated current signals are (4 to 20) mA and (0 to 20) mA both with input impedance of ≤ 300 Ω .

Analogue output voltage outputs are rated ± 10 V, (0 to 10) V and (1 to 5) V with input impedance limit of ≥ 10 k Ω , ≥ 10 k Ω and ≥ 5 k Ω respectively. The rated current outputs are (4 to 20) mA and (0 to 20) mA both with input impedance of ≤ 600 Ω .

A.2.5.4 Remote Input/Output Stations (RIOs) requirements

RIOs are part of the permanent PLC installation and are therefore to be tested accordingly. In the case of loss of communication with the MPU application program, RIOs are able to fix the states of their outputs to specified values, within specified delays and without passing through unspecified states and are capable of providing a fault indication signal. The MPU system needs to provide the user's application program with relevant information on current status of RIOs.

A.2.5.5 Peripherals (PADTs, TEs, HMIs) requirements

Peripherals which are not a permanent part of the PLC system should not cause malfunction of the system when making or breaking communication with an operating system.

Connectors for the peripherals need to be polarized to prevent improper connection, or the PLC system needs to be so designed that no malfunction occurs if a connection is improper.

The system consisting of the peripheral and the PLC system needs to be designed to ensure that the edited program executing in the PLC system is functionally identical to the edited program displayed on the peripheral.

If on-line modification of the application program and/or the modes of operation of the PLC system by a peripheral is possible (i.e. when the PLC system is in active control of a machine or industrial process), then:

- The peripheral needs to automatically give clear warnings equivalent to "during on-line modification, program display may differ from application program, control of the machine/process may be interrupted during ... ms, etc.", as applicable.
- The peripheral needs to ask the operator "do you really want to carry out this action?" or some similar words and execute the command only after a positive reply has been given by the operator.

It has to be possible to upload the new application program to the manufacturer's supplied data media and verify, on-line, that the record is functionally equivalent to it, and means need to be provided to prevent unauthorized use of these functions (hardware or software).

A.2.5.6 PLC system self-tests and diagnostics requirements

The manufacturer needs to provide means of self-tests and diagnostics of the PLC system operation. Such means are built-in services of the PLC system, and/or recommended ways to implement the intended application.

The following need to be provided;

- a means for monitoring the user's application program (i.e. watchdog timer, etc.),
- a hardware or software means to check the memory integrity,
- a means to check the validity of the data exchanged between memory(ies), processing unit(s) and I/O modules (such as an application loop-back test),
- a means to check that the power supply unit(s) does not exceed the current and voltage limits allowed by the hardware design,
- a means to monitor the status of MPU.

The permanently installed PLC system needs to be capable of operating an alarm signal on an alarm output. When the system is monitored as "functioning correctly", this alarm output shall be in a predetermined state; in the other case it shall go to the opposite state. The manufacturer needs to specify the conditions of the "correct functioning state" and the self-tests which are executed to drive this alarm output.

RIOSs need to be capable of operating an alarm signal on an alarm output (for example, through a digital output module) in the event of loss of power or loss of normal communication with the MPU and go to a predetermined state.

A.2.5.7 Other requirements

Other requirements prescribed in IEC 61131-2 include: functional earthing, mounting requirements, and general marking requirements.

For marking, functional earth terminals (i.e. used for non-safety purposes such as interference immunity improvement) are marked with the following symbol:



A.2.6 Normal service and function type tests and verification

IEC 61131-2 prescribes the following tests and verifications:

- climatic tests, mechanical tests;
- shut-down test, start-up test;
 - gradual shut-down/start-up test;
- verification of special functional requirements for power ports and memory back-up;
 - special Immunity limits for power ports;
 - verification of functional mains power port (AC or DC);
 - voltage range, ripple and frequency;
 - external energy supply variation tests (immunity tests);
 - supply voltage variation test;
 - Improper power supply connection tests;
 - reverse of DC power supply polarity test (withstand test);
 - improper voltage level and/or frequency test;
- verification of memory back-up requirements;
- verification of input/output requirements;
- verification of digital inputs;
- operating range test;
- reversal of signal polarity test (withstand test);
- verification of digital outputs, including:
 - operating range test,
 - test of protected not-protected,
 - short-circuit proof outputs, and
 - reversal of signal polarity;
- verification of analogue I/Os, including:
 - operating range test,
 - analogue input overload withstand test,
 - short-circuit test (voltage output), and
 - open-circuit test (current output);

NOTE No physical damage or abnormal phenomenon should be detected. Functional verification is performed after the tests, voltage supply variation test and reversal of signal polarity test (withstand test).

- verification of remote I/O station, including:
 - response time test;
 - loss of communication test;
- verification of peripherals (PADTs, TEs, HMIs) requirements;
- verification of PLC system self-tests and diagnostics;
- verification of markings and manufacturer's documentation.

A.2.7 Equipment information to be provided by the manufacturer

A.2.7.1 Information on type and content of documentation

A.2.7.1.1 Information on catalogues and datasheets

These documents need to contain the description and the specifications of the PLC system and its associated peripherals. Additionally, they need to contain any other relevant information to aid in understanding the application and use of these products including functional characteristics, equipment configuration rules, normal service conditions, physical dimensions and weights, and list compliance with standards and certifications.

A.2.7.1.2 Information on user's manuals

These documents include the necessary information for the proper installation, wiring, troubleshooting, user programming and commissioning of the PLC system by the user. They are to include as a minimum:

- installation and commissioning instructions;
- programming and troubleshooting instructions;
- maintenance and service requirements, and
- accessory and spare parts lists (e.g. fuses).

A.2.7.1.3 Information on technical documentation

The manufacturer may optionally provide a set of documents which contain more information than those given in the users manual such as: schematic diagrams, internal or external data protocols, bus assignments, physical dimension characteristics, energy available, firmware, internal test programs or repair procedures, etc.

A.2.7.2 Information on compliance with this standard

The manufacturer needs to provide information on compliance with IEC 61131-2, which can be claimed on two levels:

- a) full compliance with all of the requirements contained in all clauses of the standard, such as indicated by reference to IEC 61131-2 without qualification;
- b) compliance with a portion of the standard where documentation identifies the specific clauses of the standard with which the product has been determined to comply.

A.2.7.3 Information on reliability

If the manufacturer provides values of the Mean Time Between Failures (MTBF) of any subassembly or module, and of the type-test configuration (s) (PLC system (s)) under normal service conditions the manufacturer also needs to explain the method used to determine it.

A.2.7.4 Information on other conditions

The user is to reach agreement with the manufacturer for any mechanical conditions that are not specified in IEC 61131-2.

A.2.7.5 Information on shipping and storage

The manufacturer provides shipping and storing instructions.

A.2.7.6 Information on AC and DC power supply

The manufacturer is to provide the following information:

- data to allow selection of a suitable power distribution network to provide specified voltage at each power utilization point. This information includes peak inrush (at cold start and warm restart), repetitive peak and steady-state r.m.s. input currents under full load conditions;
- external terminal identification for power supply interfaces;
- typical example(s) for power supply system(s);
- special supply installation requirements, if any, for PLC systems energized through multiple power supplies or supply voltages and frequencies not included in IEC 61131-2;
- the effect of the following incorrect connections of power to the supply(ies): reverse polarity, improper voltage level and/or frequency and improper lead connection;
- complete information on PLC system behaviour for typical power up/down sequences;
- data to allow evaluation of the maximum values of interruption time which do not affect the normal operation of any PLC system configuration; PS class (PS-1 or PS-2) of DC supplied devices;
- memory back-up time with respect to temperature and maintenance requirements;
- recommended time interval between replacement of energy sources, if applicable, and recommended procedure and subsequent effects on the PLC system;
- peak inrush current (at cold start and warm restart) or recommended fuse size and blowing characteristics.

A.2.7.7 Information on digital inputs (current sinking)

The manufacturer is to provide the following information:

- volt-ampere curve over the full-operating range, with tolerances or equivalent;
- digital input delay time for 0 to 1 and 1 to 0 transitions;
- existence of common points between channels;
- effect of incorrect input terminal connection;
- isolation potentials between channel and other circuits (including ground) and between channels under normal operation;
- type of input (Type 1, Type 2 or Type 3);
- monitoring point and binary state of visual indicator;
- effects when withdrawing/inserting input module under power;
- additional external load when interconnecting inputs and outputs, if needed;
- explanation of signal evaluation (for example static/dynamic evaluation, interrupt release, etc.);
- recommended cable and cord lengths depending on cable type and electromagnetic compatibility;
- terminal arrangements;
- typical example(s) of external connections.

A.2.7.8 Information on digital outputs for alternating currents (current sourcing)

The manufacturer is to provide the following information with respect to digital outputs for AC operation:

- type of protection (i.e. protected, short-circuit proof, not-protected output) and:
 - for protected outputs: operating characteristics beyond 1,1 rated current including the current(s) level(s) at which the protecting device energizes, the current behaviour beyond, and the time(s) involved;
 - for short-circuit proof outputs: information for replacement or resetting the protective device as required;
 - for not-protected outputs: specification for protective device to be provided by the user, as required;
- output delay time for state 0 to state 1 and state 1 to state 0 transitions;
- commutation characteristics and turn-on voltage with respect to zero voltage crossing;
- existence of common points between channels;
- terminal arrangements;
- typical example(s) of external connections;
- number and type of outputs (e.g. NO/NC contacts, solid state, individually isolated channels, etc.);
- for electromechanical relays, the rated current and voltage complying with IEC 61131-2;
- output ratings for the other loads such as incandescent lamps;
- total output current for multi-channel modules;
- characteristics of suppresser networks incorporated into the output circuit against voltage peaks due to inductive kickback;
- type of external protective networks, if required;
- effects of incorrect output terminal connection;
- isolation potentials between channel and other circuits (including ground) and between channels under normal operation;
- monitoring points of visual indicators in the channel (e.g. MPU side/load side);
- recommended procedures for changing output modules;
- output behaviour during interruptions of MPU control, voltage drops and interruptions and power up/down sequences;
- type of operation (i.e. latching/non-latching type);
- effects of multiple overloads on isolated multi-channel modules.

A.2.7.9 Information on digital outputs for direct current (current sourcing)

The information to be provided by the manufacturer for digital outputs for DC is the same as for digital outputs for AC. However, the specification of commutation for zero voltage crossing does not apply, and with regard to electromechanical relay outputs.

A.2.7.10 Information on analogue inputs

Besides the type and standard range, the manufacturer is to provide the following information:

a) Information on analogue inputs - static characteristics

Static characteristics	Units and examples
1) Input impedance in signal range (manufacturer should specify if this is in the ON or OFF state)	Ω
2) Analogue input error: – Maximum error at 25 °C – Temperature coefficient	- \pm % of full scale \pm % of full scale/K
3) Maximum error over full temperature range	\pm % of full scale
4) Digital resolution	Number of bits
5) Data format returned of the application program	Binary, BCD, etc.
6) Value of a LSB (least significant bit)	mV, mA
7) Maximum permanent allowed overload (no damage)	V, mA
8) Digital output reading under overload condition	e.g. flag
9) Type of input	e.g. differential
10) Common mode characteristics (DC, AC 50 Hz, AC 60 Hz) if applicable	CMRR-dB, CMV-V
11) For other inputs (thermocouples, RTD, etc): – Type(s) sensor(s) – Measurement range(s) – Linearisation method	- J, K, T, etc.: Pt, 100, etc. Min. °C to Max. °C Internal or user-provided

b) Information on analogue inputs - dynamic characteristics

Dynamic Characteristics	Units and examples
1) Sample duration time (including setting time)	ms
2) Sample repetition time	ms
3) Input filter characteristics: – Order – Transition frequency	- First, second, etc. Hz
4) Maximum temporary deviation during each specified electrical interference test	\pm % of full scale

c) Information on analogue inputs general characteristics

General characteristics	Units and examples
1) Conversion method	Dual slope, S.A, etc.
2) Operating modes	Trig, self-scan, etc.
3) Type of protection	RC, opto-isolator, MOVs, etc..
4) Isolation potentials under normal operation between channel and other circuits (including ground), between channels, power supply(ies) and interface(s)	V -
5) External power supply data, if required	Technical data
6) Common points between channel if any	-
7) Type, length of cable, installation rules recommended to provide interference immunity	Twisted pair, 50 m max. -
8) Calibration or verification to maintain rated accuracy	Months, years
9) Terminal arrangements	-
10) Typical example(s) of external connections	-
11) Effect of incorrect input terminal connection	-

d) Information on analogue inputs - miscellaneous characteristics

Miscellaneous characteristics	Units and examples
1) Monotonicity with no missing codes	Yes, no
2) Crosstalk between channels at DC, AC 50 Hz and AC 60 Hz	dB
3) Non-linearity	% of full scale
4) Repeatability at fixed temperature after specified stabilization time	% of full scale
5) Life time of electromagnetic relay multiplexers, if applicable	Number of cycles, of hours

A.2.7.11 Information on analogue outputs

Besides the type and standard range, the manufacturer is to provide the following information:

a) Information on analogue outputs - static characteristics

Static characteristics	Units and examples
1) Output impedance in signal range (manufacturer should specify if this is in the ON or OFF state)	Ω
2) Analogue output error: - Maximum error at 25 °C - Temperature coefficient	- \pm % of full scale (which scale) \pm % of full scale/K
3) Maximum error over full temperature range	\pm % of full scale (which scale)
4) Digital resolution	Number of bits
5) Data format returned of the application program	Binary, BCD, etc
6) Value of a LSB (Least Significant Bit)	mV, mA

b) Information on analogue outputs - dynamic characteristics

Dynamic Characteristics	Units and examples
1) Settling time for full range change	ms
2) Overshoot	% of full scale
3) Maximum temporary deviation during each specified electrical interference test	\pm % of full scale

c) Information on analog outputs - general characteristics

General characteristics	Units and examples
1) Type of protection	Opto-isolator, etc.
2) Isolation potentials between channel and other circuits (including ground) and between channels under normal operation	V -
3) External power supply data, if required	Technical data
4) For current outputs with external supply, the maximum and minimum voltage drop across the output terminals in the full output range	V -
5) Type, length of cable, installation rules recommended to provide interference immunity	Twisted pair, 50 m max. -
6) Calibration or verification to maintain rated accuracy	Month, years
7) Terminal arrangements	-
8) Common points between channels if any	-
9) Allowed type(s) of loads	Floating, grounded
10) Maximum capacitive load (for voltage outputs)	pF
11) Maximum inductive load (for current outputs)	mH
12) Typical example(s) of external connections	-
13) Output response at power up and power down	-
14) Effect of incorrect output terminal connection	-

d) Information on analogue outputs - miscellaneous characteristics

Miscellaneous characteristics	Units and examples
1) Monotonicity	Yes, no
2) Crosstalk between channels at DC, AC 50 Hz and AC 60 Hz	dB
3) Non-linearity	% of full scale
4) Repeatability at fixed temperature after specified stabilization time	% of full scale
5) Output ripple	% of full scale

A.2.7.12 Information on communication interfaces

If the manufacturer provides communication interfaces to other than his own equipment, he needs to provide the necessary information for correct operation. This may be achieved by referencing a specific standard or specification together with details of any options such as baud rate, type of cable to be used, etc.

A.2.7.13 Information on main processing unit(s) and memory(ies) of the PLC system

The following information is to be provided by the manufacturer for main processing unit(s) and memory(ies):

- 1) organization, capacity of program memory;
- 2) organization, capacity of data memory and number of bits per word;
- 3) memory type(s) (i.e. CMOS-EEPROM, etc.) available;
- 4) memory back-up functionality and service requirements if any;
- 5) data, constraints and procedures to determine a desired configuration (racks, cables, bus expanders, power supply unit, maximum number of I/Os per type, maximum number of I/O modules, etc.);
- 6) description of the programming languages supported by the PLC system (combination of the PADT and the main processing unit(s));
- 7) to what extent the languages defined in IEC 61131-3 are supported, including the differences if any (objects, instructions, semantic and syntactic rules, etc.);
- 8) calculation methods to determine every memory utilization (user's application program and data, firmware program and data where applicable) and average values of every relevant time (scan time(s), system response time(s), transfer time(s), execution time(s));
- 9) mechanisms in which I/Os are processed (i.e. use of I/O image registers periodically refreshed by the system, immediate "get/put" type instructions, interrupt and event-driven programs, etc.) and their effect on the following subjects:
 - system response time(s);
 - restart capabilities (i.e. cold, warm, hot restart);
 - detailed times for inputs, outputs, processing, etc.;
 - effect of non-permanently installed peripherals on every relevant time (see item 8 above) when they are plugged/unplugged, connected/disconnected to their PLC system interface;
 - PLC system status information concerning cold, warm and hot restart if applicable. Description and usage of programmable timers usable to determine the process-dependent difference between warm and hot restart;
 - self-test and diagnostic functions implemented.

A.2.7.14 Information on Remote Input/Output Stations (RIOS)

The manufacturer is to provide the following information:

- specifications for the selection of adequate cables and other devices needed for the communication link;
- specifications for proper installation of the whole system (including proper selection of energy source(s));
- type of I/O communication network (point to point, star, multi-drop, ring, etc.)
- principles, procedures and transmission speeds used on the communication link and their capability to transfer data from and to the RIOSs with respect to error coding/detection and to the delays of transmission in the best, most likely and worst cases;
- effect on transfer time(s) introduced to provide remote input information and RIOSs status to the user's application program and to transmit its logical decisions to remote outputs;
- specified values and delays;
- configuration related data: maximum number of RIOSs in one single PLC system configuration, min/max size of each;
- which I/O modules of the total I/O system may not be used in RIOSs and/or which of their functions are altered if any;
- type, architecture and characteristics of redundancy if provided;
- modems/repeaters if applicable. Maximum distance with or without repeaters;
- terminating devices if required;
- physical characteristics of the communication interface including isolation characteristics, maximum acceptable common mode voltage, built-in short-circuit protections, etc.;
- type of standard link interface (i.e. RS 232, RS 422, RS 485, RS 511, etc.);
- functional and safety earthing specifications;
- procedures for making/breaking logical and physical connection of a RIOS to a PLC system (e.g. "on line").

A.2.7.15 Information on peripherals (PADTs, TEs, HMIs)

The manufacturer is to provide the following information through convenient documentation and marking:

- clear warnings and precautions to be observed when using functions enabling alteration of control conditions such as PLC system status modification, changing of data or programs in the memory, forcing input or output signal, etc.;
- usability of peripherals at RIOSs;
- service conditions for peripherals which are intended for use in an environment less severe than stated under normal conditions (such peripherals may need to be remotely connected to the rest of the PLC system through communication lines);
- specifications for the selection of adequate cables and other devices needed for the communication link;
- specifications for proper installation of the whole system (including proper selection of energy source(s));
- type of communication network (point to point, star, multi-drop, ring, etc.);
- principles, procedures and transmission speeds used on the communication link and their capability to transfer data from and to the RIOSs with respect to error coding/detection and to the delays of transmission in the best, most likely and worst cases;
- terminating devices if required;
- physical characteristics of the communication interface including isolation characteristics, maximum acceptable common mode voltage, built-in short-circuit protections, etc.;

- type of standard link interface (i.e. RS 232, RS 422, RS 485, etc.);
- functional and safety earthing specifications.

A.2.7.16 Information on self-tests and diagnostics

The manufacturer is to provide the following information through convenient documentation and marking:

- description of tests and diagnostics which are implemented and when they are executed (i.e. permanently, periodically, upon user's application program request, during start-up procedure, etc.);
- correct functioning state and driving conditions of the alarm output(s).

A.2.8 Electromagnetic compatibility (EMC) requirements

A.2.8.1 General

The requirements of IEC 61131-2 are intended to characterize the EMC performance of the PLC system equipment and are the responsibility of the manufacturer. The user, advised by the manufacturer, is responsible for the electromagnetic compatibility of the product as installed.

Since the PLC system is only one component of the overall automated system, this standard does not deal with the EMC compatibility of the overall automated system.

If an optional EMC enclosure (e.g. cabinet) or other protection device (e.g. filter) is specified by the manufacturer it needs to be included as part of the Equipment Under Test (EUT).

The EMC enclosure port is the physical boundary of the PLC system through which electromagnetic fields may radiate or impinge.

A.2.8.2 Emission requirements

For emissions, the objective of the requirements, given in Table A.4, is to ensure protection of the radio frequency spectrum.

Since the PLC system is not connected to the public mains, there is no requirement up to 150 kHz. Emission limits in the high frequency range are shown in Table A.4.


Table A.4 – Emission limits

Port	Frequency range	Severity level (normative)	Severity level (optional)	Basic standard
Enclosure port (radiated)	- - (30 to 230) MHz (230 to 1 000) MHz	Measured at 10 m distance 40 dB ($\mu\text{V}/\text{m}$) quasi-peak 47 dB ($\mu\text{V}/\text{m}$) quasi-peak	Measured at 30 m distance 30 dB ($\mu\text{V}/\text{m}$) quasi-peak 37 dB ($\mu\text{V}/\text{m}$) quasi-peak	CISPR 11 Class A, Group 1
AC power port (conducted)	(0,15 to 0,5) MHz - (0,5 to 30) MHz -	79 dB (μV) quasi-peak 66 dB (μV) average 73 dB (μV) quasi-peak 60 dB (μV) average		CISPR 11 Class A, Group 1
NOTE Emission limits at frequencies above 1 000 MHz are under consideration.				

A.2.8.3 EMC immunity requirements

A.2.8.3.1 General

If a product is to be used in multiple zones, then it needs to be designed and tested to the most severe combination of requirements for its intended immunity zones. PLC's are designed for Zone B (which encompasses Zone A), unless otherwise indicated by manufacturer's information. Immunity zones are illustrated in Figure A.6 and further described in Table A.8.



IEC 1033/04

Zone C: Factory mains (isolated from public mains by dedicated transformer), primary surge protection and severe interference coupling.

Zone B: Dedicated power distribution, secondary surge protection and typical industrial interference coupling. Zone B is the most typical industrial environment.

Zone A: Local power distribution, I/O impedance limiting and low interference coupling.

Figure A.6 – Immunity zones

Figure A.6 is meant to describe the EMC and interference coupling mechanisms in a factory environment. Zone separation is determined by power distribution and I/O wiring. Dotted lines are not meant to indicate physical separation of segregation. The letters (F, K, C, D, etc.) correspond to those referred to in Figure A.3.

A.2.8.3.2 Performance criteria

See Table A.5.

Table A.5 – Criteria to prove the performance of a PLC-system against EMC disturbances

Performance criterion		
Criterion	Operation	
	During test	After test
I	The PLC system should continue to operate as intended. No loss of function or performance, according to PFVPs.	The PLC system should continue to operate as intended.
II	Degradation of performance accepted, e.g. analogue values can vary within manufacturer-specified limits, but no change of operating mode and no irreversible loss of stored data, according to PFVPs.	The PLC system should continue to operate as intended. Temporary degradation of performance must be self recoverable.
III	Loss of functions accepted, but no destruction of hardware or software (program or data).	The PLC system should continue to operate as intended automatically, after manual restart or power OFF/power ON.

A.2.8.3.3 General radiated immunity limits

Radiated and conducted immunity limits in Zones A and B are detailed in IEC 61131-2 based on IEC 61000-4.

A.2.8.3.4 Voltage drops and interruptions power ports

For longer interruptions of the supply(ies), the PLC system needs to be either maintain normal operation or go to a predefined state and have a clearly specified behaviour until normal operation is resumed.

Table A.6 – Voltage drops and interruptions

(5)	(3),(4)	Maximum Interruption Time	Time interval between drops	Low voltage
DC supply	Severity level PS1	1 ms	≥ 1 s	Any voltage under lower operational limit $U_{e \min}$ (2)
	Severity level PS2	10 ms	≥ 1 s	
AC supply		0,5 period (1)	≥ 1 s	
Any arbitrary phase angle. $U_{e \min}$ is the rated voltage at tolerance minimum. PS1 applies to PLC systems supplied by battery. PS2 applies to PLC systems energized from rectified AC supplies and/or long DC lines. Voltage interruptions are from $U_{e \min}$.				

The requirements of Table A.6 apply to the mains power interface/port in Figure A.3 for short disturbances of the power supply to the PLC system, including RIOS.

A.2.9 Electromagnetic compatibility (EMC) type tests and verification

The following tests and verifications are detailed in IEC 61131-2:

- EMC related tests;
- test environment;
- measurement of radiated interference;
- measurement of conducted interference;
- electrostatic discharge;
- radio frequency electromagnetic field – amplitude modulated;
- power frequency magnetic fields;
- fast transient bursts;
- high energy surge immunity;
- conducted radio frequency interference immunity;
- damped oscillatory wave immunity (for Zone C only);
- voltage drop and interruptions immunity – power port type test and verification.

A.2.10 EMC information to be provided by the manufacturer

Information to be made available can be in other than printed form.

General rules of installation are as noted in IEC 61131-4. Specific installation information needs to be provided by the manufacturer.

The manufacturer needs to state if its devices are intended to be used under normal service conditions or in a less severe environment (e.g. office environment). If the PLC is intended for other than Zone B (which encompasses Zone A), the manufacturer needs to state the intended zone.

The Test Report needs to describe all the tests, the rationale for the selection of the typical (representative) configuration of the EUT and the test results. The EUT software during the test is to be documented.

A.2.11 Safety requirements

The PLC safety clauses in IEC 61131-2 has two main subjects: protection against electrical shock and protection against the spread of fire. IEC 61131-2 specifies the design, material and testing methods to meet the safety requirements.

A.2.11.1 Protection against electrical shock

Protection against electric shock of the PLC system is maintained in normal and single fault conditions. Accessible parts of equipment should not be, or become, hazardous live.

Protection is provided by compliance with dielectric strength, operator accessibility, normal condition, single fault and clearance and creepage requirements in IEC 61131-2.

A.2.11.1.1 Permissible limits for accessible parts

To ensure that accessible parts are not hazardous live, the voltage, current, charge or energy between an accessible part and reference test earth, or between any two accessible parts on the same piece of equipment within a distance of 1,8 m (over a surface or through air) are specified in IEC 61131-2.

a) Values in normal conditions

Hazardous live conditions are voltage values above AC 30 V r.m.s. and 42,4 V peak or DC 60 V.

b) Value in single-fault conditions

In single fault conditions, voltage values above AC 50 V r.m.s. and 70 V peak or DC 20 V are deemed hazardous live.

A.2.11.1.2 Open PLC system equipment

Open PLC system equipment is equipment that may have live electrical parts accessible, e.g. a main processing unit. Protection against electric shock needs to be provided for those interfaces that are so classified in A.2.11.1.5. Open equipment is to be incorporated into other assemblies manufactured to provide safety.

A.2.11.1.3 Enclosed PLC system equipment

Enclosed PLC system equipment is equipment which is enclosed on all sides, with the possible exception of its mounting surface, to prevent personnel from accidentally touching live or moving parts contained therein, to protect the equipment against ingress of 12,5 mm diameter and greater solid foreign bodies, and meeting requirements of mechanical strength, flammability, and stability (where applicable). Protection degree must be \geq IP20 as per IEC 60529.

Protection against electric shock needs to be provided for those interfaces that are classified as in A.2.11.1.5. Each entity of an enclosed PLC system needs to comply with the requirements of Equipment Classes I, II or III. The protection degree is \geq IP20. The protective earthing conductor is a part of a flexible cord set.

A.2.11.1.4 Dielectric strength type test

The dielectric withstand type test is detailed in IEC 61131-2 between all parts and circuits where basic, reinforced or double insulation are specified for protection against electric shock.

A.2.11.1.5 Operator accessibility

Table A.7 defines ports of a PLC system requiring protection against shock. Under special circumstances, some ports of either open or enclosed equipment may or may not be considered operator accessible. This is to be agreed upon between the manufacturer and the user.

Table A.7 – Shock protection requirements for open and enclosed equipment

Port	Protection required	
	Open equipment	Enclosed equipment
Al – Communication interface/port for local IO extension rack	No	Yes
Ar – Communication interface/port for remote IO station	No	Yes
Be – Open communication interface/port also open to third party devices (e.g. personal computer used for programming instead of a PADT)	Yes	Yes
Bi – Internal communication interface/port for peripherals	No	No
C – Interface/port for digital and analogue input signals	No	Yes
D – Interface/port for digital and analogue output signals	No	Yes
E – Serial or parallel communication interfaces/ports for data communication with third party devices	Yes	Yes
F – Mains power interface/port	No	Yes
G – Interface/port for protective earthing	No	Yes
H – Interface/port for functional earthing	No	Yes
J – I/O power interface/port used to power sensors and actuators.	No	Yes
K – Auxiliary power output interface/port	No	Yes

A.2.11.1.6 Protection in normal condition

Operator accessible parts need to be prevented from becoming hazardous live under normal conditions by one or more means of basic insulation, enclosures or barriers, and/or protective impedance.

A.2.11.1.7 Protection in single fault condition

Additional protection needs to be provided to ensure that operator accessible conductive parts are prevented from becoming hazardous live when a single fault occurs. This additional protection needs to be provided by means of protective earthing and bonding, supplementary insulation and/or protective impedance.

A single fault is considered to occur when a single component providing protection is unable to continue providing that protection. Requirements on fault tests are detailed in IEC 61131-2, including the following.

a) Protective Earthing and Bonding

Operator accessible conductive parts are to be bonded to the protective conductor terminal if they could become hazardous live in case of a single fault of the primary protective means specified in IEC 61131-2. Alternatively, such accessible parts are separated from parts that are hazardous live by a conductive protective screen or barrier bonded to the protective conductor terminal.

Operator accessible conductive parts need not be bonded to the protective earth terminal if they are separated from all hazardous live parts by double insulation or reinforced insulation.

b) Supplementary Insulation

Clearances and creepage distances are specified in IEC 61131-2. The requirements for protection under single fault conditions are satisfied with double or reinforced insulation.

c) Protective Impedance

The protective impedance needs to limit the voltage from becoming hazardous live under normal or single fault conditions on operator accessible parts or to values for SELV. The use of a single component not liable to become defective in such a manner as to cause a risk of hazard is allowed. Verification of these requirements is specified in IEC 61131-2.

A.2.11.2 Protection against the spread of fire

Protection against the spread of fire is to be evaluated between limited power circuits and other circuits. There are no requirements for protection against the spread of fire within limited power circuits.

If limited power circuits are not employed, all other requirements of IEC 61131-2 for the protection against the spread of fire are to be met. Where breakdown of components is involved, compliance is to be verified.

A.2.11.3 Limited power circuits

A limited power circuit is a circuit supplied by sources such as a battery or a transformer winding where the open-circuit potential is not more than AC 30 V r.m.s. and 42,4 V peak or DC 60 V, and the energy available to the circuit is limited according to one of the following means:

- the maximum output current and power are inherently limited and specified in IEC 61131-2;
- the maximum output current under all conditions and power are limited by impedance to below the limits set in IEC 61131-2;
- an over-current protective device limits the maximum output current and power to below the limits set by IEC 61131-2;
- a regulating network limits the maximum output current and power to those set by IEC 61131-2;
- a regulating network limits the maximum output current and power as the result of any one fault in the regulating network set by IEC 61131-2.

Where an over-current protective device is used, it needs to be a fuse or a non-adjustable non-self-resetting device.

Conformity is checked by measuring the output voltage, the maximum output current and the maximum available output power.

A.2.11.4 Clearance and creepage distances requirements

Creepage values are primarily directed at accommodating pollution concerns. Clearance values are primarily directed at accommodating overvoltage concerns.

IEC 61131-2 specifies clearance and creepage distances, including:

- a) Clearances relating to overvoltage Category II:
 - Field wiring terminal clearance.
 - Clearance of other than field wiring terminals.
- b) Clearance for micro-environment where voltages are known and controlled.
 - Creepage distances for basic and supplementary insulation.
 - Minimum creepage distances for printed circuits and other types of circuits.
- c) Creepage distance requirements for recurring peak voltages.
- d) Creepage distance for double/reinforced insulation.
- e) Creepage for field-wiring terminals.

A.2.11.5 Flame-retardant requirements for non-metallic materials

Requirements are specified in IEC 61131-2 for the following:

- a) non-metallic enclosure material;
- b) non-metallic material supporting live parts;
- c) components, including:
 - non-metallic components;
 - decorative and labelling materials;
 - internal wiring or interconnection cables.

A.2.11.6 Temperature limits

Component temperature limits: components should not be operated beyond their rated temperature limits or rated temperature rises. Easily touched parts: parts likely to be touched by an operator in normal use or by service personnel should not exceed the temperature limits of Table A.8.

Table A.8 – Temperature limits

Absolute maximum temperatures	Access time	Metallic	Non-metallic	Examples
Operator hand-held equipment	Continuous	55 °C	70 °C	Handheld terminals
Operator parts normally touched in operation	Momentary	70 °C	85 °C	Push buttons on cabinet
Parts accessible during servicing, normally touched in operation	Momentary	70 °C	85 °C	Key switches on PLC
Parts accessible during servicing, not normally touched in operation	Momentary	100 °C (1)	100 °C (1)	Heatsinks
Warning label is necessary if temperature exceeds level shown.				

Field wiring terminals need to be monitored for the temperature during the temperature test. This data is to be used in conjunction with the device's rated ambient to determine the field wiring insulation temperature rating.

A.2.11.7 Enclosures

Enclosures need to provide protection against the hazards of moving parts and contact with live parts. Requirements for equipment enclosures are specified in IEC 61131-2, including:

- a) Open equipment.
- b) Enclosed equipment.
 - Enclosed equipment need to meet IP20 requirements as a minimum. This protection also needs to be provided under all conditions of operator use.
 - Shafts and knobs external to the enclosure does not need to be in contact with hazardous live parts.
 - Mechanical Strength of the enclosure needs to be such as to withstand rough handling in normal use.

A.2.11.8 Field wiring terminals constructional requirements

Terminals need to be so designed that loose strands of wire should not reduce the required clearance/creepage requirements and other requirements as per IEC 61131-2.

A.2.11.9 Provisions for protective earthing

The requirements specified below do not apply to SELV circuits where protective earthing is not required.

A.2.11.9.1 Protective earthing constructional requirements

The accessible parts of Class I equipment (e.g. chassis, framework and fixed metal parts of metal enclosures) other than those which do not constitute a danger need to be electrically interconnected and connected to a protective earth terminal for connection to an external protective conductor. This requirement can be met by structural parts providing adequate electrical continuity and applies whether the equipment is used on its own or incorporated in an assembly.

Cords or cables that supply power to portable peripherals need to be provided with a protective earthing conductor. Protective earthing conductor insulation, if provided, is to be green with a yellow stripe.

NOTE In North America, the colour green is also acceptable.

Accessible isolated conductive parts are considered not to constitute a danger if they are so located as to exclude any contact with live parts and withstand the dielectric test voltage specified in IEC 61131-2 for reinforced insulation corresponding to the highest rated operational voltage of the unit.

Class II equipment may have an internal functional bonding conductor but may not be provided with a protective earthing terminal or a protective earthing conductor in the mains power input cord.

A.2.11.10 Protective earthing terminal

If the PLC system is provided with a protective earthing terminal (class I equipment), the following requirements also apply in addition to the previous general connection specifications:

- The protective earthing terminal needs to be readily accessible and so placed that the connection of the equipment to the protective earthing conductor is maintained when the cover or any removable part is removed.
- Products which are intended for cord connected use (such as peripherals) need to be provided with a protective earthing terminal integral to the plug cap, or socket (if removable cord set).
- The protective earthing terminal needs to be of screw, stud or pressure type and needs to be made of a suitable corrosion resistant material.
- The clamping means of protective earthing terminals need to be adequately locked against accidental loosening and it should not be possible to loosen them without the aid of a tool.
- Protective earthing terminals and earthing contacts are not to be directly connected to the neutral terminal within the PLC system. This does not prevent the connection of appropriately rated devices (such as capacitors or surge suppression devices) between the protective earthing terminal and neutral.
- The protective earthing terminal and subsequent protective equipment internal to the PLC system need to comply with the test specified in IEC 61131-2.

The protective earthing terminal needs to have no other function.

A.2.11.11 Wiring

IEC 61131-2 specifies wiring requirements applicable to all wiring provided by the manufacturer for the internal and/or external wiring of the PLC system, including internal wiring and interconnecting wiring. This Subclause does not apply to SELV/PELV circuits, earthing or bonding conductors.

A.2.11.11.1 Internal wiring

Insulation on all internal wiring is to be rated for the voltage and temperature of use.

A.2.11.11.2 Interconnection wiring

Cables and cords provided for interconnection of equipment should comply with requirements as for internal wiring.

A.2.11.11.3 Mains power input cord

The mains power input cord provided by the manufacturer should comply with the mains power input cord requirements in IEC 61010-1.

The circuitry connected to a cord set (removable or fixed) needs to be so designed that there is no risk of electric shock after 1 s when touching the pins of the plug and/or receptacle. Test are to be conducted in accordance with specifications of IEC 61131-2.

A.2.11.12 Switching devices

Switching devices should be used within their ratings, as per IEC 60947-5-1, or equipment utilizing them need to be subjected to the overload and endurance tests specified in IEC 61131-2. The endurance test is not conducted on solid state output devices for general or resistive use.

A.2.11.13 Components

Components should comply with the applicable safety requirements of the relevant IEC product standard(s) or have been approved by a recognized testing authority for conformity with applicable safety requirements and need not be re-tested.

NOTE Components are parts of PLC system units; e.g., capacitors, resistors, printed circuit boards, relays, transformers, switches.

A.2.11.14 Battery requirements

Battery cases or compartments need to be designed to protect against accumulation of flammable gases or damage from spilling of corrosive liquid as applicable.

Rechargeable and non-rechargeable batteries, if used in the PLC, need to be provided with suitable protection, internal or external to the battery cell, so as to minimize the risk of battery explosion. Parameters to be considered in the design should include temperature, possibility/prevention of reverse current flow, limited discharge, etc.

Means need to be provided to prevent charging and to limit the discharge current of non-rechargeable batteries in both normal and single fault conditions.

A.2.11.15 Maximum voltage and minimum voltage

The equipment should operate as intended without an increased risk of fire or electric shock when subjected to maximum voltage or minimum voltage conditions. This requirement needs to be verified as per IEC 61131-2.

A.2.11.16 Markings and identification

Markings as indicated below need to be visible from the exterior of enclosed equipment, or be visible after removing a cover or opening a door without the aid of a tool, if the cover or door is intended to be removed or opened by an operator. For open equipment, markings are permitted to be on any surface that becomes visible after removal of the equipment from the rack or panel.

For all equipment, as a minimum, the information marked on the device need to identify the manufacturer (the company bringing the product to market) and the device. The remaining information needs to be provided in the data sheet, supplied with the device.

The following information needs to be provided by the manufacturer:

- manufacturer's name, trademark or other identification;
- model/catalogue number, type designation or name;
- hardware serial number or series and/or revision level, and date code or equivalent;
- information on replaceable fuses, including current, voltage and type;
- live parts and protective earth terminals markings as required.

A.2.11.16.1 External wiring terminals identification

External wiring terminals need to be marked to indicate the proper connections for the power supply, load, control circuit, and the like, or a wiring diagram coded to the terminal marking needs to be provided. A marking or manufacturers installation instructions need to be provided to identify the temperature rating of field wiring to be connected to the wiring terminals.

A.2.11.16.2 Live parts

A live part exceeding SELV limits and likely to be mistaken as dead-metal (non-energized metal) and exposed to service personnel needs to be marked with the following "Dangerous voltage" symbol:



NOTE Symbol according to IEC 60417- 5036 (DB:2002-10).

A.2.11.16.3 Protective earth terminals markings

The protective earth terminal markings need to be durable and clearly identifiable. The identification needs to be achieved by the notation PE, or by a graphical symbol for use on equipment or by the colour green-yellow.

NOTE Notation PE according to 5.3 of IEC 60445. In North America, the colour green only is also acceptable.


The graphical symbol for protective earth is:



NOTE Symbol according to IEC 60417- 5019-a (DB:2002-10).

A.2.11.16.4 Equipment protected by double/reinforced insulation

Equipment protected throughout by double/reinforced insulation (Class II) needs to be marked with the following symbol unless it is provided with a protective terminal.



Equipment, which is only partially protected by double/reinforced insulation, should not bear this symbol.

NOTE Symbol according to IEC 60417- 5172 (DB:2002-10).

A.2.11.16.5 Equipment supplied by SELV/PELV

Equipment intended to only be energized by a SELV or PELV source of supply needs to be so marked on equipment and/or provided in product literature.

A.2.11.16.6 Rating information

Equipment needs to be marked with the following as applicable:

- rated voltage(s) or range of voltage in volts (V);
- rated frequency in Hertz (Hz);
- kind of supply system (AC, DC, AC/DC or the symbols 5032 (DB:2002-10), 5931 (DB:2002-10) or 5033 (DB:2002-10) from IEC 60417);
- number of phase conductors if more than one;
- rated current in Amperes (A); and/or
- rated input and/or output power in Watts (W) or Volt-Amperes (VA).

For open type equipment, the information needs to be marked on the equipment or in the manual. This includes: requirements for safety type tests and verifications test and verifications for safety in accordance with IEC 61131-2, and requirements for safety routine tests and verifications safety routine tests or an equivalent verification method.

A.2.11.17 Requirement for dielectric strength verification

Protection against electric shock needs to be verified between non-SELV circuits and SELV circuits, non-SELV circuits and accessible conductive parts, and isolated non-SELV circuits. This verification needs to be performed by one of the following approaches:

- routine dielectric withstand testing of the product in accordance with IEC 61131-2;
- verification, during product development, that all of the relevant insulating materials and creepage and clearance distances of the product and that all isolating components meet one of the following:
 - the component requirements of IEC 61131-2;
 - 100 % dielectric withstand tested;
 - verified by measurement to meet the required creepage and clearance distances.

A.2.11.18 Requirement for protective earthing verification

The manufacturer needs to verify protective earthing continuity between the protective earthing interface/port and all operator accessible metal parts intended to be earthed, in accordance with the test described in IEC 61131-2.

A.2.11.19 Requirements for information on safety

Information on safety needs to be provided by the manufacturer in accordance with IEC 61131-2.

A.2.11.20 Safety type tests and verifications

The safety related tests and verifications prescribed in IEC 61131-2 are mainly for the manufacturer. These include the following:

A.2.11.21 Safety related mechanical tests and verifications

- impact withstand test;
- operator accessibility test;
- general examination of openings;
- wire flexibility test;
- temperature test;
- protective coating test;
- rigidity test;
- clearance and creepage verification;
- field-wiring terminals constructional verification.

A.2.11.22 Safety related electrical tests

- dielectric withstand verification test;
- protective earthing continuity test;
- stored energy injury risk test;
- overload test;
- endurance test.

A.2.11.23 Single-fault condition test

- breakdown of component test;
- protective impedance test;
- mains transformer test.

A.2.12 Safety routine tests

These tests include:

- dielectric withstand test;
- dielectric withstand verification test (routine dielectric withstand test);
- protective earthing test.

A.2.13 Safety information to be provided by the manufacturer

The manufacturer's data are to include the following information as a minimum:

- Protective earthing requirements and recommendations concerning personnel safety circuits.
- Requirements for the maintenance of protective devices, such as protective earthing circuits, overcurrent protective devices, and batteries utilized for memory back-up, etc.

- If the PLC system is provided as "open equipment", a suitable enclosure is required to provide the necessary level of safety and environmental protection and guidelines for mounting, spacing, and/or internal barriers or shields if needed for safety.
- Precautionary instructions, if removal of any module while the equipment is in operation can affect safety related to electrical shock, fire hazard and electrical damage.
- A statement of the intended use of the PLC system relative to Overvoltage Category.
- Isolation potentials between channel and other circuits (including ground) and between channels under normal conditions.
- Information to be made available can be in other than printed form.

In addition, the following information is to be provided:

A.2.13.1 Information on evaluation of enclosures for open equipment (power dissipation)

The manufacturer's documents are to provide information to allow the evaluation of the power dissipation of every PLC configuration, sub-assembly and module and provide information regarding minimum spacing required to assure adequate cooling under normal service conditions.

A.2.13.2 Information on mechanical terminal connection

The manufacturer is to provide the following information through convenient documentation and/or marking:

- a) Type, cross-sectional area and material of the conductors that may be connected to the PLC system.
- b) Recommendations for use of shielded cables, and how they are to be connected and earthed.

A.2.14 Illustration of PLC system hardware definition

Figure A.7 illustrates the hardware in the PLC system as defined for the purposes of IEC 61131-1 and IEC 61131-2.




Figure A.7 – Programmable Controller System (PLC system)

Portable and hand-held peripherals have specific requirements and have to be distinguished from permanently installed peripherals.

A.3 Overview of IEC 61131-3

A.3.1 Introduction

IEC 61131-3 specifies the basic PLC programming languages and the syntax and semantics. IEC 61131-3 starts with the foundation of PLC programming languages, i.e. software model, common elements data types, program organization units which culminate in the specifications of the four common programming languages. IEC 61131-3 includes the following clauses:

- Clause 1 contains the scope of IEC 61131-3, the normative references, the definitions of terms used in IEC 61131-3 and the normative requirements for compliant programs and compliant programming systems.
- Clause 2 defines the language elements which are common for the standardised languages. The common languages are given elements in textual and graphical representation.

- Clause 3 and 4 defines the various standard languages. Two textual languages "Instruction List" and "Structured Text" and two graphical languages "Ladder Diagram" and "Function Block Diagram" are normative.

Sequential Function Chart (SFC) elements are defined for structuring the internal organization of programmable controller programs and function blocks. Also, configuration elements are defined which support the installation of programmable controller programs into programmable controller systems.

In the annexes of IEC 61131-3, the formal specifications, keywords, examples, etc. are given.

A.3.2 General

A.3.2.1 Scope

IEC 61131-3 specifies syntax and semantics of programming languages for programmable controllers as defined in IEC 61131-1.

A.3.2.2 Definitions

Some of the definitions listed in IEC 61131-3 are examples for use of PLC language terms in IEC 61131-3:

a) **action**

Boolean variable, or a collection of operations to be performed, together with an associated control structure.

b) **action block**

Graphical language element which utilizes a Boolean input variable to determine the value of a Boolean output variable or the enabling condition for an action, according to a predetermined control structure.

c) **access path**

The association of a symbolic name with a variable for the purpose of open communication.

d) **bistable function block**

Function block with two stable states controlled by one or more inputs.

e) **call**

Language construct for invoking the execution of a function or function block.

f) **configuration**

Language element corresponding to a programmable controller system as defined in IEC 61131-1.

g) **declaration**

The mechanism for establishing the definition of a language element. A declaration normally involves attaching an identifier to the language element, and allocating attributes such as data types and algorithms to it.

h) **function (procedure)**

Program organization unit which, when executed, yields exactly one data element and possibly additional output variables (which may be multi-valued, for example, an array or structure), and whose invocation can be used in textual languages as an operand in an expression.

i) function block (function block type)

PLC programming language element consisting of:

- the structure of data structure partitioned into input, output, and internal variables; and
- a set of operations to be performed upon the elements of the data structure when an instance of the function block type is invoked.

j) function block diagram

Network in which the nodes are function block instances, graphically represented functions (procedures), variables, literals, and labels.

k) global variable

Variable whose scope is global.

l) in-out variable

Variable that is declared in a VAR_IN_OUT . . . END_VAR block.

m) instance

Individual, named copy of the data structure associated with a function block type or program type, which persists from one invocation of the associated operations to the next.

n) instantiation

The creation of an instance.

o) invocation

The process of initiating the execution of the operations specified in a program organization unit.

p) keyword

Lexical unit that characterises a language element, for example “IF”.

q) label

Language construction naming an instruction, network or group of networks, including an identifier.

r) network

Arrangement of nodes and interconnecting branches.

s) pragma

Language construct for the inclusion of text in a program organization unit which may affect the preparation of the program for execution.

t) resource

Language element corresponding to a “signal processing function” and its “man-machine interface” and “sensor and actuator interface functions”, if any, as defined in IEC 61131-1.

u) semantics

The relationships between the symbolic elements of a programming language and their meanings, interpretation and use.

v) step

Situation in which the behaviour of a program organization unit with respect to its inputs and outputs follows a set of rules defined by the associated actions of the step.

w) task


Execution control element providing for periodic or triggered execution of a group of associated program organization units.

x) transition

The condition whereby control passes from one or more predecessor steps to one or more successor steps along a directed link.

A.3.3 Software model

The basic high-level language elements and their interrelationships are illustrated in Figure A.8. These consist of elements which are programmed using the languages defined in IEC 61131-3, that is, programs and function blocks; and configuration elements, namely, configurations, resources, tasks, global variables, access paths, and instance-specific initialisations, which support the installation of programmable controller programs into programmable controller systems.



NOTE 1 This figure is illustrative only. The graphical representation is not normative.

NOTE 2 In a configuration with a single resource, the resource needs not be explicitly represented.

IEC 2468/02

Figure A.8 – Software model

The mapping of the language elements defined in this Subclause onto communication objects is defined in IEC 61131-5.

A.3.4 Communication between software elements

Values of variables can be communicated among software elements in the following ways:

- a) directly by connection of the output of one program element to the input of another;
- b) global variables (VAR_GLOBAL) can be used to pass variables between programs in the same configuration;

- c) using the communication function blocks defined in IEC 61131-5 between different parts of a program, between programs in the same or different configurations, or between a programmable controller program and a non-programmable controller system;
- d) data can be made available by access paths (VAR_ACCESS) between programmable controllers or non-programmable controller systems.


A.3.5 Programming model

The elements of programmable controller programming languages are classified as follows:

- Data types Variables
- Program organization units
 - Functions
 - Function blocks
 - Programs
- Sequential Function Chart (SFC) elements
- Configuration elements
 - Global variables
 - Resources
 - Access paths
 - Tasks

Figure A.9 shows the combination of PLC program language elements.

IECNORM.COM : Click to view the full PDF of IEC TR 61131-4:2004



IEC 1035/04

Key

LD – Ladder Diagram

FBD – Function Block Diagram

IL – Instruction List

ST – Structured Text

OTHERS – Other programming languages

NOTE Subclause numbers refer to clauses in IEC 61131-3.

Figure A.9 – Combination of programmable controller language elements

A.3.6 Compliance

This Subclause defines the requirements for programmable controller systems and programs which claim compliance with IEC 61131-3.

A.3.6.1 System compliance

A PLC system which claims to comply, wholly or partially, with the requirements of IEC 61131-3 shall do so only as described in the following manner.

A compliance statement shall be included in the documentation accompanying the system, or is produced by the system itself. The form of the compliance statement is:

“This system complies with the requirements of IEC 61131-3, for the following language features:” followed by a set of compliance tables.

For details on the compliance tables and the remaining compliance requirements, see IEC 61131-3.

A.3.6.2 Program compliance

A programmable controller program complying with the requirements of IEC 61131-3 needs to:

- a) use only those features specified in this standard for the particular language used;
- b) not use any features identified as extensions to the language;
- c) not rely on any particular interpretation of implementation-dependent features.

The results produced by a complying program is to be the same when processed by any complying system which supports the features used by the program, such results are influenced by program execution timing, the use of implementation-dependent features in the program, and the execution of error handling procedures.

A.3.7 Common language elements

The following language elements are common to all standardized programmable controller languages to assure their harmonized usage and exchange.

A.3.7.1 Printed characters

Printed characters include:

- character set;
- identifiers;
- keywords;
- white space;
- comments;
- pragmas.

A.3.7.2 External representation of data

- numerical literals;
- character string literals;
- time literals:
 - duration;
 - time of day.

A.3.8 Data type

For the standard languages, the data types are commonly defined. Data typing prevents errors in an early stage of the life cycle of a user program. It is used to define the type of any parameter used, i.e. variables or constants. This avoids, for instance, dividing a date by an integer.

A.3.8.1 Elementary data types

Elementary data types represented in keywords include:

BOOL (Boolean);
SINT (short integer);
INT (integer);
LINT (long integer);
USINT (un-signed short integer);
UINT (un-signed integer);
UDINT (un-signed double integer);
ULINT (un-signed long integer);
REAL (real number);
LREAL (long reals);
TIME (duration);
DATE – only for calendar date (date);
TOD or TIME_OF_DAY – only for clock time (Time of day);
DT or DATE_AND_TIME (date and time of day);
STRING (variable-length single-byte string);
BYTE (bite string of length 8);
WORD (byte string of length 16);
DWORD (byte string of length 32);
LWORD (byte string of length 64);
WSTRING (variable-length double-byte character string).

A.3.8.2 Generic data types

Generic data types are used in the specification of inputs and outputs of standard functions and function blocks. They are pre-fixed with the keyword "ANY". Generic data types are not used in user-declared program organization.

A.3.8.3 Derived data type

Derived data type is user or manufacturer defined using the other data types. For example, an analogue input channel can be defined as a data type and re-used over and over again. Derived data types are declared in manners shown in Table A.9.

Table A.9 – Data type declaration features

No.	Feature/textual example
1	Direct derivation from elementary types, e.g.: TYPE RU_REAL: REAL; END_TYPE
2	Enumerated data types, e.g.: TYPE ANALOGUE_SIGNAL_TYPE: (SINGLE_ENDED, DIFFERENTIAL); END_TYPE
3	Sub-range data types, e.g.: TYPE ANALOGUE_DATA: INT (-4095..4095); END_TYPE
4	Array data types, e.g.: TYPE ANALOGUE_16_INPUT_DATA: ARRAY [1..16] OF ANALOGUE_DATA; END_TYPE
5	Structured data types, e.g.: TYPE ANALOGUE_CHANNEL_CONFIGURATION : STRUCT RANGE : ANALOGUE_SIGNAL_RANGE ; MIN_SCALE : ANALOGUE_DATA ; MAX_SCALE : ANALOGUE_DATA ; END_STRUCT ; ANALOGUE_16_INPUT_CONFIGURATION : STRUCT SIGNAL_TYPE : ANALOGUE_SIGNAL_TYPE ; FILTER_PARAMETER : SINT (0..99) ; CHANNEL : ARRAY [1..16] OF ANALOGUE_CHANNEL_CONFIGURATION ; END_STRUCT ; END_TYPE

A.3.9 Variables

The IEC 61131 series distinguishes variables which are directly assigned to explicit hardware addresses (e.g. input and outputs) in configurations, resources or programs and variables which may be globally or locally accessed. In this way, a high level of hardware independency is created, supporting the reusability of the software.

The scope of the variables are normally limited to the organization unit in which they are declared, e.g. local. This means that their names can be reused in other parts without any conflict, eliminating another source of errors, e.g. the scratchpad. If the variables should have global scope, they have to be declared as such (VAR_GLOBAL). Parameters can be assigned an initial value at start up and cold restart, in order to have the right setting.

Prefixes for directly represented variables are shown in Table A.10. Variable declaration keywords are shown in Table A.11.

Table A.10 – Location and size prefix features for directly represented variables

No.	Prefix	Meaning	Default data type
1	I	Input location	
2	Q	Output location	
3	M	Memory location	
4	X	Single bit size	BOOL
5	None	Single bit size	BOOL
6	B	Byte (8 bits) size	BYTE
7	W	Word (16 bits) size	WORD
8	D	Double word (32 bits) size	DWORD
9	L	Long (quad) word (64 bits) size	LWORD
10	Use of an asterisk (*) to indicate a not yet specified location		
NOTE National standards organizations can publish tables of translations of these prefixes.			

Table A.11 – Variable usage

Keyword	Variable usage
VAR	Internal to organization unit.
VAR_INPUT	Externally supplied, not modifiable within organization unit.
VAR_OUTPUT	Supplied by organization unit to external entities.
VAR_IN_OUT	Supplied by external entities – can be modified within organization unit.
VAR_EXTERNAL	Supplied by configuration via VAR_GLOBAL Can be modified within organization unit.
VAR_GLOBAL	Global variable declaration.
VAR_ACCESS	Access path declaration.
VAR_TEMP	Temporary storage for variables in function blocks and programs.
VAR_CONFIG	Instance-specific initialisation and location assignment.
RETAIN ^{b,c,d,e}	Retentive variables.
NON_RETAIN ^{b,c,d,e}	Non-retentive variables.
CONSTANT ^a	Constant (variable cannot be modified).
AT	Location assignment.
<p>NOTE The usage of these keywords is a feature of the program organization unit or configuration element in which they are used. Normative requirements for the use of these keywords are given in IEC 61131-3.</p> <p>a The CONSTANT qualifier should not be used in the declaration of function block instances.</p> <p>b The RETAIN and NON_RETAIN qualifiers may be used for variables declared in VAR, VAR_INPUT, VAR_OUTPUT, and VAR_GLOBAL blocks but not in VAR_IN_OUT blocks and not for individual elements of structures.</p> <p>c Usage of RETAIN and NON_RETAIN for function block and program instances is allowed. The effect is that all members of the instance are treated as RETAIN or NON_RETAIN, except if:</p> <ul style="list-style-type: none"> - the member is explicitly declared as RETAIN or NON_RETAIN in the function block or program type definition; - the member itself is a function block. <p>d Usage of RETAIN and NON_RETAIN for instances of structured data types is allowed. The effect is that all structure members, also those of nested structures, are treated as RETAIN or NON_RETAIN.</p> <p>e Both RETAIN and NON_RETAIN are features. If a variable is neither explicitly declared as RETAIN nor as NON_RETAIN, the “warm start” behaviour of the variable is implementation-dependent.</p>	

A.3.10 Program Organization Units (POUs)


The program organization units defined in IEC 61131-3 are the function, function block, and program. These program organization units can be delivered by the manufacturer, or programmed by the user by the means defined in IEC 61131-3.

Program organization units is not to be recursive; that is, the invocation of a program organization unit does not cause the invocation of another program organization unit of the same type.

A.3.10.1 Functions

For the purposes of programmable controller programming languages, a function is defined as a program organization unit which, when executed, yields exactly one data element, the function result. Output elements (VAR_OUTPUT and VAR_IN_OUT) can be added. The invocation of a function can be used in textual languages as an operand in an expression. For example, the SIN and COS functions could be used as shown in Figure A.11.

There are defined standard functions and user defined functions. Standard functions are for instance ADD(addition), ABS(absolute value), SQRT(square-root), SIN(sine) and COS(cosine). User defined functions, once defined, can be used over and over again. Figure A.10 shows two examples of function usage.



IEC 2474/02

Key

- a) Structured Text (ST) language.
- b) Function Block Diagram (FBD) language.

Figure A.10 – Examples of function usage

Figure 10 shows two different representations of the same functionality. It is not required to support any automatic transformation between the two forms of representation.

A.3.10.2 Function Block (FB)

For the purposes of programmable controller programming languages, a function block is a program organization unit which, when executed, yields one or more values. Only the input and output variables are accessible outside of an instance of a function block, i.e., the function block's internal variables are hidden from the user of the function block.

The scope of an instance of a function block is local to the program organization unit in which it is instantiated, unless it is declared to be global in a VAR_GLOBAL block.

The maximum number of function block types and instantiations for a given resource are implementation-dependent parameters.

Figure A.11 shows instantiation of a FB by the graphical language and by textual language. Input and output variables of an instance of a function block can be represented as elements of structured data types.

Graphical (FBD language)	Textual (ST language)
<pre> FF75 +-----+ SR %IX1--- S1 Q1 ---%QX3 %IX2--- R +-----+ </pre>	<pre> VAR FF75: SR; END_VAR (* Declaration *) FF75(S1:=%IX1, R:=%IX2); (* Invocation *) %QX3 := FF75.Q1 ; (* Assign Output *) </pre>
<pre> MyTon +-----+ +-----+ TON a-- NE ---O EN ENO -- b-- r-- IN Q O-out +-----+ -- PT ET -- +-----+ </pre>	<pre> VAR a,b,r,out : BOOL; MyTon : TON; END_VAR MyTon(EN := NOT (a <> b), IN := r, NOT Q => out); </pre>

IEC 2479/02

Figure A.11 – Function block instantiation examples

Assignment of a value to an output variable of a function block is not allowed except from within the function block. The assignment of a value to the input of a function block is permitted only as part of the invocation of the function block. Allowable usages of function block inputs and outputs are summarized in Table A.12.

Table A.12 – Examples of function block I/O variable usage

Usage	Inside function block	Outside function block
Input read	IF IN1 THEN ...	Not allowed (Notes 1 and 2)
Input assignment	Not allowed (Notes 1 and 3)	FB_INST(IN1:=A, IN2:=B);
Output read	OUT:= OUT AND NOT IN2;	C:= FB_INST.OUT;
Output assignment	OUT:= 1;	Not Allowed (Note 1)
In-out read	IF INOUT THEN ...	IF FB1.INOUT THEN...
In-out assignment	INOUT:= OUT OR IN1; (Note 3)	FB_INST(INOUT:=D);

NOTE 1 Those usages listed as “not allowed” in this table could lead to implementation-dependent, unpredictable side effects.

NOTE 2 Reading and writing of input, output and internal variables of a function block may be performed by the “communication function”, “operator interface function”, or the “programming, testing, and monitoring functions” defined in IEC 61131-1.

NOTE 3 Modification within the function block of a variable declared in a VAR_IN_OUT block is permitted.


Standard FB include: bi-stable FB, counters, timers, and communication FB.

A.3.10.3 Programs

As defined in the IEC 61131 series, a program is a “logic assembly of all the programming language elements and constructs necessary for the intended signal processing required for the control of a machine or process by a programmable controller system.” Therefore by its scope, a program is in itself a POU. Typically, a program consists of a network of Functions and Function Blocks, which are able to exchange data. Function and Function Blocks are the basic building blocks, containing a data-structure and an algorithm. An action block is a graphical element for the combination of a Boolean variable with one of the action qualifiers to produce an enabling condition for an associated action. These features are shown in Table A.17. Action block operates under specific control rules detailed in IEC 61131-3.

A.3.10.4 Sequential Function Chart (SFC)

Sequential Function Chart (SFC) is a common element for use in structuring internal organization of a PLC program organization unit. SFC can be written in one of the programming languages defined in IEC 61131-3 for the purpose of performing sequential control functions, as shown in Figure A.12.



IEC 1036/04

Figure A.12 – Sequential function chart

SFC describes the behaviour of a control program. It is derived from Petri Nets and IEC 60848 Grafset, with the changes necessary to convert the representation from a documentation standard to a set of execution control elements. SFC structures the internal organization of a program, and helps to decompose a control problem into manageable parts, while maintaining the overview. SFC consists of Steps, linked with Action Blocks and Transitions. Each step represents a particular state of the systems being controlled. A transition is associated with a condition, which, when true, causes the step before the transition to be deactivated, and the next step to be activated. Steps are linked to action blocks, performing a certain control action. Each element can be programmed in any of the standard languages, including SFC itself.

SFC program features include: steps, transitions and action, as shown in Table A.13 to Table A.15.

Table A.13 – Step features

No.	Representation	Description
1	<pre> +-----+ *** +-----+ </pre>	<p>Step - graphical form with directed links " *** " = step name</p>
	<pre> +=====+ *** +=====+ </pre>	<p>Initial step - graphical form with directed links " *** " = name of initial step</p>
2	<pre> STEP *** : (* Step body *) END_STEP </pre>	<p>Step - textual form without directed links " *** " = step name</p>
	<pre> INITIAL_STEP *** : (* Step body *) END_STEP </pre>	<p>Initial step - textual form without directed links " *** " = name of initial step</p>
3A^a	<pre> ***.X </pre>	<p>Step flag - general form " *** " = step name ***.X = BOOL#1 when *** is active BOOL#0 otherwise</p>
3B^a	<pre> +-----+ *** ---- +-----+ </pre>	<p>Step flag - direct connection of Boolean variable ***.X to right side of step " *** "</p>
4^a	<pre> ***.T </pre>	<p>Step elapsed time - general form " *** " = step name ***.T = a variable of type TIME</p>
<p>NOTE The upper directed link to an initial step is not present if it has no predecessors.</p>		
<p>^a When feature 3A, 3B, or 4 is supported, it needs to be an error if the user program attempts to modify the associated variable. For example, if S4 is a step name, then the following statements would be errors in the ST language:</p> <pre> S4.X:= 1; (* ERROR *) S4.T:= t#100ms; (* ERROR *) </pre>		

IEC NORM.COM Click to view the full PDF of IEC TR 61131-4:2004

Table A.14 – Transition and transition conditions

No	Example	Description
1	<pre> +-----+ STEP7 +-----+ + %IX2.4 & %IX2.3 +-----+ STEP8 +-----+ </pre>	<p>Predecessor step</p> <p>Transition condition physically or logically adjacent to the transition using ST language</p> <p>Successor step</p>
2	<pre> +-----+ STEP7 +-----+ %IX2.4 %IX2.3 +---+ +---+ +---+ + +-----+ +-----+ STEP8 STEP8 +-----+ +-----+ </pre>	<p>Predecessor step</p> <p>Transition condition physically or logically adjacent to the transition using LD language</p> <p>Successor step</p>
3	<pre> +-----+ STEP7 +-----+ +-----+ +-----+ & STEP7 %IX2.4--- -----+ %IX2.3--- STEP8 +-----+ +-----+ STEP8 STEP8 +-----+ +-----+ </pre>	<p>Predecessor step</p> <p>Transition condition physically or logically adjacent to the transition using FBD language</p> <p>Successor step</p>
4	<pre> +-----+ STEP7 +-----+ >TRANX>-----+ +-----+ STEP8 +-----+ </pre>	<p>Use of connector:</p> <p>predecessor step</p> <p>transition connector</p> <p>successor step</p>

<p>4A</p>	<pre> %IX2.4 %IX2.3 +--- ----- ----->TRANX> </pre>	<p>Transition condition: Using LD language</p>
<p>4B</p>	<pre> +-----+ & %IX2.4--- --->TRANX> %IX2.3--- +-----+ </pre>	<p>Using FBD language</p>
<p>5</p>	<pre> STEP STEP7: END_STEP TRANSITION FROM STEP7 TO STEP8 := %IX2.4 & %IX2.3 ; END_TRANSITION STEP STEP8: END_STEP </pre>	<p>Textual equivalent of feature 1 using ST language</p>
<p>6</p>	<pre> STEP STEP7: END_STEP TRANSITION FROM STEP7 TO STEP 8: LD %IX2.4 AND %IX2.3 END_TRANSITION STEP STEP8: END_STEP </pre>	<p>Textual equivalent of feature 1 using IL language</p>
<p>7</p>	<pre> +-----+ STEP7 +-----+ + TRAN78 +-----+ STEP8 +-----+ </pre>	<p>Use of transition name: predecessor step transition name successor step</p>
<p>7A</p>	<pre> TRANSITION TRAN78 FROM STEP7 TO STEP8: %IX2.4 %IX2.3 TRAN78 +--- ----- ----- () ---+ END_TRANSITION </pre>	<p>Transition condition using LD language</p>
<p>7B</p>	<pre> TRANSITION TRAN78 FROM STEP7 TO STEP8: +-----+ & %IX2.4--- ---TRAN78 %IX2.3--- +-----+ END_TRANSITION </pre>	<p>Transition condition using FBD language</p>
<p>7C</p>	<pre> TRANSITION TRAN78 FROM STEP7 TO STEP8: LD %IX2.4 AND %IX2.3 END_TRANSITION </pre>	<p>Transition condition using IL language</p>
<p>7D</p>	<pre> TRANSITION TRAN78 FROM STEP7 TO STEP8 := %IX2.4 & %IX2.3 ; END_TRANSITION </pre>	<p>Transition condition using ST language</p>

Table A.15 – Declaration of action

No.	Feature	
1	Any Boolean variable declared in a VAR or VAR_OUTPUT block, or their graphical equivalents, can be an action.	
	Example	Feature
2L	<pre> +-----+ ACTION_4 +-----+ %IX1 %MX3 S8.X %QX17 +---+ ----- ----- ----- -----+ +-----+ +---+ EN ENO %MX10 C-- LT ----- (S)-----+ D-- +-----+ +-----+ </pre>	Graphical declaration in LD language
2S	<pre> +-----+ OPEN_VALVE_1 +-----+ ... +-----+ VALVE_1_READY +-----+ + STEP8.X +-----+ +-----+ +-----+ +-----+ VALVE_1_OPENING N VALVE_1_FWD +-----+ +-----+ +-----+ +-----+ ... +-----+ </pre>	Inclusion of SFC elements in action
2F	<pre> +-----+ ACTION_4 +-----+ +---+ %IX1-- & %MX3-- --%QX17 S8.X----- +---+ FF28 +-----+ SR +-----+ Q1 -%MX10 C-- LT -- S1 D-- +-----+ +---+ +-----+ </pre>	Graphical declaration in FBD language

No.	Feature	
3S	<pre> ACTION ACTION_4: %QX17 := %IX1 & %MX3 & S8.X ; FF28(S1 := (C<D)); %MX10 := FF28.Q; END_ACTION </pre>	Textual declaration in ST language
3I	<pre> ACTION ACTION_4: LD S8.X AND %IX1 AND %MX3 ST %QX17 LD C LT D S1 FF28 LD FF28.Q ST %MX10 END_ACTION </pre>	Textual declaration in IL language
<p>NOTE The step flag <code>S8.X</code> is used in these examples to obtain the desired result such that, when <code>S8</code> is deactivated, <code>%QX17:= 0</code>.</p>		

Programming in SFC can use alternative sequences and parallel sequences, such as commonly required in batch applications. For instance, one sequence is used for the primary process, and the second for monitoring the overall operating constraints. Because of its general structure, SFC provides also a communication tool, allowing program sharing between users of different localities.

Actions are associated with Steps as shown in Table A.16. This figure is normative to the IEC 61131 series because IEC 61131-3 requires that a PLC supporting SFC elements is to have one or more of the association mechanisms shown in Figure A.15.

IECNORM.COM : Click to view the full PDF of IEC TR 61131-4:2004

Table A.16 – Step/action association

No.	Example	Feature
1	<pre> +-----+ +-----+-----+-----+ S8 -- L ACTION_1 DN1 +-----+ t#10s +-----+-----+-----+-----+ + DN1 </pre>	<p>Action block physically or logically adjacent to the step</p>
2	<pre> +-----+ +-----+-----+-----+-----+ S8 -- L ACTION_1 DN1 +-----+ t#10s +-----+-----+-----+-----+-----+ +DN1 P ACTION_2 +-----+-----+-----+-----+-----+ N ACTION_3 +-----+-----+-----+-----+-----+ </pre>	<p>Concatenated action blocks physically or logically adjacent to the step</p>
3	<pre> STEP S8: ACTION_1(L,t#10s, DN1) ; ACTION_2(P) ; ACTION_3(N) ; END_STEP </pre>	<p>Textual step body</p>
4 ^a	<pre> +-----+-----+-----+-----+ ---- N ACTION_4 ---- +-----+-----+-----+-----+ %QX17 := %IX1 & %MX3 & S8.X ; FF28 (S1 := (C<D)); %MX10 := FF28.Q; +-----+-----+-----+-----+ </pre>	<p>Action block "d" field</p>
<p>^a When feature 4 is used, the corresponding action name cannot be used in any other action block.</p>		

IECNORM.COM : Click to view the full PDF of IEC TR 61131-4:2004

Table A.17 – Action block features

No.	Feature	Graphical form
1 ^a	"a": Qualifier	
2	"b": Action name	+-----+-----+-----+
3 ^b	"c": Boolean "indicator" variables	--- "a" "b" "c" ---
4	"d": Action using:	+-----+-----+-----+
5	– IL language	"d"
6	– ST language	
7	– LD language	
	– FBD language	+-----+-----+-----+
No.	Feature/Example	
8	Use of action blocks in ladder diagrams (see 4.2 of IEC 61131-3):	
	<pre> S8.X %IX7.5 +---+-----+-----+ OK1 +--- ----- ----- N ACT1 DN1 --()---+ +---+-----+-----+ </pre>	
9	Use of action blocks in function block diagrams (see 4.3):	
	<pre> +---+ +---+-----+-----+ S8.X--- & ----- N ACT1 DN1 ---OK1 %IX7.5--- +-----+-----+ +---+ </pre>	
^a Field "a" can be omitted when the qualifier is "N".		
^b Field "c" can be omitted when no indicator variable is used.		

A.3.11 Configuration elements

A very simple programmable controller may contain one resource, running one task, controlling one program in a closed loop. IEC 61131-3 adds much to this, making it open to the future that includes multi-processing and event driven programs. Within IEC 61131-3, the Programs, Function Blocks and Functions are called Program Organization Units (POUs).

At the highest level, the entire software required to solve a particular control problem can be formulated as a Configuration. A configuration is specific to a particular type of control system, including the arrangement of the hardware, i.e. processing resources, memory addresses for I/O channels and system capabilities.

Within a configuration one can define one or more Resources. One can look at a resource as a processing facility that is able to execute PLC programs.

Within a resource, one or more Tasks can be defined. Tasks control the execution of a set of programs and/or function blocks. These can either be executed periodically or upon the occurrence of a specified trigger, such as the change of a variable.

Figure A.13 shows an example of configuration with FB and program declarations.

<pre> FUNCTION_BLOCK A VAR_OUTPUT y1 : UINT ; y2 : BYTE ; END_VAR END_FUNCTION_BLOCK </pre>	<pre> FUNCTION_BLOCK B VAR_INPUT b1 : UINT ; b2 : BYTE ; END_VAR END_FUNCTION_BLOCK </pre>
<pre> FUNCTION_BLOCK C VAR_OUTPUT c1 : BOOL ; END_VAR VAR C2 AT %Q* : BYTE; C3 : INT; END_VAR END_FUNCTION_BLOCK </pre>	<pre> FUNCTION_BLOCK D VAR_INPUT d1 : BOOL ; END_VAR VAR_OUTPUT y2 : INT ; END_VAR END_FUNCTION_BLOCK </pre>
<pre> PROGRAM F VAR_INPUT x1 : BOOL ; x2 : UINT ; END_VAR VAR_OUTPUT y1 : BYTE ; END_VAR VAR COUNT : INT; TIME1 : TON; END_VAR END_PROGRAM </pre>	
<pre> PROGRAM G VAR_OUTPUT out1 : UINT ; END_VAR VAR_EXTERNAL z1 : BYTE ; END_VAR VAR FB1 : A ; FB2 : B ; END_VAR FB1(...); out1 := FB1.y1; z1 := FB1.y2; FB2(b1 := FB1.y1, b2 := FB1.y2) ; END_PROGRAM </pre>	
<pre> PROGRAM H VAR_OUTPUT HOUT1 : INT ; END_VAR VAR FB1 : C ; FB2 : D ; END_VAR FB1(...); FB2(...); HOUT1 := FB2.y2; END_PROGRAM </pre>	

IEC 1037/04

Figure A.13 – Function block and program declarations for configuration example

In the configuration of Figure A.13, the FBs are resources. A resource is a signal processing function storing data and program code and execution upon invocation of a POU. Table A.18 lists configuration and resource declaration. Table A.19 shows an example of configuration and resource declaration.

Table A.18 – Configuration and resource declaration features

No.	Description
1	CONFIGURATION...END_CONFIGURATION construction
2	VAR_GLOBAL...END_VAR construction within CONFIGURATION
3	RESOURCE...ON...END_RESOURCE construction
4	VAR_GLOBAL...END_VAR construction within RESOURCE
5a	Periodic TASK construction
5b	Non-periodic TASK construction
6a	WITH construction for PROGRAM to TASK association
6b	WITH construction for Function Block to TASK association
6c	PROGRAM declaration with no TASK association
7	Declaration of directly represented variables in VAR_GLOBAL
8a	Connection of directly represented variables to PROGRAM inputs
8b	Connection of GLOBAL variables to PROGRAM inputs
9a	Connection of PROGRAM outputs to directly represented variables
9b	Connection of PROGRAM outputs to GLOBAL variables

No.	Description
10a	VAR_ACCESS...END_VAR construction
10b	Access paths to directly represented variables
10c	Access paths to PROGRAM inputs
10d	Access paths to GLOBAL variables in RESOURCEs
10e	Access paths to GLOBAL variables in CONFIGURATIONs
10f	Access paths to PROGRAM outputs
10g	Access paths to PROGRAM internal variables
10h	Access paths to function block inputs
10i	Access paths to function block outputs
11	VAR_CONFIG...END_VAR construction
12a	VAR_GLOBAL CONSTANT in RESOURCE declarations
12b	VAR_GLOBAL CONSTANT in CONFIGURATION declarations
13a	VAR_EXTERNAL in RESOURCE declarations
13b	VAR_EXTERNAL CONSTANT in RESOURCE declarations

Table A.19 – Examples of configuration and resource declaration features

No.	Example
1	CONFIGURATION CELL_1
2	VAR_GLOBAL w: UINT; END_VAR
3	RESOURCE STATION_1 ON PROCESSOR_TYPE_1
4	VAR_GLOBAL z1: BYTE; END_VAR
5a	TASK SLOW_1(INTERVAL := t#20ms, PRIORITY := 2) ;
5a	TASK FAST_1(INTERVAL := t#10ms, PRIORITY := 1) ;
6a	PROGRAM P1 WITH SLOW_1 :
8a	F(x1 := %IX1.1) ;
9b	PROGRAM P2 : G(OUT1 => w,
6b	FB1 WITH SLOW_1,
6b	FB2 WITH FAST_1) ;
3	END_RESOURCE
3	RESOURCE STATION_2 ON PROCESSOR_TYPE_2
4	VAR_GLOBAL z2 : BOOL ;
7	AT %QW5 : INT ;
4	END_VAR
5a	TASK PER_2(INTERVAL := t#50ms, PRIORITY := 2) ;
5b	TASK INT_2(SINGLE := z2, PRIORITY := 1) ;
6a	PROGRAM P1 WITH PER_2 :
8b	F(x1 := z2, x2 := w) ;
6a	PROGRAM P4 WITH INT_2 :
9a	H(HOUT1 => %QW5,
6b	FB1 WITH PER_2);

No.	Example
3	END_RESOURCE
10a	VAR_ACCESS
10b	ABLE : STATION_1.%IX1.1 : BOOL READ_ONLY ;
10c	BAKER : STATION_1.P1.x2 : UINT READ_WRITE ;
10d	CHARLIE : STATION_1.z1 : BYTE ;
10e	DOG : w : UINT READ_ONLY ;
10f	ALPHA : STATION_2.P1.y1 : BYTE READ_ONLY ;
10f	BETA : STATION_2.P4.HOUT1 : INT READ_ONLY ;
10d	GAMMA : STATION_2.z2 : BOOL READ_WRITE ;
10g	S1_COUNT : STATION_1.P1.COUNT : INT ;
10h	THETA : STATION_2.P4.FB2.d1 : BOOL READ_WRITE ;
10i	ZETA : STATION_2.P4.FB1.c1 : BOOL READ_ONLY ;
10k	OMEGA : STATION_2.P4.FB1.C3 : INT READ_WRITE ;
10a	END_VAR
11	<pre> VAR_CONFIG STATION_1.P1.COUNT : INT := 1 ; STATION_2.P1.COUNT : INT := 100 ; STATION_1.P1.TIME1 : TON := (PT := T#2.5s) ; STATION_2.P1.TIME1 : TON := (PT := T#4.5s) ; STATION_2.P4.FB1.C2 AT %QB25 : BYTE ; END_VAR </pre>
1	END_CONFIGURATION
<p>NOTE 1 Graphical and semi-graphic representation of these features are allowed but is beyond the scope of IEC 61131-3.</p> <p>NOTE 2 It is an error if the data type declared for a variable in a VAR_ACCESS statement is not the same as the data type declared for the variable elsewhere, e.g., if variable BAKER is declared of type WORD in the above examples.</p>	

A.3.12 Programming languages

In IEC 61131-3, four programming languages are defined. This means that their syntax and semantics have been defined. The languages are:

1) Textual languages:

- Instruction List, IL
- Structured Text, ST

2) Graphical languages:

- Ladder Diagram, LD
- Function Block Diagram, FBD

Basic appearances of these languages are illustrated in Figure A.14.




Figure A.14 – The four programming languages

In Figure A.14, all four languages describe the same part of a program. The choice of programming language depends on:

- background of the user company and programmer;
- the nature of control project at hand;
- the level of project description;
- the structure of the overall automation system; and
- the interface between the program to other people/departments within the user company.

The four languages provide a common suite evolved from industrial practice. The programming languages defined in IEC 61131-3 therefore serves as a communication tool for PLC workers of different backgrounds.

A.3.13 Textual languages

A.3.13.1 Common elements

Program structuring elements common to both IL and ST languages include:

```
TYPE...END_TYPE;
VAR...END_VAR;
VAR_INPUT...END_VAR;
VAR_OUTPUT...END_VAR;
VAR_IN_OUT...END_VAR;
VAR_EXTERNAL...END_VAR;
VAR_TEMP...END_VAR;
VAR_ACCESS...END_VAR;
VAR_GLOBAL...END_VAR;
VAR_CONFIG...END_VAR;

FUNCTION...END_FUNCTION;
FUNCTION_BLOCK...END_FUNCTION_BLOCK;
STEP...END_STEP;
TRANSITION...END_TRANSITIO;
ACTION...END_ACTION;
PROGRAM...END_PROGRAM.
```

A.3.13.2 Instruction list (IL)

Instruction list has its roots in Europe. A textual language, it resembles assembly language. IL is generally used to program specialised low level functions. Programming elements of instruction are Operators, which are illustrated in Table A.20.

Table A.20 – Operators of Instruction List language

Operation	Operator
Main	LD load, ST store, S set, R reset, &/AND and, OR, XOR, NOT, ADD, SUB, MUL, DIV, MOD
Compare	GT, GE, EQ, NE, LE, LT
Jump	JMP, CAL call function or functional block RET return (after call)
Modification	N negative, C conditional jump,) evaluate deferred execution

An example for the use of IL programming is illustrated below. In this example, the function WEIGH provides BCD-to-binary conversion of a gross-weight input from a scale.

```

FUNCTION WEIGH : WORD      (* BCD encoded *)
  VAR_INPUT (* "EN" input is used to indicate "scale ready" *)
    weigh_command : BOOL;
    gross_weight : WORD ; (* BCD encoded *)
    tare_weight : INT ;
  END_VAR
  (* Function Body *)
END_FUNCTION              (* Implicit "ENO" *)

```

The body of function WEIGH in the IL language is:

```

          LD          weigh_command
          JMPG        WEIGH_NOW
          ST          ENO          (* No weighing, 0 to "ENO" *)
          RET
WEIGH_NOW: LD          gross_weight
          BCD_TO_INT
          SUB          tare_weight
          INT_TO_BCD          (* Return evaluated weight *)
          ST          WEIGH

```

A.3.13.3 Structured Text (ST)

Structured text is a very powerful language with its roots in Ada, Pascal and "C". It can be used excellently for the definition of complex function blocks, which can then be used within any of the other languages. ST is especially useful for data manipulation and calculation. Lists of ST operators and statements are shown in Table A.21 and A.22 below.

Table A.21 – Operators of the ST language

No.	Operation ^a	Symbol	Precedence
1	Parenthesisation	(expression)	HIGHEST
2	Function evaluation	identifier(argument list)	
	EXAMPLES	LN(A), MAX(X,Y), etc.	
4	Negation	-	
5	Complement	NOT	
3	Exponentiation ^b	**	
6	Multiply	*	
7	Divide	/	
8	Modulo	MOD	
9	Add	+	
10	Subtract	-	
11	Comparison	< , > , <= , >=	
12	Equality	=	
13	Inequality	<>	
14	Boolean AND	&	
15	Boolean AND	AND	
16	Boolean Exclusive OR	XOR	
17	Boolean OR	OR	LOWEST

^a The same restrictions apply to the operands of these operators as to the inputs of the corresponding functions.

^b The result of evaluating the expression A**B needs to be the same as the result of evaluating the function EXPT(A,B).

Table A.22 – ST language statements:

No.	Statement type/Reference	Examples
1	Assignment	A := B; CV := CV+1; C := SIN(X);
2	Function block Invocation and FB output usage	CMD_TMR(IN:=%IX5, PT:=T#300ms) ; A := CMD_TMR.Q ;
3	RETURN	RETURN ;
4	IF	D := B*B - 4*A*C ; IF D < 0.0 THEN NROOTS := 0 ; ELSIF D = 0.0 THEN NROOTS := 1 ; X1 := - B/(2.0*A) ; ELSE NROOTS := 2 ; X1 := (- B + SQRT(D))/(2.0*A) ; X2 := (- B - SQRT(D))/(2.0*A) ; END_IF ;

No.	Statement type/Reference	Examples
5	CASE	<pre>TW := BCD_TO_INT(THUMBWHEEL); TW_ERROR := 0; CASE TW OF 1,5: DISPLAY := OVEN_TEMP; 2: DISPLAY := MOTOR_SPEED; 3: DISPLAY := GROSS - TARE; 4,6..10: DISPLAY := STATUS(TW - 4); ELSE DISPLAY := 0; TW_ERROR := 1; END_CASE; QW100 := INT_TO_BCD(DISPLAY);</pre>
6	FOR	<pre>J := 101; FOR I := 1 TO 100 BY 2 DO IF WORDS[I] = 'KEY' THEN J := I; EXIT; END_IF; END_FOR;</pre>
7	WHILE	<pre>J := 1; WHILE J <= 100 & WORDS[J] <> 'KEY' DO J := J+2; END_WHILE;</pre>
8	REPEAT	<pre>J := -1; REPEAT J := J+2; UNTIL J = 101 OR WORDS[J] = 'KEY' END_REPEAT;</pre>
9	EXIT ^a	EXIT;
10	Empty Statement	;

^a If the EXIT statement (9) is supported, then it needs to be supported for all of the iteration statements (FOR, WHILE, REPEAT) which are supported in the implementation.

The example function WEIGH in ST program is illustrated below:

```
FUNCTION WEIGH : WORD      (* BCD encoded *)
  VAR_INPUT (* "EN" input is used to indicate "scale ready" *)
    weigh_command : BOOL;
    gross_weight : WORD; (* BCD encoded *)
    tare_weight : INT;
  END_VAR
  (* Function Body *)
END_FUNCTION                (* Implicit "ENO" *)
```

The ST form of the declaration of this function is the same as in the IL program. The body of function WEIGH in the ST language is:

```

IF weigh_command THEN

    WEIGH := INT_TO_BCD (BCD_TO_INT(gross_weight) - tare_weight);

END_IF ;
    
```

A.3.14 Graphic languages

The graphic languages defined in IEC 61131-3 are Ladder Diagram (LD) and Function Block Diagram (FBD). Sequential Function Chart (SFC) elements can be used in conjunction with either graphic languages.

A.3.14.1 Common elements

Elements common to LD, FBD and SFC

- representation of lines and blocks;
- direction of flow in network;
- evaluation of network;
- execution control.

A.3.14.2 Ladder Diagram (LD)

Ladder diagram is based on the graphical presentation of Relay Ladder Logic. It is a well established PLC programming language used widely in machinery and process controls where permissives and interlocks are frequent. Ladder logic allows functional transparency that facilitates on-site trouble shooting.


For the LD language, IEC 61131-3 defines the elements: power rails, link elements and states, contacts, coils, functions and function blocks.

A network within a program organization is evaluated top to bottom order, except modified executing by execution control elements.

A.3.14.3 Function Block Diagram (FBD)

Function Block Diagram is very common to the process industry. It expresses the behaviour of functions, function blocks and programs as a set of interconnected graphical blocks, like in electronic circuit diagrams. It looks at a system in terms of the flow of signals between processing elements. FBD is most suitable for general logic and control and therefore is widely used.

Figure A.15 illustrates the equivalency between LD and FBD:




IEC 1039/04

Key:

- a) "Wired-OR" in LD language.
- b) Function in FBD language.

Figure A.15 – Boolean OR examples

Some typical programming elements of FBD language are shown in Figure A.16.




IEC 1040/04

Figure A.16 – Programming elements of Function Block Diagram language

When a program organization unit in the FBD language contains more than one network, the manufacturer is to provide implementation-dependent means by which the user may determine the order of execution.

A.3.15 Top-down and bottom-up program development

IEC 61131-3 readily facilitates two ways of developing control programs: top-down and bottom-up as shown in Figure A.17. In the top-down method, the whole application is specified and divided into sub parts, variables declared, and programs developed. Bottom-up programming starts the application at the bottom, for instance via derived functions and function blocks. Whichever method is being used, the development environment given in the IEC 61131 series provides logically organised programming process.



IEC 1041/04

Figure A.17 – Top-down and bottom-up programming

A.4 (blank)

This Clause is blank.


IEC 61131-4 is this Technical Report.

There is no overview of IEC 61131-4 in this Technical Report.

A.5 Overview of IEC 61131-5

A.5.1 Scope of IEC 61131-5

IEC 61131-5 covers data exchange between PLC and other devices, as illustrated in Figure A.18. IEC 61131-5 specifies the communication aspects of Programmable Controllers (PLC). It describes from the viewpoint of a PLC how PLC can communicate among themselves or how any device can communicate with a PLC. It describes the communication services a PLC can provide to other devices and it describes the services a PLC can request from other devices.



IEC 1042/04

Figure A.18 – Scope of IEC 61131-5

Communication partners in terms of IEC 61131-5 are Programmable Controllers, Process Controllers, Control Systems, HMI systems or other automations systems like numeric controllers or roboters. The communication services of IEC 61131-5 may also be used to communicate with smart field devices. The access to remote I/O or to simple field devices connected to a actor/sensor interface or to a field bus is not in the scope of IEC 61131-5.

IEC 61131-5 defines communication services most appropriate for the communication used at control level and area control level and for the connection of a PLC to the process supervision level and plant management level. The automation systems which need to communicate are connected by one communication system or a hierarchy of communication systems.

IEC 61131-5 does not define a new communication system, but it specifies the use of communication services defined in existing communication systems. All communication services are described independently of a specific communication subsystem. They may be used with different communication subsystems. The used communication subsystem should support connections at transport level, provide variable access and event services and should support the transfer of large amounts of data, to support the whole functionality of IEC 61131-5.

IEC 61131-5 contains the mapping of its communication services to ISO 9506-1 and ISO 9506-2 (MMS) and ISO/IEC 95065-5 (SPS Companion Standard) and may be used with communication systems based on these standards. But the communication server may be used with communication subsystems based on the IEC 61158 series or even on implementer-specific communication subsystems as well.

A.5.2 Technical contents of IEC 61131-5 and the PLC model

IEC 61131-5 is best used with PLC systems which support programming languages according to IEC 61131-3 and may be connected to a standardised communication system. Following this recommendation, the PLC user obtains a standardized application program interface for PLC communication which simplifies to portability of a PLC application program to PLC of different manufacturers. Additionally, the user also obtains interoperability among different PLC systems and with other devices which support communication according to IEC 61131-5.

A.5.2.1 Technical contents of IEC 61131-5

The IEC 61131-5 standard on PLC communication contains the following:

- the definition of communication objects of a PLC;
- the definition of communication function blocks and their programming interface;
- the description of the communication services requested from or provided to a communication subsystem; and
- the mapping of the communication objects and communication services onto different standardised communication systems.

Using IEC 61131-5 necessary communication objects are automatically deduced from the existing PLC application program. This allows communications to and from the PLC with a programming environment already familiar to the user.

IEC 61131-5 describes the application program interface of the PLC communication. It describes a set of communication function blocks. The parameter interface, the internal behaviour of the function blocks, and the mapping onto the communication service of a communication subsystem are specified.

IEC 61131-5 also describes the communication services of a PLC from the viewpoint of a PLC programmer. It defines communication functions and communication function blocks using the programming language elements of IEC 61131-3.

A.5.2.2 PLC communication

PLC communication is based on the definitions and models defined in other parts of the IEC 61131 series. Each part of the IEC 61131 series provides a model for the communication function to interface, as illustrated in Figure A.19.

The data are transmitted between instances of the IEC 61131-5 function blocks. In the application program, the sending function block has a variable set of inputs with the data to be sent (SD_i) via the communication system. This data set is sent to the corresponding receiving side, and made available to the other application program via the outputs (RD_i). Both data-types of SD-n and RD_n have to match.

In IEC 61131-5, the communication itself is done via communication connection. This handles addressing, data integrity and security, data flow control and others. This model provides secure and communication partners. It insures that Client and Server can find each other and understand each other, or change the role of client and server. With this set, not only 1-to-1 connections, but also 1-to-n connections (multi-cast) as well as 1-to-all connections (broadcast) can be supported with suitable communication system. With these last two, the Publisher-Subscriber model is also supported.





Figure A.19 – Relationship of the communication model to IEC 61131-2 and IEC 61131-3

A.5.3 Communication model

A.5.3.1 Client-server model

Communication, as defined in IEC 6113-5 uses the client-server-model, Figure A.20. A client requests a communication service from a remote device, the server. The server responds to the request of a client either positively if it can provide the requested service or negatively if it could not provide the service.



IEC 1044/04

Figure A.20 – Programmable controller communication model

Figure A.20 illustrates the devices in a communication network, showing three possible devices that request PLC functions (clients) from PLC2 (server). The two highlighted PLCs are in the scope of IEC 61131-5. From the communication viewpoint the 'Supervisory Controller' and the 'Other End System Which Talks to PLC' mentioned in this figure exhibit the same behaviour to a PLC communication server, i.e., they submit requests to PLC2.

In IEC 61131-5, the communication itself is done via communication connection. Connections connect the client and the server of a communication relationship. Within a connection, the participating devices may change their client and server role. Connections can be made within a system, for instance between different CPUs in one PLC, or between different tasks on a SoftPLC, or between different PLC applications in different devices. All communication services of IEC 61131-5 need connections. In most cases, these are constructed and maintained in an implicit way.

Within IEC 61131-5 not only 1-to-1 (one-to-one) connections between one client and one server, but also 1-to- n connections (multi-cast) as well as 1-to-all connections (broadcast) are supported.

A.5.3.2 Communication relating to PLC hardware model

Communication modules of a PLC are parts of PLC equipment, as depicted in the PLC hardware model of Figure A.2. The Communication Module is therefore integrated within the PLC equipment and passes data internally.

A.5.4 PLC communication services

IEC 61131-5 specifies the services the PLC provides to the control system via the communication subsystem. Accordingly, the PLC application program can be designed to use the communication subsystem to interact with other devices.

A.5.4.1 PLC subsystems and their status

Status data provided by a PLC include state formation and fault indications. Status can be reported on some of the subsystems identified in Table A.23. In addition, a summary status provides general information about the PLC.

Table A.23 – Status presenting entities

No.	Status presenting entities
1	PLC (as a whole)
2	I/O subsystem (includes Input and Output modules and other intelligent I/O devices)
3	Processing unit
4	Power supply subsystem
5	Memory subsystem
6	Communication subsystem
7	Implementer specific subsystems
<p>NOTE The status is intended to provide information about the controller including its hardware and firmware subsystems, not considering configuration information. It is not intended to provide information about the controlled process nor the PLC application program. The status data contains information concerning the state and the health.</p>	

There are two concepts used in IEC 61131-5 relating to status: health and state.

The "health" of a PLC or its subsystems is specified by returning one and only one of the three possible values. The semantics associated with each value is specified below. They are, in order of decreasing health:

GOOD – If "TRUE", the PLC (or the specified subsystem) has not detected any problems which would prohibit it from performing the intended function.

WARNING – If "TRUE", the PLC (or the specified subsystem) has not detected any problems which would prohibit it from performing the intended function, but it has detected at least one problem which could place some limits on its abilities. The limit may be time, performance, etc. (See the following statements for further definition of these limits.).

BAD – If "TRUE", the PLC (or the specified subsystem) has detected at least one problem which could prohibit it from performing the intended function.

The "state" of the PLC system is indicated by a list of attributes, each of which may be TRUE or FALSE. Zero, one, or more of these attributes may be TRUE at the same time. The semantics associated with each attribute is specified in the remainder of this Clause.

Each of the status information can also have implementer specified attributes. Some examples of implementer specified attributes are:

- a) additional error diagnostics (e.g. EEPROM (Electrically Erasable Programmable Read Only Memory) write cycles exceeded);
- b) additional operational states (e.g. auto-calibrate enabled); and
- c) local key status (e.g. auto-restart required).

The status is intended to provide information about the controller including its hardware and firmware subsystems, not considering configuration information. It is not intended to provide information about the controlled process nor the PLC application program. The status data contains information concerning the state and the health of the PLC and its subsystems. Each status information can also have implementer specified attributes.

A.5.4.2 PLC summary status

Summary status of the PLC is part of its communication services as listed in Table A.24.

Table A.24 – PLC summary status

No.	Item	Description	
		1	Health
2		WARNING	At least one subsystem indicates a WARNING health condition and no subsystem indicates a BAD health condition.
3		BAD	At least one subsystem indicates a BAD health condition.
4	Running	If TRUE, this attribute indicates if at least one part of the user application has been loaded and is under control of the PLC.	
5	Local control	If TRUE, this attribute indicates if local override control is active. If active, the ability to control a PLC and its subsystems from the network may be limited. For example, this could be closely tied to the use of a local key switch.	
6	No outputs disabled	If TRUE, this attribute indicates that the PLC can change the physical state of all outputs as a result of application program execution or other means. If not TRUE, the physical state of some of the outputs are not affected (logical state may be affected). This is typically used in the testing and modifying of application programs in the PLC.	
7	No inputs disabled	If TRUE, this attribute indicates that the PLC can access the physical state of all inputs as a result of application program execution or other means. If not TRUE, the physical state of some inputs cannot be accessed. This is typically used in the testing and modifying of application programs where the inputs can be simulated.	
8	Forced	If TRUE, this attribute indicates that at least one I/O point associated with the PLC has been forced. When an input is forced, the application program will receive the value specified by the PADT instead of the actual value from the machine or process. When an output is forced, the machine or process will receive the value specified by the PADT instead of the value generated by execution of the application program. When a variable is forced, the application program will use the value specified by the PADT instead of the one generated by the normal program execution.	
9	User application present	If TRUE, this attribute indicates that the processing unit has at least one user application present.	
10	I/O subsystem	If TRUE, this attribute indicates "WARNING" or "BAD" which is caused by an I/O subsystem.	
11	Processing unit subsystem	If TRUE, this attribute indicates "WARNING" or "BAD" which is caused by a processing unit subsystem.	
12	Power supply subsystem	If TRUE, this attribute indicates "WARNING" or "BAD" which is caused by a power supply subsystem.	
13	Memory subsystem	If TRUE, this attribute indicates "WARNING" or "BAD" which is caused by a memory subsystem.	
14	Communication subsystem	If TRUE, this attribute indicates "WARNING" or "BAD" which is caused by a communication subsystem.	
15	Implementer specified subsystem	If TRUE, this attribute indicates "WARNING" or "BAD" which is caused by an implementer specified subsystem.	

A.5.4.3 Status of I/O subsystem and Processing Unit

The status reported by the PLC on its I/O subsystem is listed in Table A.25. That of its processing unit is in Table A.26. In addition, IEC 61131-5 also defines status information for power supplies, memory and the communication subsystem.

Table A.25 – Status of I/O subsystem

No.	Item	Description	
1	Health	GOOD	Indicates that there have been no errors detected in this I/O subsystem.
2		WARNING	Indicates that a minor fault has been detected in the I/O subsystem. An example of a minor fault is the occurrence of recoverable errors in the communication with a remote I/O station.
3		BAD	Indicates that a major fault has been detected in the I/O subsystem. An example of a major fault is losing communication with a remote I/O station.
4	No outputs disabled	If TRUE, this attribute indicates that the PLC can change the physical state of all outputs associated with the specified I/O subsystem as a result of application program execution or other means. If not TRUE, the physical state of some of the outputs is not affected (logical state may be affected). This is typically used in the testing and modifying of application programs in the PLC.	
5	No inputs disabled	If TRUE, this attribute indicates that the PLC can access the physical state of all inputs associated with the specified I/O subsystem as a result of application program execution or other means. If not TRUE, the physical state some inputs cannot be accessed. This is typically used in the testing and modifying of application programs where the inputs can be simulated.	
6	I/O forced	If TRUE, this attribute indicates that at least one I/O point associated with this subsystem has been forced. When an input is forced, the application program will receive the value specified by the PADT instead of the actual value from the machine or process. When an output is forced, the machine or process will receive the value specified by the PADT instead of the value generated by execution of the application program.	
NOTE The definition of "major fault" and "minor fault" needs to be provided by the implementer.			

Table A.26 – Status of processing unit

No.	Item	Description
1 2 3	Health	This attribute identifies the health of the processing unit. The implementer should specify the conditions when GOOD, WARNING or BAD are valid.
4	Running	If TRUE, this attribute indicates if at least one part of the user application has been loaded and is under control of the processing unit.
5	Local control	If TRUE, this attribute indicates if local override control is active. If active, the ability to control the processing unit from the network may be limited. For example, this could be closely tied to the use of a local key switch.
6	No outputs disabled	If TRUE, this attribute indicates that the processing unit can change the physical state of all outputs controlled by this processing unit as a result of application program execution or other means. If not TRUE, the physical state of some of the outputs are not affected (logical state may be affected). This is typically used in the testing and modifying of application programs in the PU.
7	No inputs disabled	If TRUE, this attribute indicates that the processing unit can access the physical state of all inputs accessible from this processing unit as a result of application program execution or other means. If not TRUE, the physical state of some inputs cannot be accessed. This is typically used in the testing and modifying of application programs where the inputs can be simulated.
8	User application present	If TRUE, this attribute indicates that the Processing Unit has at least one User Application present.
9	Forced	If TRUE, this attribute indicates that at least one variable associated with this Processing Unit has been forced. When a variable is forced, the application program will use the value specified by the PADT instead of the one generated by the normal program execution.

A.5.5 Application functions

IEC 61131-5 describes the functions which a PLC provides to a control system, using the communication subsystem, as in Table A.27. Generation of alarm messages is one of the application functions.

Table A.27 – PLC application functions

PLC communication function	PLC as requester	PLC as responder	Function block available
Device verification	Yes	Yes	Yes
Data acquisition	Yes	Yes	Yes
Control	Yes	Yes	Yes
Alarm reporting	Yes	No	Yes
Program execution and I/O control	No	Yes	No
Application program transfer	No	Yes	No
Connection management	Yes	Yes	Yes

The application program interface of many PLC communication functions is a communication function block (FB) defined in IEC 61131-5. All these Functional Blocks are described using state diagrams with transitions and actions.

A.5.5.1 Device verification

The device verification allows other devices to determine if the PLC is able to perform its intended function in the automated system. A PLC can provide status of itself and its subsystems. A device may explicitly request status from the PLC or the PLC may initiate an unsolicited status report using services provided by the communication interface.

A PLC can request a remote communication partner to send back to it its status information using the STATUS function block. A PLC can itself enable to receive status information of a remote communication partner using the USTATUS function block. The remote communication partner needs to at least inform the USTATUS instance whenever its status information presented in the PHYS and LOG output changes.

A.5.5.2 Data acquisition

Data contained in a PLC are presented as variables. This data may come from a variety of sources and may have a wide range of meanings. Variables with direct representation or other variables which have access paths (see IEC 61131-3 for the definition of access paths can be used for data transfer).

The client may read the value of one or more variables at a time or condition determined by the client. The access to the variables may be controlled by the PLC, or the data is provided by the PLC to the client at a time or condition determined by the PLC application program holding the variables.

The Function Block READ is used to read one or many variables of the remote communication partner. The Function Block pair USEND/URCV transmits a set of variables between a pair of instances of USEND/URCV or between one instance of USEND and many instances of URCV. BSEND/BRCV are used for the transmission of a data buffer, with length as specified in the application program. The number of bytes to be transferred can dynamically be set via one input parameter.

A.5.5.3 Parameter control

Parametric control is when the operation of the PLC is directed by writing values to variables residing in the PLC. This change in operation is determined by either the application program or other local mechanisms. The Function Block WRITE is used to set value of variables in the remote communication partner.

Interlocked control is when the client requests the server to execute an application operation and to inform the client of the result of the operation. There are two aspects of this service, the synchronization of the client and server, and the exchange of data between them. In interlocked control, this data exchange occurs at synchronization points in the application program. This service can be used to have the effect of a remote procedure call from one application program to another.

The Function Block pair SEND/RCV is used for interlocked control. The SEND instance requests the RCV instance to execute an application operation and to inform the SEND instance of the result of the operation.

A.5.5.4 Alarm reporting

The PLC can have the ability to signal alarm messages to a client when a predetermined condition occurs. The client may indicate an acknowledgement of these alarms to the PLC. This differs from normal data acquisition in that the state of an alarm point is remembered by the PLC until it is acknowledged by the client.

A PLC can be programmed using the ALARM Function Block to report an alarm message with an acknowledgement capability. Or, it can be programmed using the NOTIFY Function Block to report an alarm message without an acknowledgement capability.

A.5.5.5 Application program execution and I/O control

PLC application programs can be started either from an initial state or from the state they were in at the time they were stopped. The state of I/O can be set to the values listed in Table A.28 when a configuration or resource is started or stopped.

The PLC application program in a PLC system consists of one configuration and zero, one or more resources according to IEC 61131-3. Configurations and resources may be started and stopped. The resources are started and stopped when the configuration is started and stopped and they can be started or stopped independently of the configuration.

At the time the application program state is changed, the outputs can be directed to either be set to implementer specified states, hold the outputs in the current state, set all outputs to zero, or change some outputs to user specified states (on or off, with those not specified holding the last state) through an implementer specified mechanism (for example: tables, PLC procedure, etc.). The inputs associated with a running application program can be directed to either provide the actual data from the sensors or to continue to use previously supplied values.

Table A.28 – Meaning of value of I/O state

Value of I/O State	Meaning	Set by
Controlled	Actuators are being controlled by the application program or the part of the application program being started. Inputs are being supplied to the application program or the part of the application program being started by the interface function to sensors and actuators.	Starting
Hold outputs	Actuators are not being controlled by the application program or the part of the application program being started, they are held in the current state. Sensors are being supplied to the application program or the part of the application program being started by the interface function to sensors and actuators.	Starting
Hold current state	Actuators are not being controlled by the application program or the part of the application program being started or stopped, they are held in the current state. Sensors are not being supplied to the application program or the part of the application program being started, they are held in the current state.	Starting, stopping
Implementer state	Actuators are not being controlled by the application program or the part of the application program being stopped, they are held in a state, which was specified by the implementer. The application program is not running, therefore the state of the Sensor Interface is not specified.	Stopping
Zero outputs	Actuators are not being controlled by the application program or the part of the application program being stopped, they are held in the zero state. The application program is not running, therefore the state of the Sensor Interface is not specified.	Stopping
User specified	Actuators are not being controlled by the application program or the part of the application program being stopped, they are held in a state which was specified by the user. The application program is not running, therefore the state of the Sensor Interface is not specified.	Stopping

A.5.5.6 Application program transfer

Application program transfer allows the client to upload the complete contents of the programmable memory or portions thereof. Upload for archive, upload for verification, download for restore to previously known good system, and download an off-line developed system are the services provided. The initiation of the program transfer is typically done by a device that is not a PLC.

The portions of the programmable memory which can be uploaded or downloaded are the whole application program of the PLC (configuration), the application program of one processing unit (resource) or parts of it like programs, global variables, or access paths.

A.5.5.7 Connection management

Connections are controlled explicitly by the application program using the CONNECT Function Block or are provided by the communication subsystem if and when needed. CONNECT is used to establish a connection between the calling communication partner and the remote communication partner.

A.5.6 Communication function blocks

A.5.6.1 Communication function and block representation

PLC communication functions and their FB representation defined in IEC 61131-5 are listed in Table A.29.

Table A.29 – List of communication function blocks

No.	Communication functions	Name of communication FB
1	Semantic of communication FB parameters (Addressing of remote variables)	REMOTE_VAR
2 3	Device verification	STATUS, USTATUS
4	Polled data acquisition	READ,
5 6 7 8	Programmed data acquisition	USEND, URCV, BSEND, BRCV
9	Parametric control	WRITE,
10 11	Interlocked control	SEND, RCV
12 13	Programmed alarm report	NOTIFY, ALARM
14	Connection management	CONNECT

The item numbers given in Table A.29 are used to state compliance to these Communication Function Blocks (CFB).

The communication function blocks use a common semantic for the function block inputs and outputs. The meaning of these inputs and outputs is described in Table A.30. Some Communication Function Blocks have special input or output parameters, they are described where the communication function blocks themselves are described.


Table A.30 – Semantic of communication function block parameters

Parameter name	Data type of the parameter	Interpretation
EN_R	BOOL	Enabled to receive data
REQ/RESP	BOOL	Perform function on raising edge
ID	COMM_CHANNEL	Identification of the communication channel
R_ID	STRING	Identification of the remote FB inside the channel
SD_i	ANY	User data to send
VAR_I	STRING or data type of the output of the function REMOTE_VAR	Identification of a variable of the remote communication partner
DONE	BOOL	Requested function performed (good and valid)
NDR	BOOL	New user data received (good and valid)
ERROR	BOOL	New non-zero status received
STATUS	INT	Last detected status (error or good)
RD_i	ANY	Last received user data

A.5.6.2 Example for the use of communication function blocks

Take as an example two PLCs needing to establish a communication channel. Both PLCs use the channel for client and server function, i.e. both need to get an appropriate value for their ID parameter of the CFBs. After establishing a communication channel, the two PLCs can transfer data using the USEND and URCV function blocks.

The structure of a communication function block program is the same as a FBD program according to specifications of IEC 61131-3. Figure A.21 illustrates a CFB program which uses a timer to supervise communication.



In the above program:

- T1.Q timer
- TO_PC2 assign communication channel to PLC2
- ORD1 remote partner identity
- FCT1 function 1
- DAT1 first parameter of FCT1
- RDAT1 variable pointing to data location
- T# 5s 5 s of time

Figure A.21 – Example of communication control in FBD language

A.5.7 Compliance

The manufacturer is required to provide a compliance statement included in the documentation accompanying the PLC system. The form of the compliance statement is:

"This system complies with the requirements of this part for the following features:" followed by a set of compliance tables in the following format

Table title

Table number	Feature number	Feature description

Features for "PLC status" are found in Tables 1 to 9 of IEC 61131-5.

A PLC system complying with the requirements of IEC 61131-5, should follow the methodology described in IEC 61131-5.

A.6 (blank)

This Clause is blank.

At the publication of this edition of IEC 61131-4, there is no IEC 61131-6.

The part number IEC 61131-6 is reserved for future use.

A.7 Overview of IEC 61131-7

A.7.1 General outline of IEC 61131-7

The scope of IEC 61131-7 is to address fuzzy control programming in the application of programmable controllers. In IEC 61131-7, fuzzy control refers to application of fuzzy logic theory to industrial control. Its wide range of applications makes fuzzy control a basic tool of programmable controller users. The object of IEC 61131-7 is to define fuzzy control terminology, programming elements and methods, and its integration in PLC programming languages defined in the IEC 61131 PLC standard. The standardization of fuzzy control programming will help to realise the portability of fuzzy control programs among different industrial automation stratagems utilising PLCs.

A language for the programming of Fuzzy Control applications used by programmable controllers, Fuzzy Control Language (FCL) is defined in IEC 61131-7. In order to cover all kinds of usage, from small and simple applications to highly sophisticated and complex ones, three classes of conformance are defined. The manufacturers are required to offer related information with their products and the users need to take care in their selections of fuzzy control in their applications.

IEC 61131-7 contains six Clauses. Clause 1 introduces the scope and object of Fuzzy Control programming and Clause 2 lists the normative references. Clause 3 gives definitions of 22 technical terms, which are necessary for understanding IEC 61131-7. Clause 4 describes how the fuzzy control applications programmed in FCL are to be integrated into the programmable controllers. FCL is defined in Clause 5. Three levels of compliance are given.

There are five annexes, all informative, attached to the text of IEC 61131-7. A short introduction of fuzzy control and fuzzy logic as far as it is necessary for the understanding of IEC 61131-7 is given in Annex A. Emphasis is put on those related to the definitions of Language Elements of FCL. Annexes B and C give some practical examples of application of fuzzy control from experiences. The methods for the use of variables in the rule blocks is given by an example in Annex D. Symbols, Abbreviations and Synonyms used in IEC 61131-7 are listed in Annex E of IEC 61131-7.

A.7.2 Integration of fuzzy control application into the programmable controllers

A fuzzy control application programmed in FCL is encapsulated in Function Blocks (or Programs) as defined in IEC 61131-3. The concept of Function Block Types and Function Block Instances given in IEC 61131-3 apply to IEC 61131-7. Therefore, to apply FCL it is essential that the PLC is compliant to IEC 61131-3 PLC language standard.

The Function Block Types defined in FCL specify the input and output parameters and the fuzzy control specific rules and declarations. The corresponding Functions Block Instances contain the specific data of the fuzzy control applications.

An example in FBD representation is illustrated in Figure A.22. The data types of both input and output parameters should be consistent with the corresponding "calling environment".




Figure A.22 – Example of a fuzzy control in FBD program

A.7.3 Fuzzy control language

The basic FCL language elements include interface, fuzzification, defuzzification and rules.

A.7.3.1 Function Block interface

Function Blocks are configured according to IEC 61131-3. With these language elements, it is possible to define a function block interface. The function block interface is defined with parameters which are passed into and out of the function block.

A.7.3.2 Fuzzification

To convert a input signal for processing in FCL the linguistic values of an input variable can be assigned several corresponding membership functions.

```

FUZZIFY variable_name
    TERM term_name = membership_function;
    ....
END_FUZZIFY

```


Following the keyword FUZZIFY, the variable being fuzzified is named. The variable name is defined in the VAR_INPUT section. This variable is termed linguistic variable in FCL. A linguistic variable is described by one or more linguistic terms. A linguistic term is invoked by the keyword TERM. A TERM is assigned a membership function made of piece-wise linear functions. The membership function is prescribed end-points in the following manner:

```
membership_function ::= (point i), (point j), ...
```

Every end-point is a paired value: (values-of-the-variable, membership-degree). Membership Degree describes the percentage of truthfulness of a linguistic variable. Membership Degree has the value between 0,0 and 1,0.

```
point i ::= value of input i | membership degree of input i
```

The membership function may be a ramp curve or triangle curve. An example of membership function is illustrated in Figure A.23. The linguistic terms "warm" and "cold" are show as ramp curves for membership functions.



IEC 1047/04

NOTE The data type of the points of membership functions is not defined. The manufacturer needs to provide a compiler that accommodates any necessary conversion.

Figure A.23 – Example of ramp curve membership functions

A.7.3.3 Defuzzification


A linguistic variable for an output variable may be a positive or a negative value. It has to be converted into a positive real value. This conversion is described between the keywords DEFUZZIFY and END_DEFUZZIFY. This is illustrated in Figure A.24.



IEC 1048/04

Figure A.24 – Defuzzification program block


Singleton is one of the principle defuzzification functions. The singleton is a special membership function described by a single value for the linguistic term. Figure A.25 gives an example of a singleton term.



IEC 1049/04

Figure A.25 – Example of singleton terms

The defuzzification method is defined by the language element Method.



Defuzzification methods defined in this standard are listed in Table A.31 below.

Table A.31 – Defuzzification methods

Keyword	Explanation
COG	Centre of Gravity (note 1)
COGS	Centre of Gravity for Singletons
COA	Centre of Area (notes 2 and 3)
LM	Left Most Maximum (note 4)
RM	Right Most Maximum (note 4)
NOTE 1 Centre of Gravity is equivalent to Centroid of Area.	
NOTE 2 Centre of Area is equivalent to Bisector of Area.	
NOTE 3 COA is not applicable if singletons are used.	
NOTE 4 LM and RM defuzzification methods are asymmetrical about zero.	

A default value for the output may be assigned for an output whose membership value is 0. This default value is the value for the output variable only in the case when no rule has been fired.

```
DEFAULT:= value | NC;
```

The keyword NC stands for "no change" which indicates that the output needs to be remain unchanged if no rule has fired.

A.7.3.4 Rule block

The inference of the fuzzy algorithm is defined in one or more rule blocks. Each rule block has a unique name. Rules are defined between the keywords RULEBLOCK and END_RULEBLOCK.

```
RULEBLOCK ruleblock_name
  operator_definition;
  [activation_method;]
  accumulation_method;
  rules;
END_RULEBLOCK
```

Priority of the operator is handled according to Boolean algebra given in Table A.32.

Table A.32 – Priority of rule block operators

Priority	Operator
1	() parenthesis
2	NOT
3	AND
4	OR

Following is an example of a simple rule:

```
RULE 1: IF subcondition1 AND variable1 OR variable2 THEN conclusion;
```

The OR operator in a rule may be implemented by defining two rules in its place:

RULE 3: IF subcondition 1 OR subcondition 2 THEN conclusion;

may be replaced with:

RULE 3a: IF condition 1 THEN conclusion;
 RULE 3b: IF condition 2 THEN conclusion;

The conclusion may be split into several sub-conclusions and output variables as shown in the following example:

IF temp IS cold AND pressure IS low
 THEN var1, valve1 IS inlet , valve2 IS closed;

may be replaced with:

IF temp IS cold AND pressure IS low
 THEN var1,
 valve1 IS inlet,
 valve2 IS closed;

In order to manipulate the fuzzy control application parameters externally, a weighting factor may be used. This enables the possibility to change the weighting factor during runtime in order to adapt the fuzzy control program to process needs. In the following example the weighting_factor is the constant 0.5.

IF temp IS cold AND pressure IS low
 THEN valve1 IS inlet WITH 0.5,
 valve2 IS closed;

A.7.4 Exchange of fuzzy control programs

The FCL is defined based on PLC programming languages specified in IEC 61131-3. The users of programmable controllers can build their fuzzy control Function Blocks or Programs by employing FCL, so long as the manufacture supports it with editor and compiler. IEC 61131-7 also defines a common representation for data exchange between fuzzy control configuration tools of different manufacturers. The end-user would be able to exchange fuzzy control projects among PLCs from different manufacturers who implement the common data interface in their specific editors.

A.7.5 Compliance

A.7.5.1 Compliance classes of fuzzy control language

There are three classes of compliance of FCL as defined in IEC 61131-7. Each compliance class supports different level of fuzzy algorithm. The levels are:

- Basic Level specifies the minimum features in mandatory nature that a complete fuzzy control application has to implement.
- Extension Level allows some optional features which may be implemented optionally by the users in their applications to be included as additional ones.
- Open Level contains further features exceeding the Basic Level and the Extension Level made available by the individual manufactures.

The manufacturers are required to clearly describe the level of compliance of their products. The required FCL language elements for the Basic Level are listed in Table A.33. FCL language elements of the Extension level are listed in Table A.34.

All of the compliance levels include the definition of the Function Block and the Data Types required for the input and output parameters of fuzzy control function block in accordance with IEC 61131-3. Basic level of compliance is mandatory for any claim of compliance with IEC 61131-7. The extension level of compliance is optional but defined in IEC 61131-7.

Table A.33 – Fuzzy logic control basic level language elements

Language element	Keyword	Details
Function block declaration	VAR_INPUT, VAR_OUTPUT	Contains input and output variables
Membership function	Input variable: TERM	Maximum of three constant points (degree of membership coordinate = 0 or 1)
	Output variable: TERM	Constant singletons only
Conditional aggregation	Operator: AND	Algorithm: MIN
Activation	-	Not relevant because only singletons are used
Accumulation (result aggregation)	Operator: ACCU	Algorithm: MAX
Defuzzification	METHOD	Algorithm: COGS
default value	DEFAULT	NC, value
Ruleblock	RULEBLOCK	One ruleblock only
Condition	IF ... IS ...	n subconditions
Conclusion	THEN	Only one subconclusion

Table A.34 – Fuzzy logic control extension level language elements (optional)

Language element	Keyword	Details
Function block declaration	VAR	Contains local variables
Membership function	Input variable: TERM	Maximum of four constant or variable points (degree of membership co-ordinate = 0 or 1)
Membership function	Output variable: TERM	Maximum of four constant or variable points (degree of membership co-ordinate = 0 or 1)
Conditional aggregation	Operator: AND	Algorithm: PROD , BDIF
Conditional aggregation	Operator: OR	Algorithm: ASUM , BSUM
Conditional aggregation	Operator: NOT	$1 - \{\text{argument}\}$
Conditional aggregation	parentheses	()
Activation	Operator: ACT	Algorithm: MIN, PROD
Accumulation	Operator: ACCU	Algorithm: BSUM , NSUM
Range for fuzzification	Operator: RANGE	RANGE (minimum value..maximum value), limits the range of the membership functions for the output variable.
Defuzzification method	Operator: METHOD	Algorithm: COG , COA , LM , RM
Ruleblock	Operator: RULEBLOCK	n rule blocks
Condition	IF	n subconditions, n input variables
Conclusion	THEN	n subconclusions, n output variables
Weighting factor	WITH	Constant value and value assigned to variable in the declaration part VAR_INPUT.....END_VAR