

# TECHNICAL REPORT



**Field device tool (FDT) interface specification –  
Part 52-90: Communication implementation for common language  
infrastructure – IEC 61784 CPF 9**

IECNORM.COM : Click to view the full PDF of IEC TR 62453-52-90:2017



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### IEC Catalogue - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

#### IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

IECNORM.COM : Click to view the full PDF IEC 60153-32-90:2017

# TECHNICAL REPORT



---

**Field device tool (FDT) interface specification –  
Part 52-90: Communication implementation for common language  
infrastructure – IEC 61784 CPF 9**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 25.040.40; 35.100.05; 35.110

ISBN 978-2-8322-4333-6

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references .....	8
3 Terms, definitions, symbols, abbreviated terms and conventions .....	8
3.1 Terms and definitions.....	8
3.2 Symbols and abbreviated terms .....	9
3.3 Conventions.....	9
3.3.1 Datatype names and references to datatypes .....	9
3.3.2 Vocabulary for requirements .....	9
3.3.3 Use of UML .....	9
4 Bus category .....	9
5 Access to instance and device data .....	9
5.1 General.....	9
5.2 IO signals provided by DTM.....	9
5.3 Data interfaces .....	10
5.3.1 General .....	10
5.3.2 Mapping HART datatypes to FDT datatypes .....	10
5.3.3 SemanticInfo .....	11
5.3.4 Data exposure using IDeviceData and IInstanceData interfaces .....	12
6 Protocol specific behaviour.....	18
6.1 Support of burst mode .....	18
6.2 Device addressing .....	19
6.3 Support of scanning.....	19
6.4 Support of extended command numbers .....	19
6.5 Support for handling of communication failures and time-outs.....	19
6.6 Support for handling of Delayed Responses.....	20
6.7 Support for topologies with mixed HART protocols.....	20
6.8 Support for nested communication with multiple gateways .....	20
6.9 Support for topologies with WirelessHART .....	20
6.10 Transparent gateways.....	20
6.10.1 General .....	20
6.10.2 Scenario 1 – Manual topology creation .....	20
6.10.3 Scenario 2 – Topology scan and add .....	21
7 Protocol specific usage of general datatypes .....	21
8 Protocol specific common datatypes.....	21
8.1 HartDeviceAddress datatype.....	21
8.2 HartDeviceIpAddress datatype .....	22
8.3 HartDeviceWirelessAddress datatype .....	23
9 Network management datatypes .....	24
10 Communication datatypes.....	24
10.1 General.....	24
10.2 HartConnectRequest datatype .....	24
10.3 HartConnectResponse datatype.....	25
10.4 HartLongAddress datatype.....	26
10.5 HartDisconnectRequest datatype .....	26

10.6	HartDisconnectResponse datatype .....	27
10.7	HartTransactionRequest datatype .....	27
10.8	HartTransactionResponse datatype .....	28
10.9	HartStatus datatype .....	29
10.10	HartAbortMessage datatype .....	29
10.11	HartSubscribeRequest datatype .....	30
10.12	HartSubscribeResponse datatype .....	30
10.13	HartUnsubscribeRequest datatype .....	30
10.14	HartUnsubscribeResponse datatype .....	31
11	Datatypes for process data information .....	31
11.1	General .....	31
11.2	HartIOSignalInfo datatype .....	32
12	Device identification datatypes .....	33
12.1	General .....	33
12.2	HartDeviceScanInfo datatype .....	33
12.3	HartDeviceIdentInfo datatype .....	37
12.4	Mapping of information source .....	38
	Bibliography .....	41
	Figure 1 – Part 52-90 of the IEC 62453 series .....	7
	Figure 2 – Structural information for device variables .....	16
	Figure 3 – Structural information for dynamic variables .....	17
	Figure 4 – Structural information for extended device status .....	18
	Figure 5 – Device-initiated data transfer with burst mode .....	19
	Figure 6 – HartDeviceAddress datatype .....	21
	Figure 7 – HartDeviceIpAddress datatype .....	22
	Figure 8 – HartDeviceWirelessAddress datatype .....	23
	Figure 9 – HartNetworkData datatype .....	24
	Figure 10 – HartConnectRequest datatype .....	25
	Figure 11 – HartConnectResponse datatype .....	26
	Figure 12 – HartDisconnectRequest datatype .....	27
	Figure 13 – HartDisconnectResponse datatype .....	27
	Figure 14 – HartTransactionRequest datatype .....	28
	Figure 15 – HartTransactionResponse datatype .....	28
	Figure 16 – HartAbortMessage datatype .....	29
	Figure 17 – HartSubscribeRequest datatype .....	30
	Figure 18 – HartSubscribeResponse datatype .....	30
	Figure 19 – HartUnsubscribeRequest datatype .....	31
	Figure 20 – HartUnsubscribeResponse datatype .....	31
	Figure 21 – HartIOSignalInfo datatype .....	32
	Figure 22 – HartDeviceScanInfo datatype .....	33
	Figure 23 – HartDeviceIdentInfo datatype .....	37
	Table 1 – Output signal info within IOSignalInfo / HartIOSignalInfo .....	10
	Table 2 – Mapping of basic datatypes .....	11

Table 3 – SemanticInfo attributes description.....	12
Table 4 – Basic Variables exported in IDeviceData and IInstanceData interfaces.....	13
Table 5 – Basic Variables exported only in IDeviceData interface .....	15
Table 6 – Protocol specific usage of general datatypes.....	21
Table 7 – HartDeviceAddress datatype .....	22
Table 8 – HartDeviceIpAddress datatype .....	23
Table 9 – HartDeviceWirelessAddress datatype .....	24
Table 10 – HartNetworkData datatype.....	24
Table 11 – HartConnectRequest datatype .....	25
Table 12 – HartConnectResponse datatype .....	26
Table 13 – HartLongAddress datatype .....	26
Table 14 – HartDisconnectRequest datatype .....	27
Table 15 – HartDisconnectResponse datatype .....	27
Table 16 – HartTransactionRequest datatype .....	28
Table 17 – HartTransactionResponse datatype .....	29
Table 18 – HartStatus datatype.....	29
Table 19 – HartAbortMessage datatype .....	29
Table 20 – HartSubscribeRequest datatype .....	30
Table 21 – HartSubscribeResponse datatype.....	30
Table 22 – HartUnsubscribeRequest datatype .....	31
Table 23 – HartUnsubscribeResponse datatype.....	31
Table 24 – Usage of IOSignalInfo datatype .....	32
Table 25 – HartIOSignalInfo datatype .....	32
Table 26 – HartDeviceScanInfo datatype .....	33
Table 27 – Protocol specific mapping of scan information .....	35
Table 28 – HartDeviceIdentInfo datatype .....	37
Table 29 – Protocol specific mapping of identity information .....	39

IECNORM.COM : Click to view the full PDF of IEC TR 62453-52-90:2017

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

#### **Part 52-90: Communication implementation for common language infrastructure – IEC 61784 CPF 9**

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 62453-52-90, which is a technical report, has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

Each part of the IEC 62453-52-xy series is intended to be read in conjunction with its corresponding part in the IEC 62453-3xy series. This document corresponds to IEC 62453-309.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
65E/440/DTR	65E/514/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The list of all parts of the IEC 62453 series, under the general title *Field device tool (FDT) interface specification*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**


## INTRODUCTION

This part of IEC 62453 is an interface specification for developers of Field Device Tool (FDT) components for function control and data access within a client/server architecture. The specification is a result of an analysis and design process to develop standard interfaces to facilitate the development of servers and clients by multiple vendors that need to interoperate seamlessly.

With the integration of fieldbuses into control systems, there are a few other tasks which need to be performed. In addition to fieldbus- and device-specific tools, there is a need to integrate these tools into higher-level system-wide planning or engineering tools. In particular, for use in extensive and heterogeneous control systems, typically in the area of the process industry, the unambiguous definition of engineering interfaces that are easy to use for all those involved is of great importance.

A device-specific software component, called Device Type Manager (DTM), is supplied by the field device manufacturer with its device. The DTM is integrated into engineering tools via the FDT interfaces defined in this specification. The approach to integration is in general open for all kind of fieldbuses and thus meets the requirements for integrating different kinds of devices into heterogeneous control systems.

Figure 1 shows how this part of the IEC TR 62453-52-xy series is aligned in the structure of the IEC 62453 series.



IEC

Figure 1 – Part 52-90 of the IEC 62453 series

## FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

### Part 52-90: Communication implementation for common language infrastructure – IEC 61784 CPF 9

#### 1 Scope

This part of the IEC 62453-52-xy series, which is a Technical Report, provides information for integrating the HART®<sup>1</sup> technology into the CLI-based implementation of FDT interface specification (IEC TR 62453-42).

This part of IEC 62453 specifies implementation of communication and other services based on IEC 62453-309.

This document neither contains the FDT specification nor modifies it.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61784-1:2014, *Industrial communication networks – Profiles – Part 1: Fieldbus profiles*

IEC 62453-1:2016, *Field device tool (FDT) interface specification – Part 1: Overview and guidance*

IEC 62453-2:2016, *Field device tool (FDT) interface specification – Part 2: Concepts and detailed description*

IEC TR 62453-42:2016, *Field device tool (FDT) interface specification – Part 42: Object model integration profile – Common language infrastructure*

IEC 62453-309:2016, *Field device tool (FDT) interface specification – Part 309: Communication profile integration – IEC 61784 CPF 9*

#### 3 Terms, definitions, symbols, abbreviated terms and conventions

##### 3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62453-1, IEC 62453-2, IEC TR 62453-42 and IEC 62453-309 apply.

---

<sup>1</sup> HART ® is the trade name of a product supplied by HART Communication Foundation. This information is given for convenience of users of this document and does not constitute an endorsement by IEC of the product named. Equivalent products may be used if they can be shown to lead to the same results.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

### 3.2 Symbols and abbreviated terms

For the purposes of this document, the symbols and abbreviations given in IEC 62453-1, IEC 62453-2, IEC 62453-309, and IEC TR 62453-42 apply.

### 3.3 Conventions

#### 3.3.1 Datatype names and references to datatypes

The conventions for naming and referencing of datatypes are explained in IEC 62453-2:2016, Clause A.1.

#### 3.3.2 Vocabulary for requirements

The following expressions are used when specifying requirements.

Usage of “shall” or “mandatory”	No exceptions allowed.
Usage of “should” or “recommended”	Strong recommendation. It may make sense in special exceptional cases to differ from the described behaviour.
Usage of “can” or “optional”	Function or behaviour may be provided, depending on defined conditions.

#### 3.3.3 Use of UML

Figures in this document are using UML notation as defined in Annex A of IEC 62453-1:2016.

## 4 Bus category

IEC 61784 CPF 9 protocol is identified in the attribute busCategory of the BusCategory element by the identifiers, as specified in IEC 62453-309.

## 5 Access to instance and device data

### 5.1 General

Used at interfaces:

- IInstanceData
- IDeviceData

These interfaces shall provide access to at least all parameters defined in IEC 62453-309.

### 5.2 IO signals provided by DTM

A DTM shall provide IO signal information of the device using the IProcessData interface.

To provide all information required to access the output signal information the DTM shall provide the information shown in Table 1 within its HartIOSignalInfo.

**Table 1 – Output signal info within IOSignalInfo / HartIOSignalInfo**

Attribute	Description
Name	Name of the IO signal
Range	Reference to the variables providing range information
Unit	Reference to an enumeration variable describing the unit information
DeviceVariableAssignment	Constant enumeration value that can take following values <ul style="list-style-type: none"> <li>– unassigned: The IO signal is not assigned to dynamic variable and can only be accessed using the indexed approach (reading device variables).</li> <li>– PV: IO signal assigned to the PV dynamic variable</li> <li>– SV: IO signal assigned to the SV dynamic variable</li> <li>– TV: IO signal assigned to the TV dynamic variable</li> <li>– QV: IO signal assigned to the QV dynamic variable</li> </ul>
DeviceVariableCode	Constant that specifies the device specific variable code (see [7] <sup>2</sup> Table 34). Because of compatibility reasons to other FDT versions (e.g. IEC TR 62453-41), this variable could be set to the value 252 that stands for "unknown".

### 5.3 Data interfaces

#### 5.3.1 General

Within HART, several command sets are defined. As part of the command set definition, HART provides a precise naming convention that is documented within the sources of the standard EDD libraries. The data provided by the access data interfaces should be named according to the HART naming convention. For backward compatibility, the semantic IDs as defined in previous versions of FDT should also be provided by the DTM.

A DTM shall provide all device data that is related to the set of Universal Commands and should provide all device data related to Common Practice Commands. If the device supports additional command sets, like device family profiles, those data should also be exported using the naming convention as defined in the HART EDD libraries and as shown in Figure 2 and Figure 3.

#### 5.3.2 Mapping HART datatypes to FDT datatypes

For a better usability of data provided by the data access interfaces IDeviceData and IInstanceData, all data from the device shall be converted into datatypes that are common to FDT. The mapping of basic datatypes is defined in Table 2.

<sup>2</sup> Figures in square brackets refer to the Bibliography.

**Table 2 – Mapping of basic datatypes**

HART Datatypes	FDT datatype	IEC datatype
Packed ASCII (see [10] 5.1.1)	String	STRING
ISO Latin-1 (see [10] 5.1.2)	String	STRING
Dates (see [10] 5.2)	DateTime	DATE_AND_TIME
Time (see [10] 5.3)	ULong (1/32 ms since midnight)	ULINT (1/32 ms since midnight)
Single Precision Floating Point (see [10] 5.4)	float	REAL
Double Precision Floating Point (see [10] 5.4)	double	LREAL
1-4 Byte Unsigned Integer (see [10] 5.5)	UInt	UDINT
5-8 Byte Unsigned Integer (see [10] 5.5)	ULong	ULINT
1-4 Byte Unsigned Integer (see [10] 5.5)	UInt	UDINT
5-8 Byte Unsigned Integer (see [10] 5.5)	ULong	ULINT
1-4 Byte Enumerated (see [10] 5.7.1)	UInt	UDINT
5-8 Byte Enumerated (see [10] 5.7.1)	ULong	ULINT
1-4 Byte Bit Fields (see [10] 5.7.2)	UInt	UDINT
5-8 Byte Bit Fields (see [10] 5.7.2)	ULong	ULINT

HCF standardized the access to device specific data using structures with the standard EDD import libraries for HART. The structure uses ARRAY and COLLECTION constructs that shall be reused when exposing data within FDT in IDeviceData and IInstanceData interfaces with elements of type StructDataGroup.

When converting a COLLECTION into a StructDataGroup, the DataItems shall be identical to the COLLECTION members with:

DataItem Name = COLLECTION member identifier

DataItem Label = COLLECTION member label

When converting an ARRAY into a StructDataGroup, the DataItem shall be identical to the ARRAY element with:

DataItem Name = ARRAY element index as string

DataItem Label = ARRAY element label

An example for such a structure is presented in Figure 2 and Figure 3.

### 5.3.3 SemanticInfo

The SemanticInfo for HART protocol related parameters is directly related to the protocol specification. The definition of the HART commands is the base for the parameter address information which shall be used in the properties ParameterReadAddress, ParameterWriteAddress and SemanticId of the SemanticInfo datatype.

The syntax of the parameter address information is as follows:

CMD<x>[Q(<r>)]B<y>B<z>L<n>

The [Q(<r>)] portion only is required to define request data.

For description of the attributes, please view Table 3.

**Table 3 – SemanticInfo attributes description**

Attribute	Datatype	Description
<x>	decimal integer	command number in the range of 0 to 255
<r>	hex-string	request data bytes
<y>	decimal integer	index of the start byte in the response data section (start index = 0)
<z>	decimal integer	index of the start bit in the byte referenced by <y>
<n>	decimal integer	length of the value in bits

According to 6.4, commands with extended command number shall be described using "CMD31Q<r>..." wherein the first two byte of the request data section shall contain the extended command number.

The property SemanticInfo.ApplicationDomain shall contain 'FDT\_HART' for all parameters in Table 4 and Table 5.

### 5.3.4 Data exposure using IDeviceData and IInstanceData interfaces

#### 5.3.4.1 Export of basic device parameters

Using the HART datatype mapping rules introduced in the preceding sections basic device parameters defined within the Universal and Common Practice Command sets can be exported.

Basic parameters that are not accessed using index information in the request part should for compatibility reasons provide additionally the SemanticInfo information specified in previous versions of FDT. Variables are identified by their standard identifier in HART. In Table 4, all variables are listed that shall be exported in the related data interfaces when supported by the device. HART identifier shall be assigned to the property Data.Id.

Variables with identifiers starting with "PV.", "SV.", "TV." and "QV." shall be seen as short cuts to variables that shall be available too, using the structured exposure of device variables as defined in 5.3.4.2.1.

IECNORM.COM : Click to view the PDF of IEC TR 62453-52-90:2017

**Table 4 – Basic Variables exported in IDeviceData and IInstanceData interfaces**

Identifier	SemanticInfo	Description
device_type	CMD0B1B0L16	Expanded Device Type (see [7], subsection 5.1 and [5], section 6).  NOTE The information from CMD0 is also available via IHardwareIdentification interface.
request_preambles	CMD0B3B0L8	Minimum number of Preambles required for the request message from the Master to the Slave. This number includes the two preambles used in asynchronous Physical Layers (along with the Delimiter) to detect the start of message.
universal_revision	CMD0B4B0L8	HART Protocol Major Revision Number implemented by this device. For HART Revision 7, this value shall be the number 7.
transmitter_revision	CMD0B5B0L8	Device Revision Level (refer to the HCF Command Summary Specification)
software_revision	CMD0B6B0L8	Software Revision Level of this device. Levels 254 and 255 are reserved.
hardware_revision	CMD0B7B3L5	(Most Significant 5 Bits) Hardware Revision Level of the electronics in this particular device. Does Not Necessarily Trace Individual Component Changes. Level 31 is Reserved.
physical_signaling_code	CMD0B7B0L3	(Least Significant 3 Bits) Physical Signaling Code (see [7], subsection 5.10)
device_flags	CMD0B8B0L8	Flags (see [7], subsection 5.11)
device_id	CMD0B9B0L24	Device ID. This number shall be different for every device manufactured with a given Device Type.
response_preambles	CMD0B12B0L8	Minimum number of preambles to be sent with the response message from the slave to the master.
max_num_device_variables	CMD0B13B0L8	Maximum Number of Device Variables. This indicates the last Device Variable code that a host application should expect to be found in the field device (e.g., when identifying the Device Variables using Command 54).
config_change_counter	CMD0B14B0L16	Configuration Change Counter
extended_fld_device_status	CMD0B16B0L8	Extended Field Device Status (see [7], subsection 5.17)
manufacturer_id	CMD0B17B0L16	Manufacturer Identification Code (see [7], subsection 5.8)
private_label_distributor	CMD0B19B0L16	Private Label Distributor Code (see [7], subsection 5.8)
device_profile	CMD0B21B0L8	Device Profile (see [7], subsection 5.57)
polling_address	CMD7B0B0L8	Polling Address of Device (refer to [13], subsection 5.3.4)
loop_current_mode	CMD7B1B0L8	Loop Current Mode (see [7], subsection 5.16)
message	CMD12B0B0L192	Message
tag	CMD13B0B0L48	Tag
descriptor	CMD13B6B0L96	Descriptor
date	CMD13B18B0L24	Date Code
PV.SENSOR_SERIAL_NUMBER	CMD14B0B0L24	Transducer Serial Number
PV.DIGITAL_UNITS	CMD14B3B0L8	Transducer Limits and Minimum Span Units Code (refer to [7], subsection 5.2)
PV.UPPER_SENSOR_LIMIT	CMD14B4B0L32	Upper Transducer Limit
PV.LOWER_SENSOR_LIMIT	CMD14B8B0L32	Lower Transducer Limit
PV.MINIMUM_SPAN	CMD14B12B0L32	Minimum Span

Identifier	SemanticInfo	Description
PV.ALARM_CODE	CMD15B0B0L8	PV Alarm Selection Code (see [7], subsection 5.6). The Alarm Selection Code indicates the action taken by the device under error conditions. For transmitters, the code indicates the action taken by the Loop Current. For Actuators, the action taken by the positioner is indicated.
PV.TRANSFER_FUNCTION	CMD15B1B0L8	PV Transfer Function Code (see [7], subsection 5.3). The Transfer Function Code shall return "0", Linear, if transfer functions are not supported by the device.
PV.RANGE_UNITS	CMD15B2B0L8	PV Upper and Lower Range Values Units Code (refer to [7], subsection 5.2)
PV.UPPER_RANGE_VALUE	CMD15B3B0L32	PV Upper Range Value
PV.LOWER_RANGE_VALUE	CMD15B7B0L32	PV Lower Range Value
PV.DAMPING_VALUE	CMD15B11B0L32	PV Damping Value (units of seconds)
write_protect	CMD15B15B0L8	Write Protect Code (see [7], subsection 5.7). The Write Protect Code shall return "251", None, when write protect is not implemented by a device.
PV.ANALOG_CHANNEL_FLAGS	CMD15B17B0L8	PV Analog Channel Flags (see [7], subsection 5.26)
final_assembly_number	CMD16B0B0L24	Final Assembly Number
longTag	CMD20B0B0L256	Long Tag
PV.DIGITAL_UNITS	CMD1B0B0L8	Primary Variable Units (refer to [7], subsection 5.2)
SV.DIGITAL_UNITS	CMD3B9B0L8	Secondary Variable Units Code (refer to [7], subsection 5.2)
TV.DIGITAL_UNITS	CMD3B14B0L8	Tertiary Variable Units Code (refer to [7], subsection 5.2)
QV.DIGITAL_UNITS	CMD3B19B0L8	Quaternary Variable Units Code (refer to [7], subsection 5.2)
PV.CLASSIFICATION	CMD8B0B0L8	Primary Variable Classification (refer to [7], subsection 5.21)
SV.CLASSIFICATION	CMD8B1B0L8	Secondary Variable Classification (refer to [7], subsection 5.21)
TV.CLASSIFICATION	CMD8B2B0L8	Tertiary Variable Classification (refer to [7], subsection 5.21)
QV.CLASSIFICATION	CMD8B3B0L8	Quaternary Variable Classification (refer to [7], subsection 5.21)
lock_device_status_code	CMD76B0B0L8	Lock Status (see HCF Common Table 25, Lock Device Status)
last_clock_date	CMD90B8B0L24	Date clock last set
last_clock_time	CMD90B11B0L32	Time clock last set
real_time_clock_flag	CMD90B15B0L8	RTC Flags (refer to [7], subsection 5.42)

Table 4 contains data that can also be read via other interfaces. In this case, the DTM shall take care about the consistency of the data. E.g. the variables which are related to CMD0 shall be identical to the HartDeviceScanInfo data, which can be read via the IHardwareScan interface.

Table 5 lists all basic device variables that shall be exported only within IDeviceData interface if supported by the device.

**Table 5 – Basic Variables exported only in IDeviceData interface**

Identifier	Semantic Info	Description
device_status	-/- (empty)	Device status information transferred with each reply. Due to the fact that device_status is accessible by standard means in each transaction, the semantic info is empty
PV.DIGITAL_VALUE	CMD1B1B0L32	Primary Variable
PV.ANALOG_VALUE	CMD2B0B0L32	Primary Variable Loop Current (units of milli amperes)
PV.PERCENT_RANGE	CMD2B4B0L32	Primary Variable Percent of Range (units of percent)
PV.DIGITAL_VALUE	CMD3B5B0L32	Primary Variable
SV.DIGITAL_VALUE	CMD3B10B0L32	Secondary Variable
TV.DIGITAL_VALUE	CMD3B15B0L32	Tertiary Variable
QV.DIGITAL_VALUE	CMD3B20B0L32	Quaternary Variable
current_date	CMD90B0B0L32	Current Date
current_time	CMD90B4B0L32	Current Time of Day

### 5.3.4.2 Export of structural information

#### 5.3.4.2.1 Device variables

Beside of the dynamic characteristics of dynamic variables, there exists data in the device that is related to the dynamic variable (e.g. range information, linearization functions). In HART, several categories of such data information are defined and standardized means are available that allow to document such relationships in a way that a client can access and analyze the structure without device specific knowledge. This information shall be exported in the IDeviceData and IInstanceData interfaces using StructDataGroup elements as mentioned in 5.3.2.

The DTM shall expose information in the structure as shown in Figure 2 and Figure 3.




Figure 2 – Structural information for device variables




Figure 3 – Structural information for dynamic variables

IEC


Future changes to the structure shall be reflected similarly.

### 5.3.4.2.2 Device specific status

HART supports two types of status information:

- device status  
This status is communicated with the response of each command and contains some flags that describe the state of the device.  
This status is already exposed in IDeviceData with variable “device\_status”.
- additional device status  
This status information contains device specific information. Usually it is presented in HART command 48 when the “additional status available” flag is set in the device\_status variable.

To expose additional device status information via the IDeviceData interface a new identifier is introduced here. The data is exposed with DataGroup “additional\_device\_status”. Elements of this data group are references to variables that contain device specific status information like shown in Figure 4.



IEC

Figure 4 – Structural information for extended device status

SemanticInfo information shall be provided for all variables referenced in this group, allowing external tools to request status information without instantiation of the DTM.

### 5.3.4.2.3 Extended burst and event information

HART 7 introduced new features in burst information including event notification. Data Propagation using these new burst and event management can be configured with standard means as defined by HART. The content of burst messages (especially for sub devices) can be evaluated using the exported structural information as presented in the preceding sections.

Support of this new handling is not defined in this document. It is open to the DTM developer to export additional information with the means introduced above.

## 6 Protocol specific behaviour

### 6.1 Support of burst mode

Support for burst mode defined in IEC 62453-309:2016, 6.2 shall be implemented as follows. A subscription of device initiated data transfer can be requested by calling `ISubscription::<SubscriptionInitialization()>`. The Communication Channel may detect if the device is already in burst mode. In HART 5 this can be detected only when HART burst frames are received from the device. In HART version 6 or later the burst mode can be detected using HART command 105. If HART Burst frames are received, the device is in burst mode and `BurstModeDetected` property of `HartSubscribeResponse` is set to `TRUE`. This means that device DTM will start to receive burst messages via `SubscriptionCallback` mechanism. In case that no burst messages were received, `BurstModeDetected` property is set to `FALSE`. It is up to the device DTM to set the device into burst mode. Then the device DTM may call `ISubscription::<SubscriptionInitialization()>` again in order to receive burst messages.

In order to unsubscribe, the device DTM calls `ISubscription::<SubscriptionTermination()>`. Device DTM will not receive any more burst information via `SubscriptionCallback` mechanism. The Communication Channel does not switch off the burst mode in the device. The device DTM may switch burst mode on or off by using normal `TransactionRequests` (HART command 109). This is independent of the subscription.

The sequence is described in Figure 5.




Figure 5 – Device-initiated data transfer with burst mode

## 6.2 Device addressing

DTMs shall support device addressing as defined in IEC 62453-309:2016, 6.3.

## 6.3 Support of scanning

DTMs shall support the `IScanning` interface.

## 6.4 Support of extended command numbers

DTMs shall support the extended command numbers as defined in IEC 62453-309:2016, 6.4.

## 6.5 Support for handling of communication failures and time-outs

DTMs shall support the handling of communication failures and time-outs as defined in IEC 62453-309:2016, 6.5.

## 6.6 Support for handling of Delayed Responses

DTMs shall support the handling of Delayed Responses as defined in IEC 62453-309:2016, 6.6.

## 6.7 Support for topologies with mixed HART protocols

DTMs shall support topologies with mixed HART protocols as defined in IEC 62453-309:2016, 6.7.

The implementation for the protocol check for the method `ValidateAddChild()` is:

- If no correlation can be found in the specific bus categories, the parent DTM shall answer the `EndValidateAddChild()` call with `FALSE`.
- If a correlation can be found, the `EndValidateAddChild()` call shall be answered with `TRUE`. During the `ChildAdded()` call, the parent DTM sets the `ActiveProtocols` property in the Child DTM.

## 6.8 Support for nested communication with multiple gateways

DTMs shall support nested communication with multiple gateways as defined in IEC 62453-309:2016, 6.8.

## 6.9 Support for topologies with WirelessHART

DTMs shall support topologies with WirelessHART as defined in IEC 62453-309, 6.9.

## 6.10 Transparent gateways

### 6.10.1 General

HART supports various types of physical layers like HART FSK, HART over Ethernet, HART over 485, HART over Infrared, etc. Because of this range of physical layers, it can be possible that a HART Network contains a gateway device which connects nodes supporting different physical layers. One example for such gateway device is the Wireless Adapter which allows connecting HART FSK devices in a WirelessHART network.

Another example for such gateway device is a HART Infrared Adapter, which may connect a HART FSK device to a HART Infrared Network.

It is possible that some adapters appear to be transparent, i.e. they do not act as HART Nodes on the network. They act as physical layer adapter, impersonating the device they are connected to. Although, currently there are no Transparent Gateways in the market, the HART protocol does not restrict the possibility of such Transparent Gateways/Converters in the network.

IEC TR 62453-42 requires that such transparent gateways/adapters are represented by a DTM.

With the definition of new protocol Ids for each of the HART types in order to create a topology, it is required that DTMs are available for each of the participating nodes in the HART network.

The following scenarios explain the behaviour of such gateway devices in a FDT Topology.

### 6.10.2 Scenario 1 – Manual topology creation

During manual topology creation, the HART Infrared Communication DTM only supports HART IR DTMs to be added to the topology. In this case, to add a HART FSK DTM to the

Topology, there shall be a Gateway DTM (HART Infrared to HART FSK DTM), though, the adapter is transparent.

It is mandatory that every participating node in the physical network shall have a DTM available. Without this, it is not possible to create a valid topology.

### 6.10.3 Scenario 2 – Topology scan and add

In case of scan topology, the Communication DTM may not detect the adapter (as it is transparent), and hence the scan result will not return the adapter. Instead, the scan result contains the HART FSK Device. However, the HART FSK device cannot be added to the topology due to different Protocol Ids.

In such scenario, unless the adapter acts as a HART node in the network, it is not possible to create the network topology.

## 7 Protocol specific usage of general datatypes

Table 6 shows how general datatypes are used with IEC 61784 CPF 9 devices.


**Table 6 – Protocol specific usage of general datatypes**

Attribute	Description for use
ProtocolId	See IEC 62453-309:2016, Table 1
PhysicalLayer	See IEC 62453-309:2016, Table 2
ApplicationDomain/ SemanticId	The application Domain is FDT_HART The SemanticId shall be built as described in 5.3.3.

## 8 Protocol specific common datatypes

### 8.1 HartDeviceAddress datatype

Figure 6 and Table 7 describe the datatype for addressing information used with protocol ID HART\_Basic, HART\_FSK, HART\_Wireless, HART\_RS485 and HART\_Infrared.



**Used in:**

- INetworkData::GetAddressInfo()
- INetworkData::SetDeviceAddress()
- ICommunication::BeginConnect()
- ICommunication::EndConnect()
- IScanning::EndScanRequest()


**Figure 6 – HartDeviceAddress datatype**

**Table 7 – HartDeviceAddress datatype**

Property	Description
ShortAddress	This property is intended to store the short address (see CMD#0) information.
AddressingMode	With this property the parent DTM defines which address property shall be used for the connection.  The possible values of this enumeration are: <ul style="list-style-type: none"> <li>- ShortAddress</li> <li>- ShortTag</li> <li>- LongTag</li> <li>- LongAddress</li> </ul>
LongTag	This property is intended to store the LongTag (see CMD#20) information.
ShortTag	This property has stored the Tag (see CMD#13).
LongAddress	Long frame address information according to the HART specification (see Table 13)

**8.2 HartDeviceIpAddress datatype**

Figure 7 and Table 8 describe the datatype derived from HartDeviceAddress with additional address information for HART TCP and UDP devices (Used with Protocol ID HART\_IP).



**Used in:**

- INetworkData::GetAddressInfo()
- INetworkData::SetDeviceAddress()
- ICommunication::BeginConnect()
- ICommunication::EndConnect()
- IScanning::EndScanRequest()


**Figure 7 – HartDeviceIpAddress datatype**

**Table 8 – HartDeviceIpAddress datatype**

Property	Description
ShortAddress	(Inherited from HartDeviceAddress)
AddressingMode	(Inherited from HartDeviceAddress)
LongTag	(Inherited from HartDeviceAddress)
ShortTag	(Inherited from HartDeviceAddress)
IpAddress	This property stores a host name or an IP address conformant to IPv4 or IPv6 standard.
Port	[Optional] This property stores the port number.
LongAddress	Long frame address information according to the HART specification (see Table 13) □

**8.3 HartDeviceWirelessAddress datatype**

Figure 8 and Table 9 describe the datatype derived from HartDeviceAddress with additional address information for HART Wireless devices (Used with Protocol ID HART\_Wireless).



**Used in:**

- INetworkData::GetAddressInfo()
- INetworkData::SetDeviceAddress()
- ICommunication::BeginConnect()
- ICommunication::EndConnect()
- IScanning::EndScanRequest()


**Figure 8 – HartDeviceWirelessAddress datatype**

**Table 9 – HartDeviceWirelessAddress datatype**

Property	Description
ShortAddress	(Inherited from HartDeviceAddress)
AddressingMode	(Inherited from HartDeviceAddress)
LongTag	(Inherited from HartDeviceAddress)
ShortTag	(Inherited from HartDeviceAddress)
NetworkID	[Optional] This property stores the Network ID for a HART Wireless network.
LongAddress	Long frame address information according to the HART specification (see Table 13)□

## 9 Network management datatypes

The data needed for management of the network are exposed by the Device DTM in the INetworkData interface as HartNetworkData (see Figure 9).



### Used in:

INetworkData::GetNetworkDataInfo()

**Figure 9 – HartNetworkData datatype**

Table 10 describes the HART specific network data. This data is read only.

**Table 10 – HartNetworkData datatype**

Attribute	Description
HartRevision	This property will be used as a informative constant that documents the HART major revision as communicated in CMD#0.
PollingAddressRange	This property describes the range of the polling address.


## 10 Communication datatypes

### 10.1 General

The datatypes contain the address information and the communication data required to execute the respective request or to transport the response information.

### 10.2 HartConnectRequest datatype

The structure of the datatype HartConnectRequest is shown in Figure 10.



**Used in:**

ICommunication::BeginConnect()

**Figure 10 – HartConnectRequest datatype**


The properties of the datatype are described in Table 11.

**Table 11 – HartConnectRequest datatype**

Property	Description
Address	In order to establish a connection the DTM shall provide address information of the HART Device (see Table 10).
ProtocolId	Unique identifier of the HART protocol
SystemTag	Unique identification of DTM within the Frame Application
PreambleCount	[Optional] Provides a hint for the communication component about the number of preambles, required by the device type.
PrimaryMaster	[Optional] Provides a hint for a communication component that a DTM requires communication as primary or secondary master.
LongAddress	Long frame address information according to the HART specification (see Table 13)

**10.3 HartConnectResponse datatype**

The structure of the datatype HartConnectResponse is shown in Figure 11.



**Used in:**

ICommunication::EndConnect ()

**Figure 11 – HartConnectResponse datatype**

The properties of the datatype are described in Table 12.

**Table 12 – HartConnectResponse datatype**

Property	Description
PreambleCount	Contains the information about the currently used preambleCount.
PrimaryMaster	Contains the information about the current state of the master.
Address	Address information including ShortAddress, ShortTag, LongTag (see Table 7)
LongAddress	Long frame address information according to the HART specification (see Table 13)
CommunicationReference	Identifier for a communication link to a device

**10.4 HartLongAddress datatype**


The properties of the datatype are described in Table 13.

**Table 13 – HartLongAddress datatype**

Property	Description
Address1	1st byte of long address
Address2	2nd byte of long address
Address3	3rd byte of long address
Address4	4th byte of long address
Address5	5th byte of long address

**10.5 HartDisconnectRequest datatype**

The structure of the datatype HartDisconnectRequest is shown in Figure 12.



IEC

**Used in:**

ICommunication::BeginDisconnect()

**Figure 12 – HartDisconnectRequest datatype**


The properties of the datatype are described in Table 14.

**Table 14 – HartDisconnectRequest datatype**

Property	Description
CommunicationReference	Identifier for a communication link to a device
AbortPendingTransactions	Indicates whether pending transactions shall be aborted.

**10.6 HartDisconnectResponse datatype**

The structure of the datatype HartDisconnectResponse is shown in Figure 13.



IEC

**Used in:**

ICommunication::EndDisconnect()

**Figure 13 – HartDisconnectResponse datatype**


The properties of the datatype are described in Table 15.

**Table 15 – HartDisconnectResponse datatype**

Property	Description
CommunicationReference	Identifier for a communication link to a device

**10.7 HartTransactionRequest datatype**

The structure of the datatype HartTransactionRequest is shown in Figure 14.



**Used in:**

ICommunication::BeginCommunicationRequest ()

**Figure 14 – HartTransactionRequest datatype**


The properties of the datatype are described in Table 16.

**Table 16 – HartTransactionRequest datatype**

Property	Description
CommandNumber	HART command number
CommunicationData	Communication data to be transferred to the device
Id	[Optional] Identifier for a single Transaction Request

**10.8 HartTransactionResponse datatype**

The structure of the datatype HartTransactionResponse is shown in Figure 15.



**Used in:**

ICommunication::EndCommunicationRequest ()

**Figure 15 – HartTransactionResponse datatype**

The properties of the datatype are described in Table 17.

**Table 17 – HartTransactionResponse datatype**

Property	Description
CommunicationReference	Identifier for a communication link to a device
ErrorInformation	[Optional] Description of a fieldbus protocol independent error occurred during communication
Id	[Optional] Identifier of the corresponding Transaction Request
CommandNumber	HART command number
Status	Status information according to the HART specification
CommunicationData	Communication data received from the device

### 10.9 HartStatus datatype


The properties of the datatype are described in Table 18.

**Table 18 – HartStatus datatype**

Property	Description
DeviceStatus	Second status byte returned in HART command responses
CommandStatus	[Optional] Command Response Code, computed according HART specification from the first status byte returned in HART command responses
CommunicationStatus	[Optional] Communication error code, computed according HART specification from the first status byte returned in HART command responses.

### 10.10 HartAbortMessage datatype

The structure of the datatype HartAbortMessage is shown in Figure 16.



IEC

#### Used in:

AbortCallback ()

**Figure 16 – HartAbortMessage datatype**


The properties of the datatype are described in Table 19.

**Table 19 – HartAbortMessage datatype**

Property	Description
Details	Details about the cause and source of the Abort
CommunicationReference	Identifier for a communication link to a device

### 10.11 HartSubscribeRequest datatype

The structure of the datatype HartSubscribeRequest is shown in Figure 17.



**Used in:**

ISubscription::BeginSubscriptionInitialization ()

**Figure 17 – HartSubscribeRequest datatype**


The properties of the datatype are described in Table 20.

**Table 20 – HartSubscribeRequest datatype**

Property	Description
CommunicationReference	Identifier for a communication link to a device

### 10.12 HartSubscribeResponse datatype

The structure of the datatype HartSubscribeResponse is shown in Figure 18.



**Used in:**

ISubscription::EndSubscriptionInitialization ()

**Figure 18 – HartSubscribeResponse datatype**


The properties of the datatype are described in Table 21.

**Table 21 – HartSubscribeResponse datatype**

Property	Description
BurstModeDetected	Indicates whether the Communication Channel has detected that the device is already in burst mode.
CommunicationReference	Identifier for a communication link to a device

### 10.13 HartUnsubscribeRequest datatype

The structure of the datatype HartSubscribeRequest is shown in Figure 19.



**Used in:**

ISubscription::BeginSubscriptionTermination ()

**Figure 19 – HartUnsubscribeRequest datatype**


The properties of the datatype are described in Table 22.

**Table 22 – HartUnsubscribeRequest datatype**

Property	Description
CommunicationReference	Identifier for a communication link to a device

**10.14 HartUnsubscribeResponse datatype**

The structure of the datatype HartUnsubscribeResponse is shown in Figure 20.



**Used in:**

ISubscription::EndSubscriptionTermination ()

**Figure 20 – HartUnsubscribeResponse datatype**

The properties of the datatype are described in Table 23.

**Table 23 – HartUnsubscribeResponse datatype**

Property	Description
CommunicationReference	Identifier for a communication link to a device

**11 Datatypes for process data information**


**11.1 General**

The process data information of a DTM represents the “Device Variables”, available on that device. A Process Control System (i.e. some external system which monitors values on a device) can query the DTM’s process data information via the IProcessData interface. The process data describes the process values such that an external system can use the

information to access and interpret the values from the device during normal device runtime. The external system might not use FDT to access the values.

### 11.2 HartIOSignalInfo datatype

The structure of the datatype HartIOSignalInfo is shown in Figure 21.



**Used in:**

IProcessData::EndGetProcessData ()

**Figure 21 – HartIOSignalInfo datatype**

Table 24 shows which properties of IOSignalInfo datatype should be provided or requires HART specific usage.

**Table 24 – Usage of IOSignalInfo datatype**

Property	Description
SignalType	SignalType is always Input
SemanticInfos	See Table 5 for assigned variables
DeviceDataRef	Reference to the related variable, exposed in IDeviceData
UnitInfoRef	Reference to the variables providing range information
RangeInfoRefs	Reference to an enumeration variable describing the unit information

The properties of the HartIOSignalInfo datatype are described in Table 25.

**Table 25 – HartIOSignalInfo datatype**

Property	Description
DeviceVariableAssignment	Constant enumeration value that can take following values <ul style="list-style-type: none"> <li>– unassigned: The dynamic variable is not assigned to process variable and can only be accessed using the indexed approach.</li> <li>– PV: Variable is assigned to the PV process variable</li> <li>– SV: Variable is assigned to the SV process variable</li> <li>– TV: Variable is assigned to the TV process variable</li> <li>– QV: Variable is assigned to the QV process variable</li> </ul>
DeviceVariableCode	Constant that specifies the device specific variable code (see [7] Table 34). Because of compatibility reasons to other FDT versions (e.g. IEC 62453-41), this variable could be set to the value 252 that stands for "unknown".


## 12 Device identification datatypes

### 12.1 General

This clause defines identification relevant protocol specific datatypes.

### 12.2 HartDeviceScanInfo datatype

The structure of the datatype HartDeviceScanInfo is shown in Figure 22.



#### Used in:

IDtmScanning::EndScanRequest ()

**Figure 22 – HartDeviceScanInfo datatype**

The properties of the datatype are described in Table 26.

**Table 26 – HartDeviceScanInfo datatype**

Property	Description
Address	Address information of the scanned device
HartMajorRevisionNumber	HART protocol revision
ManufacturerIdentificationCode	Manufacturer specific code registered at the HART Foundation
DeviceTypeCode	Device type specific code registered at the HART Foundation
SoftwareRevision	Revision of the device embedded software
HardwareRevisionLevel	Hardware revision of the device
PhysicalSignalingCode	Physical signaling code
DeviceId	Individual serial number of the device
DeviceRevisionLevel	Device Command Revision Level supported by the device
DeviceFlags	Device Flags
ScannedPhysicalLayer	Determines the physical medium for which the scan information is provided.
ManufacturerSpecificExtension	[Optional] Can be used by DTM for a vendor specific device identification information, e.g. by combining a number of device parameter values into one string value. This can be used to identify a specific device variant.

Table 27 defines the semantics of HartDeviceScanInfo properties and how this information is mapped to predefined properties of DeviceScanInfo.

The Communication Channel will read these values from the device and writes them to the properties of HartDeviceScanInfo.

IECNORM.COM : Click to view the full PDF of IEC TR 62453-52-90:2017