

TECHNICAL REPORT

Mnemonics and designations of symbols for measuring relays, instruments and related device

IECNORM.COM : Click to view the full PDF of IEC TR 62711:2011



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

IECNORM.COM : Click to view the full PDF of IEC TR 62711:2011

TECHNICAL REPORT

Mnemonics and designations of symbols for measuring relays, instruments and related device

IECNORM.COM : Click to view the full PDF of IEC TR 62711:2011

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

T

ICS 01.080.40; 29.200

ISBN 978-2-88912-691-0

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	6
3 Terms and definitions	6
4 Measuring relay symbols	6
5 Measuring instruments	6
6 Mnemonics and designations for measuring relays and instruments	7
6.1 Overview	7
6.2 Measuring relays.....	7
6.3 Power system measuring instruments.....	17
Bibliography.....	24
Figure 1 – The general symbol for a measuring relay in IEC 60617.....	5
Figure 2 – The general symbols for a measuring instrument in IEC 60617	5
Table 1 – Measuring relays – Prefix.....	7
Table 2 – Measuring relays – Suffix	7
Table 3 – Measuring relays – General.....	8
Table 4 – Measuring relays – Current	9
Table 5 – Measuring relays – Voltage	10
Table 6 – Measuring relays – Frequency.....	10
Table 7 – Measuring relays – Impedance.....	11
Table 8 – Measuring relays – Power.....	11
Table 9 – Measuring relays – Phase	12
Table 10 – Measuring relays – Other quantities	12
Table 11 – Measuring relays – Other fault phenomenon.....	12
Table 12 – Measuring relays – Pilot wire relay	13
Table 13 – Measuring relays – Carrier pilot relay	13
Table 14 – Measuring relays – Microwave relay.....	14
Table 15 – Measuring relays – Calculation type	14
Table 16 – Measuring relays – Apparatus protection and control	14
Table 17 – Measuring relays – Other type.....	15
Table 18 – Measuring relays – Power system control.....	17
Table 19 – Measuring instruments – Power system measuring instruments	18

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MNEMONICS AND DESIGNATIONS OF SYMBOLS FOR MEASURING RELAYS, INSTRUMENTS AND RELATED DEVICE

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 62711, which is a technical report, was prepared by IEC technical committee 3: Information structures, documentation and graphical symbols.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
3/1029A/DTR	3/1041/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

IECNORM.COM : Click to view the full PDF of IEC TR 62711:2011

MNEMONICS AND DESIGNATIONS OF SYMBOLS FOR MEASURING RELAYS, INSTRUMENTS AND RELATED DEVICE


1 Scope

This Technical Report provides recommendations for consistent use of mnemonics and qualifying symbols to be applied to symbols representing devices used in systems for monitoring, protection, switching, and controlling of apparatus in electrical substations, generating stations, power utilization and conversion facilities, and equipment designed for automatic protection of power systems. The recommendations are intended for designers, manufacturers and engineers of such systems.

For symbols of measuring relay and measuring instrument, it is intended to serve two purposes, namely:

- Give a review of standardized designations (as defined in this report);
- Limit the range of possible variants (after final standardization and introduction in IEC 60617).


Symbols for measuring relays are symbols in which the functional behaviour of an element, mostly because of its complexity, is described by qualifying symbols e.g. IEC 60617-S00328 (2001-07), IEC 60617-S00337 (2001-07), particularly by referring to supporting documentation; the relevant rules and explanations are to be found in IEC 60617 in the application notes associated with the symbols, e.g. IEC 60617-S00327 (2001-07) (A00091 through A00094).




IEC 60617-S00327 (2001-07):
Measuring relay

Figure 1 – The general symbol for a measuring relay in IEC 60617


Symbols for indicating, recording or integrating instruments are symbols in which the functional behaviour of an element is fully described by standardized means. The relevant rules and explanations are to be found in IEC 60617 in the application notes associated with the symbols IEC 60617-S00910 (2001-07), IEC 60617-S00911 (2001-07) and IEC 60617-S00912 (A00144 through A00147).



IEC 60617-S00910 (2001-07):
Indicating instrument



IEC 60617-S00911 (2001-07):
Recording instrument



IEC 60617-S00912 (2001-07):
Integrating instrument

Figure 2 – The general symbols for a measuring instrument in IEC 60617

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60617, *Graphical symbols for diagrams*

ISO/IEC 81714-1, *Design of graphical symbols for use in the technical documentation of products – Part 1: Basic rules*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

protection relay

measuring relay which, either solely or in combination with other relays, is a constituent of a protection equipment

[IEC 60050-448:1995, 448-11-02]

4 Measuring relay symbols

Power systems are extremely complicated electrical networks that are geographically spread over very large areas. The power systems are so complex that a complete conventional diagram showing all the connections is impractical. There is some concise way of communicating the basic arrangement of power system components. This is done by using diagrams with universally accepted symbols in IEC 60617.

When measuring relay symbols are required, pick the general symbol IEC 60617-S00327 (2001-07) (see Figure 1), and then combine it with one or more appropriate supplementary symbols.

Some devices, especially newer devices, may not have universally accepted symbols. These devices could be represented in a number of ways, usually a matter of personal choice. In such instances, the symbol is usually accompanied by a verbal description.

When an appropriate symbol does not exist, either the general symbol IEC 60617-S00327 (2001-07) should be applied, or a symbol may be constructed following the rules of IEC 60617 and ISO/IEC 81714-1.

5 Measuring instruments

When measuring instrument symbols are required, pick the general symbols from among IEC 60617-S00910 (2001-07), IEC 60617-S00911 (2001-07) and IEC 60617-S00912 (2001-07) according to the function, that is, indicating, recording and integrating (see Figure 1). Then the asterisk within the symbol is replaced with the letter symbol or the graphical symbol.

The replacing symbol is related to the information displayed by the instrument regardless of the means used to obtain the information.

6 Mnemonics and designations for measuring relays and instruments

6.1 Overview

Where in Tables 1 to 19 below the letter “M” is shown in the second column, this means that the designation concerned may be used in measuring relay symbols. A letter “I” in the second column means that the designation concerned may be in indicating instrument symbols. A letter “R” in the second column means that the designation concerned may be in recording instrument symbols. A letter “G” in the second column means that the designation concerned may be in integrating instrument symbols. In these tables, the English descriptions appear in the fourth column, because in many cases designations are derived from terms in English.

6.2 Measuring relays

Tables 1 to 18 present the mnemonics and designations for measuring relays.

Table 1 – Measuring relays – Prefix

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
O	-	over	Actuating when the characteristic quantity is higher than the setting value.	> IEC 60617-S0 0108(2001-07)
U	-	under	Actuating when the characteristic quantity is lower than the setting value.	< IEC 60617-S0 0109(2001-07)
B	-	band	Actuating when the characteristic quantity is either higher than a given high setting or lower than a given low setting.	> < IEC 60617-S0 0110(2001-07)
R	-	reverse	Actuating when the characteristic quantity is contrary or opposite to what has been mentioned.	N/A
H	-	high or high speed	Actuating at high speed or other high level of a measured value or indicating signal.	N/A

Table 2 – Measuring relays – Suffix

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
B	-	balance	Relay which operates by comparing the magnitudes of two similar input quantities. NOTE The balance may be affected by counteracting electromagnetic forces on a common armature, or by counteracting magnetomotive forces in a common magnetic circuit, or by similar means, such as springs, levers, etc.	N/A
V	-	with voltage restraint	Method of restraining the operation of a relay by means of a voltage input which opposes the typical response of the relay to other inputs.	N/A
NOTE With regard to suffixes, designation variables as described in IEC 60909-0 and IEC 60909-3 may be used as a suffix.				

Table 3 – Measuring relays – General

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
D	M	<u>D</u> irectional relay	Relay that responds to the relative phase position of a current with respect to another current or voltage reference. NOTE the above definition which applies basically to a single phase directional relay may be extended to cover a polyphase directional relay.	 IEC 60617-S0 0104 (2001-07)
Df	M	<u>D</u> ifferential relay	Measuring relay having two windings so connected in different parts of a circuit that the relay will operate if the difference between the currents in the two circuits exceeds a specified value. (IEC 60050-811:1991, 811-31-16)	 IEC 60617-S0 0331 (2001-07)
RDf	M	Ratio (Percentage) <u>D</u> ifferential relay	Differential relay which functions when the difference between two quantities of the same nature exceeds a fixed ratio (percentage) of the smaller quantity.	 IEC 60617-S0 0332(2001-07)
G	M	<u>G</u> round relay, Earth fault relay	Relay which operates when a failure of insulation to earth is detected in the equipment or circuits protected. (IEC 60050-811:1991, 811-31-15)	 IEC 60617-S0 0200(2001-07)
DG	M	<u>D</u> irectional <u>G</u> round relay	Directional relay used primarily to detect single-phase-to-ground faults, but also sensitive to double-phase-to-ground faults. NOTE This type of relay is usually operated from the zero-sequence components of voltage and current, but is sometimes operated from negative-sequence quantities.	N/A
DfG	M	<u>D</u> ifferential <u>G</u> round relay	Differential relay used primarily to detect internal ground faults of generators.	N/A
S	M	<u>S</u> hort-circuit relay	Device that operates with no intentional time delay when the current exceeds a preset value.	N/A
SG	M	<u>S</u> electing <u>G</u> round relay	Measuring relay that, by comparing the magnitudes of the zero sequence currents in two parallel lines, will identify a line having ground fault.	N/A
SS	M	<u>S</u> electing <u>S</u> hort-circuit relay	Measuring relay that, by comparing the magnitudes of the currents in two parallel lines, will identify a line having a short-circuit fault.	N/A
DS	M	<u>D</u> irectional <u>S</u> hort-circuit relay	Directional relay used primarily to detect short-circuit faults.	N/A
TT	M	<u>T</u> ransfer <u>T</u> rip relay	Form of remote trip in which a communication channel is used to transmit a trip signal from the relay location to a remote location.	N/A

Table 4 – Measuring relays – Current


MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
C	M	<u>C</u> urrent relay	Actuating when the current quantity is equal to a setting value.	N/A
BC	M	<u>B</u> and <u>C</u> urrent relay	Current relay with maximum and minimum setting.	 IEC 60617-S0 0345(2001-07)
CB	M	<u>C</u> urrent <u>B</u> alance relay	Balance relay that operates by comparing the magnitudes of two current inputs.	N/A
OC	M	<u>O</u> ver <u>C</u> urrent relay	Measuring relay which operates when the value of the current exceeds the setting (operating value) of the relay. (IEC 60050-811:1991, 811-31-12)	N/A
DCG	M	<u>D</u> irect <u>C</u> urrent <u>G</u> round relay	Device that functions when the d.c. input current exceeds a predetermined value, and in which the input current and operating time are inversely related through a substantial portion of the performance range.	N/A
OCG	M	<u>O</u> ver <u>C</u> urrent <u>G</u> round relay	Device that functions when the net (phasor sum) current flowing in the phase and neutral conductors or the total current flowing in the normal neutral to ground connection exceeds a predetermined value.	N/A
OCV	M	<u>O</u> ver <u>C</u> urrent relay with <u>V</u> oltage restraint	Overcurrent relay which is used primarily to protect a generator. The function of the voltage is to prevent or moderate over current operation until the generator voltage is reduced by a fault.	N/A
DOC	M	<u>D</u> irectional <u>O</u> ver <u>C</u> urrent relay	Relay consisting of an overcurrent unit and a directional unit combined to operate jointly.	N/A
UC	M	<u>U</u> nder <u>C</u> urrent relay	Relay that operates when the current is less than a predetermined value.	N/A
RC	M	<u>R</u> everse <u>C</u> urrent relay	Relay that operates on a current flow in a direct-current circuit in a direction opposite to a predetermined reference direction.	 IEC 60617-S0 0339(2001-07)
CL	M	<u>C</u> urrent <u>L</u> imiting relay	Relay specifying a range of currents between the threshold current and the rated interrupting current within which current limitation occurs.	N/A

Table 5 – Measuring relays – Voltage


MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
V	M	<u>V</u> oltage relay	Relay that responds to voltage.	N/A
VB	M	<u>V</u> oltage <u>B</u> alance relay	Balance relay which operates by comparing the magnitudes of two voltage inputs.	N/A
OV	M	<u>O</u> ver <u>V</u> oltage relay	Measuring relay which operates when the value of the current exceeds the setting (operating value) of the relay. (IEC 60050-811:1991, 811-31-13)	N/A
UV	M	<u>U</u> nder <u>V</u> oltage relay	Measuring relay which operates when the value of the voltage is equal to or less than the setting (operating value) of the relay.	 IEC 60617-S0 0344(2001-07)
OVG	M	<u>O</u> ver <u>V</u> oltage <u>G</u> round relay	Relay that operates when its input zero sequence voltage exceeds a predetermined value.	N/A
VDf	M	<u>V</u> oltage <u>D</u> ifferential relay	Measuring relay which intended to protect grounded-wye shunt capacitor banks.	N/A
SOG	M	<u>S</u> elective <u>O</u> ver voltage <u>G</u> round relay	Relay that determines the fault feeders of the high impedance ground fault by shedding the feeders of the bus in predetermined order. It operates when the zero sequence voltage of the bus exceeds the specific value for a specific time.	N/A
UVC	M	<u>U</u> nder <u>V</u> oltage relay with <u>C</u> urrent compensation	Undervoltage relay whose setting (operating) value is varied by the magnitude of the current.	N/A

Table 6 – Measuring relays – Frequency

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
F	M	<u>F</u> requency relay	Relay that responds to the frequency of an alternating electrical input quantity.	N/A
Of	M	<u>O</u> ver frequency relay	Relay that responds to the frequency of an electrical quantity, operating when the frequency or rate of change of frequency exceeds a predetermined value.	N/A
Uf	M	<u>U</u> nder frequency relay	Relay that responds to the frequency of an electrical quantity, operating when the frequency or rate of change of frequency is less than a predetermined value.	N/A

Table 7 – Measuring relays – Impedance


MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
Z	M	Distance relay; Impedance relay	Relay that functions when the circuit admittance, impedance or reactance increases or decreases beyond a predetermined value.	 IEC 60617-S0 0346(2001-07)
DZ	M	<u>D</u> irectional <u>D</u> istance relay	Relay consisting of a distance unit and a directional unit combined to operate jointly.	(S00346)
DGZ	M	<u>D</u> irectional <u>G</u> round distance relay	Relay consisting of a ground distance unit and a directional unit combined to operate jointly.	(S00346)
OM	M	<u>O</u> ffset <u>M</u> ho relay	Distance relay for which the inherent operating characteristic on an R-X diagram is a circle which passes through the origin. NOTE The operating characteristics may be described by the equation $Z = K \cdot \cos(\theta - \alpha)$ where K and α are constants and θ is the phase angle by which the input voltage leads the input current.	(S00346)
CZ	M	<u>C</u> ontinuous curve distance-time relay	Distance relay in which the operating time is in proportion to the impedance.	(S00346)

Table 8 – Measuring relays – Power


MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
P	M	<u>P</u> ower relay	Relay that responds to a suitable product of voltage and current in an electric circuit.	N/A
Q	M	Reactive power relay	Power relay that responds to reactive power.	N/A
RP	M	<u>R</u> everse <u>P</u> ower relay	Device that operates on a predetermined value of power flow in a given direction such as reverse power flow resulting from the motoring of a generator upon loss of its prime mover.	N/A
UP	M	<u>U</u> nder <u>P</u> ower relay	Relay that functions when the power flow decreases below a predetermined value.	 IEC 60617-S0 0340(2001-07)

Table 9 – Measuring relays – Phase

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
ϕ	M	Phase comparison relay	Form of pilot protection that compares the relative phase-angle position of specified currents at the terminals of a circuit.	N/A
ϕB	M	Phase <u>b</u> alance relay	Relay that responds to differences between quantities of the same nature associated with different phases of a normally balanced polyphase circuit.	N/A
ϕSI	M	Phase <u>s</u> elector relay	Programming relay whose function is to select the faulted phase or phases thereby controlling the operation of other relays or control devices.	N/A

Table 10 – Measuring relays – Other quantities

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
Fl	M	<u>F</u> low relay	Relay that responds to a rate of fluid flow.	N/A
ArFl	M	<u>A</u> ir <u>F</u> low relay	Relay that responds to a rate of air flow.	N/A
Pr	M	<u>P</u> ressure relay	Relay that responds to liquid or gas pressure.	N/A
Po	M	<u>P</u> osition relay	Relay that responds to a position.	N/A
T	M	<u>T</u> emperature relay	Relay whose operation is caused by specified external temperature.	N/A
Th	M	<u>T</u> hermal relay	Relay whose operation is caused by heat developed within the relay as a result of specified external conditions.	N/A
v	M	<u>V</u> elocity relay	Relay that responds to a velocity.	N/A
VC	M	<u>V</u> acuum relay	Relay that responds to a vacuum.	N/A
WL	M	<u>W</u> ater <u>L</u> evel relay	Relay that responds to a water level.	N/A
OS	M	<u>O</u> ver <u>S</u> peed relay	Form of protection that operates when the speed of rotation exceeds a predetermined value.	N/A
OSS	M	<u>O</u> ver-speed <u>s</u> witch	Switch that operates when the value of the speed exceeds the setting (operating value).	N/A

Table 11 – Measuring relays – Other fault phenomenon

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
Fc	M	<u>F</u> licker relay	Relay that functions to energize a circuit periodically or for fractions of specified time intervals, or that is used to permit intermittent acceleration.	N/A
OP	M	<u>O</u> pen <u>P</u> hase relay	Polyphase relay designed to operate when one or more input phases of a polyphase circuit are open.	N/A
SP	M	<u>S</u> udden <u>P</u> ressure relay	Relay that operates by the rate of rise in pressure of a liquid or gas.	N/A
RPH	M	<u>R</u> eversal <u>P</u> hase-sequence relay	Protection relay that prevents energizing of the protected equipment on the reversal of the phase sequence in a polyphase circuit.	N/A

Table 12 – Measuring relays – Pilot wire relay

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
Pw	M	<u>P</u> ilot <u>w</u> ire relay	Line protection that uses a communication channel as a means to compare electrical conditions at the terminals of a line. Traditionally the pilot wire protections use an auxiliary metallic circuit for the communicating means between relays at the circuit terminals. Today optical fibre or other means of communication may be used for the comparison between line ends.	N/A
PwD	M	<u>P</u> ilot <u>w</u> ire relay with <u>D</u> irectional comparison	Pilot wire relay in which the relative operating conditions of the directional units at the line terminals are compared to determine whether a fault is in the protected line section.	N/A
PwDf	M	<u>P</u> ilot <u>w</u> ire relay with <u>D</u> ifferential type	Pilot wire relay that by its design or application is intended to respond to the difference between current entering one terminal of a transmission line section and leaving another.	N/A
PwMo	M	<u>P</u> ilot <u>w</u> ire <u>M</u> onitoring relay	Auxiliary relay to a pilot wire relay that has as its function to verify that system or control circuit conditions conform to prescribed limits.	N/A
PwTT	M	<u>P</u> ilot <u>w</u> ire relay with <u>T</u> ransfer <u>T</u> rip	Pilot wire relay using a carrier pilot channel to transmit a trip signal from the relay location to remote location.	N/A

Table 13 – Measuring relays – Carrier pilot relay

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
Cr	M	<u>C</u> arrier pilot relay	Form of pilot communicating relay in which the communication means between relays is a carrier current channel.	N/A
CrRe	M	<u>C</u> arrier pilot <u>R</u> eceived relay	Relay that operates or restrained by a signal used in connection with carrier-current or direct-current (dc) in the pilot-wire.	N/A
CrD	M	<u>C</u> arrier pilot relay with <u>D</u> irectional comparison	Form of carrier pilot relay in which the relative operating conditions of the directional units at the line terminals are compared to determine whether a fault is in the protected line section.	N/A
Crφ	M	<u>C</u> arrier pilot relay with <u>Phase</u> (φ) comparison	Form of carrier pilot relay that compares the relative phase-angle position of specified currents at the terminals of a circuit.	N/A
CrTT	M	<u>C</u> arrier pilot relay with <u>T</u> ransfer <u>T</u> rip	Form of remote trip in which its carrier pilot channel is used to transmit a trip signal from the relay location to remote location.	N/A

Table 14 – Measuring relays – Microwave relay

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
M	M	<u>M</u> icrowave relay	Form of pilot communicating relay in which the communication means between relays is a beamed microwave radio channel.	N/A
MD	M	<u>M</u> icrowave relay with <u>D</u> irectional comparison	Form of microwave relay in which the relative operating conditions of the directional units at the line terminals are compared to determine whether a fault is in the protected line section.	N/A
Mφ	M	<u>M</u> icrowave relay with <u>φ</u> (phase) comparison	Form of microwave relay that compares the relative phase-angle position of specified currents at the terminals of a circuit.	N/A
MTT	M	<u>M</u> icrowave relay with <u>T</u> ransfer <u>T</u> rip	Form of remote trip in which its carrier pilot channel is used to transmit a trip signal from the relay location to remote location.	N/A

Table 15 – Measuring relays – Calculation type

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
∞/∞≈1	M	Balance relay	Relay actuating when the absolute value of the quotient of two kinds of characteristic quantity deviates from 1.	N/A
U/U≈1	M	Voltage balance relay	Balance relay which operates by comparing the magnitudes of two voltage inputs.	N/A

Table 16 – Measuring relays – Apparatus protection and control

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
BP	M	<u>B</u> us <u>P</u> rotection relay	Protection relay used primarily to detect bus bar faults. The relay whose function is to trip the breakers of all circuits connected to the bus bar.	N/A
FA	M	<u>F</u> ield <u>A</u> ccelerating relay	Relay that functions automatically to maintain the rotor current within the limits, when a motor accelerating to speeds above base speed, by controlling the excitation of the motor field.	N/A
FG	M	<u>F</u> ield <u>G</u> rounding relay	Protection relay used to detect ground faults in the field or exciter circuit of generators.	N/A
LyS	M	<u>L</u> ayer <u>S</u> hort circuit relay	Relay that used to detect short-circuits between windings in motors or generators.	 IEC 60617-S0 0347(2001-07)
LF	M	<u>L</u> oss-of-field relay, <u>L</u> oss-of-excitation relay	Device that functions on a given or otherwise abnormally value or failure of machine field current, or on an excessive value of the reactive component of rotor current in an alternating current machine indicating abnormal field excitation.	N/A


MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
BH	M	<u>B</u> uch <u>h</u> oltz's relay	Relay with two measuring devices (stages) intended to protect a power transformer. The first stage (slight failure contact) operates by gas to be generated by a slight accident and the second stage (serious failure contact) that operates by an oil flow to be generated by a sudden pressure rise.	 IEC 60617-S0 0352(2001-07)
Rec	M	<u>R</u> eclosing relay	Programmable relay whose function is to initiate the automatic reclosing of a circuit breaker.	 IEC 60617-S0 0353(2001-07)
Sy	M	<u>S</u> ynchronizing relay, Synchronism-check relay	Programmable relay whose function is to initiate the closing of a circuit breaker between two ac sources when the voltages of these two sources meet a predetermined relationship of magnitude, phase angle and frequency.	N/A
SO	M	<u>S</u> tep-out relay, Out-of-step relay	Protection relay that separates the appropriate parts of a power system, or prevents separation that might otherwise occur, in the event of loss of synchronism.	N/A
TIS	M	<u>T</u> ap <u>I</u> ncomplete <u>S</u> equence relay	Device that generally returns the equipment to the normal or off position and locks it out if the normal starting, operating or stopping sequence is not properly completed within a predetermined time. Applicable for control of tap changers on power transformers.	N/A
TOS	M	<u>T</u> ap <u>O</u> ut of <u>S</u> tep condition relay	Device that monitors and indicates that the main contact of a tap changer has reaches its highest or lowest position.	N/A
TF	M	<u>T</u> rip- <u>f</u> ree relay, Release-free relay	Auxiliary relay whose function is to open the closing circuit of an electrically operated switching device so that the opening operation can prevail over the closing operation.	N/A
OL	M	<u>O</u> ver <u>L</u> oad relay	Relay operative on excessive current, but not necessarily on short circuit, to cause and maintain the interruption of current flow to the device governed.	N/A

Table 17 – Measuring relays – Other type

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
2E	M	<u>T</u> wo <u>E</u> lement relay for overload and open-phase relay	Relay consisting of an overload unit and an open-phase unit.	N/A
3E	M	<u>T</u> hree <u>E</u> lement relay for overload, open-phase and phase-sequence reversal relay	Relay consisting of an overload unit, an open-phase unit and phase-sequence reversal unit.	N/A
ALT	M	<u>A</u> lternating relay	Relay designed for automatic duplex control of motors or other types of loads.	N/A
Ax	M	<u>A</u> uxiliary relay	Relay whose function is to assist another relay or control device in performing a general function by supplying supplementary actions.	N/A

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
B	M	<u>B</u> locking relay	Relay whose function is to render another relay or device ineffective under specified conditions	N/A
Con	M	<u>C</u> ontrol relay	Auxiliary relay whose function is to initiate or permit the next desired operation in a control sequence.	N/A
DI	M	<u>D</u> is <u>I</u> nterconnecting relay; System separation relay	Programmable relay whose function is to initiate the disconnection of a faulty part while operation and service in the rest of the system continue.	N/A
EL	M	<u>E</u> arth <u>L</u> eakage relay	Ground relay that is primarily used to a low voltage circuit.	N/A
FI	M/ I	<u>F</u> ault <u>I</u> ndicator	Device that presents a visual display, audible alarm, and so forth, when a failure or marginal condition exists.	N/A
K	M	<u>K</u> eep relay, Electric reset auxiliary relay	Relay that is so constructed that it remains in the picked-up condition even after the input quantity is removed: an independent electric input is required to reset the relay.	N/A
L	M	<u>L</u> ockout relay	Electrically reset or hand-reset auxiliary relay whose function is to hold associated devices inoperative until it is reset.	N/A
MgC	M	Electro <u>m</u> agnetic <u>C</u> ontrol relay	Electro-mechanical relay that operates principally by action of an electromagnetic element which is energized by the input quantity.	N/A
PI	M	<u>P</u> olarity relay	Relay which responds to the predetermined direct current polarity.	N/A
R	M	<u>R</u> eceiver relay	Auxiliary relay whose function is to respond to the output of a communications set such as an audio, carrier, radio, or microwave receiver.	N/A
R ϕ C	M	<u>R</u> everse-phase sequence <u>C</u> urrent relay, Negative-phase sequence Current relay	Relay that responds to the negative-phase-sequence component of a polyphase input current.	N/A
R ϕ V	M	<u>R</u> everse-phase sequence <u>V</u> oltage relay, Negative-phase sequence Voltage relay	Relay that responds to the negative-phase-sequence component of a polyphase input voltage.	N/A
PRO	M	<u>P</u> rotector relay	Relay whose function is to open a circuit for automatically disconnecting a transformer from a secondary network in response to predetermined electrical conditions on the primary feeder or transformer and for connecting a transformer to secondary network either through manual control or automatic control responsive to predetermined electrical conditions on the feeder and the secondary network. NOTE This is not the definition of the general term Protective relay.	N/A

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
ST	M	<u>S</u> tarting relay	Relay, actuated by current, voltage, or the combined effect of current and voltage, used to perform a circuit-changing function in the primary winding of a single-phase induction motor within a predetermined range of speed as the rotor accelerates; and to perform the reverse circuit- changing operation when the motor is disconnected from the supply line. One of the circuit changes that are usually performed is to open or disconnect the auxiliary-winding circuit.	N/A
TD	M	<u>T</u> ime-delay relay, Delayed relay	Relay having an assured or programmable time interval between being triggered and operating.	N/A
TL	M	<u>T</u> ime-lag relay, Timing relay	Auxiliary relay or relay unit whose function is to introduce one or more time delays in the completion of an associated function	N/A
PCM	M	<u>P</u> ulse <u>C</u> ode <u>M</u> odulation relay	Differential current relay operating on the deviation between time synchronized samples of digitalized measured current of the local end and the comparable measured current transmitted from a remote end of a power line.	N/A

Table 18 – Measuring relays – Power system control


MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
ARE	M	<u>A</u> utomatic <u>R</u> estoration <u>E</u> quipment	Equipment that performs actions or tasks for the automatic restoration of the power system in the event of a local disturbance.	N/A
AVR	M	<u>A</u> utomatic <u>V</u> oltage <u>R</u> egulator	Controller for automatic regulation of voltage by operation an OLTC (on load tap changer) on a power transformer as per pre-set voltage limits.	N/A
VQC	M	<u>V</u> oltage and <u>Q</u> <u>C</u> ontroller	Equipment that brings bus voltage close to its target voltage independently, by controlling the OLTC, capacitors and shunt reactors.	N/A

6.3 Power system measuring instruments

Table 19 presents the mnemonics and designations for measuring instruments.

Table 19 – Measuring instruments – Power system measuring instruments

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
θ	I	Thermo measuring equipment	Instrument intended to measure electrical resistance.	 IEC 60617-S0 0926(2001-07)
φ	I	Phase measuring equipment, Phase-angle measuring equipment	Instrument intended to measure the phase difference between two alternating electrical quantities of the same frequency, one of which is taken as the phase reference. [IEC 60050-300:2001, 313-01-13]	 IEC 60617-S0 0918(2001-07)
Ω	I	Resistance measuring equipment, ohm measuring equipment	Instrument intended to measure electrical resistance. [IEC 60050-300:2001, 313-01-09]	N/A
λ	I	Waveform measuring equipment	Instrument for measuring waveform.	 IEC 60617-S0 0921(2001-07)
A	I/R	current measuring equipment (<u>A</u> mmeter)	Instrument intended to measure the value of a current. [IEC 60050-300:2001, 313-01-01]	N/A
A_0	I	Zero phase current measuring equipment	Instrument intended to measure the value of a zero phase current of the three phase power system.	N/A
C	I	<u>C</u> ounter	Instrument in which a number is stored and to which a constant integer number is added algebraically depending on switching variables (variable quantities) at the counter input.	N/A
CD	I	<u>C</u> urrent <u>D</u> etector	Instrument intended to detect a current.	 IEC 60617-S0 0924(2001-07)
CO	I	pulse <u>C</u> ounter	Instrument for counting the number of edges on a digital signal.	N/A
CONV	I	<u>C</u> ON <u>V</u> erter	Device which changes the manner of representing information from one form to another.	 IEC 60617-S0 0213(2001-07)
$\cos \varphi$	I	Power-factor measuring instrument	Instrument intended to measure the ratio of the active to the apparent power in an electrical circuit. [IEC 60050-300:2001, 313-01-14]	 IEC 60617-S0 0917(2001-07)
D	I	<u>D</u> etector, Sensor	Device that monitors the presence of the something.	N/A

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
DV	I	<u>D</u> ifferential <u>V</u> oltage measuring equipment	Instrument intended to measure the value of a voltage between the different parts of a circuit.	 IEC 60617-S0 0923(2001-07)
Dy	I	<u>D</u> ynamo measuring equipment	Instrument for measuring a net power torque by which generation torque and rotational speed are measured.	N/A
FI	I/G	<u>F</u> low measuring equipment	Instrument for measuring the quantification of bulk fluid movement. It can be measured in a variety of way.	N/A
GD	I	<u>G</u> round leakage <u>D</u> etector, <u>G</u> rounding <u>D</u> etector earth leakage detector	Instrument intended to detect a leakage current to earth. [IEC 60050-300:2001, 313-01-24]	N/A
H	I/G	<u>h</u> our measuring equipment	Instrument for counting hour.	 IEC 60617-S0 0931(2001-07)
HLV	I	<u>H</u> igh <u>L</u> ow <u>V</u> oltage measuring equipment	Instrument intended to measure the minimum and maximum occurring voltage.	N/A
Hz	I	<u>F</u> requency measuring equipment	Instrument intended to measure the frequency of a periodic quantity. [IEC 60050-300:2001, 313-01-12]	 IEC 60617-S0 0919(2001-07)
L	I	<u>L</u> iquid level indicator	Device used to assist in the measurement of the level of liquid in a tank.	N/A
MA	I	<u>M</u> aximum <u>A</u> mpere measuring equipment	Instrument for measuring the maximum value of a current.	N/A
MA ₀	I	<u>M</u> aximum zero-phase <u>A</u> mpere measuring equipment	Instrument for measuring the maximum value of a zero phase current of the three phase power system.	N/A
MCO	I	<u>M</u> agnetic <u>C</u> ounter	Instrument for counting the number of edges on a digital signal by electro-magnetic coil.	N/A
MDA	I	<u>M</u> aximum- <u>D</u> emand current measuring equipment	Indicating device intended for indication of a maximum reach value of the current measurement that has occurred since the previous resetting of the device.	N/A
MDW	I	<u>M</u> aximum- <u>D</u> emand power measuring equipment	Indicating device intended for indication of a maximum reach value of the power measurement that has occurred since the previous resetting of the device.	N/A
MLT	I	<u>Mu</u> <u>L</u> tiplier	Device used for the expansion of the measurement range of the direct current volt measuring equipment.	N/A
MV	I	<u>M</u> aximum(<u>M</u> inimum) <u>V</u> oltage measuring equipment	Instrument for measuring the maximum (minimum) voltage.	N/A
MV ₀	I	<u>M</u> aximum zero-phase <u>V</u> oltage measuring equipment	Instrument for measuring the maximum zero-phase voltage.	N/A

MNEMONICS DESIGNATION	M//R/G	NAMES	DESCRIPTIONS	GRAPHICAL SYMBOLS
N	I	Tacho measuring equipment	Instrument for measuring the rotation speed of a shaft or disk, as in a motor or other machine.	 IEC 60617-S0 0927(2001-07)
NaCl	I	salt measuring equipment, salinity measuring equipment	Instrument for measuring salinity.	 IEC 60617-S0 0925(2001-07)
OL	I	Oil Level indicator, Oil Level measuring equipment, Oil gauge	Instrument for measuring oil level.	N/A
OSC	I	OSCilloscope	Instrument primarily for making visible the instantaneous value of one or more rapidly varying electrical quantities as a function of time or of another electrical or mechanical quantity.	 IEC 60617-S0 0922(2001-07)
PI	I	(tap) Position Indicator	Electrical, mechanical or electromechanical device for indicating the tap position of a tap-changer. [IEC 60050-421:1991, 421-12-03]	N/A
PG	I	Pressure Gauge	Instrument is used to measure the liquid or gas pressure.	N/A
PS	I	Phase-Sequence indicator	Instrument intended to indicate, in a polyphase system, the sequence in which the instantaneous voltages of the phase conductors reach their maximum values. [IEC 60050-300:2001, 313-01-21]	N/A
RTD	I	Resistance Temperature Detector	Temperature detecting device using resistance.	N/A
RTh	I	Resistance Thermo measuring equipment	Thermo measuring equipment by resistance.	N/A
SC	I	Search Coil, Exploring coil	Device for measuring eye movement	N/A
Sh	I	Shunt	Resistor connected in parallel with the current circuit of a measuring instrument in order to extend its measuring range. [IEC 60050-300:2001, 313-09-04]	 IEC 60617-S0 0564(2001-07)
SI	I	fault Selection Indicator	Instrument that help reduce fault-finding time so that power can be restored quickly after a fault occurs.	N/A
sin φ	I	Reactive-factor measuring equipment	Instrument for measuring reactive factor. It is provided with a scale graduated in reactive factor.	N/A
SSG	I	Speed Signal Generator	Instrument for measuring the turbine rotational speed.	N/A