

TECHNICAL SPECIFICATION

**Classification of environmental conditions –
Part 4-3: Guidance for the correlation and transformation of environmental
condition classes of IEC 60721-3 to the environmental tests of IEC 60068 –
Stationary use at weatherprotected locations**

IECNORM.COM : Click to view the full PDF of IEC TS 60721-4-3:2023



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IECNORM.COM : Click to view the full PDF IEC 607214-3:2023

TECHNICAL SPECIFICATION

**Classification of environmental conditions –
Part 4-3: Guidance for the correlation and transformation of environmental
condition classes of IEC 60721-3 to the environmental tests of IEC 60068 –
Stationary use at weatherprotected locations**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 19.040

ISBN 978-2-8322-7300-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 General	7
4.1 General remarks concerning IEC 60721-3-3.....	7
4.2 General remarks concerning the IEC 60068-2 series	7
4.3 Recommended test procedures and severities	7
4.4 Environmental tests for in-use classes	7
4.5 Test durations.....	8
4.6 Ambient	8
5 Climate conditions, classes 3K20 to 3K24 from IEC 60721-3-3.....	8
5.1 Class 3K20 (fully air-conditioned enclosed locations).....	8
5.2 Class 3K21 (continuously temperature-controlled enclosed locations).....	8
5.3 Class 3K22 (temperature-controlled enclosed locations).....	10
5.4 Class 3K23 (enclosed locations having no temperature or humidity control).....	12
5.5 Class 3K24 (enclosed locations having neither temperature nor humidity control)	14
6 Special climate conditions, classes 3Z12 to 3Z14 from IEC 60721-3-3.....	16
7 Biological conditions, classes 3B1 to 3B3 from IEC 60721-3-3.....	16
8 Mechanical conditions, classes 3M10 to 3M12 from IEC 60721-3-3	17
Annex A (informative) Interdependence of air temperature, relative air humidity, and absolute air humidity.....	18
Bibliography.....	19
Figure A.1 – Climatogram of interdependence of air temperature, relative air humidity, and absolute air humidity.....	18
Table 1 – Class 3K21 (continuously temperature-controlled enclosed locations).....	8
Table 2 – Class 3K22 (temperature-controlled enclosed locations)	10
Table 3 – Class 3K23 (enclosed locations having no temperature or humidity control).....	12
Table 4 – Class 3K24 (enclosed locations having neither temperature nor humidity control).....	14
Table 5 – Class 3Z12 to 3Z14	16
Table 6 – Class 3B1 to 3B3	16
Table 7 – Class 3M10 to 3M12.....	17

INTERNATIONAL ELECTROTECHNICAL COMMISSION

CLASSIFICATION OF ENVIRONMENTAL CONDITIONS –**Part 4-3: Guidance for the correlation and transformation of environmental condition classes of IEC 60721-3 to the environmental tests of IEC 60068 – Stationary use at weatherprotected locations**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 60721-4-3 has been prepared by IEC technical committee 104: Environmental conditions, classification, and methods of test. It is a Technical Specification.

This first edition cancels and replaces IEC TR 60721-4-3:2001 and IEC TR 60721-4-3:2001/AMD1:2003. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TR 60721-4-3:2001 and IEC TR 60721-4-3:2001/AMD1:2003:

- a) the document has been totally reworked;
- b) all figures have been removed, except in Annex A;

c) severities have been aligned with those of IEC 60721-3-3:2019.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
104/977/DTS	104/1014/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60721 series, published under the general title *Classification of environmental conditions*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IECNORM.COM : Click to view the full PDF of IEC TS 60721-4-3:2023

INTRODUCTION

It is essential to emphasize the guidance nature of this document since it is virtually impossible to specify mandatory requirements for worldwide use. However, for those cases which require different tests from those recommended in this document, the guidance given should establish principles and methodology to determine alternative tests.

The reasons for correlation are provided to enable specification writers to modify a test if their application warrants it.

[IECNORM.COM](https://www.iecnorm.com) : Click to view the full PDF of IEC TS 60721-4-3:2023

CLASSIFICATION OF ENVIRONMENTAL CONDITIONS –

Part 4-3: Guidance for the correlation and transformation of environmental condition classes of IEC 60721-3 to the environmental tests of IEC 60068 – Stationary use at weatherprotected locations

1 Scope

This part of IEC 60721 deals with the correlation and transformation of the conditions given in IEC 60721-3-3 to the environmental test procedures defined in IEC 60068-2.

This document provides test procedures and test severities for electrotechnical equipment operated at stationary weatherprotected locations for the product classes set out in IEC 60721-3-3.

An environment can consist of several environmental conditions such as dynamic, climatic, and biological, and other effects due to chemically and mechanically active substances. In this document, dynamic, air pressure, biological and climatic conditions have been considered.

The purpose of this document is to provide the specification writer with guidance together with a set of easy-to-use tables which correlate and transform these environmental conditions.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-1:2013, *Environmental testing – Part 1: General and guidance*

IEC 60721-1, *Classification of environmental conditions – Part 1: Environmental parameters and their severities*

IEC 60721-3-3:2019, *Classification of environmental conditions – Part 3-3: Classification of groups of environmental parameters and their severities – Stationary use at weatherprotected locations*

3 Terms and definitions

For the purposes of this document, the terms and definitions given IEC 60721-1 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

enclosed location

location at which a product is protected from direct exposure to meteorological conditions

4 General

4.1 General remarks concerning IEC 60721-3-3

IEC 60721-3-3 provides classes of groups of environmental parameters with their associated environmental conditions to which the products can be exposed during use. For more information of the classes used in this document, IEC 60721-3-3 shall be used.

Parameters in these classes are given individually, but the product can be exposed to conditions simultaneously. Some of the parameters are independent whilst others can be strongly correlated, for example, solar radiation and temperature.

4.2 General remarks concerning the IEC 60068-2 series

The IEC 60068-2 series provides a series of environmental test procedures. Each test procedure can contain a list of several recommended test severities.

Selection of test severities depends upon the failure consequences of the product. Two different types of products can be placed at a location covered by the same environmental class. However, one of the products can be tested under significantly more severe conditions than the other, because of the different failure consequences of the products. This document only addresses normal failure consequences; for more critical failure consequences, it can be necessary for the test severity to be increased on the basis of specialist knowledge of the product.

4.3 Recommended test procedures and severities

Table 1, Table 2, Table 3, Table 4, Table 5, Table 6 and Table 7 provided within this document set out recommended test procedures and severities, related to classes of groups of environmental parameters provided within IEC 60721-3-3. These test procedures and severities are those considered to be suitable for testing most electrotechnical products.

IEC 60721-3-3 specifies severities which have a low probability of being exceeded within that environmental class. The suggested test severities given in Table 1 to Table 7 of this document take this into account. For further information, refer to IEC TR 60721-4-0, which serves as an introduction to the IEC TR 60721-4 series.

The value for the recommended test duration or number of applications provided in Table 1 to Table 7 are selected on the basis that experience has shown them to be sufficient to demonstrate the effect of the condition on most products. It is possible that the durations recommended will not be suitable if the purpose of the test is to establish the durability, safety or life of an equipment or to quantify reliability. The combination of severity and applied test duration can also be unsuitable if the purpose of the test is to improve reliability.

4.4 Environmental tests for in-use classes

The in-use classes specify environmental conditions to which the product is exposed whilst being used, including assembly, non-operational state, maintenance, and repair. Environmental conditions created by co-located equipment within an enclosure are not included in this class. The relevant specification should detail when, during the environmental test programme, the product is in its operational state and which performance requirements should be measured before, during and after the test, together with the failure criteria.

It is important for the product specification, when referring to a certain class in the IEC 60721-3 series, to define whether the product is required to be capable of operating or only to survive without permanent damage when being exposed to the conditions described by the class.

4.5 Test durations

The durations recommended in Table 1 to Table 7 are selected on the basis that experience has shown them to be sufficient to demonstrate the effect of the condition on most products. It is possible that the durations recommended will not be suitable if the purpose of the test is to establish the durability or life of an equipment or to quantify reliability. The combination of severity and applied test duration can also be unsuitable if the purpose of the test is to improve reliability.

4.6 Ambient

The term "ambient" which is used for some recommended tests refers to the standard atmospheric conditions for measurements and tests specified in IEC 60068-1, which shall be used. The temperature shall be between 15 °C and 35 °C and relative humidity shall be between 25 % and 75 % RH with a maximum absolute humidity of 22 g/m³ and at air pressure between 86 kPa and 106 kPa.

5 Climate conditions, classes 3K20 to 3K24 from IEC 60721-3-3

5.1 Class 3K20 (fully air-conditioned enclosed locations)

No tests are recommended for class 3K20 as the severities are within standard atmosphere conditions as defined in IEC 60068-1 and are therefore considered benign for most products.

5.2 Class 3K21 (continuously temperature-controlled enclosed locations)

**Table 1 – Class 3K21
(continuously temperature-controlled enclosed locations)**

Class	Environmental parameter	Environmental severity	Recommended test procedure	Recommended test severity	Recommended test duration and number of applications	Note
3K21	Low air temperature	+15 °C	IEC 60068-2-1, Test Ab/Ae: Cold	No	No	a
	High air temperature	+32 °C	IEC 60068-2-2: Dry heat, test Bb/Be	+32 °C	16 h	b
	Low relative humidity	10 %	IEC 60068-2-78, Test Cab: Damp heat steady state	No	No	c
	High relative humidity	75 %				
	Low absolute humidity	2 g/m ³				
	High absolute humidity	22 g/m ³				
	Rate of change of temperature	0,5 K/min	IEC 60068-2-14, Test Nb: Change of temperature	0,5 K/min +15 °C to +32 °C	2 cycles $t_1 = 3$ h	d
	Low air pressure	70 kPa	IEC 60068-2-13, Test M: Low air pressure	70 kPa	30 min	e
	High air pressure	106 kPa	IEC 60068-2-13, Test M: Low air pressure	No	No	f
	Solar radiation	500 W/m ²	No suitable IEC test procedure exists	None	None	g
Heat radiation	See ^h	-	-	-	i	
Movement of surrounding air	1,0 m/s	No suitable IEC test procedure exists	None	None	j	

	Condensation	No	No	No	No	
	Water from sources other than rain	No	No	No	No	
	Formation of ice and frost (including freeze-thaw)	No	No	No	No	
a	The low temperature conditions are within the standard atmospheric conditions described in IEC 60068-1, and so no test is recommended.					
b	The choice of the duration of 16 h is sufficient for most products to demonstrate that its design is adequately tolerated to function at this temperature.					
c	The high humidity conditions are within the standard atmospheric conditions described in IEC 60068-1, and so no test is recommended. For the interdependence of air temperature, relative air humidity and absolute air humidity see Annex A.					
d	Only recommended for products that are sensitive to temperature change. In other cases, no test is recommended as the severities are within the standard atmospheric conditions described in IEC 60068-1.					
e	Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. For sealed products or for products containing liquids, test M is recommended or if a special value is required, see Clause 6.					
f	Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. If a special value is required, see Clause 6.					
g	As this condition is secondary effects of the solar radiation through e.g. a window, no test is recommended. The heating effect is normally included in the high air temperature severity. For products mounted near e.g. a window, special precautions such as heat shields or insulation can be necessary, or an additional elevated temperature test can be required.					
h	User selection from classes 3Z1, 3Z2, 3Z3.					
i	No test is recommended. No value is available in IEC 60721-3-3 for heat radiation and the effect is normally included in the dry heat test. For products mounted near sources of high heat radiation, special precautions such as heat shields or insulation can be necessary or an additional elevated temperature test can be required, the degree of elevation being dependent on the severity of the heat source.					
j	No test is recommended. No suitable test exists in the IEC 60068-2 series, and the condition is considered as benign for most products. Precautions should be taken, especially for large products, and it is possible that the users will have to develop their own methodology if the condition is to be evaluated.					

5.3 Class 3K22 (temperature-controlled enclosed locations)

**Table 2 – Class 3K22
(temperature-controlled enclosed locations)**

Class	Environmental parameter	Environmental severity	Recommended test procedure	Recommended test severity	Recommended test duration and number of applications	Note
3K22	Low air temperature	+5 °C	IEC 60068-2-1, Test Ab/Ae: Cold	+5 °C	16 h	a
	High air temperature	+40 °C	IEC 60068-2-2: Dry heat, test Bb/Be	+40 °C	16 h	a
	Low relative humidity	5 %	IEC 60068-2-78, Test Cab: Damp heat steady state	+30 °C, 85 % RH	4 days	b
	High relative humidity	85 %				
	Low absolute humidity	1 g/m ³				
	High absolute humidity	25 g/m ³				
	Rate of change of temperature	0,5 K/min	IEC 60068-2-14, Test Nb: Change of temperature	0,5 K/min +5 °C to +40 °C	2 cycles <i>t</i> ₁ = 3 h	c
	Low air pressure	70 kPa	IEC 60068-2-13, Test M: Low air pressure	70 kPa	2 h	d
	High air pressure	106 kPa	IEC 60068-2-13, Test M: Low air pressure	No	No	e
	Solar radiation	700 W/m ²	No	No	No	f
	Heat radiation	See ^g	-	-	-	h
	Movement of surrounding air	1 m/s	No	No	No	i
	Condensation	No	No	No	No	
	Water from sources other than rain	No	No	No	No	
Formation of ice and frost (including freeze-thaw)	No	No	No	No		

- ^a The choice of the duration of 16 h is sufficient for most products to demonstrate that its design is adequately tolerated to function at this temperature.
- ^b These severities are the nearest preferred values in the IEC 60068-2 series, and the minor differences in both temperature and humidity from the environmental parameter of IEC 60721-3-3 are considered to be insignificant and are within normal measurement tolerances. The duration of 4 days is considered to be sufficient for most products to demonstrate that its design is adequately tolerated to function at this humidity. For the interdependence of air temperature, relative air humidity and absolute air humidity see Annex A.
- ^c In this class, the temperature range is small and condensation is unlikely to occur, so it is recommended that, with the possible exception of hermetically sealed products, products containing oscillators, this test should be omitted.
- ^d Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. For sealed products or for products containing liquids, test M is recommended or if a special value is required, see Clause 6.
- ^e Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. If a special value is required, see Clause 6.
- ^f As this condition is secondary effects of the solar radiation through e.g. a window. No test is recommended. The heating effect is normally included in the high air temperature severity. For products mounted near e.g. a window, special precautions such as heat shields or insulation can be necessary, or an additional elevated temperature test can be required.
- ^g User selection from classes 3Z1, 3Z2, 3Z3.
- ^h No test is recommended. No value is available in IEC 60721-3-3 for heat radiation and the effect is normally included in the dry heat test. For products mounted near sources of high heat radiation, special precautions such as heat shields or insulation can be necessary or an additional elevated temperature test can be required, the degree of elevation being dependent on the severity of the heat source.
- ⁱ No test is recommended. No suitable test exists in the IEC 60068-2 series, and the condition is considered as benign for most products. Precautions should be taken, especially for large products, and it is possible that the users will have to develop their own methodology if the condition is to be evaluated.

5.4 Class 3K23 (enclosed locations having no temperature or humidity control)

**Table 3 – Class 3K23
(enclosed locations having no temperature or humidity control)**

Class	Environmental parameter	Environmental severity	Recommended test procedure	Recommended test severity	Recommended test duration and number of applications	Note
3K23	Low air temperature	-5 °C	IEC 60068-2-1, Test Ab/Ae: Cold	-5 °C	16 h	a
	High air temperature	+55 °C	IEC 60068-2-2: Dry heat, test Bb/Be	+55 °C	16 h	a
	Low relative humidity	10 %	IEC 60068-2-78, Test Cab: Damp heat steady state	+30 °C, 93 % RH	4 days	b
	High relative humidity	100 %				
	Low absolute humidity	0,5 g/m ³				
	High absolute humidity	29 g/m ³				
	Rate of change of temperature	0,5 K/min	IEC 60068-2-14, Test Nb: Change of temperature	0,5 K/min -5 °C to +25 °C	2 cycles $t_1 = 3$ h	c
				0,5 K/min -5 °C to +55 °C	2 cycles $t_1 = 3$ h	d
	Low air pressure	70 kPa	IEC 60068-2-13, Test M: Low air pressure	70 kPa	2 h	e
	High air pressure	106 kPa	IEC 60068-2-13, Test M: Low air pressure	No	No	f
	Solar radiation	700 W/m ²	No	No	No	g
	Heat radiation	See ⁿ				i
	Movement of surrounding air	1 m/s	No	No	No	j
	Condensation	Yes	IEC 60068-2-30, Test Db, variant 2: Damp heat cyclic	+30 °C, 90 % to 100 % RH	2 cycles	k
Water from sources other than rain	Dripping water	IEC 60068-2-18, Test R, method Ra 2: Water	2 m 0° 60 ⁺³⁰ / ₀ mm/h	60 min	l	
Formation of ice and frost (including freeze-thaw)	Yes	No suitable IEC test procedure exists	None	None	m	

- ^a The choice of the duration of 16 h is sufficient for most products to demonstrate that its design is adequately toleranced to function at this temperature.
- ^b These severities are the nearest preferred values in IEC 60068-2-78, and the minor differences in both temperature and humidity from the environmental parameter of IEC 60721-3-3 are considered to be insignificant and are within normal measurement tolerances. The duration of 4 days is considered to be sufficient for most products to demonstrate that its design is adequately toleranced to function at this humidity. For the interdependence of air temperature, relative air humidity and absolute air humidity see Annex A.
- ^c As condensation can occur a range is proposed which crosses the 0 °C boundary in order to allow condensation to occur for low-heat-dissipating products.
- ^d For other products the change of temperature can affect the function therefore the complete temperature range is recommended.
- ^e Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. For sealed products or for products containing liquids, test M is recommended or if a special value is required, see Clause 6.
- ^f Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. If a special value is required, see Clause 6.
- ^g As this condition is secondary effects of the solar radiation through e.g. a window, no test is recommended. The heating effect is normally included in the high air temperature severity. For products mounted near e.g. a window, special precautions such as heat shields or insulation can be necessary, or an additional elevated temperature test can be required.
- ^h User selection from classes 3Z1, 3Z2, 3Z3.
- ⁱ No test is recommended. No value is available in IEC 60721-3-3 for heat radiation, and the effect is normally included in the dry heat test. For products mounted near sources of high heat radiation, special precautions such as heat shields or insulation can be necessary or an additional elevated temperature test can be required, the degree of elevation being dependent on the severity of the heat source.
- ^j No test is recommended. No suitable test exists in the IEC 60068-2 series, and the condition is considered as benign for most products. Precautions should be taken, especially for large products, and it is possible that the users will have to develop their own methodology if the condition is to be evaluated.
- ^k The temperature severity is different from the preferred value in IEC 60068-2-30. It is, however, strongly recommended that this temperature be lowered to 30 °C in order to test within the specified limits. The duration of two cycles (48 h) is considered adequate for most products. For products with high heat dissipation, omit this test since the self-heating effect will prevent condensation from occurring and the effect of high humidity is covered by test Cab. Variant 2 of test Db is chosen since it adequately tests the condition and is simpler to perform than variant 1.
- ^l No value is available in IEC 60721-3-3 other than the description of the type of source, dripping water. If the product is likely to be exposed to falling drops from condensation or leakage from upper surfaces, IEC 60068-2-18: Ra 2 – drip box with a 2 m drop height, a tilt angle of 0°, and a 1 h duration – is the preferred method.
- ^m No suitable test exists in the IEC 60068-2 series other than the cold test, however, special precautions should be taken if the product contains moving parts.

5.5 Class 3K24 (enclosed locations having neither temperature nor humidity control)

**Table 4 – Class 3K24
(enclosed locations having neither temperature nor humidity control)**

Class	Environmental parameter	Environmental severity	Recommended test procedure	Recommended test severity	Recommended test duration and number of applications	Note
3K24	Low air temperature	-25 °C	IEC 60068-2-1, Test Ab/Ae: Cold	-25 °C	16 h	a
	High air temperature	+55 °C	IEC 60068-2-2: Dry heat, test Bb/Be	+55 °C	16 h	a
	Low relative humidity	5 %	IEC 60068-2-78, Test Cab: Damp heat steady state	+30 °C, 93% RH	4 days	b
	High relative humidity	100 %				
	Low absolute humidity	0,5 g/m ³				
	High absolute humidity	29 g/m ³				
	Rate of change of temperature	0,5 K/min	IEC 60068-2-14, Test Nb: Change of temperature	0,5 K/min -25 °C to +25 °C	2 cycles <i>t</i> ₁ = 3 h	c
				0,5 K/min -25 °C to +55 °C	2 cycles <i>t</i> ₁ = 3 h	d
	Low air pressure	70 kPa	IEC 60068-2-13, Test M: Low air pressure	70 kPa	2 h	e
	High air pressure	106 kPa	IEC 60068-2-13, Test M: Low air pressure	No	No	f
	Solar radiation	700 W/m ²	No	No	No	g
	Heat radiation	See ⁿ				i
	Movement of surrounding air	5 m/s	No	No	No	j
	Condensation	Yes	IEC 60068-2-30, Test Db, variant 2: Damp heat cyclic	+30 °C, 90 % to 100% RH	2 cycles	k
Water from sources other than rain	Dripping water	IEC 60068-2-18, Test R, method Ra 2: Water	2 m 0° 60 ⁺³⁰ / ₀ mm/h	60 min	l	
Formation of ice and frost (including freeze-thaw)	Yes	No suitable IEC test procedure exists	None	None	m	

- ^a The choice of the duration of 16 h is sufficient for most products to demonstrate that its design is adequately toleranced to function at this temperature.
- ^b These severities are the nearest preferred values in IEC 60068-2-78, and the minor differences in both temperature and humidity from the environmental parameter of IEC 60721-3-3 are considered to be insignificant and are within normal measurement tolerances. The duration of 4 days is considered to be sufficient for most products to demonstrate that its design is adequately toleranced to function at this humidity. For the interdependence of air temperature, relative air humidity and absolute air humidity see Annex A.
- ^c As condensation can occur so a range is proposed which crosses the 0 °C boundary in order to allow condensation to occur for low-heat-dissipating products.
- ^d For other products the change of temperature can affect the function therefore the complete temperature range is recommended.
- ^e Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. For sealed products or for products containing liquids, test M is recommended or if a special value is required, see Clause 6.
- ^f Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. If a special value is required, see Clause 6.
- ^g As this condition is secondary effects of the solar radiation through e.g. a window, no test is recommended. The heating effect is normally included in the high air temperature severity. For products mounted near e.g. a window, special precautions such as heat shields or insulation can be necessary, or an additional elevated temperature test can be required.
- ^h User selection from classes 3Z1, 3Z2, 3Z3.
- ⁱ No test is recommended. No value is available in IEC 60721-3-3 for heat radiation and the effect is normally included in the dry heat test. For products mounted near sources of high heat radiation, special precautions such as heat shields or insulation can be necessary or an additional elevated temperature test can be required, the degree of elevation being dependent on the severity of the heat source.
- ^j No test is recommended. No suitable test exists in the IEC 60068-2 series, and the condition is considered as benign for most products. Precautions should be taken, especially for large products, and it is possible that the users will have to develop their own methodology if the condition is to be evaluated.
- ^k The temperature severity is different from the preferred value in IEC 60068-2-30. It is, however, strongly recommended that this temperature be lowered to 30 °C in order to test within the specified limits. The duration of two cycles (48 h) is considered adequate for most products. For products with high heat dissipation, omit this test since the self-heating effect will prevent condensation from occurring and the effect of high humidity is covered by test Cab. Variant 2 of test Db is chosen since it adequately tests the condition and is simpler to perform than variant 1.
- ^l No value is available in IEC 60721-3-3 other than the description of the type of source, dripping water. If the product is likely to be exposed to falling drops from condensation or leakage from upper surfaces, IEC 60068-2-18: Ra 2 – drip box with a 2 m drop height, a tilt angle of 0°, and a 1 h duration – is the preferred method.
- ^m No suitable test exists in the IEC 60068-2 series other than the cold test, however, special precautions should be taken if the product contains moving parts.

6 Special climate conditions, classes 3Z12 to 3Z14 from IEC 60721-3-3

Table 5 – Class 3Z12 to 3Z14

Class	Environmental parameter	Environmental severity	Recommended test procedure	Recommended test severity	Recommended test duration	Note
3Z12	Low air pressure	84 kPa	IEC 60068-2-13, Test M: Low air pressure	84 kPa	30 min	a
3Z13	Low air pressure	62 kPa	IEC 60068-2-13, Test M: Low air pressure	62 kPa	2 h	b
			IEC 60068-2-39, Combined temperature with low air pressure	62 kPa Temperature ^c	16 h	d
3Z14	High air pressure	114 kPa	IEC 60068-2-13, Test M: Low air pressure	114 kPa	2h	e

a Test normally not required as this air pressure is covered by standard atmospheric conditions according to IEC 60068-1. For sealed products or for products containing processing liquids, test M is recommended.

b For sealed products or for products containing liquids, test M is recommended.

c The high temperature should be selected from the appropriate class 3K21 to 3K24.

d Low air pressure reduces the cooling capacity and the test procedure specified in IEC 60068-2-39 is recommended. The choice of the duration of 16 h is sufficient for most products to demonstrate that its design is adequately tolerated to function at this combination.

e Test normally not required. Even if the test M does not contain high air pressure the method can be used for high air pressure and depends on the test chamber capability.

7 Biological conditions, classes 3B1 to 3B3 from IEC 60721-3-3

Table 6 – Class 3B1 to 3B3

Class	Environmental parameter	Environmental severity	Recommended test procedure	Recommended test severity	Recommended test duration	Note
3B1	Flora and fauna	Negligible	-	-	-	
3B2	Flora	Presence of mould, fungus, etc.	IEC 60068-2-10, Test J: Mould growth	Test variant 1	28 days	
	Fauna	Presence of rodents and other animals harmful to products	No suitable IEC test procedure exists	None	None	a
	Termites	No	-	-	-	
3B3	Flora	Presence of mould, fungus, etc.	IEC 60068-2-10, Test J: Mould growth	Test variant 2	28 days	
	Fauna	Presence of rodents and other animals harmful to products	No suitable IEC test procedure exists	None	None	a
	Termites	Yes	No suitable IEC test procedure exists	None	None	

a No suitable test exists in the IEC 60068-2 series. Rodent resistance can no longer be tested with live animals. The material hardness specified in ISO 2039-2, Rockwell R87 or higher, or equivalent can be used to prove compliance.

8 Mechanical conditions, classes 3M10 to 3M12 from IEC 60721-3-3**Table 7 – Class 3M10 to 3M12**

Class	Environmental parameter	Environmental severity	Recommended test procedure	Recommended test severity	Recommended test duration and number of applications	Note
3M10	Stationary vibration, Random: acceleration spectral density	None				
	Shock	None				
3M11	Stationary vibration, Random: Acceleration spectral density	Acceleration spectral density 0,01 (m/s ²) ² /Hz	IEC 60068-2-64, Test Fh: Vibration broadband random	Acceleration spectral density 0,01 (m/s ²) ² /Hz	30 min in each direction	
	Frequency	5 Hz to 200 Hz		5 Hz to 200 Hz		
	Shock	None				
3M12	Stationary vibration, Random: Acceleration spectral density	0,1 (m/s ²) ² /Hz	IEC 60068-2-64, Test Fh: Vibration broadband random	0,1 (m/s ²) ² /Hz	30 min in each direction	
	Frequency	5 Hz to 200 Hz		5 Hz to 200 Hz		
	Shock	Amplitude 20 m/s ²	IEC 60068-2-27 Test Ea: Shock	Half-sine pulse Amplitude 20 m/s ² , Duration 11 ms	3 shocks in each axis and each direction, 18 in total	

IECNORM.COM : Click to view the full PDF of IEC TS 60721-4-3:2023