

TECHNICAL SPECIFICATION



Electrical insulating materials and systems – Electrical measurement of partial discharges (PD) under short rise time and repetitive voltage impulses

IECNORM.COM : Click to view the full PDF of IEC TS 61934:2011



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

IECNORM.COM : Click to view the full PDF of IEC TS 61934:2011

TECHNICAL SPECIFICATION



Electrical insulating materials and systems – Electrical measurement of partial discharges (PD) under short rise time and repetitive voltage impulses

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

U

ICS 17.220.99; 29.035.01; 29.080.30

ISBN 978-2-88912-479-4

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions.....	7
4 Measurement of partial discharge pulses during repetitive, short rise-time voltage impulses and comparison with power frequency.....	9
4.1 Measurement frequency.....	9
4.2 Measurement quantities.....	9
4.3 Test objects.....	10
4.3.1 General.....	10
4.3.2 Inductive test objects.....	10
4.3.3 Capacitive test objects.....	10
4.3.4 Distributed impedance test objects.....	10
4.4 Impulse generators.....	10
4.4.1 General.....	10
4.4.2 Impulse waveforms.....	11
4.5 Effect of testing conditions.....	11
4.5.1 General.....	11
4.5.2 Effect of environmental factors.....	12
4.5.3 Effect of testing conditions and ageing.....	12
5 PD detection methods.....	12
5.1 General.....	12
5.2 PD pulse coupling and detection devices.....	12
5.2.1 Introductory remarks.....	12
5.2.2 Coupling capacitor with multipole filter.....	13
5.2.3 HFCT with multipole filter.....	14
5.2.4 Electromagnetic couplers.....	15
5.2.5 Charge measurements.....	16
5.3 Source-controlled gating techniques.....	17
6 Measuring instruments.....	17
7 Sensitivity check of the PD measuring equipment.....	17
7.1 General.....	17
7.2 Test diagram for sensitivity check.....	18
7.3 PD detection sensitivity check.....	18
7.4 Background noise check.....	19
7.5 Detection system noise check.....	19
7.6 Sensitivity report.....	19
8 Test procedure for increasing and decreasing the repetitive impulse voltage magnitude.....	19
9 Test report.....	20
Annex A (informative) Voltage impulse suppression required by the coupling device.....	22
Annex B (informative) PD pulses extracted from a supply voltage impulse through filtering techniques.....	24
Annex C (informative) Result of round-robin tests of RPDIV measurement.....	26
Annex D (informative) Examples of noise levels of practical PD detectors.....	28

Bibliography.....	29
Figure 1 – Coupling capacitor with multipole filter	13
Figure 2 – Example of voltage impulse and PD pulse frequency spectra before and after filtering	14
Figure 3 – HFCT between supply and test object with multipole filter	14
Figure 4 – HFCT between test object and earth with multipole filter	15
Figure 5 – Circuit using an electromagnetic coupler (for example an antenna) to suppress impulses from the test supply.....	15
Figure 6 – Circuit using an electromagnetic UHF antenna.....	15
Figure 7 – Example of waveforms of repetitive bipolar impulse voltage and charge accumulation for a twisted-pair sample	16
Figure 8 – Charge measurements	16
Figure 9 – Example of PD detection using electronic source-controlled gating (other PD coupling devices can be used)	17
Figure 10 – Test diagram for sensitivity check	18
Figure 11 – Example of relation between the outputs of LVPG and PD detector.....	19
Figure 12 – Example of increasing and decreasing the impulse voltage magnitude	20
Figure A.1 – Example of overlap between voltage impulse and PD pulse spectra (dotted area).....	22
Figure A.2 – Example of voltage impulse and PD pulse spectra after filtering	22
Figure A.3 – Example of impulse voltage damping as a function of impulse voltage magnitude and rise time.....	23
Figure B.1 – Power supply waveform and recorded signal using an antenna during supply voltage commutation.....	24
Figure B.2 – Signal detected by an antenna from the record of Figure B.1, using a filtering technique (400 MHz high-pass filter)	25
Figure B.3 – Characteristic of the filter used to pass from Figure B.1 to Figure B.2	25
Figure C.1 – The sequence of negative voltage impulses used for RRT	26
Figure C.2 – PD pulses (under) corresponding to voltage impulses (above).....	26
Figure C.3 – Dependence of normalized RPDIV on 100 data (NRPIV/100) on relative humidity (A-F indicates the participants of RRT)	27
Table 1 – Example of parameter values of impulse voltage waveform without load	11
Table D.1 – Examples of bandwidths and noise levels for practical PD sensors	28

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL INSULATING MATERIALS AND SYSTEMS –
ELECTRICAL MEASUREMENT OF PARTIAL DISCHARGES (PD)
UNDER SHORT RISE TIME AND REPETITIVE VOLTAGE IMPULSES**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC/TS 61934, which is a technical specification, has been prepared by IEC technical committee 112: Evaluation and qualification of electrical insulating materials and systems.

This second edition cancels and replaces the first edition, published in 2006, and constitutes a technical revision.

The principal changes with regard to the previous edition concern the addition of

- an Introduction that provides some background information on the progress being made in the field of power electronics;
- impulse generators;
- PD detection methods;
- a new informative Annex C covering practical experience obtained from round-robin testing (RRT);
- example of noise levels, as shown in new informative Annex D.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
112/163/DTS	112/175/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Power electronics has developed along with both control theory and semiconductor technology. Switching is one of the essential features of power electronics control. For higher efficiency and smoother operation, switching times of the latest devices such as insulated-gate bipolar transistor (IGBT) tend to be shorter than microseconds. Such a short rise time may cause transient overvoltage impulses or surges in the systems. When the voltage impulses reach the breakdown strength of an air gap, partial discharge (PD) may occur. In addition, the impulses are repetitive from power electronics modulation such as pulse width modulation (PWM). Since PD may cause degradation of electrical insulation parts in the system, it is one of the most important parameters to be measured.

The first edition of IEC/TS 61934 was issued in April 2006. Because of rapid development in this field, the revision activity for the latest information was approved in TC112 at the Berlin meeting in September 2006. In addition to technical and editorial changes, practical experience obtained through round-robin test (RRT) is also presented in Annex C.

IECNORM.COM : Click to view the full PDF of IEC TS 61934:2011

ELECTRICAL INSULATING MATERIALS AND SYSTEMS – ELECTRICAL MEASUREMENT OF PARTIAL DISCHARGES (PD) UNDER SHORT RISE TIME AND REPETITIVE VOLTAGE IMPULSES

1 Scope

IEC/TS 61934, which is a technical specification, is applicable to the off-line electrical measurement of partial discharges (PD) that occur in electrical insulation systems (EIS) when stressed by repetitive voltage impulses generated from electronic power devices.

Typical applications are EIS belonging to apparatus driven by power electronics, such as motors, inductive reactors and windmill generators.

NOTE 1 Use of this technical specification with specific products may require the application of additional procedures.

NOTE 2 The procedures described in this technical specification are emerging technologies. Experience and caution, as well as certain preconditions, are needed to apply it.

Excluded from the scope of this technical specification are

- methods based on optical or ultrasonic PD detection,
- fields of application for PD measurements when stressed by non-repetitive impulse voltages such as lightning impulse or switching impulses from switchgear.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034 (all parts), *Rotating electrical machines*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

repetitive voltage impulses

voltage impulses which are used as test voltage for the evaluation of switching surges from power electronic devices with a carrier or driven frequency

3.2

partial discharge

PD

electric discharge that only partially bridges the insulation between conductors

[IEC 60270:2000, 3.1, modified]

3.3

partial discharge pulse

current pulse in an object under test that results from a partial discharge occurring within the object under test

NOTE 1 The pulse is measured using suitable detector circuits, which have been introduced into the test circuit for the purpose of the test.

NOTE 2 A detector in accordance with the provisions of this technical specification produces a current or a voltage signal at its output related to the PD pulse at its input.

[IEC 60270:2000, 3.2, modified]

3.4

repetitive partial discharge inception voltage

RPDIV

minimum peak-to-peak impulse voltage at which more than five PD pulses occur on ten voltage impulses of the same polarity

NOTE This is a mean value for the specified test time and a test arrangement where the voltage applied to the test object is gradually increased from a value at which no partial discharges can be detected.

3.5

repetitive partial discharge extinction voltage

RPDEV

maximum peak-to-peak impulse voltage at which less than five PD pulses occur on ten voltage impulses of the same polarity

NOTE This is a mean value for a specified test time and a test arrangement where the voltage applied to the test object gradually decreases from a voltage at which PD have been detected.

3.6

impulse voltage polarity

polarity of the applied impulse voltage with respect to earth

[IEC 62068-1:2003, 3.10]

3.7

unipolar impulse

repetitive voltage impulse, the polarity of which is either positive or negative

[IEC 62068-1:2003, 3.8, modified]

NOTE The magnitude of the oscillation of the opposite polarity has to be less than 20 %.

3.8

bipolar impulse

repetitive voltage impulse, the polarity of which changes

[IEC 62068-1:2003, 3.9, modified]

3.9

impulse voltage repetition rate

inverse of the average time between successive impulses of the same polarity, whether unipolar or bipolar

[IEC 62068-1:2003, 3.11, modified]

3.10

impulse rise time

time for the voltage impulse to go from 0 % to 100 %

NOTE Unless otherwise stated, this is estimated as 1,25 times the time for the voltage to rise from 10 % to 90 %.

[IEC 62068-1:2003, 3.12, modified]

3.11

impulse decay time

time interval between the instants at which the instantaneous value of an impulse decreases from a specified upper value to a specified lower value

NOTE Unless otherwise specified, the upper and lower values are fixed at 90 % and 10 % of the impulse magnitude.

3.12

impulse width

interval of time between the first and last instants at which the instantaneous value of an impulse reaches a specified fraction of impulse magnitude or a specified threshold

3.13

impulse duty cycle

ratio, for a given time interval, of the impulse width to the total time

3.14

peak partial discharge magnitude

largest magnitude of any quantity related to PD pulses observed in a test object at a specified voltage following a specified conditioning and test

[IEC 60270:2000, 3.4 modified]

NOTE For impulse voltage tests, the peak magnitude of the PD pulse is the largest repeatedly occurring PD magnitude.

4 Measurement of partial discharge pulses during repetitive, short rise-time voltage impulses and comparison with power frequency

4.1 Measurement frequency

IEC 60270 describes the methods employed to measure the electrical pulses associated with PD in test objects excited by DC and alternating voltages up to 400 Hz. The methods used to measure PD pulses when the test object is subjected to supply voltage impulses have to be modified from the standard narrow-band and wide-band frequency methods described in IEC 60270.

To measure the PD during repetitive short rise time voltage impulses, it is necessary to avoid the induced current of the excited impulse voltage. One technique is current or electromagnetic wave measurement at ultra-high frequency, that is, higher than that of the impulse. Ultra-wide band (UWB) detection is often used with a high-pass filter for the suppression of relatively lower frequency components of impulse voltage. In principle, narrow-band measurement in the ultra-high frequency (UHF: 300 MHz to 3 GHz) region is also effective for the suppression of the impulse voltage. The other method is the integration of PD current at a very low frequency compared to that of the impulse voltage.

4.2 Measurement quantities

Measured quantities concern the RPDIV, the RPDEV, the peak partial discharge magnitude and partial discharge pulse repetition rate.

RPDIV and RPDEV may depend on PD measurement sensitivity and measurement circuit noise, so that normalization, as indicated in Clause 7, is needed. Moreover, they depend on the test object and the pulse deformation from the discharge to the measurement point.

In this technical specification, PD readings are reported in units of mV. In all cases, a sensitivity evaluation of the measuring system is necessary and shall be carried out according to Clause 7.

4.3 Test objects

4.3.1 General

Test objects behave predominantly as inductive, capacitive or distributed equivalent impedances according to the voltage supply frequency content. For some test objects, whether they are predominantly inductive, capacitive or distributed impedances may depend on the PD detection frequency range (not only on the voltage supply frequency). Test objects with distributed behaviour have transmission line characteristics which may cause attenuation and distortion of the PD pulses as the pulses propagate through the test object. The following classification is effective only for low-frequency, narrow-band measurements.

4.3.2 Inductive test objects

Types of inductive test objects may include:

- stator and rotor windings;
- inductive reactors;
- transformer windings;
- motorettes and formettes (see the IEC 60034 series).

4.3.3 Capacitive test objects

Types of capacitive test objects may include:

- twisted pairs of winding wire;
- capacitors;
- packaging of switching devices;
- power electronic modules and substrates;
- isolated heat sinks;
- mainwall insulation models in stator coils and bars;
- printed circuit boards;
- optocouplers.

4.3.4 Distributed impedance test objects

The following test objects may have distributed equivalent impedance properties:

- cables;
- busbars;
- stator and rotor windings;
- transformer windings;
- turn insulation of stator and rotor windings.
- bushings with capacitive voltage stress control;

4.4 Impulse generators

4.4.1 General

Impulse generators used in this technical specification shall generate short rise time and repetitive voltage impulses with a low noise level. For a short rise time of impulses,

semiconductor devices may be used for switching in addition to conventional sphere electrode gaps. For repetitive impulses, the main capacitor shall be charged from a DC power supply in a short period of time. The ranges of rise time, repetition frequency and other parameters are described in 4.4.2.

The polarity of successive impulses is important for PD behaviour. To simulate the turn-to-turn voltage of a motor driven by a PWM phase voltage, a bipolar repetitive impulse voltage is preferable. When a bipolar generator is hard to obtain, a unipolar repetitive impulse generator may be used.

For PD measurements, impulse generators shall suppress noise emission by means of sufficient electromagnetic shielding.

4.4.2 Impulse waveforms

For the purpose of comparison between different insulating materials or design solutions, partial discharge measurements can be performed using appropriate voltage supply waveforms. The specification of the impulse generator shall include amongst other factors:

- impulse rise time;
- impulse voltage polarity;
- impulse voltage repetition rate;
- impulse width;
- impulse duty cycle.

Examples are given in Table 1.

Table 1 – Example of parameter values of impulse voltage waveform without load

Characteristic	Range
Rise time	0,04 μ s to 1 μ s
Repetition rate	1 Hz to 10 000 Hz
Impulse width	0,08 μ s to 25 μ s
Shape	Square or triangular
Polarity	Unipolar or bipolar (preferred)

The impulse waveform depends not only on the impulse generator specification but also on sample impedance. The impulse waveform will change significantly with load. The impulse generator needs to be designed to deliver the required wave shape to the load. As the capacitance of the sample increases, the rise time of the voltage impulse increases in general. On the other hand, the inductive test object, or distributed equivalent impedance mentioned in 4.3.4, can cause damped oscillation after the impulse waveform in addition to the change of rise time. It is important to check the waveform of the impulse voltage across the tested electrical insulation. In this case, it is strongly recommended that impulse and PD waveforms are observed with a wide band oscilloscope. It is noted that PD can occur during the voltage oscillation following the first impulse.

4.5 Effect of testing conditions

4.5.1 General

In general, PD-associated quantities may depend upon specific features of the impulse waveform, for example the impulse rise time, the impulse decay time, the impulse repetition rate, the polarity and the number of oscillations in the impulse.

4.5.2 Effect of environmental factors

In general, PD-associated quantities may be affected by the following factors:

- temperature;
- humidity;
- atmospheric pressure;
- type of environment gas;
- degree of contamination of the test object.

NOTE PD phenomena may change with longer rise time in the case of high altitude.

4.5.3 Effect of testing conditions and ageing

PD-associated quantities may be affected by

- voltage distribution,
- position of PD occurrence,
- previous voltage applications as well as the time between voltage applications,
- operation time or time under stress of the test object.

In addition, they may vary as ageing of the electrical insulation occurs, that is, during operation of the EIS.

5 PD detection methods

5.1 General

Any PD pulse detection system where the test object is excited by voltage impulses requires strong suppression of the residual voltage impulse, measured by the PD detection circuit, and negligible suppression of the PD pulse. The PD pulse shall have a magnitude after processing by the detection system that is greater than the residual transmitted voltage impulse. The amount of impulse voltage suppression required will be dependent on the test voltage and the rise time of the impulse.

As the impulse voltage increases in amplitude, greater suppression is required in order to ensure that important PD pulse magnitudes are higher than the residual transmitted voltage impulse on the output of the detector. Similarly, as the rise time of the applied impulse voltage becomes shorter, the suppression shall be greater, due to the increased overlap of frequency spectra of supply impulse and PD pulse (see Annex A). PD pulse coupling devices shall be designed to ensure that important PD pulse magnitudes are higher than the residual transmitted voltage impulse on the output of the detector, or the residual be clearly distinguishable from the PD pulses.

Annex A provides indications of the voltage impulse suppression action required by the coupling device. Suggestions for the amount of supply voltage impulse suppression needed as a function of impulse magnitude and rise time are given.

Examples of PD pulses extracted from a supply voltage impulse through filtering techniques are reported in Annex B.

5.2 PD pulse coupling and detection devices

5.2.1 Introductory remarks

PD current or voltage pulses in a test object can be detected either by means of high-voltage capacitors, high-frequency current transformers (HFCT) or electromagnetic couplers (e.g. antennae). The detectors, in conjunction with the rest of the measuring system, shall be able

to suppress the impulse voltage to a magnitude less than that expected from the PD pulse (using e.g. appropriate filters).

Short low-inductance connections between the supply, the test object and the PD detector are required, since the voltage impulses and PD pulses contain high-frequency components. The impulse supply shall be as physically close to the test object as possible, in order to prevent attenuation and dispersion of the applied impulse due to the equivalent transmission parameters of the connecting leads. Since the PD is measured with a UWB detection system, earthing of the test object shall be made directly to the impulse voltage supply, with leads as short as possible and with low inductance. It is recommended that lead lengths should not exceed 1 m.

The following circuits are applicable for PD pulse detection.

5.2.2 Coupling capacitor with multipole filter

A coupling capacitor with a voltage rating exceeding that of the expected applied impulse voltage together with a filter that strongly attenuates the test voltage impulses can be used. The filter shall have at least three poles and special measures to inhibit cross coupling of the input signal to the output. The filter can be designed using passive or active filtering technology. The coupling capacitor is connected to the test object high-voltage terminal (Figure 1). Annex A shows a schematic example of filter behaviour. Figure 2 reports an example of frequency spectra of PD pulse and impulse voltage before and after filtering for an 8th order filter.




Figure 1 – Coupling capacitor with multipole filter




Figure 2a – Example of voltage impulse and PD pulse frequency spectra before filtering




Figure 2b – Example of voltage impulse and PD pulse frequency spectra after filtering

NOTE Impulse voltage rise time 50 ns, PD pulse rise time 2 ns, 8th order filter with filter cut-off frequency equal to 500 MHz.

Figure 2 – Example of voltage impulse and PD pulse frequency spectra before and after filtering

5.2.3 HFCT with multipole filter

An HFCT, together with a filter, can be used to detect PD pulses while suppressing the impulse voltage. Note that HFCTs may have a very wide range of upper cut-off frequencies that may affect the performance of this method. The HFCT shall have a higher cut-off frequency than the voltage impulse frequency. The filter shall have at least three poles and special measures to inhibit cross-coupling of the input signal to the output. The filter can be implemented using passive or active filtering technology. The HFCT can be placed over the high-voltage cable between the impulse supply and the test object (Figure 3). In this case, the HFCT shall have sufficient electrical insulation to ensure that breakdown between the cable and the HFCT does not occur. Alternatively, the HFCT can be connected between the test object and earth (Figure 4). Only low-voltage insulation is then required. The latter arrangement is effective, in general, only if the metallic enclosure of the test object can be isolated from earth. Annex A shows a schematic example of filter behaviour.




Figure 3 – HFCT between supply and test object with multipole filter




Figure 4 – HFCT between test object and earth with multipole filter

5.2.4 Electromagnetic couplers

Antenna-type couplers can be used to separate impulses from the supply from PD originating in the test object (Figure 5).

Various antenna-type couplers can be used to detect an electromagnetic signal from the partial discharge site in the test object. For the separation of the PD signal from the impulse voltage, the couplers shall have suitable frequency characteristics.

An ultra-wide band (UWB) coupler can detect a PD signal with impulse noise. To suppress the impulse voltage, an electromagnetic near-field coupler with a fixed coupling impedance to the lead from the impulse supply to the test object can be effective (Figure 5).




Figure 5 – Circuit using an electromagnetic coupler (for example an antenna) to suppress impulses from the test supply

An alternative electromagnetic coupler can detect the radiated electromagnetic signals propagating through free space from the PD site in the test object (Figure 6). If the antenna has UWB characteristics including lower frequency component of voltage impulses, a filtering function is necessary to suppress the residual signal inside the acquisition system. Some double-ridged guide antennae (horn antennae) have a cut-off frequency above 0,5 GHz which need no filters. UHF antennae with narrow-band characteristics, the centre frequency of which is higher than those of voltage impulse also do not need a filter for the same reason. Note that the coupling efficiency will depend on the distance between the PD site and the antenna as well as the presence of any metallic shielding between the PD site and the antenna.





Figure 6 – Circuit using an electromagnetic UHF antenna

5.2.5 Charge measurements

For simple, unearthed capacitive test objects, such as twisted pairs (with equivalent capacitance C_s), it is possible to measure PD charge using both a detection capacitor with a capacitance C_d ($C_d \gg C_s$) in series with the test object and a voltage detector with high input resistance R .

Charge builds up on the detecting capacitor through the charging current due to the impulse voltage rise. When the impulse voltage decays to zero, the capacitor charge is cancelled out by the opposite charge. Consequently, without PD, the voltage of the detecting capacitor shows the same shape of the applied impulse voltage, with amplitude scaled by the ratio C_s/C_d . When PD occurs during the impulse voltage, the PD charge decays to zero with the time constant RC_d , where R is the impedance of the measuring system. When the time constant is selected to be long enough with respect to the impulse voltage duration, charge decay can be observed after a single voltage impulse. Figure 7 shows an experimental example of impulse voltage and accumulated charge for a twisted pair sample. The charge measurement is meaningful as a PD detection tool only if the voltage impulses are bipolar and identical for both polarities. The sensitivity of PD measurement depends on the background noise in the same way as for conventional PD measurement. A schematic of the test circuit is shown in Figure 8.



NOTE Peak impulse voltage magnitude = 2,3 kV, impulse voltage repetition rate = 250 Hz.

Figure 7 – Example of waveforms of repetitive bipolar impulse voltage and charge accumulation for a twisted-pair sample




Figure 8 – Charge measurements

5.3 Source-controlled gating techniques

An alternative method to suppress the impulse voltage is to gate the PD signal electronically (from any of the above detectors) so that the signal is blocked from being displayed or registered for the duration of the initial portion of the short rise time of the impulse (Figure 9). With this method, any PD reaching the detector during the initial part of the impulse rise time will not be detected. Hence, only PD reaching the detector after the supply voltage commutation transient will be recorded.




Figure 9 – Example of PD detection using electronic source-controlled gating (other PD coupling devices can be used)

6 Measuring instruments

The results of a PD test are the RPDIV and RPDEV. The PD pulse repetition rate, the largest peak PD pulse magnitude at a specified test voltage and the test conditions shall be measured as well. It should be pointed out that PD magnitude is only a relative measure of PD activity, given that PD pulses are attenuated and distorted when they travel from the source to the measurement point.

The PD signal output from the coupler and detection system can be recorded on a digital oscilloscope or pulse magnitude analyser. When using an oscilloscope, the PD output is normally displayed on one channel while a reduced magnitude version of the applied impulse voltage is recorded on another channel (Annex B). The magnitudes of the PD pulses as well as the temporal position in which they occur with respect to the impulse voltage are recorded. Note that the retrigger rate of the oscilloscope is recommended to be higher than that of the impulse voltage repetition rate.

Electronic pulse magnitude analysers can be used to measure the magnitude of the PD pulses and their repetition rate (see 4.4 of IEC 60270:2000).

Typical test circuits are shown in Figures 1 to 9.

7 Sensitivity check of the PD measuring equipment

7.1 General

The RPDIV, RPDEV and PD-associated quantities depend on the sensitivity of the measuring system to PD and how well the PD pulses can be distinguished from other electrical interference or noise (such as the residual signal from the voltage impulse itself). Thus the sensitivity of the PD measuring system shall be assessed and recorded. The sensitivity is measured in mV.

NOTE The PD is not measured in pC, since the procedure of IEC 60270 cannot be used for UWB PD detection systems (integration of the pulse current to yield the apparent charge cannot be performed as indicated in IEC 60270).


7.2 Test diagram for sensitivity check

A sensitivity check of a PD measuring system is performed using the test diagram shown in Figure 10. The output of the PD detector is measured step by step with different combinations of the low-voltage pulse generator (LVPG) and high-voltage impulse generator (HVIG) connected to a test object.

Pulse waveform from the LVPG shall be selected with respect to both the original PD pulses and the frequency limit of detecting system. The rise time of the pulse waveform may be selected around $1/f$, where f is the upper frequency limit of the PD detection system. For example, if the upper cut-off frequency of the PD detection system is 100 MHz, the rise time of LVPG may be less than 10 ns.

The location where LVPG is connected to the circuit of test object shall be cleared as injection point. For test objects having distributed equivalent impedance, such as motor and transformer windings, propagation effects of PD pulses may cause strong attenuation of the high-frequency components, thus only PD close to the measurement point may be observed.

PD sensitivity and the effect of noise may be assessed in steps, as addressed in Figure 10 and 7.3 to 7.5:



IEC 841/11

	A	B	C	Clause
PD detection sensitivity check	Closed	Opened	Opened	7.3
Background noise check	Closed	Closed	Opened	7.4
Detection system noise check	Opened	Closed	Closed	7.5

Figure 10 – Test diagram for sensitivity check

7.3 PD detection sensitivity check

Disconnect the HVIG from the test object and measure the output of the PD detector while increasing the output of LVPG. Measure the minimum output voltage of LVPG at which the PD detector shows a detectable signal. This is the sensitivity of the PD detection system.

7.4 Background noise check

Connect the unenergized HVIG to the test object and measure the output of the PD detector while increasing the output of the LVPG. Measure the minimum output voltage of the LVPG at which the PD detector shows a detectable signal. This is the background noise of the PD detection circuit.


7.5 Detection system noise check

Disconnect the LVPG and apply the voltage impulse of the HVIG to the test object. Measure the output of the PD detector under PD-free condition. For example, replace the test object with a PD-free capacitance that has about the same high-frequency capacitance as the test object. Record the output of PD detector with voltage impulse used for PD measurement. This is the detection system noise, or residual of HVIG.

NOTE Subclause 7.5 may not be feasible if appropriate capacitors are not available. In such cases, reference should be made to the results of 7.3.

7.6 Sensitivity report

PD sensitivity is presented as the relation between the outputs of LVPG and HVIG. An example of the possible behaviour of PD sensitivity is shown in Figure 11.



IEC 842/11

Figure 11 – Example of relation between the outputs of LVPG and PD detector

8 Test procedure for increasing and decreasing the repetitive impulse voltage magnitude


The background noise and detection limits shall first be measured using the procedures set out in Clause 7. For PDIV, PDEV, RPDIV and RPDEV measurements, the voltage amplitude of repetitive impulse shall rise continuously or step-by-step with a low voltage and then fall. One method for determining the PDIV, RPDIV, RPDEV and PDEV is as follows (Figure 12):

- Decide minimum and maximum impulse voltages, voltage step, number of impulses with same magnitude and repetition frequency before the test.
- With the preliminary test the minimum voltage shall be selected as no PD is detected.

- With the preliminary test the maximum voltage shall be selected as every voltage impulses causes PD pulses.
- Set an impulse generator with the parameters mentioned above, if necessary.
- Start the repetitive impulse of the minimum voltage.
- Repeat the repetitive impulse with increased voltage step successively.
- PDIV is the impulse voltage when the first PD pulse is detected.
- RPDIV is the minimum impulse voltage when a mean of five PD pulses occur on ten voltage impulses of the same polarity. When less than ten impulses are tested with the same voltage, the ratio of PD pulse to voltage impulses may be used.
- After maximum voltage the repetitive impulses fall with decreased voltage step.
- RPDEV is the maximum voltage at which a mean of five PD pulses occur on ten voltage impulses of the same polarity.
- PDEV is the impulse voltage when no PD pulse is detected.

Other methods of determining these quantities are also possible.

Note that the PDIV and PDEV may be highly variable when this sequence is repeated.



IEC 843/11

Figure 12 – Example of increasing and decreasing the impulse voltage magnitude

9 Test report

The following quantities shall be reported:

- PD sensitivity level (see Clause 7);
- background noise level;
- detection system noise level;
- RPDIV, RPDEV and minimum PD detection level in mV;
- parameters of applied voltage impulses reported in Clause 8;

- shape of the impulse voltage with load reported in 4.4.2.;
- testing conditions reported in 4.5.2 and 4.5.3.

Reporting of the following parameters is optional:

- peak partial discharge magnitude at a specified applied voltage;
- maximum (peak-to-peak) test impulse voltage level;
- operation time or time under stress of the test object;
- state of cleanliness of the test object (e.g. no cleaning, factory shipment cleanliness).

IECNORM.COM : Click to view the full PDF of IEC TS 61934:2011

Annex A (informative)

Voltage impulse suppression required by the coupling device

A schematic representation of the possible overlap of voltage impulse and PD pulse frequency spectra is shown in Figure A.1. The steeper the voltage impulse the larger the overlap area between the two spectra. The cut-off frequency for an optimal voltage impulse suppression coupling device is indicated in Figure A.1. The action of a filter is displayed in Figure A.2. Impulse voltage and PD pulse magnitude are damped by the filter transfer function, $H(f)$ (f being the frequency). The filter cut-off frequency should be selected in such a way that, after filtering, the PD signal magnitude exceeds the voltage impulse magnitude within the bandwidth of the PD detector. A broadband PD detector is generally required for this purpose.

A typical example of acceptable impulse voltage attenuation as a function of voltage magnitude and rise time is reported in Figure A.3. Note that attenuation depends on the voltage impulse magnitude and the rise time.




Figure A.1 – Example of overlap between voltage impulse and PD pulse spectra (dotted area)





Figure A.2 – Example of voltage impulse and PD pulse spectra after filtering



IEC 846/11

Key

- A voltage impulse rise time = 100 ns
- B voltage impulse rise time = 1 000 ns

Figure A.3 – Example of impulse voltage damping as a function of impulse voltage magnitude and rise time


IECNORM.COM : Click to view the full PDF of IEC TS 61934:2011

Annex B (informative)

PD pulses extracted from a supply voltage impulse through filtering techniques


A typical example of PD pulses occurring during a supply voltage commutation transient for a square bipolar generator feeding a 400 V, 1 kW motor is shown in Figures B.1 and B.2. In Figure B.1 the recorded signal is predominantly noise due to impulse supply voltage switching. Figure B.2 is obtained using an antenna as a coupling device and a high-pass filter (four poles), with cut-off frequency at 400 MHz. The filtered signal is predominantly a PD pulse generated inside the test object where the supply voltage commutation has been suppressed effectively through filtering. Figure B.3 is the example of the attenuation achieved with an 8th order filter with cut-off frequency 400 MHz.

It should be noted that, in the absence of filtering, PD pulses cannot be detected as they are hidden by the noise produced by the voltage impulses.




IEC 847/11

Figure B.1 – Power supply waveform and recorded signal using an antenna during supply voltage commutation



IEC 848/11

Figure B.2 – Signal detected by an antenna from the record of Figure B.1, using a filtering technique (400 MHz high-pass filter)



IEC 849/11

Figure B.3 – Characteristic of the filter used to pass from Figure B.1 to Figure B.2