

# INTERNATIONAL STANDARD



Information technology – Small computer system interface (SCSI) –  
Part 372: Enclosure Services - 2 (SES-2)

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011



**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2011 ISO/IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about ISO/IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### **About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### **About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011



ISO/IEC 14776-372

Edition 1.0 2011-10

# INTERNATIONAL STANDARD



---

**Information technology –Small computer system interface (SCSI) –  
Part 372: Enclosure Services - 2 (SES-2)**

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE **XA**

---

ICS 35.200

ISBN 978-2-88912-751-1

## CONTENTS

FOREWORD.....	10
INTRODUCTION .....	12
1 Scope .....	14
2 Normative references .....	15
3 Terms, definitions, symbols, abbreviations, keywords and conventions .....	16
3.1 Terms and definitions .....	16
3.2 Symbols and abbreviations .....	20
3.3 Keywords .....	20
3.4 Conventions .....	21
4 SCSI enclosure services model .....	23
4.1 Access to the enclosure services process .....	23
4.1.1 Access to the enclosure services process overview .....	23
4.1.2 Standalone enclosure services process .....	23
4.1.3 Attached enclosure services process .....	24
4.2 Management of indicators and controls .....	25
4.3 Subenclosures .....	26
4.3.1 Subenclosures overview .....	26
4.3.2 Generation code .....	27
4.3.3 Simple subenclosures .....	28
4.3.4 Multiple enclosure services processes in a subenclosure.....	29
4.4 Use of the Enclosure Busy diagnostic page.....	29
4.5 Invalid field errors.....	29
4.6 Thresholds .....	30
4.7 Reporting methods .....	31
4.7.1 Reporting methods overview.....	31
4.7.2 Polling .....	31
4.7.3 Timed completion function .....	31
4.7.4 CHECK CONDITION status .....	31
4.7.5 Asynchronous event notification.....	32
4.8 Additional sense codes .....	32
5 Commands for enclosure services peripheral devices .....	34
6 Parameters for enclosure services devices.....	36
6.1 Diagnostic parameters .....	36
6.1.1 Diagnostic parameters overview .....	36
6.1.2 Configuration diagnostic page.....	38
6.1.3 Enclosure Control diagnostic page.....	41
6.1.4 Enclosure Status diagnostic page .....	43
6.1.5 Help Text diagnostic page.....	45
6.1.6 String Out diagnostic page.....	46
6.1.7 String In diagnostic page .....	47

6.1.8 Threshold Out diagnostic page .....	47
6.1.9 Threshold In diagnostic page .....	49
6.1.10 Element Descriptor diagnostic page .....	50
6.1.11 Short Enclosure Status diagnostic page .....	52
6.1.12 Enclosure Busy diagnostic page .....	52
6.1.13 Additional Element Status diagnostic page .....	53
6.1.14 Subenclosure Help Text diagnostic page .....	63
6.1.15 Subenclosure String Out diagnostic page .....	64
6.1.16 Subenclosure String In diagnostic page .....	65
6.1.17 Supported SES Diagnostic Pages diagnostic page .....	67
6.1.18 Download Microcode Control diagnostic page .....	67
6.1.19 Download Microcode Status diagnostic page .....	70
6.1.20 Subenclosure Nickname Control diagnostic page .....	73
6.1.21 Subenclosure Nickname Status diagnostic page .....	74
6.2 Log parameters for enclosure services devices .....	76
6.3 Mode parameters for enclosure services devices .....	77
6.3.1 Mode parameters overview .....	77
6.3.2 Enclosure Services Management mode page .....	78
7 Element definitions .....	79
7.1 Element definitions overview .....	79
7.2 Element formats .....	81
7.2.1 Element formats overview .....	81
7.2.2 Control element format .....	81
7.2.3 Status element format .....	82
7.2.4 Threshold control element format .....	83
7.2.5 Threshold status element format .....	84
7.3 Field definitions for all element types .....	84
7.3.1 Unspecified element .....	84
7.3.2 Device Slot element .....	85
7.3.3 Array Device Slot element .....	88
7.3.4 Power Supply element .....	90
7.3.5 Cooling element .....	92
7.3.6 Temperature Sensor element .....	94
7.3.7 Door Lock element .....	95
7.3.8 Audible Alarm element .....	96
7.3.9 Enclosure Services Controller Electronics element .....	98
7.3.10 SCC Controller Electronics element .....	99
7.3.11 Nonvolatile Cache element .....	100
7.3.12 Invalid Operation Reason element .....	101
7.3.13 Uninterruptible Power Supply element .....	103
7.3.14 Display element .....	105
7.3.15 Key Pad Entry element .....	107
7.3.16 Enclosure element .....	108
7.3.17 SCSI Port/Transceiver element .....	110
7.3.18 Language element .....	111
7.3.19 Communication Port element .....	113
7.3.20 Voltage Sensor element .....	114
7.3.21 Current Sensor element .....	115
7.3.22 SCSI Target Port element .....	117

7.3.23 SCSI Initiator Port element.....	118
7.3.24 Simple Subenclosure element.....	119
7.3.25 SAS Expander element.....	119
7.3.26 SAS Connector element.....	120
Bibliography .....	122

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011

Figure 0 – SCSI document structure .....	12
Figure 1 – Standalone enclosure services process .....	24
Figure 2 – Attached enclosure services process .....	25
Figure 3 – Subenclosures .....	27
Figure 4 – Multiple enclosure service processes in a subenclosure .....	29

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011

Table 1 – Numbering conventions .....	22
Table 2 – Sense keys and additional sense codes .....	33
Table 3 – Commands for standalone enclosure services processes .....	34
Table 4 – Diagnostic page codes for enclosure service devices .....	36
Table 5 – Configuration diagnostic page .....	38
Table 6 – Enclosure descriptor .....	39
Table 7 – Type descriptor header format .....	40
Table 8 – Enclosure Control diagnostic page .....	41
Table 9 – Control descriptor .....	42
Table 10 – Control element processing .....	43
Table 11 – Enclosure Status diagnostic page .....	43
Table 12 – Status descriptor .....	45
Table 13 – Help Text diagnostic page .....	46
Table 14 – String Out diagnostic page .....	46
Table 15 – String In diagnostic page .....	47
Table 16 – Threshold Out diagnostic page .....	48
Table 17 – Threshold control descriptor .....	48
Table 18 – Threshold In diagnostic page .....	49
Table 19 – Threshold status descriptor .....	50
Table 20 – Element Descriptor diagnostic page .....	51
Table 21 – Element descriptor by type descriptor .....	51
Table 22 – Overall descriptor format and element descriptor format .....	52
Table 23 – Short Enclosure Status diagnostic page .....	52
Table 24 – Enclosure Busy diagnostic page .....	52
Table 25 – Additional Element Status diagnostic page .....	54
Table 26 – Additional Element Status descriptor with the EIP bit set to one .....	54
Table 27 – Additional Element Status descriptor with the EIP bit set to zero .....	54
Table 28 – Additional Element Status descriptor protocol-specific information for Fibre Channel with the EIP bit set to one .....	55
Table 29 – Additional Element Status descriptor protocol-specific information for Fibre Channel with the EIP bit set to zero .....	56
Table 30 – Port descriptor .....	56
Table 31 – BYPASS REASON field .....	57
Table 32 – Additional Element Status descriptor protocol-specific information for SAS .....	58
Table 33 – DESCRIPTOR TYPE field .....	58
Table 34 – Additional Element Status descriptor protocol-specific information for Device Slot elements and Array Device Slot elements for SAS with the EIP bit set to one .....	58
Table 35 – Additional Element Status descriptor protocol-specific information for Device Slot elements and Array Device Slot elements for SAS with the EIP bit set to zero .....	59
Table 36 – Phy descriptor .....	59
Table 37 – Additional Element Status descriptor protocol-specific information for SAS Expander elements .....	61
Table 38 – Expander phy descriptor .....	61

Table 39 – Additional Element Status descriptor protocol-specific information for SCSI Initiator Port, SCSI Target Port, and Enclosure Services Controller Electronics elements for SAS .....	62
Table 40 – Phy descriptor .....	62
Table 41 – Subenclosure Help Text diagnostic page .....	63
Table 42 – Subenclosure help text format .....	64
Table 43 – Subenclosure String Out diagnostic page .....	65
Table 44 – Subenclosure String In diagnostic page .....	66
Table 45 – Subenclosure string in data format .....	66
Table 46 – Supported SES Diagnostic Pages diagnostic page .....	67
Table 47 – Download Microcode Control diagnostic page .....	68
Table 48 – DOWNLOAD MICROCODE MODE field .....	69
Table 49 – Download Microcode Status diagnostic page .....	71
Table 50 – Download microcode status descriptor format .....	71
Table 51 – SUBENCLOSURE DOWNLOAD MICROCODE STATUS field .....	72
Table 52 – Subenclosure Nickname Control diagnostic page .....	74
Table 53 – Subenclosure Nickname Status diagnostic page .....	75
Table 54 – Subenclosure nickname status descriptor format .....	75
Table 55 – SUBENCLOSURE NICKNAME STATUS field .....	76
Table 56 – Log page codes for enclosure services devices .....	76
Table 57 – Mode page codes for enclosure services devices .....	77
Table 58 – Enclosure Services Management mode page .....	78
Table 59 – Element type codes .....	80
Table 60 – Control element format .....	81
Table 61 – Status element format .....	82
Table 62 – ELEMENT STATUS CODE field .....	82
Table 63 – ELEMENT STATUS CODE field usage in an overall status element .....	83
Table 64 – Threshold control element format .....	83
Table 65 – Threshold status element format .....	84
Table 66 – Unspecified control element .....	84
Table 67 – Unspecified status element .....	85
Table 68 – Device Slot control element .....	85
Table 69 – Device Slot status element .....	86
Table 70 – SLOT ADDRESS field .....	86
Table 71 – Array Device Slot control element .....	88
Table 72 – Array Device Slot status element .....	89
Table 73 – Power Supply control element .....	90
Table 74 – Power Supply status element .....	91
Table 75 – Cooling control element .....	92
Table 76 – REQUESTED SPEED CODE field .....	93
Table 77 – Cooling status element .....	93
Table 78 – ACTUAL SPEED CODE field .....	94
Table 79 – Temperature Sensor threshold control element field definitions .....	94

Table 80 – Temperature Sensor threshold status element field definitions .....	94
Table 81 – Temperature Sensor control element .....	94
Table 82 – Temperature Sensor status element .....	95
Table 83 – Door Lock control element .....	96
Table 84 – Door Lock status element .....	96
Table 85 – Audible Alarm control element .....	96
Table 86 – Audible Alarm status element .....	97
Table 87 – Enclosure Services Controller Electronics control element .....	98
Table 88 – Enclosure Services Controller Electronics status element .....	99
Table 89 – SCC Controller Electronics control element .....	99
Table 90 – SCC Controller Electronics status element .....	100
Table 91 – Nonvolatile Cache control element .....	100
Table 92 – Nonvolatile Cache status element .....	100
Table 93 – SIZE MULTIPLIER field and NONVOLATILE CACHE SIZE field .....	101
Table 94 – Invalid Operation Reason threshold control element field definitions .....	101
Table 95 – Invalid Operation Reason threshold status element field definitions .....	101
Table 96 – Invalid Operation Reason control element .....	102
Table 97 – Invalid Operation Reason status element .....	102
Table 98 – INVOP TYPE field .....	102
Table 99 – Invalid Operation Reason status element with the INVOP TYPE field set to 00b .....	102
Table 100 – Invalid Operation Reason status element with the INVOP TYPE field set to 01b .....	103
Table 101 – Invalid Operation Reason status element with the INVOP TYPE field set to 11b .....	103
Table 102 – Uninterruptible Power Supply threshold control element field definitions .....	103
Table 103 – Uninterruptible Power Supply threshold status element field definitions .....	104
Table 104 – Uninterruptible Power Supply control element .....	104
Table 105 – Uninterruptible Power Supply status element .....	104
Table 106 – BATTERY STATUS field .....	104
Table 107 – Display control element .....	106
Table 108 – DISPLAY MODE field .....	106
Table 109 – Display status element .....	106
Table 110 – DISPLAY MODE STATUS field .....	107
Table 111 – Key Pad Entry control element .....	107
Table 112 – Key Pad Entry status element .....	107
Table 113 – Enclosure control element .....	108
Table 114 – POWER CYCLE REQUEST field .....	108
Table 115 – POWER CYCLE DELAY field .....	108
Table 116 – POWER OFF DURATION field .....	109
Table 117 – Enclosure status element .....	109
Table 118 – TIME UNTIL POWER CYCLE field .....	109
Table 119 – REQUESTED POWER OFF DURATION field .....	110
Table 120 – SCSI Port/Transceiver control element .....	110
Table 121 – SCSI Port/Transceiver status element .....	111

Table 122 – Language control element .....	111
Table 123 – LANGUAGE CODE field .....	112
Table 124 – Language status element .....	112
Table 125 – LANGUAGE CODE field .....	113
Table 126 – Communication Port control element .....	113
Table 127 – Communication Port status element .....	113
Table 128 – Voltage Sensor threshold control element field definitions .....	114
Table 129 – Voltage Sensor threshold status element field definitions .....	114
Table 130 – Voltage Sensor control element .....	114
Table 131 – Voltage Sensor status element .....	115
Table 132 – Current Sensor threshold control element field definitions .....	115
Table 133 – Current Sensor threshold status element field definitions .....	116
Table 134 – Current Sensor control element .....	116
Table 135 – Current Sensor status element .....	116
Table 136 – SCSI Target Port control element .....	117
Table 137 – SCSI Target Port status element .....	117
Table 138 – SCSI Initiator Port control element .....	118
Table 139 – SCSI Initiator Port status element .....	118
Table 140 – Simple Subenclosure control element .....	119
Table 141 – Simple Subenclosure status element .....	119
Table 142 – SAS Expander control element .....	119
Table 143 – SAS Expander status element .....	120
Table 144 – SAS Connector control element .....	120
Table 145 – SAS Connector status element .....	120
Table 146 – CONNECTOR TYPE field .....	121

## INFORMATION TECHNOLOGY – SMALL COMPUTER SYSTEM INTERFACE (SCSI) –

### Part 372: Enclosure Services - 2 (SES-2)

#### FOREWORD

- 1) ISO (International Organization for Standardization) and IEC (International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards. Their preparation is entrusted to technical committees; any ISO and IEC member body interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with ISO and IEC also participate in this preparation.
- 2) In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1. Draft International Standards adopted by the joint technical committee are circulated to national bodies for voting. Publication as an International Standard requires approval by at least 75 % of the national bodies casting a vote.
- 3) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO member bodies.
- 4) IEC, ISO and ISO/IEC publications have the form of recommendations for international use and are accepted by IEC and ISO member bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC, ISO and ISO/IEC publications is accurate, IEC or ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 5) In order to promote international uniformity, IEC and ISO member bodies undertake to apply IEC, ISO and ISO/IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any ISO/IEC publication and the corresponding national or regional publication should be clearly indicated in the latter.
- 6) ISO and IEC provide no marking procedure to indicate their approval and cannot be rendered responsible for any equipment declared to be in conformity with an ISO/IEC publication.
- 7) All users should ensure that they have the latest edition of this publication.
- 8) No liability shall attach to IEC or ISO or its directors, employees, servants or agents including individual experts and members of their technical committees and IEC or ISO member bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication of, use of, or reliance upon, this ISO/IEC publication or any other IEC, ISO or ISO/IEC publications.
- 9) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 10) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights.

International Standard ISO/IEC 14776-372 was prepared by subcommittee 25: Interconnection of information technology equipment, of ISO/IEC joint technical committee 1: Information technology.

The list of all currently available parts of the ISO/IEC 14776 series, under the general title *Information technology – Small computer system interface (SCSI)*, can be found on the IEC web site.

This International Standard has been approved by vote of the member bodies and the voting results may be obtained from the address given on the second title page.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

**IMPORTANT – The ‘colour inside’ logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its content. Users should therefore print this document using a colour printer.**

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011

## INTRODUCTION

This International Standard documents the commands and parameters necessary to manage and sense the state of the power supplies, cooling devices, displays, indicators, individual drives, and other non-SCSI elements installed in an enclosure. The command set uses the SCSI SEND DIAGNOSTIC and RECEIVE DIAGNOSTIC RESULTS commands (see SPC-4) to obtain configuration information for the enclosure and to set and sense standard bits for each type of element that may be installed in the enclosure.

The standard is organized as follows:

- Clause 1 Scope describes the relationship of this standard to the SCSI family of standards.
- Clause 2 Normative references provide references to other standards and documents.
- Clause 3 Definitions, symbols, abbreviations, and conventions describe terms and conventions used throughout this standard.
- Clause 4 SCSI enclosure services model describes the model for SCSI enclosure services peripheral devices, both standalone and attached.
- Clause 5 Commands for enclosure services peripheral devices define the command set for a SCSI enclosure services peripheral device.
- Clause 6 Parameters for enclosure services devices define diagnostic pages, log pages, and mode parameters and pages specific to SCSI enclosure services peripheral devices.
- Clause 7 Element definitions define elements used by several of the diagnostic pages.

### SCSI standards family

Figure 0 shows the relationship of this standard to the other standards and related projects in the SCSI family of standards as of the publication of this standard.




Figure 0 — SCSI document structure

The SCSI document structure in figure 0 is intended to show the general applicability of the documents to one another. Figure 0 is not intended to imply a relationship such as a hierarchy, protocol stack, or system architecture.

**SCSI Architecture Model:** Defines the SCSI systems model, the functional partitioning of the SCSI standard set and requirements applicable to all SCSI implementations and implementation standards.

**Device-Type Specific Command Sets:** Implementation standards that define specific device types including a device model for each device type. These standards specify the required commands and behaviors that are specific to a given device type and prescribe the requirements to be followed by a SCSI initiator device when sending commands to a SCSI target device having the specific device type.

The commands and behaviors for a specific device type may include reference commands and behaviors that are shared by all SCSI devices.

**Shared Command Set:** An implementation standard that defines a model for all SCSI device types. This standard specifies the required commands and behavior that is common to all SCSI devices, regardless of device type, and prescribes the requirements to be followed by a SCSI initiator device when sending commands to any SCSI target device.

**SCSI Transport Protocols:** Implementation standards that define the requirements for exchanging information so that different SCSI devices are capable of communicating.

**Interconnects:** Implementation standards that define the communications mechanism employed by the SCSI transport protocols. These standards may describe the electrical and signalling requirements essential for SCSI devices to interoperate over a given interconnect. Interconnect standards may allow the interconnection of devices other than SCSI devices in ways that are outside the scope of this standard.

The term SCSI is used to refer to the family of standards described in this subclause.

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011

## INFORMATION TECHNOLOGY – SMALL COMPUTER SYSTEM INTERFACE (SCSI) –

### Part 372: Enclosure Services - 2 (SES-2)

#### 1 Scope

This part of ISO/IEC 14776 documents the commands and parameters necessary to manage and sense the state of the power supplies, cooling devices, displays, indicators, individual drives, and other non-SCSI elements installed in an enclosure. The command set uses the SCSI SEND DIAGNOSTIC and RECEIVE DIAGNOSTIC RESULTS commands (see SPC-4) to obtain configuration information for the enclosure and to set and sense standard bits for each type of element that may be installed in the enclosure.

The following concepts from SES are made obsolete by this standard:

- a) Array Control and Array Status diagnostic pages (page code 06h); and
- b) secondary subenclosure support in the Help Text, String Out, and String In diagnostic pages.

The set of SCSI standards specifies the interfaces, functions, and operations necessary to ensure interoperability between conforming SCSI implementations. This standard is a functional description. Conforming implementations may employ any design technique that does not violate interoperability.

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

The provisions of the referenced specifications other than ISO/IEC, IEC, ISO and ITU documents, as identified in this clause, are valid within the context of this International Standard. The reference to such a specification within this International Standard does not give it any further status within ISO/IEC. In particular it does not give the referenced specifications the status of an International Standard.

ISO 639-1:2002, *Codes for the representation of names of languages – Part 1: Alpha-2 code*

ISO/IEC 8859-1:1998, *Information technology - 8-bit single-byte coded graphic character sets – Part 1: Latin alphabet No. 1*

ISO/IEC 10646:2003, *Information technology – Universal Multiple-Octet Coded Character Set (UCS)*

ISO/IEC 14165-122:2005, *Information technology – Fibre channel – Part 122: Arbitrated loop - 2 (FC-AL-2)*<sup>1</sup>

ISO/IEC 14776-342:2000, *Information technology – Small computer system interface (SCSI) – Part 342: Controller Commands - 2 (SCC-2)*<sup>2</sup>

ISO/IEC 14776-414, *Information technology – Small computer system interface (SCSI) – Part 414: Architecture Model - 4 (SAM-4)*<sup>3</sup>

T10/1760-D, *Information technology – Serial Attached SCSI - 2 (SAS-2)*

T10/1828-D, *Information technology – Fibre Channel Protocol - 4 (FCP-4)*

T10/1731-D, *Information technology – SCSI Primary Commands - 4 (SPC-4)*

NOTE 1 For more information on the current status of T10 documents, contact the INCITS Secretariat at 202-737-8888 (phone), 202-638-4922 (fax) or via Email at [incits@itic.org](mailto:incits@itic.org). To obtain copies of this document, contact Global Engineering at 15 Inverness Way, East Englewood, CO 80112-5704 at 303-792-2181 (phone), 800-854-7179 (phone), or 303-792-2192 (fax), or see <http://www.incits.org>.

*Serial ATA 2.6 (SATA-2) specification*. 15 February 2007

NOTE 2 For information on the current status of Serial ATA documents, see the Serial ATA International Organization at <http://www.sata-io.org>.

---

1. ANSI INCITS 332-1999  
2. ANSI INCITS 318-1998  
3. T10/1683\_D

### 3 Terms, definitions, symbols, abbreviations, keywords and conventions

#### 3.1 Terms and definitions

##### 3.1.1

###### **application client**

class whose objects are, or an object that is, the source of commands (see 3.1.6) and task management function (see 3.1.40) request; see SAM-4

##### 3.1.2

###### **ASCII string**

string of US-ASCII characters each encoded in 8 bits per ISO/IEC 8859-1 containing only graphic characters (i.e., code values 20h through 7Eh); ASCII strings do not contain the NULL character (i.e., 00h)

##### 3.1.3

###### **attached enclosure services process**

enclosure services process (see 3.1.17) that is attached to a device server (see 3.1.11) in another SCSI target device (see 3.1.33); see 4.1.3

##### 3.1.4

###### **byte**

sequence of eight contiguous bits considered as a unit

##### 3.1.5

###### **class**

description of a set of objects (see 3.1.26) that share the same characteristics; see SAM-4

##### 3.1.6

###### **command**

request describing a unit of work to be performed by a device server (see 3.1.11); see SAM-4

##### 3.1.7

###### **command descriptor block**

###### **CDB**

structure used to communicate a command (see 3.1.6) from an application client (see 3.1.1) to a device server (see 3.1.11); see SAM-4

##### 3.1.8

###### **control element**

data structure used to access an element (see 3.1.13) via the Enclosure Control diagnostic page (see 6.1.3); see clause 7

##### 3.1.9

###### **critical condition**

enclosure condition established when one or more elements inside the enclosure have failed or are operating outside of their specifications; the failure of the element makes continued normal operation of at least some elements in the enclosure impossible; some elements within the enclosure may be able to continue normal operation

##### 3.1.10

###### **device**

mechanical, electrical, or electronic contrivance with a specific purpose

##### 3.1.11

###### **device server**

class whose objects process, or an object that processes, commands (see 3.1.6); see SAM-4

##### 3.1.12

###### **device slot**

position into which a SCSI device may be inserted in an enclosure; the position provides appropriate power, signal, and control connections to the SCSI device; the position may also provide mechanical protection, locking capability, automatic insertion, visual device status indicators, and other features to manage the SCSI device in the enclosure

**3.1.13****element**

portion of an enclosure (see 3.1.15) that is controlled, interrogated, or described by the enclosure services process (see 3.1.17)

**3.1.14****element type**

type or kind of element (see 3.1.13) (e.g., Array Device Slot, Power Supply, or Cooling); see clause 7

**3.1.15****enclosure**

box, rack, or set of boxes providing the powering, cooling, mechanical protection, and external electronic interfaces for one or more SCSI devices

**3.1.16****enclosure services****ES**

services that establish the mechanical environment, electrical environment, and external indicators and controls for the proper operation and maintenance of devices within an enclosure

**3.1.17****enclosure services process**

process that manages and implements enclosure services and is either a standalone enclosure services process (see 3.1.37) or an attached enclosure services process (see 3.1.3); see 4.1

**3.1.18****field**

group of one or more contiguous bits

**3.1.19****hard reset**

condition resulting from the events defined by SAM-4 in which the SCSI device performs the hard reset operations described in SAM-4, this standard, and other applicable command standards (see table 3 in clause 5)

**3.1.20****I\_T nexus loss**

condition resulting from the events defined by SAM-4 in which the SCSI device performs the I\_T nexus loss operations described in SAM-4, this standard, and other applicable command standards (see table 3 in clause 5)

**3.1.21****information condition**

an enclosure condition that should be made known to the application client (see 3.1.1); the condition is not an error and does not reduce the capabilities of the devices in the enclosure

**3.1.22****logical unit**

class whose objects implement, or an object that implements, a device model that manages and processes commands (see 3.1.6) sent by an application client (see 3.1.1); see SAM-4

**3.1.23****logical unit number****LUN**

identifier for a logical unit; see SAM-4

**3.1.24****logical unit reset**

condition resulting from the events defined by SAM-4 in which the logical unit performs the logical unit reset operations described in SAM-4, this standard, and other applicable command standards (see table 3 in clause 5)

**3.1.25****noncritical condition**

enclosure condition established when one or more elements inside the enclosure have failed or are operating outside of their specifications; the failure of the elements does not affect continued normal operation of the enclosure; all SCSI devices in the enclosure continue to operate according to their specifications; the ability of the devices to operate correctly if additional failures occur may be reduced by a noncritical condition

**3.1.26****object**

entity with a well-defined boundary and identity that encapsulates state and behavior; see SAM-4

**3.1.27****power on**

condition resulting from the events defined by SAM-4 in which the SCSI device performs the power on operations described in SAM-4, this standard, and other applicable command standards (see table 3 in clause 5)

**3.1.28****primary subenclosure**

subenclosure (see 3.1.39) whose enclosure services process (see 3.1.17) provides access to the enclosure services information of all the subenclosures in an enclosure (see 3.1.15); see 4.3

**3.1.29****redundancy**

the presence in an enclosure of one or more elements capable of automatically taking over the functions of an element that has failed

**3.1.30****SCSI initiator device**

class whose objects originate, or an object that originates, device service and task management requests to be processed by a SCSI target device (see 3.1.33) and receives device service and task management responses from SCSI target devices; see SAM-4

**3.1.31****SCSI initiator port**

class whose objects act, or an object that acts, as the connection between application clients (see 3.1.1) and a service delivery subsystem through which requests, indications, responses, and confirmations are routed; see SAM-4

**3.1.32****SCSI port**

class whose objects connect, or an object that connects, the application client (see 3.1.1), device server (see 3.1.11), or task manager (see 3.1.41) to a service delivery subsystem; a SCSI port is one of a SCSI initiator port (see 3.1.31) or a SCSI target port (see 3.1.34); see SAM-4

**3.1.33****SCSI target device**

class whose objects receive, or an object that receives, device service and task management requests from SCSI initiator devices (see 3.1.33) for processing and sends device service and task management responses to SCSI initiator devices; see SAM-4

**3.1.34****SCSI target port**

class whose objects act, or an object that acts, as the connection between device servers (see 3.1.11) and task managers (see 3.1.41) and a service delivery subsystem through which requests, indications, responses, and confirmations are routed; see SAM-4

**3.1.35****secondary subenclosure**

subenclosure (see 3.1.39) whose enclosure services process (see 3.1.17) does not provide access to the enclosure services information of all the subenclosures in an enclosure (see 3.1.15); see 4.3

**3.1.36****simple subenclosure**

subenclosure (see 3.1.39) that does not support any SES diagnostic page (see 6.1.1) except the Short Enclosure Status diagnostic page (see 6.1.11); see 4.3.3

**3.1.37****standalone enclosure services process**

enclosure services process (see 3.1.17) that is also the device server (see 3.1.11); see 4.1.2

**3.1.38****status element**

data structure used to access an element (see 3.1.13) via the Enclosure Status diagnostic page (see 6.1.4); see clause 7

**3.1.39****subenclosure**

portion of an enclosure (see 3.1.15) accessed through a primary subenclosure's (see 3.1.28) enclosure services process (see 3.1.17); see 4.3

**3.1.40****task management function**

task manager (see 3.1.41) service capable of being requested by an application client (see 3.1.1) to affect the processing of one or more commands (see 3.1.6); see SAM-4

**3.1.41****task manager**

class whose objects control, or an object that controls the sequencing of commands (see 3.1.6) and processes task management functions (see 3.1.40); see SAM-4

**3.1.42****text string**

string of characters using the character encoding and language indicated by the Language element (see 7.3.18) containing only graphic characters; text strings do not contain the NULL character (i.e., 00h or 0000h)

**3.1.43****threshold control element**

data structure used to access an element (see 3.1.13) via the Threshold Out diagnostic page (see 6.1.8); see clause 7

**3.1.44****threshold status element**

data structure used to access an element (see 3.1.13) via the Threshold In diagnostic page (see 6.1.9); see clause 7

**3.1.45****type descriptor**

type descriptor header (see 3.1.46) and corresponding type descriptor text, if any, accessed via the Configuration diagnostic page (see 6.1.2)

**3.1.46****type descriptor header**

data structure in the Configuration diagnostic page (see 6.1.2) defining a set of elements (see 3.1.13) sharing the same element type (see 3.1.14) and type descriptor text (see 3.1.47)

**3.1.47****type descriptor text**

text string (see 3.1.42) reported in the Configuration diagnostic page (see 6.1.2) describing the elements (see 3.1.13) defined by a type descriptor (see 3.1.45)

**3.1.48****unrecoverable condition**

enclosure condition established when one or more elements inside the enclosure have failed and have disabled some functions of the enclosure; the enclosure may be incapable of recovering or bypassing the failure and requires repairs to correct the condition

**3.1.49****wrapping counter**

counter that wraps back to zero after reaching its maximum value

**3.2 Symbols and abbreviations**

AC	alternating current
CDB	command descriptor block (see 3.1.7)
DC	direct current
ES	enclosure services (see 3.1.16)
ESI	enclosure services interface (see SFF-8067)
FCP	Fibre Channel Protocol standard (any version)
FCP-4	Fibre Channel Protocol - 4 standard (see clause 2)
GPIO	general purpose input/output
LED	light emitting diode
LSB	least significant bit
LUN	logical unit number (see 3.1.23)
MSB	most significant bit
ROM	read only memory
RMS	root mean squared
rpm	revolutions per minute
SAS	Serial Attached SCSI standard (any version)
SAS-2	Serial Attached SCSI - 2 standard (see clause 2)
SCA-2	Single Connector Attach connector (see SFF-8067)
SCSI	Small Computer System Interface family of standards (see clause 2)
SAM-4	SCSI Architecture Model - 4 standard (see clause 2)
SCC	SCSI Controller Commands standard (any version)
SCC-2	SCSI Controller Commands - 2 standard (see clause 2)
SPC-4	SCSI Primary Commands - 4 standard (see clause 2)

**3.3 Keywords****3.3.1  
invalid**

A keyword used to describe an illegal or unsupported bit, byte, word, field or code value. Receipt of an invalid bit, byte, word, field or code value shall be reported as an error.

**3.3.2  
mandatory**

A keyword indicating an item that is required to be implemented as defined in this standard.

**3.3.3  
may**

A keyword that indicates flexibility of choice with no implied preference (equivalent to “may or may not”).

**3.3.4  
may not**

Keywords that indicates flexibility of choice with no implied preference (equivalent to “may or may not”).

**3.3.5  
obsolete**

A keyword indicating that an item was defined in prior standards but has been removed from this standard.

### 3.3.6

#### **optional**

A keyword that describes features that are not required to be implemented by this standard. However, if any optional feature defined in this standard is implemented, it shall be implemented as defined in this standard.

### 3.3.7

#### **prohibited**

A keyword used to describe a feature, function, or coded value that is defined in a non-SCSI standard (i.e., a standard that is not a member of the SCSI family of standards) to which this standard makes a normative reference where the use of said feature, function, or coded value is not allowed for implementations of this standard.

### 3.3.8

#### **reserved**

A keyword referring to bits, bytes, words, fields and code values that are set aside for future standardization. Their use and interpretation may be specified by future extensions to this or other standards. A reserved bit, byte, word or field shall be set to zero, or in accordance with a future extension to this standard. Recipients are not required to check reserved bits, bytes, words or fields for zero values. Receipt of reserved code values in defined fields shall be reported as an error.

### 3.3.9

#### **shall**

A keyword indicating a mandatory requirement. Designers are required to implement all such mandatory requirements to ensure interoperability with other products that conform to this standard.

### 3.3.10

#### **should**

A keyword indicating flexibility of choice with a strongly preferred alternative (equivalent to "is strongly recommended").

### 3.3.11

#### **vendor specific**

Something (e.g., a bit, field, or code value) that is not defined by this standard and may be used differently in various implementations.

## 3.4 Conventions

Certain words and terms used in this standard have a specific meaning beyond the normal English meaning. These words and terms are defined either in clause 3 or in the text where they first appear.

Names of SCSI commands, statuses, sense keys, and additional sense codes are in all uppercase (e.g., SEND DIAGNOSTIC command).

Names of SCSI diagnostic pages, mode pages, log pages, and elements are in mixed case (e.g., Disconnect-Reconnect mode page).

Names of fields are in small uppercase (e.g., PAGE LENGTH). Normal case is used when the contents of a field are being discussed. Fields containing only one bit are usually referred to as the NAME bit instead of the NAME field.

Normal case is used for words having the normal English meaning.

A binary number is represented in this standard by any sequence of digits consisting of only the Western-Arab numerals 0 and 1 immediately followed by a lower-case b (e.g., 0101b). Underscores or spaces may be included in binary number representations to increase readability or delineate field boundaries (e.g., 0 0101 1010b or 0\_0101\_1010b).

A hexadecimal number is represented in this standard by any sequence of digits consisting of only the Western-Arab numerals 0 through 9 and/or the upper-case English letters A through F immediately followed by a lower-case h (e.g., FA23h). Underscores or spaces may be included in

hexadecimal number representations to increase readability or delineate field boundaries (e.g., B FD8C FA23h or B\_FD8C\_FA23h).

A decimal number is represented in this standard by any sequence of digits consisting of only the Western-Arabic numerals 0 through 9 not immediately followed by a lower-case b or lower-case h (e.g., 25).

This standard uses the following conventions for representing decimal numbers:

- a) the decimal separator (i.e., separating the integer and fractional portions of the number) is a period;
- b) the thousands separator (i.e., separating groups of three digits in a portion of the number) is a space; and
- c) the thousands separator is used in both the integer portion and the fraction portion of a number.

Table 1 shows some examples of decimal numbers using various numbering conventions.

**Table 1 — Numbering conventions**

French	English	This standard
0,6	0.6	0.6
3,141 592 65	3.14159265	3.141 592 65
1 000	1,000	1 000
1 323 462,95	1,323,462.95	1 323 462.95

A decimal number represented in this standard with an overline over one or more digits following the decimal point is a number where the overlined digits are infinitely repeating (e.g.,  $666.\overline{6}$  means  $666.666\ 666\dots$  or  $666\ 2/3$ , and  $12.\overline{142\ 857}$  means  $12.142\ 857\ 142\ 857\dots$  or  $12\ 1/7$ ).

Lists sequenced by letters (e.g., a) red, b) blue, c) green) show no ordering relationship between the listed items. Lists sequenced by numbers (e.g., 1) red, 2) blue, 3) green) show an ordering relationship between the listed items. Lists are associated with an introductory paragraph or phrase, and are numbered relative to that paragraph or phrase (i.e., all lists begin with an a) or 1) entry).

In the event of conflicting information the precedence for requirements defined in this standard is:

- 1) text;
- 2) tables; then
- 3) figures.

Notes do not constitute any requirements for implementers.

## 4 SCSI enclosure services model

### 4.1 Access to the enclosure services process

#### 4.1.1 Access to the enclosure services process overview

Enclosures may provide power, cooling, and protection for devices. In addition, enclosures may provide external indicators about the state of the enclosure and devices. The indicators may identify the enclosure, identify proper operation of the devices and enclosure elements, provide indications of the state of RAID devices in the enclosure, and provide failure and maintenance information. Some of the individual elements of an enclosure may be removable and replaceable while the enclosure continues to operate. An enclosure services process typically manages all these enclosure elements and communicates with the SCSI application client. All those elements managed by the enclosure services process are in the enclosure domain of that process. The enclosure domain may extend outside the actual box containing the enclosure services process. As an example, an Uninterruptible Power Supply element may be located remotely and attached to the enclosure services process by a serial link.

The application client has two mechanisms for accessing the enclosure services process, both using the RECEIVE DIAGNOSTIC RESULTS and SEND DIAGNOSTIC commands (see SPC-4):

- a) directly to a standalone enclosure services process (see 4.1.2); or
- b) indirectly through a logical unit of another peripheral device type (e.g., a block device) to an attached enclosure services process (see 4.1.3).

#### 4.1.2 Standalone enclosure services process

An application client may address the enclosure services process as a logical unit having the peripheral device type of enclosure services (i.e., 0Dh) (see the INQUIRY command in SPC-4). The commands for this peripheral device type are described in clause 5.

Standalone enclosure services processes shall set the ENCSERV (enclosure services) bit to one in the Standard INQUIRY data (see SPC-4).

The application client uses the SEND DIAGNOSTIC command and the SES control-type diagnostic pages (see 6.1) to set various indicators and states within the enclosure domain, allowing the enclosure to provide the most appropriate environment for the other SCSI devices contained within it. Similarly, the application client requests information from the enclosure services process using the RECEIVE DIAGNOSTIC RESULTS command and the SES status-type diagnostic pages (see 6.1) to examine various status and warning information available from the enclosure. The diagnostic pages and page formats are defined in 6.1.

The Enclosure Services Management mode page (see 6.3.2) may be implemented by a standalone enclosure services process.

Figure 1 shows an example of an enclosure with a standalone enclosure services process.




Figure 1 – Standalone enclosure services process

#### 4.1.3 Attached enclosure services process

An application client may also be able to address the enclosure services process using a logical unit with some other peripheral device type (e.g., a block device) as a transport for enclosure services information. Such peripheral devices have a communications connection to the attached enclosure services process defined outside this standard (e.g., the Enclosure Services Interface (ESI) in SFF-8067). The attached enclosure services process is not accessible as its own logical unit; instead, it transports the standard enclosure services information through the addressed logical unit.

A device server with an attached enclosure services process shall set the ENCSERV (enclosure services) bit to one in the Standard INQUIRY data (see SPC-4). The attached enclosure services process may or may not be currently attached.


Such device servers shall use the same SEND DIAGNOSTIC and RECEIVE DIAGNOSTIC RESULTS commands and page formats used by a standalone enclosure services process (see 4.1.2), but otherwise support the peripheral device model specified by their peripheral device type value.

An application client determines whether an enclosure services process is attached to the device server by using the RECEIVE DIAGNOSTIC RESULTS command to request a Configuration diagnostic page (see 6.1.2). If the device server is not able to communicate with an enclosure services process, the device server shall terminate the command as described in 4.8.

The Enclosure Services Management mode page (see 6.3.2) may be implemented by a logical unit that allows access to an attached enclosure services process.

NOTE 3 One example using an attached enclosure services process is an enclosure of Fibre Channel disk drives with SCA-2 connectors defined in SFF-8067. The SCA-2 connector include pins for an Enclosure Services Interface (ESI). The backplane connects selected disk drives' ESI interfaces to an enclosure management processor serving as the attached enclosure services process.

Figure 2 shows an example of an enclosure with an attached enclosure services process.



**Figure 2 — Attached enclosure services process**

The only SCSI device condition (see SAM-4) supported by an attached enclosure services process is power on. The logical unit does not communicate hard reset, logical unit reset, or I\_T nexus loss to the attached enclosure services process.

#### 4.2 Management of indicators and controls

An application client uses the SEND DIAGNOSTIC command to transmit control information to the enclosure services process. The control information may include internal and external state indicators as well as instructions to the enclosure to perform certain operations or to modify its operating mode.

The internal and external state indicators may be set to one or zero by any application client. The instructions of the application client may be ignored or overridden by the enclosure services process to assure that the proper state information is available to any application client that wants to sense an indicator (e.g., an application client may set the CRIT bit to zero in the Enclosure Control diagnostic page (see 6.1.3) to specify that it believes that a critical condition does not exist

in the enclosure. The enclosure may choose to ignore the instruction if a critical condition still exists.

The instructions to the enclosure may be ignored by the enclosure services process if the instructions request an operation not implemented by the enclosure. Enclosure services processes may modify the values requested by an application client to the most appropriate value implemented in the enclosure. Instructions may also be ignored if the enclosure services process detects that the instructions would generate undesirable conditions within the enclosure. As an example, an application client may choose to save energy by selecting low fan speeds, but the enclosure services process may ignore the request because high ambient temperatures are present, requiring high fan speeds.

An application client uses the RECEIVE DIAGNOSTIC RESULTS command with the PCV bit set to one to obtain many kinds of enclosure status information. The information shall indicate the actual state of the enclosure. The actual state is a vendor specific combination of the indications set by the instructions from application clients and the indications established by the enclosure services process.

### **4.3 Subenclosures**

#### **4.3.1 Subenclosures overview**


An enclosure consists of one subenclosure or multiple subenclosures.

When a single subenclosure is present, it is considered the primary subenclosure. There are no secondary subenclosures.

When multiple subenclosures are present:

- a) the primary subenclosure is the subenclosure whose enclosure services process provides access to enclosure services information of all the subenclosures; and
- b) all other subenclosures are considered secondary subenclosures.

Figure 3 shows an example of subenclosures.



**Figure 3 — Subenclosures**

Each subenclosure is identified by a one-byte subenclosure identifier. The primary subenclosure shall have a subenclosure identifier of 00h. The primary subenclosure shall assign a non-zero subenclosure identifier for each secondary subenclosure. The relationship between the subenclosure identifier and the subenclosure's location is vendor specific.

The enclosure services information from multiple subenclosures is combined together into a single set of SES diagnostic pages by the primary subenclosure. The information from each subenclosure is distinguished in the Configuration diagnostic page (see 6.1.2) by its subenclosure identifier.

The primary subenclosure may access enclosure service information in a subenclosure using the SEND DIAGNOSTIC command and RECEIVE DIAGNOSTIC RESULTS commands over a SCSI transport protocol, or may use a vendor-specific interface.

#### 4.3.2 Generation code

The primary subenclosure's enclosure services process shall maintain a four-byte wrapping counter called the generation code. The generation code shall be incremented by one every time that the Configuration diagnostic page changes (e.g., there is a change in the number or configuration of subenclosures). The counter shall not be changed because of status element changes. Enclosures that do not change in configuration should set the generation code to

00000000h. If the generation code is at its maximum value (i.e., FFFFFFFh), it shall wrap to 00000000h. The generation code should be set to 00000000h on power on.

The relationship between the subenclosure identifier and the subenclosure is fixed for a particular configuration and generation code. As subenclosures are added or removed, the configuration and generation code shall change. The addition or removal of a subenclosure may result in a change in the relationship between a physical subenclosure and the corresponding subenclosure identifier.

The generation code is reported in most SES status-type diagnostic pages (see 6.1). The expected generation code is used in most SES control-type diagnostic pages (see 6.1).

Standalone enclosure services processes (see 4.1.2) shall establish a unit attention condition (see SAM-4 and SPC-4) for all I\_T nexuses when there is a change in the generation code. The additional sense code for the unit attention condition shall be TARGET OPERATING CONDITIONS HAVE CHANGED. The unit attention condition shall be cleared for all I\_T nexuses without being reported if a RECEIVE DIAGNOSTIC RESULTS command is processed that requests the Configuration diagnostic page (i.e., the PCV bit is set to one and the PAGE CODE field is set to 01h).

Application clients accessing an attached enclosure services process (see 4.1.3) should verify that the generation code has not unexpectedly changed, since no unit attention condition is established by the device server.

#### 4.3.3 Simple subenclosures

A simple subenclosure is a subenclosure that does not support any SES diagnostic page (see 6.1.1) except the Short Enclosure Status diagnostic page (see 6.1.11). If a simple subenclosure is a primary subenclosure, no secondary subenclosures exist.

The enclosure services process in a simple subenclosure shall always return the Short Enclosure Status diagnostic page, regardless of which SES diagnostic page is requested by a RECEIVE DIAGNOSTIC RESULTS command. If a simple subenclosure is used as a secondary subenclosure, it shall be represented by a Simple Subenclosure element (see 7.3.24).

The enclosure services process in a simple subenclosure shall terminate any SEND DIAGNOSTIC command using an SES diagnostic page code with CHECK CONDITION status with a sense key set to ILLEGAL REQUEST and an additional sense code set to UNSUPPORTED ENCLOSURE FUNCTION.

#### 4.3.4 Multiple enclosure services processes in a subenclosure

A subenclosure may be managed by more than one enclosure services process, as shown in figure 4.




Figure 4 — Multiple enclosure service processes in a subenclosure

Elements may be accessible by one or more of the enclosure services processes. Coordination of access between multiple enclosure services processes is vendor specific.

#### 4.4 Use of the Enclosure Busy diagnostic page

An enclosure services process may return the Enclosure Busy diagnostic page (see 6.1.12) with the BUSY bit set to one rather than the requested diagnostic page when it is temporarily unable to provide the requested diagnostic page.

#### 4.5 Invalid field errors

A standalone enclosure services process (see 4.1.2) shall report errors detected while processing the SEND DIAGNOSTIC command and the RECEIVE DIAGNOSTIC RESULTS commands as defined in SPC-4 (e.g., if the PAGE CODE field in the parameter list for the SEND DIAGNOSTIC command is set to an unsupported value, terminate the command with CHECK CONDITION status with the sense key set to ILLEGAL REQUEST).

For an attached enclosure services process (see 4.1.3):

- for the SEND DIAGNOSTIC command with the PF bit set to one and the PAGE CODE field in the parameter list set to a value in the SES diagnostic page code range (see 6.1.1), the device server is not capable of completely checking the fields in the CDB and parameter list. Instead, the device server shall pass the page code and parameter list to the attached enclosure services process and complete the command with GOOD status;
- for the SEND DIAGNOSTIC command with PF bit set to zero or with the PF bit set to one and the PAGE CODE field in the parameter list set to a value outside the SES diagnostic page code range (see 6.1.1), the device server shall report errors detected while processing other fields in

- the CDB and while processing parameter lists containing page codes outside the SES diagnostic page code range as defined in SPC-4;
- c) for the RECEIVE DIAGNOSTIC RESULTS command with the PCV bit set to one and the PAGE CODE field set to a value in the SES diagnostic page code range (see 6.1.1), the device server is not capable of completely checking the fields in the CDB. Instead, the device server shall pass the page code to the attached enclosure services process, retrieve the diagnostic page, if any, from the attached enclosure services process and return it to the application client as parameter data, and complete the command with GOOD status; and
  - d) for the RECEIVE DIAGNOSTIC RESULTS command with the PCV bit set to zero or with the PCV bit set to one and the PAGE CODE field set to a value outside the SES diagnostic page code range (see 6.1.1), the device server shall report errors detected while processing other fields in the CDB and while processing page codes outside the SES diagnostic page code range as defined in SPC-4.

The attached enclosure services process uses the INVOP bit in the Enclosure Status diagnostic page (see 6.1.4) and the Threshold In diagnostic page (see 6.1.9) to report errors.

To report errors detected in the SEND DIAGNOSTIC command CDB fields or parameter list, the attached enclosure services process shall:

- a) if the PAGE CODE field is set to an unsupported value, set the INVOP bit to one in the next Enclosure Status diagnostic page returned to any application client;
- b) if the PAGE CODE field is set to 05h (i.e., Threshold Out diagnostic page) and that is a supported value, set the INVOP bit to one in the next Threshold In diagnostic page (see 6.1.9) returned to any application client; and
- c) if the PAGE CODE field is set to a supported value other than 05h, set the INVOP bit to one in the next Enclosure Status diagnostic page (see 6.1.4) returned to any application client.

To report errors detected in the RECEIVE DIAGNOSTIC RESULTS command CDB fields, the attached enclosure services process shall:

- a) if the PAGE CODE field is set to an unsupported value, return no data; and
- b) if the PAGE CODE field is set to a supported value, set the INVOP (invalid operation requested) bit to one in the next Enclosure Status diagnostic page (see 6.1.4) returned to any application client. If this command is returning the Enclosure Status diagnostic page, report the error in this command.

The attached enclosure services process may include an Invalid Operation Reason element (see 7.3.12) in the element list to indicate the reason for the error.

#### 4.6 Thresholds

For elements that have limited sensing capability (e.g., temperature sensors, uninterruptible power supplies, voltage sensors, and current sensors), an enclosure services process may support reporting when the element crosses certain threshold values:

- a) a high critical threshold;
- b) a high warning threshold;
- c) a low warning threshold; and
- d) a low critical threshold.

Thresholds are supported using the Threshold Out diagnostic page (see 6.1.8), the Threshold In diagnostic page (see 6.1.9), the threshold control element (see 7.2.4), and the threshold status element (see 7.2.4).

When the value of a sensed parameter increases above the high critical threshold value or falls below the low critical threshold value, the enclosure services process shall report a critical condition to the application client by one of the mechanisms defined in 4.7. For those device servers that use CHECK CONDITION status to indicate enclosure failures (see 4.7.4), the command shall be terminated and the sense key shall be set to HARDWARE ERROR and the additional sense code shall be set to ENCLOSURE FAILURE.

When the value of a sensed parameter increases above the high warning threshold value or falls below the low warning threshold value, the enclosure services process shall report a noncritical condition to the application client by one of the mechanisms defined in 4.7. For those device servers that use CHECK CONDITION status to indicate enclosure failures (see 4.7.4), the command shall be completed and the sense key shall be set to RECOVERED ERROR and the additional sense code shall be set to WARNING – ENCLOSURE DEGRADED.

## **4.7 Reporting methods**

### **4.7.1 Reporting methods overview**

Many enclosure functions are managed simply by setting controls and testing the status of the elements within an enclosure. However, the enclosure services process also monitors a variety of warning and error conditions. These conditions may be communicated to an application client using any of the following methods:

- a) polling (see 4.7.2);
- b) polling based on the timed completion function (see 4.7.3);
- c) CHECK CONDITION status (see 4.7.4); and
- d) asynchronous event notification (see 4.7.5).

### **4.7.2 Polling**

The application client may periodically poll the enclosure by sending a RECEIVE DIAGNOSTIC RESULTS command requesting an Enclosure Status diagnostic page (see 6.1.4) with an allocation length greater than one. The information returned in byte 1 of the Enclosure Status diagnostic page includes bits that summarize the status of the enclosure and its elements as described in 6.1.4. If one of these bits is set to one, detailed information may then be obtained by the application client by sending a RECEIVE DIAGNOSTIC RESULTS command requesting a complete Enclosure Status diagnostic page, Help Text diagnostic page (see 6.1.5), or Subenclosure Help Text diagnostic page (see 6.1.14).

### **4.7.3 Timed completion function**

The application client may enable the optional timed completion function using the Enclosure Services Management mode page (see 6.3.2). The application client may then periodically poll the enclosure by sending a RECEIVE DIAGNOSTIC RESULTS command requesting an Enclosure Status diagnostic page (see 6.1.4) with an allocation length greater than one. The return of the diagnostic page may be delayed until one or more of the bits in byte 1 of the diagnostic page are set to one. The command shall be completed by the device server before the time specified in the MAXIMUM TASK COMPLETION TIME field is exceeded whether or not one of these bits is set to one. This polling option allows the application client to access warning and error information at a time closer to the detection of the information by the enclosure services process.

### **4.7.4 CHECK CONDITION status**

A standalone device server should not terminate a RECEIVE DIAGNOSTIC RESULTS command with CHECK CONDITION status to report warning conditions and failure conditions relating to enclosure services.

The device server may use informational exception conditions (see SPC-4) to indicate conditions that do not require any recovery action.

For attached enclosure services processes (see 4.1.3), the device server shall not terminate commands with CHECK CONDITION status to indicate the presence of information from the enclosure services process. Application clients shall use polling (see 4.7.2) to access the enclosure information through such device servers.

#### 4.7.5 Asynchronous event notification

For standalone enclosure services processes with a SCSI target port using a SCSI transport protocol that supports notification of SES asynchronous events (e.g., Broadcast (SES) in SAS-2), the enclosure services process:

- a) shall report an asynchronous event when the generation code changes (see 4.3.2);
- b) shall report an asynchronous event when an element change results in a change to the PRDFAIL bit or the ELEMENT STATUS CODE field in a status element (see 7.2.3) (e.g., an element exceeds a threshold);
- c) may report an asynchronous event when an element change does not result in a change to the PRDFAIL bit or the ELEMENT STATUS CODE field in a status element (see 7.2.3);
- d) should report an asynchronous event when the Element Descriptor diagnostic page (see 6.1.10) changes;
- e) should report an asynchronous event when the Short Enclosure Status diagnostic page (see 6.1.11) changes;
- f) should report an asynchronous event when the Additional Element Status diagnostic page (see 6.1.13) changes;
- g) should report an asynchronous event when the Download Microcode Status diagnostic page (see 6.1.19) changes to a code implementing completion; and
- h) should report an asynchronous event when the Subenclosure Nickname Status diagnostic page (see 6.1.21) changes.

#### 4.8 Additional sense codes

The additional sense code values defined for this standard are described in table 2. The values are assigned in SPC-4.

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011

**Table 2 — Sense keys and additional sense codes**

Sense key	Additional sense code	Reason
HARDWARE ERROR	ENCLOSURE SERVICES FAILURE <sup>a</sup>	The enclosure services process has failed in an unknown manner.
	ENCLOSURE SERVICES TRANSFER FAILURE <sup>a</sup>	The device server communication with the enclosure services process has failed.
	ENCLOSURE FAILURE <sup>b</sup>	An unrecoverable enclosure failure (e.g., from a threshold exceeding a critical limit (see 4.6)) has been detected by the enclosure services process. Further information may be available using the RECEIVE DIAGNOSTIC RESULTS command and requesting the Enclosure Status diagnostic page (see 6.1.4).
HARDWARE ERROR or ILLEGAL REQUEST	ENCLOSURE SERVICES TRANSFER REFUSED <sup>a</sup>	The device server or the enclosure services process indicated either an error or an invalid format in their communication.
ILLEGAL REQUEST	UNSUPPORTED ENCLOSURE FUNCTION <sup>a</sup>	A SEND DIAGNOSTIC command has been attempted to a simple subenclosure (see 4.3.3).
NOT READY	ENCLOSURE SERVICES UNAVAILABLE <sup>a</sup>	The device server communication with the enclosure service process has encountered an error, but may become available again.
RECOVERED ERROR	WARNING – ENCLOSURE DEGRADED <sup>b</sup>	A noncritical failure (e.g., from a threshold exceeding a warning limit (see 4.6)) has been detected by the enclosure services process. This may be managed by the Informational Exceptions Control mode page (see SPC-4). Further information may be available using the RECEIVE DIAGNOSTIC RESULTS command and requesting the Enclosure Status diagnostic page (see 6.1.4).
<sup>a</sup> May be returned by any logical unit that provides access to enclosure services, either standalone (see 4.1.2) or attached (see 4.1.3). <sup>b</sup> Should only be returned by a standalone enclosure services process in the sense data for a CHECK CONDITION status returned for a command other than RECEIVE DIAGNOSTIC RESULTS.		

## 5 Commands for enclosure services peripheral devices

The commands for standalone enclosure services processes (i.e., logical units with the peripheral device type of enclosure services (i.e., 0Dh)) (see 4.1.2) are shown in table 3.

**Table 3 — Commands for standalone enclosure services processes (part 1 of 2)**

Command name	Operation code <sup>a</sup>	Type <sup>b</sup>	Reference
ACCESS CONTROL IN	86h	O	SPC-4
ACCESS CONTROL OUT	87h	O	SPC-4
CHANGE ALIASES	A4h/0Bh	O	SPC-4
INQUIRY <sup>f</sup>	12h	M	SPC-4
LOG SELECT	4Ch	O	SPC-4
LOG SENSE	4Dh	O	SPC-4
MAINTENANCE IN	A3h/00h to 04h A3h/06h to 09h	X <sup>e</sup>	SCC-2
MAINTENANCE OUT	A4h/00h to 05h A4h/07h to 09h	X <sup>e</sup>	SCC-2
MODE SELECT (10)	55h	O	SPC-4
MODE SELECT (6)	15h	O	SPC-4
MODE SENSE (10)	5Ah	O	SPC-4
MODE SENSE (6)	1Ah	O	SPC-4
PERSISTENT RESERVE IN	5Eh	O	SPC-4
PERSISTENT RESERVE OUT	5Fh	O	SPC-4
READ BUFFER	3Ch	O	SPC-4
RECEIVE DIAGNOSTIC RESULTS <sup>c</sup>	1Ch	M	SPC-4
REDUNDANCY GROUP IN	BAh	X <sup>e</sup>	SCC-2
REDUNDANCY GROUP OUT	BBh	X <sup>e</sup>	SCC-2
REPORT ALIASES	A3h/0Bh	O	SPC-4
REPORT IDENTIFYING INFORMATION	A3h/05h	O	SPC-4
REPORT LUNS	A0h	M	SPC-4
REPORT PRIORITY	A3h/0Eh	O	SPC-4
REPORT SUPPORTED OPERATION CODES	A3h/0Ch	O	SPC-4
REPORT SUPPORTED TASK MANAGEMENT FUNCTIONS	A3h/0Dh	O	SPC-4
REPORT TARGET PORT GROUPS	A3h/0Ah	O	SPC-4
REPORT TIMESTAMP	A3h/0Fh	O	SPC-4

<sup>a</sup> Some commands are defined by a combination of operation code and service action. The operation code value is shown preceding the slash and the service action value is shown after the slash.

<sup>b</sup> M means command implementation is mandatory. O means command implementation is optional. X means command implementation requirements are detailed in the reference.

<sup>c</sup> SES status-type diagnostic pages (see 6.1) are transferred by the RECEIVE DIAGNOSTIC RESULTS command with the PCV bit set to one.

<sup>d</sup> SES control-type diagnostic pages (see 6.1) are transferred by the SEND DIAGNOSTIC command with the PF bit set to one. Device servers are only required to accept a single diagnostic page in each command.

<sup>e</sup> If the SCCS bit is set to one in the standard INQUIRY data (see SPC-4), these commands shall be supported as required by SCC-2. If the SCCS bit is set to zero, these commands shall not be supported.

<sup>f</sup> In the standard INQUIRY data (see SPC-4), the MCHNGR bit shall be set to zero.

<sup>g</sup> The following operation codes are obsolete: 16h, 17h, 56h, and 57h.

**Table 3 — Commands for standalone enclosure services processes (part 2 of 2)**

Command name	Operation code <sup>a</sup>	Type <sup>b</sup>	Reference
REQUEST SENSE	03h	M	SPC-4
SEND DIAGNOSTIC <sup>d</sup>	1Dh	M	SPC-4
SET IDENTIFYING INFORMATION	A4h/06h	O	SPC-4
SET PRIORITY	A4h/0Eh	O	SPC-4
SET TARGET PORT GROUPS	A4h/0Ah	O	SPC-4
SET TIMESTAMP	A4h/0Fh	O	SPC-4
SPARE IN	BCh	X <sup>e</sup>	SCC-2
SPARE OUT	BDh	X <sup>e</sup>	SCC-2
TEST UNIT READY	00h	M	SPC-4
VOLUME SET IN	BEh	X <sup>e</sup>	SCC-2
VOLUME SET OUT	BFh	X <sup>e</sup>	SCC-2
WRITE BUFFER	3Bh	O	SPC-4
Obsolete <sup>g</sup>			
Reserved	All others		

<sup>a</sup> Some commands are defined by a combination of operation code and service action. The operation code value is shown preceding the slash and the service action value is shown after the slash.

<sup>b</sup> M means command implementation is mandatory. O means command implementation is optional. X means command implementation requirements are detailed in the reference.

<sup>c</sup> SES status-type diagnostic pages (see 6.1) are transferred by the RECEIVE DIAGNOSTIC RESULTS command with the PCV bit set to one.

<sup>d</sup> SES control-type diagnostic pages (see 6.1) are transferred by the SEND DIAGNOSTIC command with the PF bit set to one. Device servers are only required to accept a single diagnostic page in each command.

<sup>e</sup> If the SCCS bit is set to one in the standard INQUIRY data (see SPC-4), these commands shall be supported as required by SCC-2. If the SCCS bit is set to zero, these commands shall not be supported.

<sup>f</sup> In the standard INQUIRY data (see SPC-4) the MCHNGR bit shall be set to zero.

<sup>g</sup> The following operation codes are obsolete: 16h, 17h, 56h, and 57h.

All the commands are described in the referenced standards. The diagnostic pages accessed by the SEND DIAGNOSTIC command and the RECEIVE DIAGNOSTIC RESULTS command are defined in 6.1. The elements accessed by some of the diagnostic pages are defined in clause 7. The format for the mode parameters and mode page accessed by the MODE SELECT commands and the MODE SENSE commands are defined in 6.3.

## 6 Parameters for enclosure services devices

### 6.1 Diagnostic parameters

#### 6.1.1 Diagnostic parameters overview

This clause defines the diagnostic page structure and the diagnostic pages that are applicable to enclosure services devices and other device types that provide communications access to an enclosure services process. Control pages are accessed with the SEND DIAGNOSTIC command. Status pages are accessed with the RECEIVE DIAGNOSTIC RESULTS command.

The diagnostic page format is specified in SPC-4. All diagnostic pages have the diagnostic page header defined in SPC-4, including the PAGE CODE and PAGE LENGTH fields.

The PAGE CODE field identifies the diagnostic page being sent or requested. The page codes are defined in table 4.

**Table 4 — Diagnostic page codes for enclosure service devices** (part 1 of 2)

Page code	Description <sup>a</sup>	Control or status	Type <sup>b</sup>	Reference
00h	Supported Diagnostic Pages diagnostic page	Status	M	SPC-4
SES diagnostic pages				
01h	Configuration diagnostic page	Status	A	6.1.2
02h	Enclosure Control diagnostic page	Control	A	6.1.3
	Enclosure Status diagnostic page	Status	A	6.1.4
03h	Help Text diagnostic page	Status	B	6.1.5
04h	String Out diagnostic page	Control	B	6.1.6
	String In diagnostic page	Status	B	6.1.7
05h	Threshold Out diagnostic page	Control	B	6.1.8
	Threshold In diagnostic page	Status	B	6.1.9
06h	Obsolete			
07h	Element Descriptor diagnostic page	Status	B	6.1.10
08h	Short Enclosure Status diagnostic page	Status	O	6.1.11
09h	Enclosure Busy diagnostic page	Status	B	6.1.12
0Ah	Additional Element Status diagnostic page	Status	B	6.1.13
0Bh	Subenclosure Help Text diagnostic page	Status	B	6.1.14
0Ch	Subenclosure String Out diagnostic page	Control	B	6.1.15
	Subenclosure String In diagnostic page	Status	B	6.1.16
0Dh	Supported SES Diagnostic Pages diagnostic page	Status	B	6.1.17
0Eh	Download Microcode Control diagnostic page	Control	B	6.1.18
	Download Microcode Status diagnostic page	Status	B	6.1.19
0Fh	Subenclosure Nickname Control diagnostic page	Control	B	6.1.20
	Subenclosure Nickname Status diagnostic page	Status	B	6.1.21

<sup>a</sup> A simple subenclosure responds with a Short Enclosure Status diagnostic page when any SES diagnostic page is requested by a RECEIVE DIAGNOSTIC RESULTS command. See 4.3.3.

<sup>b</sup> M means mandatory. O means optional. A means mandatory if the Short Enclosure Status diagnostic page is not supported, prohibited if the Short Enclosure Status diagnostic page is supported (i.e., in a simple subenclosure). B means optional if the Short Enclosure Status diagnostic page is not supported, prohibited if the Short Enclosure Status diagnostic page is supported (i.e., in a simple subenclosure).

**Table 4 — Diagnostic page codes for enclosure service devices** (part 2 of 2)

Page code	Description <sup>a</sup>	Control or status	Type <sup>b</sup>	Reference
10h to 1Fh	Vendor-specific SES diagnostic pages			
20h to 2Fh	Reserved for this standard			
Additional non-SES diagnostic pages				
30h to 3Eh	Reserved for all peripheral device types			SPC-4
3Fh	See specific SCSI transport protocol for definition			SCSI transport protocol
40h to 7Fh	See specific peripheral device type for definition. Reserved for the SES peripheral device type			SPC-4
80h to FFh	Vendor-specific diagnostic pages			SPC-4
<sup>a</sup> A simple subenclosure responds with a Short Enclosure Status diagnostic page when any SES diagnostic page is requested by a RECEIVE DIAGNOSTIC RESULTS command. See 4.3.3. <sup>b</sup> M means mandatory. O means optional. A means mandatory if the Short Enclosure Status diagnostic page is not supported, prohibited if the Short Enclosure Status diagnostic page is supported (i.e., in a simple subenclosure). B means optional if the Short Enclosure Status diagnostic page is not supported, prohibited if the Short Enclosure Status diagnostic page is supported (i.e., in a simple subenclosure).				

The Supported Diagnostic Pages diagnostic page defined in SPC-4 contains a list of all diagnostic page codes implemented by the device server in ascending order beginning with diagnostic page code 00h. If the device server is capable of accessing a diagnostic page that may temporarily or permanently be unavailable, then its diagnostic page code shall be included in the list. The unavailability of the resources necessary to transfer a diagnostic page shall not result in an error until a command attempts to access that diagnostic page.

Device servers supporting access to an attached enclosure services process (see 4.1.3) shall direct diagnostic pages 01h through 2Fh to the attached enclosure services process and shall report all diagnostic page codes 00h through 2Fh in the Supported Diagnostic Pages diagnostic page.

## 6.1.2 Configuration diagnostic page

### 6.1.2.1 Configuration diagnostic page overview

The Configuration diagnostic page returns information about the enclosure, including the list of elements in the enclosure. The element list shall include all elements with defined element status or controls and may list any other elements in the enclosure. The Configuration diagnostic page provides enclosure descriptor information and parameters. The Configuration diagnostic page may provide descriptive text identifying element types in more detail.

The Configuration diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 01h. A PAGE CODE field set to 01h in the parameter list for a SEND DIAGNOSTIC command is an invalid field error (see 4.5).

Table 5 defines the Configuration diagnostic page.

**Table 5 — Configuration diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (01h)							
1	NUMBER OF SECONDARY SUBENCLOSURES							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	(MSB)	GENERATION CODE						(LSB)
7								
Enclosure descriptor list								
8	Enclosure descriptor(s) (one per subenclosure) (see table 6 in 6.1.2.2)							
Type descriptor header list (see 6.1.2.3)								
Type descriptor header(s) (see table 7 in 6.1.2.3)								
Type descriptor text list (see 6.1.2.4)								
n	Type descriptor text(s) (one per type descriptor header) (see 6.1.2.4)							

The PAGE CODE field is set to 01h.

The NUMBER OF SECONDARY SUBENCLOSURES field indicates the number of secondary subenclosures included in the enclosure descriptor list. The primary subenclosure shall be described by the first enclosure descriptor. Secondary subenclosures shall be described in subsequent enclosure descriptors, and may be included in any order.

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The GENERATION CODE field indicates the value of the generation code (see 4.3.2).

The enclosure descriptor list contains an enclosure descriptor (see 6.1.2.2) for the primary subenclosure and each secondary subenclosure, if any. The first enclosure descriptor shall describe the primary subenclosure. Subsequent enclosure descriptors shall describe the secondary subenclosures, and may be in any order.

The type descriptor header list is defined in 6.1.2.3.

The type descriptor text list is defined in 6.1.2.4.

NOTE 4 The type descriptor text list follows the complete type descriptor header list (i.e., after all type descriptor headers).

### 6.1.2.2 Enclosure descriptor

Table 6 defines the enclosure descriptor.

**Table 6 — Enclosure descriptor**

Bit Byte	7	6	5	4	3	2	1	0
0	Reserved	RELATIVE ENCLOSURE SERVICES PROCESS IDENTIFIER			Reserved	NUMBER OF ENCLOSURE SERVICES PROCESSES		
1	SUBENCLOSURE IDENTIFIER							
2	NUMBER OF TYPE DESCRIPTOR HEADERS							
3	ENCLOSURE DESCRIPTOR LENGTH (m - 3)							
4	ENCLOSURE LOGICAL IDENTIFIER							
11	ENCLOSURE VENDOR IDENTIFICATION							
12	PRODUCT IDENTIFICATION							
35	PRODUCT REVISION LEVEL							
36	VENDOR-SPECIFIC ENCLOSURE INFORMATION							
39								
40								
m								

The RELATIVE ENCLOSURE SERVICES PROCESS IDENTIFIER field identifies the enclosure services process relative to other enclosure services processes in the subenclosure. A value of 0h is reserved.

The NUMBER OF ENCLOSURE SERVICES PROCESSES field indicates the number of enclosure services processes in the subenclosure. A value of 0h indicates the number is not known.

The SUBENCLOSURE IDENTIFIER field indicates the subenclosure (see 4.3) described by this enclosure descriptor.

The NUMBER OF TYPE DESCRIPTOR HEADERS field indicates the number of type descriptor headers (see 6.1.2.3) in the Configuration diagnostic page with this subenclosure identifier. The total number of type descriptor headers is equal to the sum of the contents of the NUMBER OF TYPE DESCRIPTOR HEADERS fields for the primary subenclosure and all of the secondary subenclosures.

The ENCLOSURE DESCRIPTOR LENGTH field indicates the number of bytes that follow in the enclosure descriptor. The value shall be a multiple of four, having allowed values between 36 and 252. The ENCLOSURE DESCRIPTOR LENGTH includes the length of the ENCLOSURE LOGICAL IDENTIFIER field, the ENCLOSURE VENDOR IDENTIFICATION field, the PRODUCT IDENTIFICATION field, the PRODUCT REVISION LEVEL field, and any vendor specific enclosure information.

The ENCLOSURE LOGICAL IDENTIFIER field contains a unique logical identifier for the subenclosure. It shall use an 8-byte NAA identifier, the format of which is defined in SPC-4 vital product data (see SPC-4). The ENCLOSURE LOGICAL IDENTIFIER field shall be unique to the subenclosure and may be different than the world wide name of the logical unit providing the enclosure services.

The ENCLOSURE VENDOR IDENTIFICATION field contains the identification string for the vendor of the subenclosure in the same format as specified for the VENDOR IDENTIFICATION field of the standard INQUIRY data (see SPC-4). The ENCLOSURE VENDOR IDENTIFICATION field may contain a different value than the vendor identification of the logical unit providing the enclosure services.

The PRODUCT IDENTIFICATION field contains the product identification string for the subenclosure in the same format as specified for the PRODUCT IDENTIFICATION field of the standard INQUIRY data (see SPC-4). The PRODUCT IDENTIFICATION field may contain a different value than the product identification of the logical unit providing the enclosure services.

The PRODUCT REVISION LEVEL field contains the product revision level string for the subenclosure in the same format as specified for the PRODUCT REVISION LEVEL field of the standard INQUIRY data (see SPC-4). The PRODUCT REVISION LEVEL field may contain a different value than the product revision level of the logical unit providing the enclosure services.

The VENDOR-SPECIFIC ENCLOSURE INFORMATION field contains vendor-specific information.

**6.1.2.3 Type descriptor header list**

The type descriptor header list shall contain type descriptor headers in the following order, regardless of their subenclosure identifiers:

- 1) type descriptor headers for Device Slot elements and Array Device Slot elements; and
- 2) type descriptor headers for elements with other element types.

The elements of an enclosure shall be listed in the same order in:

- a) the type descriptor header list;
- b) the type descriptor text list (see 6.1.2.4);
- c) the Enclosure Control diagnostic page (see 6.1.3);
- d) the Enclosure Status diagnostic page (see 6.1.4);
- e) the Threshold Out diagnostic page (see 6.1.8); and
- f) the Threshold In diagnostic page (see 6.1.9).

The type descriptor header is defined in table 7.

**Table 7 — Type descriptor header format**

Bit Byte	7	6	5	4	3	2	1	0
0	ELEMENT TYPE							
1	NUMBER OF POSSIBLE ELEMENTS							
2	SUBENCLOSURE IDENTIFIER							
3	TYPE DESCRIPTOR TEXT LENGTH							

The ELEMENT TYPE field in the type descriptor header indicates the element type being described in the type descriptor. The list of element types is shown in table 59 (see 7.1). More than one type descriptor header may contain the same ELEMENT TYPE field value (e.g., there may be two power supplies that provide +12 V and five power supplies that provide +5 V. In this case, a separate TYPE DESCRIPTOR HEADER may be used for the +12 V power supplies and for the +5 V power supplies).

The NUMBER OF POSSIBLE ELEMENTS field in the type descriptor header indicates the number of elements of the indicated type that it is possible to install in the subenclosure. The actual number of elements installed may be smaller than the number that the configuration is capable of accepting. If the NUMBER OF POSSIBLE ELEMENTS field is set to zero, then the type descriptor corresponds to one overall element and no individual elements. The maximum number of elements represented by a single type descriptor shall be 255.

The SUBENCLOSURE IDENTIFIER field in the type descriptor header indicates the subenclosure (see 4.3) in which the elements described by this type descriptor reside.

The TYPE DESCRIPTOR TEXT LENGTH field in the type descriptor header indicates the number of bytes in the type descriptor text (see 6.1.2.4), if any. If the ELEMENT TYPE field is set to a vendor specific value, then the TYPE DESCRIPTOR TEXT LENGTH field shall be set to a nonzero value and shall have type descriptor text adequate to identify the element to an application client. Other element types may have a TYPE DESCRIPTOR TEXT LENGTH field set to 00h.

#### 6.1.2.4 Type descriptor text list

The type descriptor text list shall contain type descriptor texts in the same order as the type descriptor headers. If the TYPE DESCRIPTOR TEXT LENGTH field is set to zero in the type descriptor header, then there is no type descriptor text.

The type descriptor text is a text string from zero to 255 bytes for each type descriptor header (see 6.1.2.3). The text string, if it has a length greater than zero, may contain any descriptive information about the element type that may be useful to an application client that is displaying the configuration of the enclosure (e.g., the manufacturer's part number for a replacement element, a brief description of the element and its properties, or instructions about configuration limitations and redundancy requirements of the elements of that type).

The type descriptor text uses the character encoding and language indicated by the Language element (see 7.3.18).

#### 6.1.3 Enclosure Control diagnostic page

The Enclosure Control diagnostic page provides access to the control elements identified by the Configuration diagnostic page (see 6.1.2).

The Enclosure Control diagnostic page is written by the SEND DIAGNOSTIC command. A RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 02h is defined as the request to read the Enclosure Status diagnostic page (see 6.1.4).

Table 8 defines the Enclosure Control diagnostic page.

**Table 8 — Enclosure Control diagnostic page**

Byte	Bit	7	6	5	4	3	2	1	0
0		PAGE CODE (02h)							
1		Reserved				INFO	NON-CRIT	CRIT	UNRECOV
2	(MSB)	PAGE LENGTH (n - 3)							
3		(LSB)							
4	(MSB)	EXPECTED GENERATION CODE							
7		(LSB)							
Control descriptor list									
8		Control descriptor (first) (see table 9)							
...									
n		Control descriptor (last) (see table 9)							

The PAGE CODE field is set to 02h.

The INFO bit, the NON-CRIT bit, the CRIT bit, and the UNRECOV bit are each mandatory and may be set to one in the enclosure by the application client when the application client has detected that one or more of the elements in the enclosure are not operating normally.

An INFO (informational condition) bit set to one specifies that the application client is detecting an informational condition. An INFO bit set to zero has no effect.

A NON-CRIT (noncritical condition) bit set to one specifies that the application client is detecting a noncritical condition. A NON-CRIT bit set to zero specifies that the application client is not detecting a noncritical condition. If the enclosure services process has independently determined that a

noncritical condition is present, then a request from the application client to set the NON-CRIT bit to zero shall be ignored by the enclosure services process.

A CRIT (critical condition) bit set to one specifies that the application client is detecting a critical condition. A CRIT bit set to zero specifies that the application client is not detecting a critical condition. If the enclosure services process has independently determined that a critical condition is present, then a request from the application client to set the CRIT bit to zero shall be ignored by the enclosure services process.

An UNRECOV (unrecoverable condition) bit set to one specifies that the application client is detecting an unrecoverable condition. An UNRECOV bit set to zero specifies that the application client is not detecting an unrecoverable condition. If the enclosure services process has independently determined that an unrecoverable condition is present, then a request from the application client to set the UNRECOV bit to zero shall be ignored by the enclosure services process.

The PAGE LENGTH field specifies the number of bytes that follow in the diagnostic page.

The EXPECTED GENERATION CODE field specifies the expected value of the generation code (see 4.3.2). If the EXPECTED GENERATION CODE field contains the current generation code (i.e., the value of the generation code field that would be returned by a Configuration diagnostic page at this time), then the enclosure services process shall process the diagnostic page. If the EXPECTED GENERATION CODE field does not contain the current generation code, then the application client shall be notified of an invalid field error (see 4.5) and the enclosure services process shall ignore the remainder of the Enclosure Control diagnostic page.

The control descriptor list contains a control descriptor for each type descriptor header in the Configuration diagnostic page (see 6.1.2).

Table 9 defines the control descriptor.

**Table 9 — Control descriptor**

Byte	Bit	7	6	5	4	3	2	1	0
0		Overall control element (see table 60 in 7.2.2)							
3		Overall control element (see table 60 in 7.2.2)							
Individual control element list									
4		Individual control element (first) (see table 60 in 7.2.2)							
7		Individual control element (first) (see table 60 in 7.2.2)							
...									
m - 3		Individual control element (last) (see table 60 in 7.2.2)							
m		Individual control element (last) (see table 60 in 7.2.2)							

The overall control element provides control for all the elements corresponding to the type descriptor header. The general format for the overall control element is defined by table 60 in 7.2.2.

The individual control element list contains an individual control element for each of the possible elements identified by the NUMBER OF POSSIBLE ELEMENTS field in the corresponding type descriptor header.

Each control element contains control information for the element. The general format for the individual control element is defined by table 60 in 7.2.2.

The individual control elements override the overall control element as defined in table 10.

**Table 10 — Control element processing**

Individual control element SELECT bit	Overall control element SELECT bit	Description
0	0	The enclosure services process shall not change the element
	1	The enclosure services process should change the element based on the overall control element
1	0 or 1	The enclosure services process should change the element based on the individual control element

#### 6.1.4 Enclosure Status diagnostic page

The Enclosure Status diagnostic page provides access to the status elements identified by the Configuration diagnostic page (see 6.1.2).

The Enclosure Status diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 02h. The transmission of a page using the SEND DIAGNOSTIC command with a PAGE CODE field set to 02h is defined as the transmission of an Enclosure Control diagnostic page (see 6.1.3).

Table 11 defines the Enclosure Status diagnostic page.

**Table 11 — Enclosure Status diagnostic page**

Byte	Bit 7	6	5	4	3	2	1	0
0	PAGE CODE (02h)							
1	Reserved			INVOP	INFO	NON-CRIT	CRIT	UNRECOV
2	(MSB)							
3	PAGE LENGTH (n - 3)							(LSB)
4	(MSB)							
7	GENERATION CODE							(LSB)
Status descriptor list								
8	Status descriptor (first) (see table 12)							
...								
n	Status descriptor (last) (see table 12)							

The PAGE CODE field is set to 02h.

The INVOP bit, the INFO bit, the NON-CRIT bit, the CRIT bit, and the UNRECOV bit are each mandatory. The bits may be read with an allocation length greater than one and may be examined by an enclosure polling procedure to determine if events have occurred that require reading the complete page. The bits are set independently and may be set in any combination. The bits may be set by either the enclosure services process or with the Enclosure Control diagnostic page.

The INVOP (invalid operation requested) bit shall be set to one if an invalid field error has occurred (e.g., an Enclosure Control diagnostic page with an invalid format has previously been transmitted to the enclosure services process and an application client has not already been informed of the

invalid field error) and the SEND DIAGNOSTIC command was not terminated with CHECK CONDITION status to notify the application client of the invalid field error.

Each time the INVOP bit is set to one:

- a) standalone enclosure services processes (see 4.1.2) shall set the INVOP bit to one the first time they return the Enclosure Status diagnostic page to the same I\_T nexus that transmitted the invalid control-type diagnostic page and shall set the INVOP bit to zero for subsequent requests; and
- b) attached enclosure services processes (see 4.1.3) shall set the INVOP bit to one the first time they return the Enclosure Status diagnostic page to any application client and shall set the INVOP bit to zero for subsequent requests.

An Invalid Operation Reason status element may be included in the element list as reported by the Configuration diagnostic page (see 6.1.2). If the INVOP bit is set to zero and an Invalid Operation Reason status element (see 7.3.12) is included, then the Invalid Operation Reason status element shall be ignored.

An INFO (information) bit set to one indicates that one or more information conditions have been detected by the enclosure services process or specified by an application client with the Enclosure Control diagnostic page. Each time the INFO bit is set to one by any mechanism:

- a) standalone enclosure services processes (see 4.1.2) shall set the INFO bit set to one the first time they return the Enclosure Status diagnostic page to each I\_T nexus and shall set the INFO bit to zero for subsequent requests; and
- b) attached enclosure services processes (see 4.1.3) shall set the INFO bit set to one the first time they return the Enclosure Status diagnostic page to any application client and may set the INFO bit to zero for subsequent requests.

An INFO bit shall be set to one once as an indication to the application client that an information condition is available and not set to one again until a new information condition occurs.

A NON-CRIT (noncritical condition) bit set to one indicates that one or more noncritical conditions have been detected by the enclosure services process or specified by an application client with the Enclosure Control diagnostic page. A NON-CRIT bit set to zero indicates that both the following conditions are met:

- a) all noncritical conditions have been corrected in the enclosure; and
- b) an application client has set the NON-CRIT bit to zero in the Enclosure Control diagnostic page.

A CRIT (critical condition) bit set to one indicates that one or more critical conditions have been detected by the enclosure services process or specified by an application client with the Enclosure Control diagnostic page. A CRIT bit set to zero indicates that both the following conditions are met:

- a) all critical conditions have been corrected in the enclosure; and
- b) an application client has set the CRIT bit to zero in the Enclosure Control diagnostic page.

An UNRECOV (unrecoverable condition) bit set to one indicates that one or more unrecoverable conditions have been detected by the enclosure services process or specified by an application client with the Enclosure Control diagnostic page. An UNRECOV bit set to zero indicates that both the following conditions are met:

- a) all unrecoverable conditions have been corrected in the enclosure; and
- b) an application client has set the UNRECOV bit to zero in the Enclosure Control diagnostic page.

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The GENERATION CODE field indicates the value of the generation code (see 4.3.2).

The status descriptor list contains a status descriptor for each type descriptor header in the Configuration diagnostic page (see 6.1.2).

Table 12 defines the status descriptor.

**Table 12 — Status descriptor**

Byte	Bit	7	6	5	4	3	2	1	0
0		Overall status element (see table 61 in 7.2.3)							
3		Overall status element (see table 61 in 7.2.3)							
Individual status element list									
4		Individual status element (first) (see table 61 in 7.2.3)							
7		Individual status element (first) (see table 61 in 7.2.3)							
...									
m - 3		Individual status element (last) (see table 61 in 7.2.3)							
m		Individual status element (last) (see table 61 in 7.2.3)							

The overall status element provides summary status for all the elements described by the type descriptor header and may provide status for elements whose individual status is not available. The general format for the overall status element is defined by table 61 in 7.2.3.

The individual status element list contains an individual status element for each of the possible elements identified by the NUMBER OF POSSIBLE ELEMENTS field in the corresponding type descriptor header.

Each individual status element contains status information for the element. The general format for the individual status element is defined by table 61 in 7.2.3.

Individual status elements override the overall status element (e.g., an enclosure with three temperature sensors may report the average of the three sensors in the overall status element and/or may report the individual sensor values in the individual status elements). Both the overall status element and the element status element may contain information (e.g., the overall status element contains the average and the individual status elements contain the specific individual values).

#### 6.1.5 Help Text diagnostic page

The Help Text diagnostic page contains a text string from the primary subenclosure that describes the present state of the primary subenclosure and indicates what corrective actions, if any, should be performed. The Help Text diagnostic page allows enclosure-independent application clients to return enclosure-specific text describing the state of the enclosure and explaining enclosure-dependent corrective actions that may be required. This page does not support secondary subenclosures. For secondary subenclosures, see the Subenclosure Help Text diagnostic page (see 6.1.14).

The Help Text diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 03h. A PAGE CODE field set to 03h in the parameter list for a SEND DIAGNOSTIC command is an invalid field error (see 4.5).

Table 13 defines the Help Text diagnostic page.

**Table 13 — Help Text diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (03h)							
1	Obsolete							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	PRIMARY SUBENCLOSURE HELP TEXT							
n								

The PAGE CODE field is set to 03h.

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The PRIMARY SUBENCLOSURE HELP TEXT field contains a text string describing what corrective actions should be performed on the primary subenclosure. The text string shall use the language and character set indicated by the Language element (see 7.3.18).

### 6.1.6 String Out diagnostic page

The String Out diagnostic page transmits an enclosure dependent binary string from the application client to the enclosure services process of the primary subenclosure. The binary string may contain bits describing indicator states, text or graphic display information, or control information outside the context of the elements defined in the Configuration diagnostic page (see 6.1.2).

This page does not support secondary subenclosures. For secondary subenclosures, see the Subenclosure String Out diagnostic page (see 6.1.15).

The format of the binary string is vendor specific. For standalone enclosure services processes (see 4.1.2), an application client may select the format of the binary string using the manufacturer name and mode from the standard INQUIRY data (see SPC-4) or using the enclosure header information in the Configuration diagnostic page. For attached enclosure services processes (see 4.1.3), an application client should select the format of the binary string using the enclosure header information in the Configuration diagnostic page.

The String Out diagnostic page is written by the SEND DIAGNOSTIC command. A RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 04h is defined as the request to read the String In diagnostic page (see 6.1.7).

Table 14 defines the String Out diagnostic page.

**Table 14 — String Out diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (04h)							
1	Obsolete							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	PRIMARY SUBENCLOSURE STRING OUT DATA							
n								

The PAGE CODE field is set to 04h.

The PAGE LENGTH field specifies the number of bytes that follow in the diagnostic page.

The PRIMARY SUBENCLOSURE STRING OUT DATA field shall contain the vendor specific information to be transferred from the application client to the enclosure services process of the primary subenclosure.

### 6.1.7 String In diagnostic page

The String In diagnostic page transmits a subenclosure dependent binary string from the enclosure services process of the primary subenclosure to the application client. The binary string may contain bits describing keyboard states, switch states, or the content of other information provided by the primary subenclosure to the application client.

This page does not support secondary subenclosures. For secondary subenclosures, see the Subenclosure String In diagnostic page (see 6.1.16).

The format of the binary string is vendor specific. For standalone enclosure services processes (see 4.1.2), an application client may determine the format of the binary string using the manufacturer name and mode from the standard INQUIRY data (see SPC-4) or using the enclosure header information in the Configuration diagnostic page (see 6.1.2). For attached enclosure services processes (see 4.1.3), an application client should select the format of the binary string using the enclosure header information in the Configuration diagnostic page.

The String In diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 04h. The transmission of a page using the SEND DIAGNOSTIC command with a PAGE CODE field set to 04h is defined as the transmission of a String Out diagnostic page (see 6.1.6).

Table 15 defines the String In diagnostic page.

**Table 15 — String In diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0	
0	PAGE CODE (04h)								
1	Obsolete								
2	(MSB)	PAGE LENGTH (n - 3)							
3								(LSB)	
4	PRIMARY SUBENCLOSURE STRING IN DATA								
n									

The PAGE CODE field is set to 04h.

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The PRIMARY SUBENCLOSURE STRING IN DATA field shall contain the vendor specific information to be transferred from the enclosure services process of the primary subenclosure to the application client.

### 6.1.8 Threshold Out diagnostic page

The Threshold Out diagnostic page is transmitted to the enclosure services process to establish threshold values for those elements that have limited sensing capability (e.g., temperature sensors, uninterruptible power supplies, voltage sensors, and current sensors).

The Threshold Out diagnostic page is written by the SEND DIAGNOSTIC command. A RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 05h is defined as the request to read the Threshold In diagnostic page (see 6.1.9).

Table 16 defines the Threshold Out diagnostic page.

**Table 16 — Threshold Out diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (05h)							
1	Reserved							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	(MSB)	EXPECTED GENERATION CODE						(LSB)
7								
Threshold control descriptor list								
8	Threshold control descriptor (first) (see table 17)							
...								
n	Threshold control descriptor (last) (see table 17)							

The PAGE CODE field is set to 05h.

The PAGE LENGTH field specifies the number of bytes that follow in the diagnostic page.

The EXPECTED GENERATION CODE field is defined in the Enclosure Control diagnostic page (see 6.1.3).

The threshold control descriptor list contains a threshold control descriptor for each type descriptor header in the Configuration diagnostic page (see 6.1.2).

Table 17 defines the threshold control descriptor.

**Table 17 — Threshold control descriptor**

Bit Byte	7	6	5	4	3	2	1	0
0	Overall threshold control element (see table 64 in 7.2.4)							
3								
Individual threshold control element list								
4	Individual threshold control element (first) (see table 64 in 7.2.4)							
7								
...								
m - 3	Individual threshold control element (last) (see table 64 in 7.2.4)							
m								

The overall threshold control element provides shared threshold control for all the elements described by the type descriptor header. The general format for the overall threshold control element is defined in table 64 (see 7.2.4).

The individual threshold control element list contains an individual threshold control element for each of the possible elements identified by the NUMBER OF POSSIBLE ELEMENTS field in the corresponding type descriptor header.

Each individual threshold control element contains threshold control information for the element. The general format for the individual threshold control element is defined in table 64 (see 7.2.4).

### 6.1.9 Threshold In diagnostic page

The Threshold In diagnostic page is transmitted from the enclosure services process to the application client to report the actual threshold values for those elements that have limited sensing capability (e.g., temperature sensors, uninterruptible power supplies, voltage sensors, and current sensors).

The Threshold In diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 05h. The transmission of a page using the SEND DIAGNOSTIC command with a PAGE CODE field set to 05h is defined as the transmission of a Threshold Out diagnostic page (see 6.1.8).

Table 18 defines the Threshold In diagnostic page.

**Table 18 — Threshold In diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0	
0	PAGE CODE (05h)								
1	Reserved			INVOP	Reserved				
2	(MSB)	PAGE LENGTH (n-3)							(LSB)
3									
4	(MSB)	GENERATION CODE							(LSB)
7									
Threshold status descriptor list									
8	Threshold status descriptor (first) (see table 19)								
...									
n	Threshold status descriptor (last) (see table 19)								

The PAGE CODE field is set to 05h.

The INVOP (invalid operation requested) bit shall be set to one if a Threshold Out diagnostic page with an invalid format has previously been transmitted to the enclosure services process and an application client has not already been informed of the error (i.e., if the SEND DIAGNOSTIC command sending the invalid Threshold Out diagnostic page was not terminated with CHECK CONDITION status to notify the application client of the error).

Each time the INVOP bit is set to one:

- a) standalone enclosure services processes (see 4.1.2) shall set the INVOP bit to one the first time they return the Threshold In diagnostic page to the same I\_T nexus that transmitted the invalid control page and shall set the INVOP bit to zero for subsequent requests; and
- b) attached enclosure services processes (see 4.1.3) shall set the INVOP bit to one the first time they return the Threshold In diagnostic page to any application client and shall set the INVOP bit to zero for subsequent requests.

An Invalid Operation Reason threshold status element may be included in the element list. If the INVOP bit is set to zero and an Invalid Operation Reason threshold status element (see 7.3.12) is included, then the Invalid Operation Reason threshold status element shall be ignored.

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The GENERATION CODE field indicates the value of the generation code (see 4.3.2).

The threshold status descriptor list contains a threshold status descriptor for each type descriptor header in the Configuration diagnostic page (see 6.1.2).

Table 19 defines the threshold status descriptor.

**Table 19 — Threshold status descriptor**

Byte	Bit	7	6	5	4	3	2	1	0
0		Overall threshold status element (see table 65 in 7.2.5)							
3									
Individual threshold status element list									
4		Individual threshold status element (first) (see table 65 in 7.2.5)							
7									
...									
m - 3		Individual threshold status element (last) (see table 65 in 7.2.5)							
m									

The overall threshold status element provides shared threshold status for all the elements described by the type descriptor header. The general format for the overall threshold status element is defined by table 65 (see 7.2.5).

The individual threshold status element list contains an individual threshold status element for each of the possible elements identified by the NUMBER OF POSSIBLE ELEMENTS field in the corresponding type descriptor header.

Each individual threshold status element contains threshold status information for the element. The general format for the individual threshold status element is defined by table 65 (see 7.2.5).

**6.1.10 Element Descriptor diagnostic page**

The Element Descriptor diagnostic page returns a list of vendor-specific, variable-length ASCII strings, one for each element in the Enclosure Status diagnostic page (see 6.1.4).

The Element Descriptor diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 07h. A PAGE CODE field set to 07h in the parameter list for a SEND DIAGNOSTIC command is as having an invalid field error (see 4.5).

Table 20 defines the Element Descriptor diagnostic page.

**Table 20 — Element Descriptor diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (07h)							
1	Reserved							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	(MSB)	GENERATION CODE						(LSB)
7								
Element descriptor by type list								
8	Element descriptor by type descriptor (first element type) (see table 21)							
...								
n	Element descriptor by type descriptor (last element type) (see table 21)							

The PAGE CODE field is set to 07h.

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The GENERATION CODE field indicates the value of the generation code (see 4.3.2).

The element type descriptor list contains an element descriptor by type descriptor for each element type.

Table 21 defines the element descriptor by type descriptor.

**Table 21 — Element descriptor by type descriptor**

Bit Byte	7	6	5	4	3	2	1	0
0	Overall descriptor (see table 22)							
variable	Element descriptor (first element) (see table 22)							
...								
x	Element descriptor (last element) (see table 22)							

The overall descriptor contains any descriptor information applying to all elements of the type or describing elements that have no individual descriptor information. The format of the overall descriptor is defined in table 22.

Following the overall descriptor, there shall be one element descriptor for each of the possible elements identified by the NUMBER OF POSSIBLE ELEMENTS field in the corresponding type descriptor header in the Configuration diagnostic page (see 6.1.2). Each element descriptor contains the descriptive information for the element. The format of the element descriptor is defined in table 22.

Table 22 defines the overall descriptor and the element descriptor.

**Table 22 — Overall descriptor format and element descriptor format**

Bit Byte	7	6	5	4	3	2	1	0	
0	Reserved								
1	Reserved								
2	(MSB)	DESCRIPTOR LENGTH (m - 3)							
3								(LSB)	
4	DESCRIPTOR								
m	DESCRIPTOR								

The DESCRIPTOR LENGTH field indicates the length in bytes of the DESCRIPTOR field. A DESCRIPTOR LENGTH of zero indicates that no DESCRIPTOR field is contained in the overall descriptor or element descriptor.

The DESCRIPTOR field indicates an ASCII string reporting vendor-specific information about the element. The DESCRIPTOR field shall not be modified by the Language element (see 7.3.18).

#### 6.1.11 Short Enclosure Status diagnostic page

The Short Enclosure Status diagnostic page indicates the status of a simple subenclosure (see 4.3.3).

Table 23 defines the Short Enclosure Status diagnostic page.

**Table 23 — Short Enclosure Status diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0	
0	PAGE CODE (08h)								
1	SHORT ENCLOSURE STATUS								
2	(MSB)	PAGE LENGTH (0000h)							
3								(LSB)	

The PAGE CODE field is set to 08h.

The SHORT ENCLOSURE STATUS field indicates vendor specific status about the simple subenclosure.

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page and is set to 0000h.

#### 6.1.12 Enclosure Busy diagnostic page

The Enclosure Busy diagnostic page indicates that the enclosure services process is busy and is unable to return the requested diagnostic page. See 4.4.

Table 24 defines the Enclosure Busy diagnostic page.

**Table 24 — Enclosure Busy diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0	
0	PAGE CODE (09h)								
1	Vendor specific							BUSY	
2	(MSB)	PAGE LENGTH (0000h)							
3								(LSB)	

The PAGE CODE field is set to 09h.

A BUSY bit set to one indicates that the enclosure services process is busy and the application client should retry the RECEIVE DIAGNOSTIC RESULTS command. A BUSY bit set to zero indicates that the enclosure services process is not busy and is capable of responding to a RECEIVE DIAGNOSTIC RESULTS command requesting an SES diagnostic page. The BUSY bit shall be set to one whenever this diagnostic page is returned in place of another diagnostic page (i.e., the requested diagnostic page).

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page and is set to 0000h.

### 6.1.13 Additional Element Status diagnostic page

#### 6.1.13.1 Additional Element Status diagnostic page overview

The Additional Element Status diagnostic page provides additional information about:

- a) Device Slot elements (see 7.3.2);
- b) Array Device Slot elements (see 7.3.3);
- c) SAS Expander elements (see 7.3.25);
- d) SCSI Initiator Port elements (see 7.3.23) containing SAS phys;
- e) SCSI Target Port elements (see 7.3.22) containing SAS phys; and
- f) Enclosure Services Controller Electronics elements (see 7.3.9).

The Additional Element Status diagnostic page returns an Additional Element Status descriptor for each of the following elements that have been allowed for by the NUMBER OF POSSIBLE ELEMENTS field in the corresponding type descriptor header in the Configuration diagnostic page (see 6.1.2):

- a) Device Slot elements;
- b) Array Device Slot elements; and
- c) SAS Expander elements;

It may include Additional Element Status descriptors for:

- a) SCSI Initiator Port elements;
- b) SCSI Target Port elements; and
- c) Enclosure Services Controller Electronics elements.

The Additional Element Status descriptors shall be in the same order as the status elements in the Enclosure Status diagnostic page (see 6.1.4).

The Additional Element Status diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 0Ah. A PAGE CODE field set to 0Ah in the parameter list for a SEND DIAGNOSTIC command is an invalid field error (see 4.5).

Table 25 defines the Additional Element Status diagnostic page.

**Table 25 — Additional Element Status diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (0Ah)							
1	Reserved							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	(MSB)	GENERATION CODE						(LSB)
7								
Additional Element Status descriptor list								
8	Additional Element Status descriptor (first) (see table 26 and table 27)							
...								
n	Additional Element Status descriptor (last) (see table 26 and table 27)							

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The GENERATION CODE field indicates the value of the generation code (see 4.3.2).

Table 26 defines the format of the Additional Element Status descriptor with the EIP bit set to one.

**Table 26 — Additional Element Status descriptor with the EIP bit set to one**

Bit Byte	7	6	5	4	3	2	1	0
0	INVALID	Reserved		EIP (1b)	PROTOCOL IDENTIFIER			
1	ADDITIONAL ELEMENT STATUS DESCRIPTOR LENGTH (x - 1)							
2	Reserved							
3	ELEMENT INDEX							
4	Protocol-specific information							
x								

Table 27 defines the format of the Additional Element Status descriptor with the EIP bit set to zero.

**Table 27 — Additional Element Status descriptor with the EIP bit set to zero**

Bit Byte	7	6	5	4	3	2	1	0
0	INVALID	Reserved		EIP (0b)	PROTOCOL IDENTIFIER			
1	ADDITIONAL ELEMENT STATUS DESCRIPTOR LENGTH (x - 1)							
2	Protocol-specific information							
x								

An INVALID bit set to one indicates that the contents of the protocol-specific information are invalid.  
 An INVALID bit set to zero indicates that the contents of the protocol-specific information are valid.  
 The enclosure services process may set the INVALID bit to one when the ELEMENT STATUS CODE field

in the element status for the associated element (see table 62 in 7.2.3) is set to 5h (i.e., not installed), 6h (i.e., unknown), or 7h (i.e., not available).

An EIP (element index present) bit set to one indicates that the Additional Element Status descriptor has the format defined in table 26. An EIP bit set to zero indicates that the Additional Element Status descriptor has the format defined in table 27 (i.e., does not include the two extra bytes including the ELEMENT INDEX field that are defined in table 26). The EIP bit should be set to one.

The PROTOCOL IDENTIFIER field is defined in SPC-4 and identifies the protocol of the device being described by the Additional Element Status descriptor.

The ADDITIONAL ELEMENT STATUS DESCRIPTOR LENGTH field indicates the number of bytes that follow in the Additional Element Status descriptor.

The ELEMENT INDEX field indicates the index of the status element that this descriptor is describing. The index is based on the position of the status element in the Enclosure Status diagnostic pages (see 6.1.4) relative to all other individual status elements. It does not include the overall status elements.

The contents of the protocol-specific information bytes depend on the contents of the PROTOCOL IDENTIFIER field. If the PROTOCOL IDENTIFIER field is set to 0h (i.e., Fibre Channel), then the protocol-specific information is defined in table 28 (see 6.1.13.2). If the PROTOCOL IDENTIFIER field is set to 6h (i.e., SAS), then the protocol-specific information is defined in table 32 (see 6.1.13.3).

#### 6.1.13.2 Additional Element Status descriptor protocol-specific information for Fibre Channel

The Additional Element Status descriptor is used to describe a Device Slot element or an Array Device Slot element that may contain:

- a) a Fibre Channel device; or
- b) a SCSI Initiator Port, SCSI Target Port, or Enclosure Services Controller Electronics element that is a Fibre Channel device.

Table 28 defines the Additional Element Status descriptor protocol-specific information for Fibre Channel devices (see FCP-4) with the EIP bit set to one.

**Table 28 — Additional Element Status descriptor protocol-specific information for Fibre Channel with the EIP bit set to one**

Bit Byte	7	6	5	4	3	2	1	0
0	NUMBER OF PORTS							
1	Reserved							
2	Reserved							
3	DEVICE SLOT NUMBER							
4	(MSB)	NODE NAME						Reserved
11	Reserved							(LSB)
Port descriptor list								
12	Port descriptor (first) (see table 30)							Reserved
27	Reserved							Reserved
...								
y - 15	Port descriptor (last) (see table 30)							Reserved
y	Reserved							

Table 29 defines the Additional Element Status descriptor protocol-specific information for Fibre Channel devices (see FCP-4) with the EIP bit set to zero. This format does not include the two extra bytes that are in table 28.

**Table 29 — Additional Element Status descriptor protocol-specific information for Fibre Channel with the EIP bit set to zero**

Bit Byte	7	6	5	4	3	2	1	0	
0	NUMBER OF PORTS								
1	Reserved								
2	(MSB)								
9	NODE NAME							(LSB)	
Port descriptor list									
10	Port descriptor (first) (see table 30)								
25								...	
y - 15	Port descriptor (last) (see table 30)								
y								(LSB)	

The NUMBER OF PORTS field indicates how many Fibre Channel ports are in the port descriptor list. There is one port descriptor for each port.

The DEVICE SLOT NUMBER field indicates the number of the device slot represented by the element.

The NODE NAME field contains the Node\_Name (see FCP-4) of the corresponding Fibre Channel node.

Table 30 defines the port descriptor.

**Table 30 — Port descriptor**

Bit Byte	7	6	5	4	3	2	1	0	
0	PORT LOOP POSITION								
1	BYPASS REASON								
2	Reserved								
3									
4	PORT REQUESTED HARD ADDRESS								
5	(MSB)								
7	N_PORT IDENTIFIER							(LSB)	
8	(MSB)								
15	N_PORT NAME							(LSB)	

The PORT LOOP POSITION field indicates the relative position of the corresponding Fibre Channel port on a Fibre Channel Arbitrated Loop (see FC-AL-2).

The BYPASS REASON field indicates the reason the corresponding Fibre Channel port is being bypassed, if it is being bypassed, and is defined in table 31.

**Table 31 — BYPASS REASON field**

Code	Description
00h	Either: a) the port is not being bypassed; or b) the port is being bypassed and no reason is available (e.g., it is being bypassed by request of an application client or the device).
01h to 0Fh	Reserved
10h	Link failure rate is too high
11h	Loss-of-synchronization rate is too high
12h	Loss-of-signal rate is too high
13h	Primitive sequence protocol error rate is too high
14h	Invalid transmission word rate is too high
15h	CRC error rate is too high
16h to 1Fh	Reserved for error rate reasons
20h	Link failure count is too high
21h	Loss-of-synchronization count is too high
22h	Loss-of-signal count is too high
23h	Primitive sequence protocol error count is too high
24h	Invalid transmission word count is too high
25h	CRC error count is too high
26h to 2Fh	Reserved for count reasons
30h to BFh	Reserved
C0h to FFh	Vendor specific

The PORT REQUESTED HARD ADDRESS field contains the Preferred Hard Address of the corresponding Fibre Channel port on a Fibre Channel Arbitrated Loop (see FC-AL-2).

The N\_PORT IDENTIFIER field contains the Port Identifier (see FCP-4) of the corresponding Fibre Channel port. Applications may compare the lower 8 bits of this field with the PORT REQUESTED HARD ADDRESS field to determine whether the port was assigned its requested address.

The N\_PORT NAME field contains the Port\_Name (see FCP-4) of the corresponding Fibre Channel port.

### 6.1.13.3 Additional Element Status descriptor protocol-specific information for SAS

#### 6.1.13.3.1 Additional Element Status descriptor protocol-specific information for SAS overview

Table 32 defines the Additional Element Status descriptor for SAS devices and expander devices (see SAS-2). This is used to describe:

- a) a Device Slot element or an Array Device Slot element that may contain a SAS device or a SATA device;
- b) a SAS Expander element;
- c) a SCSI Initiator Port element containing SAS phys;
- d) a SCSI Target Port element containing SAS phys; or

e) an Enclosure Services Controller Electronics element containing SAS phys.

**Table 32 — Additional Element Status descriptor protocol-specific information for SAS**

Bit Byte	7	6	5	4	3	2	1	0
0	Descriptor-type specific							
1	DESCRIPTOR TYPE		Descriptor-type specific					
2	Descriptor-type specific							
y	Descriptor-type specific							

The DESCRIPTOR TYPE field is defined in table 33.

**Table 33 — DESCRIPTOR TYPE field**

Code	Description
00b	Used for Device Slot elements and Array Device Slot elements (see 6.1.13.3.2)
01b	Used for: a) SAS Expander elements (see 6.1.13.3.3); b) SCSI Initiator Port element (see 6.1.13.3.4); c) SCSI Target Port element (see 6.1.13.3.4); and d) Enclosure Services Controller Electronics elements (see 6.1.13.3.4).
All others	Reserved

**6.1.13.3.2 Additional Element Status descriptor protocol-specific information for Device Slot elements and Array Device Slot elements for SAS**

Table 34 defines the Additional Element Status descriptor protocol-specific information for Device Slot elements and Array Device Slot elements with the EIP bit (see 6.1.13.1) set to one.

**Table 34 — Additional Element Status descriptor protocol-specific information for Device Slot elements and Array Device Slot elements for SAS with the EIP bit set to one**

Bit Byte	7	6	5	4	3	2	1	0
0	NUMBER OF PHY DESCRIPTORS							
1	DESCRIPTOR TYPE (00b)		Reserved				NOT ALL PHYS	
2	Reserved							
3	DEVICE SLOT NUMBER							
Phy descriptor list								
4	Phy descriptor (first) (see table 36)							
31	...							
z - 27	Phy descriptor (last) (see table 36)							
z								

Table 35 defines the Additional Element Status descriptor protocol-specific information for Device Slot elements and Array Device Slot elements with the EIP bit (see 6.1.13.1) set to zero. This

format does not include the two extra bytes including the DEVICE SLOT NUMBER field that are in table 34.

**Table 35 — Additional Element Status descriptor protocol-specific information for Device Slot elements and Array Device Slot elements for SAS with the EIP bit set to zero**

Bit Byte	7	6	5	4	3	2	1	0	
0	NUMBER OF PHY DESCRIPTORS								
1	DESCRIPTOR TYPE (00b)		Reserved					NOT ALL PHYS	
Phy descriptor list									
2	Phy descriptor (first) (see table 36)								
29									
									...
z - 27	Phy descriptor (last) (see table 36)								
z									

The DESCRIPTOR TYPE field is set to 00b.

The NUMBER OF PHY DESCRIPTORS field indicates how many phy descriptors are in the phy descriptor list.

A NOT ALL PHYS bit set to one indicates that all phys in the SAS device or SATA device may or may not be described. A NOT ALL PHYS bit set to zero indicates that all phys in the SAS device or SATA device are described.

NOTE 5 The NOT ALL PHYS bit may be set to one for SAS devices with multiple ports, where the enclosure services process only has access to information about the phys in one of the ports (e.g., in the same SAS domain as the enclosure services process).

The DEVICE SLOT NUMBER field, if any, indicates the number of the device slot.

Table 36 defines the phy descriptor.

**Table 36 — Phy descriptor**

Bit Byte	7	6	5	4	3	2	1	0
0	Reserved		DEVICE TYPE		Reserved			
1	Reserved							
2	Reserved				SSP INITIATOR PORT	STP INITIATOR PORT	SMP INITIATOR PORT	Reserved
3	SATA PORT SELECTOR	Reserved			SSP TARGET PORT	STP TARGET PORT	SMP TARGET PORT	SATA DEVICE
4	ATTACHED SAS ADDRESS							
11								
12								
19	PHY IDENTIFIER							
20	Reserved							
21								
27								

If the device in the device slot is a SAS device, then:

- a) the DEVICE TYPE field, SSP INITIATOR PORT bit, STP INITIATOR PORT bit, SMP INITIATOR PORT bit, SSP TARGET PORT bit, STP TARGET PORT bit, SMP TARGET PORT bit, SAS ADDRESS field, and PHY IDENTIFIER field contain the values of the fields in the IDENTIFY address frame transmitted by the phy;
- b) the SATA PORT SELECTOR bit shall be set to zero; and
- c) the SATA DEVICE bit shall be set to zero.

NOTE 6 The phy transmits these fields in the IDENTIFY address frame to the attached phy (e.g., an expander phy in an expander device). The enclosure services process may retrieve the values from the attached phy (e.g., an enclosure process built into an expander device has direct access to the values received by the expander phy).

If the device in the device slot is a SATA device, then:

- a) the DEVICE TYPE field shall be set to 000b;
- b) the SSP INITIATOR PORT bit shall be set to zero;
- c) the STP INITIATOR PORT bit shall be set to zero;
- d) the SMP INITIATOR PORT bit shall be set to zero;
- e) the SSP TARGET PORT bit shall be set to zero;
- f) the STP TARGET PORT bit shall be set to zero;
- g) the SMP TARGET PORT bit shall be set to zero;
- h) if the SATA device is attached to a SATA port selector, the SATA PORT SELECTOR bit shall be set to one;
- i) if the SATA device is not attached to a SATA port selector, the SATA PORT SELECTOR bit shall be set to zero;
- j) the SATA DEVICE bit shall be set to one;
- k) the SAS ADDRESS field shall be set to the SAS address of the STP target port of the STP/SATA bridge, and
- l) the PHY IDENTIFIER field shall be set to 00h.

The ATTACHED SAS ADDRESS field contains the SAS address of the attached phy (e.g., the SAS address of the expander phy to which the SAS device or SATA device is attached).

NOTE 7 All the fields are from the perspective of the SAS device or SATA device associated with the element (e.g., the disk drive), not the device (e.g., the expander device) which receives the IDENTIFY address frame. The ATTACHED SAS ADDRESS fields for multiple phys in the same SAS device or SATA device differ if it is attached to more than one SAS domain.

NOTE 8 A SATA device may be attached to more than one SAS domain using a SATA port selector.

### 6.1.13.3.3 Additional Element Status descriptor protocol-specific information for SAS

IECNORM.COM . Click to view the full PDF of ISO/IEC 14776-372:2011

## Expander elements

Table 37 defines the Additional Element Status descriptor protocol-specific information for SAS Expander elements (see SAS-2).

**Table 37 — Additional Element Status descriptor protocol-specific information for SAS Expander elements**

Bit Byte	7	6	5	4	3	2	1	0
0	NUMBER OF EXPANDER PHY DESCRIPTORS							
1	DESCRIPTOR TYPE (01b)		Reserved					
2	Reserved							
3	Reserved							
4	Reserved							
11	SAS ADDRESS							
Expander phy descriptor list								
12	Expander phy descriptor (first) (see table 38)							
13	...							
y - 1	Expander phy descriptor (last) (see table 38)							
y								

The DESCRIPTOR TYPE field is set to 01b.

The NUMBER OF EXPANDER PHY DESCRIPTORS field indicates how many expander phy descriptors are in the expander phy descriptor list.

The SAS ADDRESS field indicates the SAS address of the expander device.

Table 38 defines the expander phy descriptor.

**Table 38 — Expander phy descriptor**

Bit Byte	7	6	5	4	3	2	1	0
0	CONNECTOR ELEMENT INDEX							
1	OTHER ELEMENT INDEX							

The CONNECTOR ELEMENT INDEX field indicates the index of a SAS Connector element (see 7.3.26) to which the expander phy is attached. If the expander phy is not attached to a connector represented by a SAS Connector element, then the CONNECTOR ELEMENT INDEX field shall be set to FFh.

The OTHER ELEMENT INDEX field indicates the index of a Device Slot element (see 7.3.2), Array Device Slot element (see 7.3.3), SAS Expander element (see 7.3.25), SCSI Initiator Port element (see 7.3.23), SCSI Target Port element (see 7.3.22), or Enclosure Services Controller Electronics element (see 7.3.9) to which the expander phy is attached. If the expander phy is not attached to one of those elements, then the OTHER ELEMENT INDEX field shall be set to FFh.

### 6.1.13.3.4 Additional Element Status descriptor protocol-specific information for SCSI Initiator Port, SCSI Target Port, and Enclosure Services Controller Electronics elements for

**SAS**

Table 39 defines the Additional Element Status descriptor protocol-specific information for SCSI Initiator Port and SCSI Target Port elements representing SCSI initiator ports and SCSI target ports with SAS phys.

**Table 39 — Additional Element Status descriptor protocol-specific information for SCSI Initiator Port, SCSI Target Port, and Enclosure Services Controller Electronics elements for SAS**

Bit Byte	7	6	5	4	3	2	1	0
0	NUMBER OF PHY DESCRIPTORS							
1	DESCRIPTOR TYPE (01b)		Reserved					
2	Reserved							
3	Reserved							
Phy descriptor list								
4	Phy descriptor (first) (see table 40)							
15	...							
y - 11	Phy descriptor (last) (see table 40)							
y								

The DESCRIPTOR TYPE field is set to 01b.

The NUMBER OF PHY DESCRIPTORS field indicates how many phy descriptors are in the phy descriptor list.

Table 40 defines the phy descriptor.

**Table 40 — Phy descriptor**

Bit Byte	7	6	5	4	3	2	1	0
0	PHY IDENTIFIER							
1	Reserved							
2	CONNECTOR ELEMENT INDEX							
3	OTHER ELEMENT INDEX							
4	SAS ADDRESS							
11								

The PHY IDENTIFIER field indicates the phy identifier (see SAS-2) of the phy.

The CONNECTOR ELEMENT INDEX field indicates the index of a SAS Connector element (see 7.3.26) to which the phy is attached. If the phy is not attached to a connector represented by a SAS Connector element, then this field shall be set to FFh.

The OTHER ELEMENT INDEX field indicates the index of a Device Slot element (see 7.3.2), Array Device Slot element (see 7.3.3), SAS Expander element (see 7.3.25), SCSI Initiator Port element (see 7.3.23), SCSI Target Port element (see 7.3.22), or Enclosure Services Controller Electronics element (see 7.3.9) to which the phy is attached. If the phy is not attached to one of those elements, then this field shall be set to FFh.

The SAS ADDRESS field indicates the SAS address of the phy. If the enclosure services process does not know the SAS address (e.g., the enclosure services process is in an expander on the back-side of an SCC controller, and this is a phy in a SCSI target port on the front-side of the SCC controller), this field shall be set to zero.

#### 6.1.14 Subenclosure Help Text diagnostic page

The Subenclosure Help Text diagnostic page contains a text string from an enclosure that describes the present state of the enclosure and provides text indicating what corrective actions, if any, should be performed. The Subenclosure Help Text diagnostic page allows enclosure-independent application clients to return enclosure-specific text describing the state of the enclosure and explain enclosure-dependent corrective actions that may be required.

The Subenclosure Help Text diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 0Bh. A PAGE CODE field set to 0Bh in the parameter list for a SEND DIAGNOSTIC command is an invalid field error (see 4.5).

Table 41 defines the Subenclosure Help Text diagnostic page.

**Table 41 — Subenclosure Help Text diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (0Bh)							
1	NUMBER OF SECONDARY SUBENCLOSURES							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	(MSB)	GENERATION CODE						(LSB)
7								
Subenclosure help text list								
8	Subenclosure help text (primary subenclosure) (see table 42)							
...								
n	Subenclosure help text (last subenclosure) (see table 42)							

The PAGE CODE field is set to 0Bh.

The NUMBER OF SECONDARY SUBENCLOSURES field specifies the number of secondary subenclosure help texts that are included in the subenclosure help text list, not including the primary subenclosure help text. The NUMBER OF SECONDARY SUBENCLOSURES field shall be set to the same value as the NUMBER OF SECONDARY SUBENCLOSURES field in the Configuration diagnostic page (see 6.1.2).

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The GENERATION CODE field indicates the value of the generation code (see 4.3.2).

Table 42 defines the format of each subenclosure help text. The first subenclosure help text shall be for the primary subenclosure; subenclosure help text for the secondary subenclosures may follow in any order.

**Table 42 — Subenclosure help text format**

Bit Byte	7	6	5	4	3	2	1	0	
0	Reserved								
1	SUBENCLOSURE IDENTIFIER								
2	(MSB)	SUBENCLOSURE HELP TEXT LENGTH (m - 3)							
3								(LSB)	
4	SUBENCLOSURE HELP TEXT								
m									

The SUBENCLOSURE IDENTIFIER field indicates the subenclosure (see 4.3) to which the subenclosure help text applies.

The SUBENCLOSURE HELP TEXT LENGTH field indicates the number of bytes in the SUBENCLOSURE HELP TEXT field. If a subenclosure has no help text, then the SUBENCLOSURE HELP TEXT LENGTH field shall be set to 0000h.

The SUBENCLOSURE HELP TEXT field contains a text string describing what corrective actions should be performed on the subenclosure. The text string shall use the language and character set indicated by the Language element (see 7.3.18).

**6.1.15 Subenclosure String Out diagnostic page**

The Subenclosure String Out diagnostic page transmits an enclosure dependent binary string from the application client to the enclosure services process of the specified subenclosure. The binary string may contain bits describing indicator states, text or graphic display information, or control information outside the context of the elements defined in the Configuration diagnostic page (see 6.1.2).

The format of the binary string is vendor specific. For standalone enclosure services processes (see 4.1.2), an application client may select the format of the binary string using the manufacturer name and mode from the standard INQUIRY data (see SPC-4) or using the enclosure header information in the Configuration diagnostic page. For attached enclosure services processes (see 4.1.3), an application client should select the format of the binary string using the enclosure header information in the Configuration diagnostic page.

The Subenclosure String Out diagnostic page is written by the SEND DIAGNOSTIC command. A RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 0Ch is defined as the request to read the Subenclosure String In diagnostic page (see 6.1.16).

Table 43 defines the Subenclosure String Out diagnostic page.

**Table 43 — Subenclosure String Out diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (0Ch)							
1	SUBENCLOSURE IDENTIFIER							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	(MSB)	EXPECTED GENERATION CODE						(LSB)
7								
8	SUBENCLOSURE STRING OUT DATA							
n								

The PAGE CODE field is set to 0Ch.

The SUBENCLOSURE IDENTIFIER field specifies the subenclosure (see 4.3) to which the application client is sending the subenclosure string out data. If the SUBENCLOSURE IDENTIFIER field does not match a SUBENCLOSURE IDENTIFIER field value indicated in the Configuration diagnostic page, then the enclosure services process shall report an invalid field error (see 4.5).

The PAGE LENGTH field specifies the number of bytes that follow in the diagnostic page.

The EXPECTED GENERATION CODE field is defined in the Enclosure Control diagnostic page (see 6.1.3).

The SUBENCLOSURE STRING OUT DATA field shall contain the vendor specific information to be transferred from the application client to the enclosure services process of the specified subenclosure.

#### 6.1.16 Subenclosure String In diagnostic page

The Subenclosure String In diagnostic page transmits enclosure dependent binary string(s) from the enclosure services process of the subenclosures to the application client. The binary strings may contain bits describing keyboard states, switch states, or the content of other information provided by the primary subenclosure to the application client.

The format of each binary string is vendor specific. For standalone enclosure services processes (see 4.1.2), an application client may determine the format of the binary string using the manufacturer name and mode from the standard INQUIRY data (see SPC-4) or using the enclosure header information in the Configuration diagnostic page (see 6.1.2). For attached enclosure services processes (see 4.1.3), an application client should select the format of the binary string using the enclosure header information in the Configuration diagnostic page.

The transmission of a page using the SEND DIAGNOSTIC command with a PAGE CODE field set to 0Ch is defined as the transmission of a Subenclosure String Out diagnostic page (see 6.1.15).

Table 44 defines the Subenclosure String In diagnostic page.

**Table 44 — Subenclosure String In diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (0Ch)							
1	NUMBER OF SECONDARY SUBENCLOSURES							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	(MSB)	GENERATION CODE						(LSB)
7								
Subenclosure string in data list								
8	Subenclosure string in data (primary subenclosure) (see table 45)							
...								
n	Subenclosure string in data (last subenclosure) (see table 45)							

The PAGE CODE field is set to 0Ch.

The NUMBER OF SECONDARY SUBENCLOSURES field indicates the number of secondary subenclosure string in data values that are included in the subenclosure string in data list, not including the primary subenclosure string in data. The NUMBER OF SECONDARY SUBENCLOSURES field shall be set to the same value as the NUMBER OF SECONDARY SUBENCLOSURES field in the Configuration diagnostic page (see 6.1.2).

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The GENERATION CODE field indicates the value of the generation code (see 4.3.2).

Table 45 defines the format of each subenclosure string in data. The first subenclosure string in data shall be for the primary subenclosure; subenclosure string in data for the secondary subenclosures may follow in any order.

**Table 45 — Subenclosure string in data format**

Bit Byte	7	6	5	4	3	2	1	0
0	Reserved							
1	SUBENCLOSURE IDENTIFIER							
2	(MSB)	SUBENCLOSURE STRING IN DATA LENGTH (m - 3)						(LSB)
3								
4	SUBENCLOSURE STRING IN DATA							
m								

The SUBENCLOSURE IDENTIFIER field indicates the subenclosure (see 4.3) to which the subenclosure string in data applies.

The SUBENCLOSURE STRING IN DATA LENGTH field indicates the number of bytes in the SUBENCLOSURE STRING IN DATA field. If a subenclosure has no subenclosure string in data, then the SUBENCLOSURE STRING IN DATA LENGTH field shall be set to 0000h.

The SUBENCLOSURE STRING IN DATA field shall contain the vendor specific information to be transferred from the enclosure services process to the application client.

### 6.1.17 Supported SES Diagnostic Pages diagnostic page

The Supported SES Diagnostic Pages diagnostic subpage returns the list of diagnostic pages in the range of 01h to 2Fh implemented by the enclosure services process.

The Supported SES Diagnostic Pages diagnostic page is read by the RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 0Dh. A PAGE CODE field set to 0Dh in the parameter list for a SEND DIAGNOSTIC command is an invalid field error (see 4.5).

Table 46 defines the Supported SES Diagnostic Pages diagnostic page.

**Table 46 — Supported SES Diagnostic Pages diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (0Dh)							
1	Reserved							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	SUPPORTED SES PAGE LIST							
n	PAD (if needed)							

The PAGE CODE field is set to 0Dh.

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The SUPPORTED SES PAGE LIST field contains a list of all diagnostic page codes, one per byte, in the range of 01h to 2Fh that are implemented by the enclosure services process. It shall be sorted in ascending order beginning with page code 01h. The Supported SES Diagnostic Pages page code (i.e., 0Dh) shall be included in the list.

The PAD field contains zero, one, two, or three bytes set to 00h such that the total length of the diagnostic page is a multiple of four.

### 6.1.18 Download Microcode Control diagnostic page

The Download Microcode Control diagnostic page transmits a vendor-specific microcode (i.e., firmware) image to the control memory space of the enclosure services process. The image may be saved to non-volatile storage (e.g., a flash ROM).

The Download Microcode Control diagnostic page is written by the SEND DIAGNOSTIC command. A RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 0Eh is defined as the request to read the Download Microcode Status diagnostic page (see 6.1.19).

The microcode image may be sent using one or more SEND DIAGNOSTIC commands. If the complete set of SEND DIAGNOSTIC commands required to deliver the microcode image are not received before:

- a) for standalone enclosure services processes (see 4.1.2), a logical unit reset, hard reset, power on, or I\_T nexus loss; or
- b) for attached enclosure services processes (see 4.1.3), power on,

then the incomplete microcode image shall not be used.

If an error is detected, then the enclosure services process shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to the appropriate value in the Download Microcode Status diagnostic page.

Table 47 defines the Download Microcode Control diagnostic page.

**Table 47 — Download Microcode Control diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (0Eh)							
1	SUBENCLOSURE IDENTIFIER							
2	(MSB)	PAGE LENGTH (n - 3)						(LSB)
3								
4	(MSB)	EXPECTED GENERATION CODE						(LSB)
7								
8	DOWNLOAD MICROCODE MODE							
9								
10	Reserved							
11	BUFFER ID							
12	(MSB)	BUFFER OFFSET						(LSB)
15								
16	(MSB)	MICROCODE IMAGE LENGTH						(LSB)
19								
20	(MSB)	MICROCODE DATA LENGTH (m - 23)						(LSB)
23								
24	MICROCODE DATA							
m								
m + 1	PAD (if needed)							
n								

The PAGE CODE field is set to 0Eh.

The SUBENCLOSURE IDENTIFIER field specifies the subenclosure (see 4.3) to which the application client is sending the microcode image. If the SUBENCLOSURE IDENTIFIER field does not match a SUBENCLOSURE IDENTIFIER field value found in the Configuration diagnostic page (see 6.1.2), then the enclosure services process shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 80h in the Download Microcode Status diagnostic page.

The PAGE LENGTH field specifies the number of bytes that follow in the diagnostic page. If the PAGE LENGTH field value does not match the number of bytes that follow in the diagnostic page, then the enclosure services process shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 80h in the Download Microcode Status diagnostic page.

The EXPECTED GENERATION CODE field is defined in the Enclosure Control diagnostic page (see 6.1.3). If the EXPECTED GENERATION CODE field is not set to the current generation code, then the enclosure services process shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 80h in the Download Microcode Status diagnostic page.

The DOWNLOAD MICROCODE MODE field is defined in table 48.

**Table 48 — DOWNLOAD MICROCODE MODE field (part 1 of 2)**

Code	Name	Description
06h	Download microcode with offsets and activate	<p>After the last SEND DIAGNOSTIC command delivering a Download Microcode Control diagnostic page to the subenclosure completes, the enclosure services process shall:</p> <ol style="list-style-type: none"> <li>1) verify the complete microcode image (e.g., perform a vendor specific checksum);</li> <li>2) provided there are no errors in the microcode image, set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 10h in the Download Microcode Status diagnostic page;</li> <li>3) wait for a RECEIVE DIAGNOSTIC RESULTS command requesting the Download Microcode Status diagnostic page; and</li> <li>4) activate the new microcode image (i.e., reboot).</li> </ol> <p>The downloaded microcode shall be used until:</p> <ol style="list-style-type: none"> <li>a) it is supplanted by another download microcode operation;</li> <li>b) for standalone enclosure services processes, hard reset or power on; or</li> <li>c) for attached enclosure services processes, power on.</li> </ol>
07h	Download microcode with offsets, save, and activate	<p>After the last SEND DIAGNOSTIC command delivering a Download Microcode Control diagnostic page to the subenclosure completes, the enclosure services process shall verify the complete microcode image (e.g., perform a vendor specific checksum) and save the new microcode image into non-volatile storage (e.g., flash ROM).</p> <p>If there are no errors in the microcode image or in the save operation, then the enclosure services process shall return the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field set to one of the following values in the Download Microcode Status diagnostic page, if requested, and activate the new microcode when specified:</p> <ol style="list-style-type: none"> <li>a) 10h: activate the new microcode image after: <ol style="list-style-type: none"> <li>A) returning the Download Microcode Status diagnostic page;</li> <li>B) power on; or</li> <li>C) for standalone enclosure services processes, hard reset;</li> </ol> </li> <li>b) 11h: for standalone enclosure services processes only. Activate the new microcode image after: <ol style="list-style-type: none"> <li>A) power on; or</li> <li>B) hard reset;</li> </ol> </li> <li>c) 12h: activate the new microcode image after power on.</li> </ol> <p>The application client may determine the microcode revision level currently in use by retrieving the PRODUCT REVISION LEVEL field in the Enclosure descriptor in the Configuration diagnostic page.</p>
0Eh	Download microcode with offsets, save, and defer activate	<p>After the last SEND DIAGNOSTIC command delivering a Download Microcode Control diagnostic page to the subenclosure completes, the enclosure services process shall verify the complete microcode image (e.g., perform a vendor-specific checksum), save the new microcode image into non-volatile storage (e.g., flash ROM), and defer activation of the new microcode.</p> <p>If there are no errors in the microcode image or in the save operation, then the enclosure services process shall return the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field set to 13h in the Download Microcode Status diagnostic page, if requested, and activate the new microcode after:</p> <ol style="list-style-type: none"> <li>a) processing a Download Microcode Control diagnostic page with the DOWNLOAD MICROCODE MODE field set to 0Fh (i.e., Activate deferred microcode);</li> <li>b) power on; or</li> <li>c) hard reset.</li> </ol>

**Table 48 — DOWNLOAD MICROCODE MODE field (part 2 of 2)**

Code	Name	Description
0Fh	Activate deferred microcode	After the SEND DIAGNOSTIC command specifying this mode completes, the enclosure services process shall activate the new microcode image.  The application client may determine the microcode revision level currently in use by retrieving the PRODUCT REVISION LEVEL field in the Enclosure descriptor in the Configuration diagnostic page.
All others	Reserved	Reserved. The enclosure services process shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 80h in the Download Microcode Status diagnostic page.

Once a download microcode operation has begun, if the DOWNLOAD MICROCODE MODE field value changes while specifying the same buffer ID, then the enclosure services process shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 80h in the Download Microcode Status diagnostic page.

The BUFFER ID field specifies a specific buffer within the enclosure services process to receive the microcode image. The enclosure services process assigns vendor specific buffer ID codes to buffers (e.g., the main firmware image may be stored in buffer 00h and a backup firmware image may be stored in buffer 01h). The enclosure services process shall support a buffer ID value of 00h. If more than one buffer is supported, then it shall assign additional buffer ID codes contiguously, beginning with 01h. If it receives an unsupported buffer ID code, then the enclosure services process shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 80h in the Download Microcode Status diagnostic page.

The enclosure services process may require that only one subenclosure download microcode operation be processed at a time, and/or may require that only one buffer ID be used at a time. If the enclosure services process does not accept the specified combination of subenclosure identifier and buffer ID, then it shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 80h in the Download Microcode Status diagnostic page.

The BUFFER OFFSET field specifies the offset in bytes within the buffer to which the microcode data is written. The BUFFER OFFSET field shall be set to a multiple of four. The enclosure services process may require that the BUFFER OFFSET field be contiguously increasing in consecutive SEND DIAGNOSTIC commands. If the enclosure services process does not accept the specified buffer offset, then it shall abort the download microcode operation and set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 80h in the Download Microcode Status diagnostic page.

The MICROCODE IMAGE LENGTH field specifies the total number of bytes in the microcode image the application intends to send to the specified buffer ID. The microcode image may be sent using one or more SEND DIAGNOSTIC commands.

The MICROCODE DATA LENGTH field specifies the number of bytes in the MICROCODE DATA field.

The MICROCODE DATA field contains part of the vendor specific microcode image.

The PAD field contains zero, one, two, or three bytes set to 00h such that the total length of the diagnostic page is a multiple of four.

### 6.1.19 Download Microcode Status diagnostic page

The Download Microcode Status diagnostic page transmits information about the status of one or more download microcode operations to the application client.

The transmission of a page using the SEND DIAGNOSTIC command with a PAGE CODE field set to 0Eh is defined as the transmission of a Download Microcode Control diagnostic page (see 6.1.18).



The SUBENCLOSURE IDENTIFIER field indicates the subenclosure (see 4.3) to which the download microcode status descriptor applies.

The SUBENCLOSURE DOWNLOAD MICROCODE STATUS field indicates the status of download microcode operations for the subenclosure and is defined in table 51. After reporting a code indicating completion, the enclosure services process shall set the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field to 00h and shall set the SUBENCLOSURE DOWNLOAD MICROCODE ADDITIONAL STATUS field to 00h.

**Table 51 — SUBENCLOSURE DOWNLOAD MICROCODE STATUS field (part 1 of 2)**

Code	Description
Codes indicating interim status	
00h	No download microcode operation in progress.
01h	Download microcode operation in progress. The enclosure services process has received one or more Download Microcode Control diagnostic pages and is awaiting additional microcode data.
02h	Download microcode operation data transfer complete, currently updating non-volatile storage
03h	The enclosure services process is currently updating non-volatile storage with deferred microcode
04h to 0Fh	Reserved for codes indicating interim status
Codes indicating completion with no errors	
10h	Download microcode operation complete with no error. The enclosure services process begins using the new microcode after returning this status.
11h	Download microcode operation complete with no error. The enclosure services process (e.g., a standalone enclosure services process) begins using the new microcode after the next hard reset or power on.
12h	Download microcode operation complete with no error. The enclosure services process (e.g., an attached enclosure services process) begins using the new microcode after the next power on.
13h	Download microcode operation complete with no error. The enclosure services process (e.g., an attached enclosure services process) begins using the new microcode after: a) processing a Download Microcode Control diagnostic page specifying the activate deferred microcode mode; b) hard reset; or c) power on.
14h to 6Fh	Reserved for codes indicating no error
Other	
70h to 7Fh	Vendor-specific
Codes indicating completion with errors	
80h	Error in one or more of the Download Microcode Control diagnostic page fields, new microcode discarded. The SUBENCLOSURE DOWNLOAD MICROCODE ADDITIONAL STATUS field shall be set to the offset of the lowest byte of the field in the Download Microcode Control diagnostic page that is in error.
81h	Microcode image error (e.g., a problem detected from a vendor-specific check of the microcode image such as a checksum), new microcode discarded.
82h	Download microcode timeout, new microcode discarded. The enclosure services process may discard microcode data after a vendor-specific amount of time if it does not receive the entire microcode image.

**Table 51 — SUBENCLOSURE DOWNLOAD MICROCODE STATUS field (part 2 of 2)**

Code	Description
83h	Internal error in the download microcode operation; new microcode image is needed before a hard reset or power on (e.g., a flash ROM write failed and no backup ROM image is available).
84h	Internal error in the download microcode operation; hard reset and power on safe (e.g., the enclosure services process will use a backup ROM image on hard reset or power on).
85h	Processed a Download Microcode Control diagnostic page with the DOWNLOAD MICROCODE MODE field set to 0Fh (i.e., activate deferred microcode) when there is no deferred microcode.
86h to EFh	Reserved for codes indicating errors
Other	
F0h to FFh	Vendor specific error in the download microcode operation; microcode image status is vendor specific.

The SUBENCLOSURE DOWNLOAD MICROCODE ADDITIONAL STATUS field provides additional status for certain values of the SUBENCLOSURE DOWNLOAD MICROCODE STATUS field as described in table 51.

The SUBENCLOSURE DOWNLOAD MICROCODE MAXIMUM SIZE field indicates the maximum size in bytes of the microcode image that the enclosure services process accepts. The image may be delivered using one or more Download Microcode Control diagnostic pages.

The SUBENCLOSURE DOWNLOAD MICROCODE EXPECTED BUFFER ID field indicates the next value that the enclosure services process expects in the BUFFER ID field in the Download Microcode Control diagnostic page. If the enclosure services process accepts multiple BUFFER ID field values concurrently, then it shall set the SUBENCLOSURE DOWNLOAD MICROCODE EXPECTED BUFFER ID field to FFh.

The SUBENCLOSURE DOWNLOAD MICROCODE EXPECTED BUFFER OFFSET field indicates the next value that the enclosure services process expects in the BUFFER OFFSET field in the Download Microcode Control diagnostic page. If the enclosure services process accepts arbitrary BUFFER OFFSET field values, then it shall set the SUBENCLOSURE DOWNLOAD MICROCODE EXPECTED BUFFER OFFSET field to FFFFFFFFh.

#### 6.1.20 Subenclosure Nickname Control diagnostic page

The Subenclosure Nickname Control diagnostic page transmits a text string to the enclosure services process to serve as the nickname for the specified subenclosure. The nickname is saved to non-volatile storage (e.g., a flash ROM) so it may be retrieved after future hard resets.

The Subenclosure Nickname Control diagnostic page is written by the SEND DIAGNOSTIC command. A RECEIVE DIAGNOSTIC RESULTS command with a PCV bit set to one and a PAGE CODE field set to 0Fh is defined as the request to read the Subenclosure Nickname Status diagnostic page (see 6.1.21).

Table 52 defines the Subenclosure Nickname Control diagnostic page.

**Table 52 — Subenclosure Nickname Control diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0
0	PAGE CODE (0Fh)							
1	SUBENCLOSURE IDENTIFIER							
2	(MSB)	PAGE LENGTH (0024h)						(LSB)
3								
4	(MSB)	EXPECTED GENERATION CODE						(LSB)
7								
8	SUBENCLOSURE NICKNAME							
39								

The PAGE CODE field is set to 0Fh.

The SUBENCLOSURE IDENTIFIER field specifies the subenclosure (see 4.3) to which the application client is sending the subenclosure nickname. If the SUBENCLOSURE IDENTIFIER value does not match a SUBENCLOSURE IDENTIFIER value found in the Configuration diagnostic page (see 6.1.2), then the enclosure services process shall set the SUBENCLOSURE NICKNAME STATUS field to 80h in the Subenclosure Nickname Status diagnostic page.

The PAGE LENGTH field specifies the number of bytes that follow in the diagnostic page. If the PAGE LENGTH field value does not match the length of the page, then the enclosure services process shall not change the subenclosure nickname and shall set the SUBENCLOSURE NICKNAME MICROCODE STATUS field to 80h in the Subenclosure Nickname Status diagnostic page.

The EXPECTED GENERATION CODE field is defined in the Enclosure Control diagnostic page (see 6.1.3). If the EXPECTED GENERATION CODE field is not set to the current generation code, the enclosure services process shall not change the subenclosure nickname and shall set the SUBENCLOSURE NICKNAME MICROCODE STATUS field to 80h in the Subenclosure Nickname Status diagnostic page.

The SUBENCLOSURE NICKNAME field specifies the subenclosure nickname. If a Language element (see 7.3.18) is present, then the SUBENCLOSURE NICKNAME field shall contain a text string with characters using the language and character set indicated by the Language element and the enclosure services process shall store the language code value indicated by the Language element along with the subenclosure nickname. If a Language element is not available, then the SUBENCLOSURE NICKNAME field shall contain an ASCII string and the enclosure services process shall store the language code value of 0000h along with the subenclosure nickname.

#### 6.1.21 Subenclosure Nickname Status diagnostic page

The Subenclosure Nickname Status diagnostic page transmits the nickname of each subenclosure to the application client.

The transmission of a page using the SEND DIAGNOSTIC command with a PAGE CODE field set to 0Fh is defined as the transmission of a Subenclosure Nickname Control diagnostic page (see 6.1.20).

Table 53 defines the Subenclosure Nickname Status diagnostic page.

**Table 53 — Subenclosure Nickname Status diagnostic page**

Bit Byte	7	6	5	4	3	2	1	0	
0	PAGE CODE (0Fh)								
1	NUMBER OF SECONDARY SUBENCLOSURES								
2	(MSB)	PAGE LENGTH (n - 3)							
3								(LSB)	
4	(MSB)	GENERATION CODE							
7								(LSB)	
Subenclosure nickname status descriptor list									
8	Subenclosure nickname status descriptor (primary subenclosure) (see table 54)								
47									
...									
n - 39	Subenclosure nickname status descriptor (last subenclosure) (see table 54)								
n									

The PAGE CODE field is set to 0Fh.

The NUMBER OF SECONDARY SUBENCLOSURES field indicates the number of secondary subenclosure nickname status descriptor values that are included, not including the primary subenclosure. The NUMBER OF SECONDARY SUBENCLOSURES field shall be set to the same value as the NUMBER OF SECONDARY SUBENCLOSURES field in the Configuration diagnostic page (see 6.1.2).

The PAGE LENGTH field indicates the number of bytes that follow in the diagnostic page.

The GENERATION CODE field indicates the value of the generation code (see 4.3.2).

Table 54 defines the format of each subenclosure's enclosure nickname status descriptor. The first subenclosure nickname status descriptor shall be for the primary subenclosure. Subenclosure nickname status descriptors for secondary subenclosures may follow in any order.

**Table 54 — Subenclosure nickname status descriptor format**

Bit Byte	7	6	5	4	3	2	1	0	
0	Reserved								
1	SUBENCLOSURE IDENTIFIER								
2	SUBENCLOSURE ENCLOSURE NICKNAME STATUS								
3	SUBENCLOSURE ENCLOSURE NICKNAME ADDITIONAL STATUS								
4	Reserved								
5									
6	(MSB)	SUBENCLOSURE NICKNAME LANGUAGE CODE							
7								(LSB)	
8	SUBENCLOSURE NICKNAME								
39									

The SUBENCLOSURE IDENTIFIER field indicates the subenclosure (see 4.3) to which the subenclosure nickname status descriptor applies.

The SUBENCLOSURE NICKNAME STATUS field indicates the status of nickname operations for the subenclosure and is defined in table 55. After reporting a non-zero value, the enclosure services process shall set the SUBENCLOSURE NICKNAME STATUS field to 00h and shall set the SUBENCLOSURE NICKNAME ADDITIONAL STATUS field to 00h.

**Table 55 — SUBENCLOSURE NICKNAME STATUS field**

Code	Description
00h	No errors
80h	Error in one or more of the Subenclosure Nickname Control diagnostic page fields. The SUBENCLOSURE NICKNAME ADDITIONAL STATUS field shall be set to the offset of the lowest byte of the field in the Subenclosure Nickname Control diagnostic page that has an error.
81h	Internal error. The nickname is lost.
82h	Internal error. The previous nickname preserved.
All others	Reserved

The SUBENCLOSURE NICKNAME ADDITIONAL STATUS field provides additional status for certain values of the SUBENCLOSURE NICKNAME STATUS field as described in table 55.

The SUBENCLOSURE NICKNAME LANGUAGE CODE field indicates the language and character set of the subenclosure nickname, as defined by the LANGUAGE CODE field in the Language element (see 7.3.18).

The SUBENCLOSURE NICKNAME field indicates the subenclosure nickname.

## 6.2 Log parameters for enclosure services devices

This subclause describes descriptors and pages for log parameters used with enclosure services devices.

Table 56 defines the log page codes for enclosure services devices.

**Table 56 — Log page codes for enclosure services devices**

Page code	Subpage code	Description	Reference
00h	00h	Supported Log Pages log page	SPC-4
	FFh	Supported Log Pages and Subpages log pages	SPC-4
06h	00h	Non-Medium Error log page	SPC-4
07h	00h	Last n Error Events log page	SPC-4
0Bh	00h	Last n Deferred Error or Asynchronous Events log page	SPC-4
0Dh	00h	Temperature log page	SPC-4
0Eh	00h	Start-Stop Cycle Counter log page	SPC-4
0Fh	00h	Application Client log page	SPC-4
10h	00h	Self-Test Results log page	SPC-4
18h	00h to FEh	Protocol Specific Port log pages	SPC-4
2Fh	00h	Informational Exceptions log page	SPC-4
01h to 3Eh	FFh	Supported Subpages log page	SPC-4
30h to 3Eh	00h to FEh	Vendor specific	
All others		Reserved	

### 6.3 Mode parameters for enclosure services devices

#### 6.3.1 Mode parameters overview

This subclause describes descriptors and pages for mode parameters used with enclosure services devices.

The mode parameter list, including the mode parameter header and mode block descriptor are described in SPC-4.

The MEDIUM TYPE field is contained in the mode parameter header (see SPC-4). For enclosure services devices, the MEDIUM TYPE field is reserved.

The DEVICE SPECIFIC PARAMETER field is contained in the mode parameter header (see SPC-4). For enclosure services devices, the DEVICE SPECIFIC PARAMETER field is reserved.

The BLOCK DESCRIPTOR LENGTH field is contained in the mode parameter header (see SPC-4). Enclosure services devices have no BLOCK DESCRIPTOR field. For enclosure services devices, the BLOCK DESCRIPTOR LENGTH field shall be set to zero.

Table 57 defines the mode page codes for enclosure services devices.

**Table 57 — Mode page codes for enclosure services devices**

Page code	Subpage code	Description	Reference
00h	N/A	Vendor specific	
01h	00h to FEh	Reserved for this standard	
02h	00h	Disconnect-Reconnect mode page	SPC-4
03h to 08h	00h to FEh	Reserved for this standard	
09h	00h	Obsolete	
0Ah	00h	Control mode page	SPC-4
	01h	Control Extension mode page	SPC-4
	F0h to FEh	Reserved for this standard	
0Bh to 13h	00h to FEh	Reserved for this standard	
14h	00h	Enclosure Services Management mode page	6.3.2
14h	01h to FEh	Reserved for this standard	
18h	00h	Protocol Specific Logical Unit mode page	SPC-4
	01h to FEh	See SCSI transport protocol standard	SPC-4
19h	00h	Protocol Specific Port mode page	SPC-4
	01h to FEh	See SCSI transport protocol standard	SPC-4
1Bh	00h to FEh	Reserved for this standard	
1Ch	00h	Informational Exceptions Control mode page	SPC-4
1Dh to 1Fh	00h to FEh	Reserved for this standard	
20h to 3Eh	N/A	Vendor specific	
3Fh <sup>a</sup>	00h <sup>a</sup>	Return all pages	SPC-4
3Fh <sup>a</sup>	FFh <sup>a</sup>	Return all pages and subpages	SPC-4
00h to 3Fh <sup>a</sup>	FFh <sup>a</sup>	Return all subpages	SPC-4
All others		Reserved for SPC-4	

<sup>a</sup> Valid only for the MODE SENSE command (see SPC-4).

### 6.3.2 Enclosure Services Management mode page

The Enclosure Services Management mode page provides controls over those features involving communication with an enclosure services process. If the Enclosure Services Management mode page is not implemented, then the device server shall not implement the timed completion function (see 4.7.3).

When a RECEIVE DIAGNOSTIC RESULTS command is received by a device server that supports enclosure services and the ENBLTC bit has been set to one, the device server may wait up to the time contained in the MAXIMUM TASK COMPLETION TIME field before returning the requested diagnostic page. The device server shall only perform this delay operation for Enclosure Status diagnostic pages (see 6.1.4). If a noncritical, critical, or unrecoverable condition exists or occurs during the waiting period, then the device server shall stop waiting and return the requested diagnostic page.

Table 58 defines the Enclosure Services Management mode page.

**Table 58 — Enclosure Services Management mode page**

Bit Byte	7	6	5	4	3	2	1	0	
0	PS	SPF (0b)	PAGE CODE (14h)						
1	PAGE LENGTH (06h)								
2	Reserved								
4	Reserved								
5	Reserved							ENBLTC	
6	(MSB)	MAXIMUM TASK COMPLETION TIME							
7								(LSB)	

The PS (parameters savable) bit is defined in SPC-4. For enclosure services devices, the PS bit is not restricted.

The SPF bit is defined in SPC-4 and is set to zero for this mode page.

The PAGE LENGTH field is defined in SPC-4 and is set to 06h for this mode page.

An ENBLTC (enable timed completion) bit set to one specifies that the device server shall enable the timed completion function (see 4.7.3). An ENBLTC bit set to zero specifies that the device server shall disable the timed completion function.

The MAXIMUM TASK COMPLETION TIME field specifies the maximum time that the device server may choose to wait before returning a diagnostic page. The timing of the wait period shall begin when the transmission of RECEIVE DIAGNOSTIC RESULTS command to the device server is complete and end with the transfer of the Enclosure Status diagnostic page and the transfer of completion status. In establishing the value for the MAXIMUM TASK COMPLETION TIME field, the application client should consider any time periods that are not controlled by the device server (e.g., reconnection overheads, congestion latency, and protocol timeouts). The value is specified in 100 ms units. A value of 0000h specifies a vendor specific maximum time (e.g., infinite).

## 7 Element definitions

### 7.1 Element definitions overview

This clause contains the format definitions for:

- a) control elements in the Enclosure Control diagnostic page (see 6.1.3);
- b) status elements in the Enclosure Status diagnostic page (see 6.1.4);
- c) threshold control elements in the Threshold Out diagnostic page (see 6.1.8); and
- d) threshold status elements in the Threshold In diagnostic page (see 6.1.9).

Field format definitions common to all element types are described in 7.2. Field format definitions that differ for different element types are described in 7.3.

IECNORM.COM : Click to view the full PDF of ISO/IEC 14776-372:2011

Table 59 defines the elements and their element type codes.

**Table 59 — Element type codes**

Element type code	Name	DISABLE bit support <sup>a</sup>	Threshold <sup>b</sup>	Reference
00h	Unspecified	no	none	7.3.1
01h	Device Slot	no	none	7.3.2
02h	Power Supply	no	none	7.3.4
03h	Cooling	no	none	7.3.5
04h	Temperature Sensor	yes	temperature	7.3.6
05h	Door Lock	no	none	7.3.7
06h	Audible Alarm	yes	none	7.3.8
07h	Enclosure Services Controller Electronics	no	none	7.3.9
08h	SCC Controller Electronics	no	none	7.3.10
09h	Nonvolatile Cache	no	none	7.3.11
0Ah	Invalid Operation Reason <sup>c</sup>	no	none	7.3.12
0Bh	Uninterruptible Power Supply	no	battery status	7.3.13
0Ch	Display	no	none	7.3.14
0Dh	Key Pad Entry	no	none	7.3.15
0Eh	Enclosure	no	none	7.3.16
0Fh	SCSI Port/Transceiver	no	none	7.3.17
10h	Language	no	none	7.3.18
11h	Communication Port	no	none	7.3.19
12h	Voltage Sensor	yes	% voltage	7.3.20
13h	Current Sensor	yes	% current	7.3.21
14h	SCSI Target Port	no	none	7.3.22
15h	SCSI Initiator Port	no	none	7.3.23
16h	Simple Subenclosure	no	none	7.3.24
17h	Array Device Slot	no	none	7.3.3
18h	SAS Expander	no	none	7.3.25
19h	SAS Connector	no	none	7.3.26
1Ah to 7Fh	Reserved			
80h to FFh	Vendor specific			
<sup>a</sup> A "DISABLE bit support" value of yes means the DISABLE bit is supported in the COMMON CONTROL field of the control element (see 7.2.2). <sup>b</sup> The "threshold" value indicates the value, if any, that is subject to comparison with the threshold specified by the threshold control element (see 7.2.4) and indicated by the threshold status element (see 7.2.5). <sup>c</sup> A special threshold status element format defined if the INVOP bit is set to one. See 7.3.12.				

## 7.2 Element formats

### 7.2.1 Element formats overview

Unless otherwise specified, all status and control bits are optional. All control bits are advisory and may be ignored or overridden to maintain a proper operating environment in the enclosure.

### 7.2.2 Control element format

Table 60 defines the format of the control element.

**Table 60 — Control element format**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
	SELECT	PRDFAIL	DISABLE	RST SWAP	Reserved			
1	Element type specific control information							
3								

The COMMON CONTROL field contains those bits that may be used by any control element.

A SELECT bit set to one specifies that the enclosure services process should perform the control functions defined by the other bits in the control element. A SELECT bit set to zero specifies that the enclosure services process shall ignore all other bits in the control element. The SELECT bit allows individual control elements to be selected for control operations.

A PRDFAIL (predicted failure) bit set to one specifies that the enclosure services process shall turn on the “predicted failure state” indicator, if any, for the element. A PRDFAIL bit set to zero specifies that the enclosure services process turn off the “predicted failure state” indicator, if any, for the element. The element is not required to implement the PRDFAIL bit or the “predicted failure state” indicator.

A DISABLE bit set to one specifies that the enclosure services process shall disable the element. A DISABLE bit set to zero specifies that the enclosure services shall allow normal operation of the element to resume. The interpretation of the disabled state is specific to the element. The DISABLE bit is defined for each element listed with disable support in table 59 (see 7.1).

A RST SWAP (reset swap) bit set to one specifies that the enclosure services process shall set the SWAP bit to zero in the status element for the I\_T nexus accessing the control element. A RST SWAP bit set to zero specifies that the enclosure services process shall not change the SWAP bit in the status element for the I\_T nexus accessing the control element.

NOTE 9 The DISABLE bit and the RST SWAP bit are not intended to be accessed as part of a read-modify-write procedure with the corresponding bits in the status element (see 7.2.3).

The element type specific control information is defined separately for each element type in 7.3. Control information containing conflicting bits may cause unpredictable behavior or may cause the enclosure services process to report an invalid field error (see 4.5).

### 7.2.3 Status element format

Table 61 defines the format of the status element.

**Table 61 — Status element format**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON STATUS							
	Reserved	PRDFAIL	DISABLED	SWAP	ELEMENT STATUS CODE			
1	Element type specific status information							
3								

The COMMON STATUS field contains those bits that may be returned by any status element.

A PRDFAIL (predicted failure) bit set to one indicates that the element has the capability of predicting failure and that a failure has been predicted. The “predicted failure state” indicator may additionally be set by the PRDFAIL bit in the corresponding control element. A PRDFAIL bit set to zero indicates that the “predicted failure state” indicator is turned off or is not implemented.

A DISABLED bit set to one indicates that the element has been disabled (see the DISABLE bit in the control element (see 7.2.2)). A DISABLED bit set to zero indicates that the element has not been disabled or that the disable function is not implemented. The DISABLED bit is defined for each element listed with disable support in table 59 (see 7.1).

A SWAP bit set to one indicates that an element has been swapped (i.e., removed and inserted) (e.g., for a Device element, the device been removed and the same or another device has been inserted in the same device slot) since the last time the RST SWAP bit was set to one in the control element (see 7.2.2) for the I\_T nexus being used to access the status element. A SWAP bit set to zero indicates that the element has not been swapped. The SWAP bit is set to zero when the RST SWAP bit is set to one in the control element and remains set to zero until another swap occurs. The SWAP bit provides an indication that an element’s properties may have been changed without any change of configuration. A standalone enclosure services process shall maintain one SWAP bit for each I\_T nexus. An attached enclosure services process shall maintain one SWAP bit shared by all I\_T nexuses.

The ELEMENT STATUS CODE field is defined in table 62.

**Table 62 — ELEMENT STATUS CODE field**

Code	Name	Condition
0h	Unsupported	Status detection is not implemented for this element.
1h	OK	Element is installed and no error conditions are known.
2h	Critical	Critical condition is detected.
3h	Noncritical	Noncritical condition is detected.
4h	Unrecoverable	Unrecoverable condition is detected.
5h	Not Installed	Element is not installed in enclosure.
6h	Unknown	Sensor has failed or element status is not available.
7h	Not Available	Element installed, no known errors, but the element has not been turned on or set into operation.
8h	No Access Allowed	The initiator port from which the RECEIVE DIAGNOSTIC RESULT command was received does not have access to this element.
9h to Fh	Reserved	

In an overall status element, the enclosure services process shall set the ELEMENT STATUS CODE field as defined in table 63.

**Table 63 — ELEMENT STATUS CODE field usage in an overall status element**

Condition		Valid values
The enclosure services process does not implement overall status detection		0h
The enclosure services process implements overall status detection	There are no individual status elements	Any value representing the overall status
	There are one or more individual status elements and, in each of them, the ELEMENT STATUS CODE field is set to 0h (i.e., Unsupported)	Any value representing the overall status
	There are one or more individual status elements and, in each of them, the ELEMENT STATUS CODE field is not set to 0h (i.e., Unsupported)	0h (i.e., Unsupported) or any value representing the overall status

The element type specific status information is defined separately for each element type in 7.3.

#### 7.2.4 Threshold control element format

Table 64 defines the format of the threshold control element.

**Table 64 — Threshold control element format**

Bit Byte	7	6	5	4	3	2	1	0
0	REQUESTED HIGH CRITICAL THRESHOLD							
1	REQUESTED HIGH WARNING THRESHOLD							
2	REQUESTED LOW WARNING THRESHOLD							
3	REQUESTED LOW CRITICAL THRESHOLD							

The REQUESTED HIGH CRITICAL THRESHOLD field recommends a value for the high critical threshold.

The REQUESTED HIGH WARNING THRESHOLD field recommends a value for the high warning threshold.

The REQUESTED LOW WARNING THRESHOLD field recommends a value for the low warning threshold.

The REQUESTED LOW CRITICAL THRESHOLD field recommends a value for the low critical threshold.

All fields in the threshold control element are advisory. The enclosure services process shall ignore the contents of the threshold control element for those elements that have no value to be compared with a threshold and for those elements that do not implement the threshold function. For those elements that have a sensor value to compare with a threshold, the enclosure services process may:

- accept the fields transmitted in the overall threshold control element or the individual threshold control element;
- set the thresholds to more appropriate values than those requested; or
- ignore the contents of any or all of the requested threshold fields.

Table 59 (see 7.1) lists those elements that use threshold control elements. The definition of each threshold field for an element type is defined in the subclause describing that element type.

See 4.6 for how the enclosure services process uses thresholds.

### 7.2.5 Threshold status element format

Table 65 defines the format of the threshold status element.

**Table 65 — Threshold status element format**

Bit Byte	7	6	5	4	3	2	1	0
0	HIGH CRITICAL THRESHOLD							
1	HIGH WARNING THRESHOLD							
2	LOW WARNING THRESHOLD							
3	LOW CRITICAL THRESHOLD							

The HIGH CRITICAL THRESHOLD field indicates the high critical threshold. The enclosure indicates a critical condition if the sensor detects a value higher than the high critical threshold. A HIGH CRITICAL THRESHOLD field set to 00h indicates that the sensor does not test a high critical threshold.

The HIGH WARNING THRESHOLD field indicates the high warning threshold. The enclosure indicates a noncritical condition if the sensor detects a value higher than the high warning threshold. A HIGH WARNING THRESHOLD field set to 00h indicates that the sensor does not test a high warning threshold.

The LOW WARNING THRESHOLD field indicates the low warning threshold. The enclosure indicates a noncritical condition if the sensor detects a value lower than the low warning threshold. A LOW WARNING THRESHOLD field set to 00h indicates that the sensor does not test a low warning threshold.

The LOW CRITICAL THRESHOLD field indicates the low critical threshold. The enclosure indicates a critical condition if the sensor detects a value lower than the low critical threshold. A LOW CRITICAL THRESHOLD field set to 00h indicates that the sensor does not test a low critical threshold.

The threshold fields indicate the thresholds that the enclosure is using at the time the Threshold In diagnostic page is returned.

Table 59 (see 7.1) lists those elements that use threshold status elements. The definition of each threshold field for an element type is defined in the subclause describing that element type.

See 4.6 for how the enclosure services process uses thresholds.

### 7.3 Field definitions for all element types

#### 7.3.1 Unspecified element

The Unspecified element manages an unspecified part of the enclosure.

Table 66 defines the Unspecified control element.

**Table 66 — Unspecified control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	Reserved							
3	Reserved							

The COMMON CONTROL field is defined in 7.2.2.

Table 67 defines the Unspecified status element.

**Table 67 — Unspecified status element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON STATUS							
1	Reserved							
3	Reserved							

The COMMON STATUS field is defined in 7.2.3.

### 7.3.2 Device Slot element

The Device Slot element manages a device slot (e.g., containing a SCSI device such as a disk drive) in the enclosure.

Additional information about a Device Slot element may be reported in the Additional Element Status diagnostic page (see 6.1.13).

Table 68 defines the Device Slot control element.

**Table 68 — Device Slot control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	Reserved							
2	RQST ACTIVE	DO NOT REMOVE	Reserved	RQST MISSING	RQST INSERT	RQST REMOVE	RQST IDENT	Reserved
3	Reserved		RQST FAULT	DEVICE OFF	ENABLE BYP A	ENABLE BYP B	Reserved	

The RQST ACTIVE (request device activity indication) bit has no effect if the enclosure provides no visual activity indication. The RQST ACTIVE bit may be set to one by the application client to cause a visual indication that the device is active. The enclosure services process shall sustain the active condition of the visual indicator for at least 0.5 s.

NOTE 10 To maintain the active indication asserted (if present), the application client sets the bit to one at least once every 0.5 s.

A DO NOT REMOVE bit set to one specifies that the device not be removed. A DO NOT REMOVE bit set to zero specifies that the device may be removed. The DO NOT REMOVE bit may control mechanical interlocks or visual indications that the device should not be removed.

A RQST MISSING (request device missing indication) bit set to one specifies that the device slot be identified by a visual indication that a previously present device is missing (e.g., has been removed). A RQST MISSING bit set to zero specifies that the device missing indication shall be cleared.

A RQST INSERT (request insert) bit set to one specifies that the device slot be prepared for the insertion of a device. A RQST INSERT bit set to zero specifies that the device slot take no action to prepare for the insertion of a device. The bit may control mechanical interlocks or visual indications that a device may be inserted in the device slot.

A RQST REMOVE (request removal) bit set to one specifies that the device slot be prepared for the removal of a device. A RQST REMOVE bit set to zero specifies that the device slot take no action to prepare for the removal of a device. The bit may control mechanical interlocks or visual indications that a device may be removed from the device slot.

A RQST IDENT (request identify) bit set to one specifies that the enclosure services process identify the element (i.e., the device slot) by a visual indication. A RQST IDENT bit set to zero specifies that the enclosure services process not identify the element by a visual indication.

A RQST FAULT (request fault indication) bit set to one specifies that the device slot be identified by a visual indication that a fault is present in the device. A RQST FAULT bit set to zero specifies that the fault indication shall be cleared if the indication is not also being set by the device or the enclosure services process.

A DEVICE OFF bit set to one specifies that the device be turned off. A DEVICE OFF bit set to zero specifies that the device may be turned on if all other prerequisites are met.

An ENABLE BYP A (enable bypass Port A) bit set to one specifies that port A for the device be bypassed. An ENABLE BYP A bit set to zero specifies that, if there is no other cause for the port to be bypassed, the port bypass shall be disabled and the device shall be included on the device interface.

An ENABLE BYP B (enable bypass Port B) bit set to one specifies that port B for the device be bypassed. An ENABLE BYP B bit set to zero specifies that, if there is no other cause for the port to be bypassed, the port bypass shall be disabled and the device shall be included on the device interface.

Table 69 defines the Device Slot status element.

**Table 69 — Device Slot status element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON STATUS							
1	SLOT ADDRESS							
2	APP CLIENT BYPASSED A	DO NOT REMOVE	ENCLOSURE BYPASSED A	ENCLOSURE BYPASSED B	READY TO INSERT	RMV	IDENT	REPORT
3	APP CLIENT BYPASSED B	FAULT SENSED	FAULT REQSTD	DEVICE OFF	BYPASSED A	BYPASSED B	DEVICE BYPASSED A	DEVICE BYPASSED B

The COMMON STATUS field is defined in 7.2.3.

Table 70 defines the SLOT ADDRESS field.

**Table 70 — SLOT ADDRESS field**

Kind of status element	Condition	Description
Overall	Any	Vendor specific
Individual	Device Slot is for a parallel SCSI device	SCSI address of the primary parallel SCSI target port of the SCSI target device
	Device Slot is not for a parallel SCSI device	Vendor specific

A DO NOT REMOVE bit set to one indicates that the corresponding control bit has been set to one. A DO NOT REMOVE bit set to zero indicates that the corresponding control bit has been set to zero or has not been implemented. If the DO NOT REMOVE bit is set to one, it indicates that mechanical interlocks or visual signals are present and activated to indicate that the device should not be removed. If the DO NOT REMOVE bit is set to zero, it indicates that mechanical interlocks or visual signals are not present or not activated, indicating that the device may be removed.

A READY TO INSERT bit set to one indicates that the device slot has been prepared for the insertion of a device. A READY TO INSERT bit set to zero indicates that the device slot is unable to accept the insertion of a device or that the RQST INSERT control bit is not implemented.

A RMV (remove) bit set to one indicates that the device slot has been prepared for the removal of the device. A RMV bit set to zero indicates that the device cannot be removed from the device slot or that the RQST REMOVE control bit is not implemented.

An IDENT (identify) bit set to one indicates that the enclosure services process is identifying the element by a visual indication because the RQST IDENT bit was set to one in the control element. An IDENT bit set to zero indicates that the enclosure services process is not identifying the element by a visual indication because of the RQST IDENT bit in the control element, or a visual indication is not implemented.

A REPORT bit set to one indicates that the enclosure services process is using this device to report the Enclosure Status diagnostic page. A REPORT bit set to zero indicates that it is not using this device to report the Enclosure Status diagnostic page. In the overall status element, the device server shall set the REPORT bit to zero and the application client should ignore the REPORT bit.

A FAULT SENSED bit set to one indicates that the enclosure or device has detected a fault condition and may be displaying a visual indication of the fault condition. A FAULT SENSED bit set to zero indicates that there is no fault condition detected by the device or enclosure.

A FAULT REQSTD (fault requested) bit set to one indicates that the RQST FAULT control bit has been set to one, specifying that the device slot be identified by a visual fault indication. A FAULT REQSTD bit set to zero indicates that the RQST FAULT control bit has been set to zero or that the RQST FAULT control bit is not implemented.

A DEVICE OFF bit set to one indicates that the device is turned off. A DEVICE OFF bit set to zero indicates that the device is turned on.

A BYPASSED A bit set to one indicates that Port A has been bypassed by request of the application client, the device, or the enclosure. A BYPASSED A bit set to zero indicates that the port bypass is disabled and the device is included on the device interface.

A BYPASSED B bit set to one indicates that Port B has been bypassed by request of the application client, the device, or the enclosure. A BYPASSED B bit set to zero indicates that the port bypass is disabled and the device is included on the device interface.

An ENCLOSURE BYPASSED A bit set to one indicates that Port A has been bypassed by request of the enclosure services process. An ENCLOSURE BYPASSED A bit set to zero indicates that Port A is not being bypassed under control of the enclosure services process. The device may still be bypassed under control of the application client or the device.

An ENCLOSURE BYPASSED B bit set to one indicates that Port B has been bypassed by request of the enclosure services process. An ENCLOSURE BYPASSED B bit set to zero indicates that Port B is not being bypassed under control of the enclosure services process. The device may still be bypassed under control of the application client or the device.

An APP CLIENT BYPASSED A (application client bypassed Port A) bit set to one indicates that Port A has been bypassed by request of an application client. An APP CLIENT BYPASSED A bit indicates that Port A is not being bypassed under control of an application client. The device may still be bypassed under control of the enclosure services process or the device.

An APP CLIENT BYPASSED B (application client bypassed Port B) bit set to one indicates that Port B has been bypassed by request of an application client. An APP CLIENT BYPASSED B bit indicates that Port B is not being bypassed under control of an application client. The device may still be bypassed under control of the enclosure services process or the device.

A DEVICE BYPASSED A bit set to one indicates that Port A has been bypassed by request of the device. A DEVICE BYPASSED A bit indicates that Port A is not being bypassed by request of the

device. When set to one, the device may be removed, turned off, not operational, or controlling the bypass signals under control of the device. When set to zero, the device may still be bypassed under control of the enclosure services process or the application client.

A DEVICE BYPASSED B bit set to one indicates that Port B has been bypassed by request of the device. A DEVICE BYPASSED B bit indicates Port B is not being bypassed by request of the device. When set to one, the device may be removed, turned off, not operational, or controlling the bypass signals under control of the device. When set to zero, the device may still be bypassed under control of the enclosure services process or the application client.

### 7.3.3 Array Device Slot element

The Array Device Slot element manages a device slot (e.g., containing a SCSI device such as a disk drive) in an enclosure that is being used in a storage array (e.g., by a RAID controller). The mapping between the visual indicators associated with the Array Device Slot element and the requests to set those indicators is vendor specific.

Additional information about an Array Device Slot element may be reported in the Additional Element Status diagnostic page (see 6.1.13).

Table 71 defines the Array Device Slot control element.

**Table 71 — Array Device Slot control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	RQST OK	RQST RSVD DEVICE	RQST HOT SPARE	RQST CONS CHECK	RQST IN CRIT ARRAY	RQST IN FAILED ARRAY	RQST REBUILD/ REMAP	RQST R/R ABORT
2	RQST ACTIVE	DO NOT REMOVE	Reserved	RQST MISSING	RQST INSERT	RQST REMOVE	RQST IDENT	Reserved
3	Reserved		RQST FAULT	DEVICE OFF	ENABLE BYP A	ENABLE BYP B	Reserved	

The COMMON CONTROL field is defined in 7.2.2.

A RQST OK (request OK) bit set to one specifies that the “device okay” indicator be turned on. A RQST OK bit set to zero specifies that the “device okay” indicator be turned off.

A RQST RSVD DEVICE (request reserved device) bit set to one specifies that the “reserved device” indicator be turned on. A RQST RSVD DEVICE bit set to zero specifies that the “reserved device” indicator be turned off.

A RQST HOT SPARE (request hot spare) bit set to one specifies that the “hot spare” indicator be turned on. A RQST HOT SPARE bit set to zero specifies that the “hot spare” indicator be turned off.

A RQST CONS CHECK (request consistency check in progress) bit set to one specifies that the “consistency check in progress” indicator be turned on. A RQST CONS CHECK bit set to zero specifies that the “consistency check in progress” indicator be turned off.

A RQST IN CRIT ARRAY (request in critical array) bit set to one specifies that the “in critical array” indicator be turned on. A RQST IN CRIT ARRAY bit set to zero specifies that the “in critical array” indicator be turned off.

A RQST IN FAILED ARRAY (request in failed array) bit set to one specifies that the “in failed array” indicator be turned on. A RQST IN FAILED ARRAY bit set to zero specifies that the “in failed array” indicator be turned off.

A RQST REBUILD/REMAP (request rebuild/remap) bit set to one specifies that the “rebuild/remap” indicator be turned on. A RQST REBUILD/REMAP bit set to zero specifies that the “rebuild/remap” indicator be turned off.

A RQST R/R ABORT (request rebuild/remap aborted) bit set to one specifies that the “rebuild/remap abort” indicator be turned on. A RQST R/R ABORT bit set to zero specifies that the “rebuild/remap abort” indicator be turned off.

The RQST ACTIVE (request device activity indication) bit, DO NOT REMOVE bit, RQST INSERT (request insert) bit, RQST REMOVE (request removal) bit, RQST MISSING (request device missing indication) bit, RQST IDENT (request identify) bit, RQST FAULT (request fault indication) bit, DEVICE OFF bit, ENABLE BYP A (enable bypass port A) bit, and ENABLE BYP B (enable bypass port B) bit are defined in the Device Slot control element (see 7.3.2).

Table 72 defines the Array Device Slot status element.

**Table 72 — Array Device Slot status element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON STATUS							
1	OK	RSVD DEVICE	HOT SPARE	CONS CHK	IN CRIT ARRAY	IN FAILED ARRAY	REBUILD/ REMAP	R/R ABORT
2	APP CLIENT BYPASSED A	DO NOT REMOVE	ENCLOSURE BYPASSED A	ENCLOSURE BYPASSED B	READY TO INSERT	RMV	IDENT	REPORT
3	APP CLIENT BYPASSED B	FAULT SENSED	FAULT REQSTD	DEVICE OFF	BYPASSED A	BYPASSED B	DEVICE BYPASSED A	DEVICE BYPASSED B

The COMMON STATUS field is defined in 7.2.3.

An OK bit set to one indicates that the “device okay” indicator is turned on. An OK bit set to zero indicates that the “device okay” indicator is turned off.

A RSVD DEVICE (reserved device) bit set to one indicates that the “reserved device” indicator is turned on. A RSVD DEVICE bit set to zero indicates that the “reserved device” indicator is turned off.

A HOT SPARE bit set to one indicates that the “hot spare” indicator is turned on. A HOT SPARE bit set to zero indicates that the “hot spare” indicator is turned off.

A CONS CHECK (consistency check in progress) bit set to one indicates that the “consistency check in progress” indicator is turned on, showing that the device is participating in an array consistency check activity. A CONS CHECK bit set to zero indicates that the “consistency check in progress” indicator is turned off.

An IN CRIT ARRAY (in critical array) bit set to one indicates that the “in critical array” indicator is turned on, showing that the device is participating in an array which would be degraded or become unavailable if the device were removed. An IN CRIT ARRAY bit set to zero indicates that the “in critical array” indicator is turned off.

An IN FAILED ARRAY bit set to one indicates that the “in failed array” indicator is turned on, showing that the device is a member of an array that has failed. The IN FAILED ARRAY bit set to zero indicates that the “in failed array” indicator is turned off.

A REBUILD/REMAP bit set to one indicates that the “rebuild/remap” indicator is turned on, showing that the device is participating in a rebuild or remap of the array contents. A REBUILD/REMAP bit set to zero indicates that the “rebuild/remap” indicator is turned off.

An R/R ABORT (rebuild/remap abort) bit set to one indicates that the “rebuild/remap abort” indicator is on, showing that a rebuild or remap of the array contents has been unsuccessfully terminated. An R/R ABORT bit set to zero indicates that the “rebuild/remap abort” indicator is turned off.

The DO NOT REMOVE bit, READY TO INSERT bit, RMV (remove) bit, IDENT (identify) bit, and REPORT bit are defined in the Device Slot status element (see 7.3.2).

The FAULT SENSED bit, FAULT REQSTD bit, and DEVICE OFF bit are defined in the Device Slot status element (see 7.3.2).

The APP CLIENT BYPASSED A bit, APP CLIENT BYPASSED B bit, ENCLOSURE BYPASSED A bit, ENCLOSURE BYPASSED B bit, BYPASSED A bit, BYPASSED B bit, DEVICE BYPASSED A bit, and DEVICE BYPASSED B bit are defined in the Device Slot status element (see 7.3.2).

**7.3.4 Power Supply element**

The Power Supply element manages a power supply (e.g., providing power to device slots (see 7.3.2), array device slots (see 7.3.3), enclosure services process electronics (see 7.3.9), and/or SCC controller electronics (see 7.3.10)).

Table 73 defines the Power Supply control element.

**Table 73 — Power Supply control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	RQST IDENT	Reserved						
2	Reserved							
3	Reserved	RQST FAIL	RQST ON	Reserved				

The COMMON CONTROL field is defined in 7.2.2.

A RQST IDENT (request identify) bit set to one specifies that the enclosure services process identify the element by a visual indication. A RQST IDENT bit set to zero specifies that the enclosure services process not identify the element by a visual indication.

A RQST FAIL (request failure indication) bit set to one specifies that the enclosure services process shall enable a visual indication that a failure is present in the element. A RQST FAIL bit set to zero specifies that the enclosure services process shall disable a visual indication that a failure is present in the element, unless the enclosure services process is itself detecting a failure in the element. Some failure indications in the STATUS INFORMATION field are latched. Setting the RQST FAIL bit to one and then setting it to zero shall reset any latched failure indications.

A RQST ON (request power supply on) bit set to one specifies that the power supply be turned on or remain on. When the RQST ON bit is set to zero, the power supply is requested to turn off or remain off.

Table 74 defines the Power Supply status element.

**Table 74 — Power Supply status element**

Bit Byte	7	6	5	4	3	2	1	0	
0	COMMON STATUS								
1	IDENT	Reserved							
2	Reserved				DC OVER VOLTAGE	DC UNDER VOLTAGE	DC OVER CURRENT	Reserved	
3	HOT SWAP	FAIL	RQSTED ON	OFF	OVERTMP FAIL	TEMP WARN	AC FAIL	DC FAIL	

The COMMON STATUS field is defined in 7.2.3.

An IDENT (identify) bit set to one indicates that the enclosure services process is identifying the element by a visual indication because the RQST IDENT bit was set to one in the control element. An IDENT bit set to zero indicates that the enclosure services process is not identifying the element by a visual indication based on the RQST IDENT bit in the control element, or a visual indication is not implemented.

A DC OVERVOLTAGE bit set to one indicates an overvoltage condition has been detected at the power supply output. A DC OVERVOLTAGE bit set to zero indicates that the RQST FAIL control bit has been set to one and then set to zero, or that a power on has occurred.

A DC UNDERVOLTAGE bit set to one indicates an undervoltage condition has been detected at the power supply output. A DC UNDERVOLTAGE bit set to zero indicates that the RQST FAIL control bit has been set to one and then set to zero, or that a power on has occurred.

A DC OVERCURRENT bit set to one indicates an overcurrent condition has been detected at the power supply output. The DC OVERCURRENT bit set to zero indicates that the RQST FAIL control bit has been set to one and then set to zero, or that a power on has occurred.

A HOT SWAP bit set to one indicates that the element may be replaced without removing power from the subenclosure that contains the element. A HOT SWAP bit set to zero may or may not indicate that the element is not a replaceable element or power is required to be removed from the subenclosure before the element is replaced.

A FAIL bit set to one indicates that the enclosure services process is identifying the element with a visual failure indication based on the RQST FAIL bit in the control element or its own detection of a failure. A FAIL bit set to zero indicates that:

- a) the enclosure services process is not identifying the element with a visual failure indication based on the RQST FAIL bit in the control element or its own detection of a failure (e.g., the ELEMENT STATUS CODE field is not set to 1h (i.e., OK)); or
- b) a visual failure indication is not implemented.

A RQSTED ON (requested on) bit set to one indicates that the power supply has been manually turned on or has been requested to turn on by setting the RQST ON control bit to one. A RQSTED ON bit set to zero indicates that the RQST ON control bit has been set to zero.

An OFF bit set to one indicates the power supply is not providing power. The OFF bit shall be set to one if:

- a) the RQST ON control bit is set to zero to request the power supply be turned off;
- b) the power supply is turned off manually; or
- c) a failure has caused the power supply to stop providing power.

An OFF bit set to zero indicates the power supply is providing its specified output.

An OVERTMP FAIL (over temperature failure) bit set to one indicates the power supply has detected a temperature above the safe operating temperature range. The power supply may shut down. An OVERTMP FAIL bit set to zero indicates that the RQST FAIL control bit has been set to one then set to zero, or that a power on has occurred.

A TEMP WARN (over temperature warning) bit set to one indicates the power supply has detected a temperature within the safe operating temperature range, but above the normal operating temperature range. A TEMP WARN bit set to zero indicates that the temperature is within the normal operating temperature range.

An AC FAIL bit set to one indicates that the power supply is not receiving the specified AC power. An AC FAIL bit set to zero indicates that normal AC power is being received.

A DC FAIL bit set to one indicates that the power supply is unable to supply the specified DC power. A DC FAIL bit set to zero indicates that normal DC power is being provided.

### 7.3.5 Cooling element

The Cooling element manages a fan, blower, or other cooling mechanism.

Table 75 defines the Cooling control element.

**Table 75 — Cooling control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	RQST IDENT	Reserved						
2	Reserved							
3	Reserved	RQST FAIL	RQST ON	Reserved		REQUESTED SPEED CODE		

The COMMON CONTROL field is defined in 7.2.2.

A RQST IDENT (request identify) bit set to one specifies that the enclosure services process identify the element by a visual indication. A RQST IDENT bit set to zero specifies that the enclosure services process not identify the element by a visual indication.

A RQST FAIL (request failure indication) bit set to one specifies that the enclosure services process shall enable a visual indication that a failure is present in the element. A RQST FAIL bit set to zero specifies that the enclosure services process shall disable a visual indication that a failure is present in the element, unless the enclosure services process is itself detecting a failure in the element.

A RQST ON (request cooling mechanism on) bit set to one specifies that the cooling mechanism be turned on or remain on. When the RQST ON bit is set to zero, the cooling mechanism is requested to turn off or remain off.

The REQUESTED SPEED CODE field specifies the requested speed or rate of cooling of the cooling mechanism, and is defined in table 76.

**Table 76 — REQUESTED SPEED CODE field**

Code	Description
000b	Leave fan at current speed
001b	Set cooling mechanism to at lowest speed
010b	Set cooling mechanism to second lowest speed
011b	Set cooling mechanism to third lowest speed
100b	Set cooling mechanism to intermediate speed
101b	Set cooling mechanism to third highest speed
110b	Set cooling mechanism to second highest speed
111b	Set cooling mechanism to highest speed

Table 77 defines the Cooling status element.

**Table 77 — Cooling status element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON STATUS							
1	IDENT	Reserved				(MSB)		
2	ACTUAL FAN SPEED (LSB)							
3	HOT SWAP	FAIL	RQSTED ON	OFF	Reserved	ACTUAL SPEED CODE		

The COMMON STATUS field is defined in 7.2.3.

The IDENT bit, HOT SWAP bit, and FAIL bit are defined in the Power Supply element (see 7.3.4).

The ACTUAL FAN SPEED field indicates the actual fan speed in revolutions per minute (rpm) when multiplied by a factor of 10 (e.g., 000h indicates 0 rpm and 7FFh indicates 20 470 rpm).

A RQSTED ON (requested on) bit set to one indicates that the cooling mechanism has been manually turned on or has been requested to be turned on by setting the RQST ON control bit to one. The RQSTED ON bit is set to zero when the RQST ON control bit is set to zero.

An OFF bit set to one indicates that the cooling mechanism is not providing cooling. The OFF bit shall be set to one if the RQST ON control bit is set to zero to request the cooling element be turned off. The OFF bit shall be set to one if the cooling mechanism is turned off manually. The OFF bit shall be set to one if a failure has caused the cooling mechanism to stop operating. An OFF bit set to zero indicates that the cooling mechanism is operating.

The ACTUAL SPEED CODE field indicates the actual speed or rate of cooling of the cooling mechanism, as defined in table 78.

**Table 78 — ACTUAL SPEED CODE field**

Code	Description
000b	Cooling mechanism is stopped
001b	Cooling mechanism is at its lowest speed
010b	Cooling mechanism is at its second lowest speed
011b	Cooling mechanism is at its third lowest speed
100b	Cooling mechanism is at its intermediate speed
101b	Cooling mechanism is at its third highest speed
110b	Cooling mechanism is at its second highest speed
111b	Cooling mechanism is at its highest speed

**7.3.6 Temperature Sensor element**

The Temperature Sensor element manages a temperature sensor.

Threshold control and threshold status elements (see 7.2.4 and 7.2.5) are supported for temperature sensors. Table 79 defines the Temperature Sensor threshold control element fields.

**Table 79 — Temperature Sensor threshold control element field definitions**

Field(s)	Description
REQUESTED HIGH CRITICAL THRESHOLD field REQUESTED HIGH WARNING THRESHOLD field REQUESTED LOW WARNING THRESHOLD field REQUESTED LOW CRITICAL THRESHOLD field	Same units as the TEMPERATURE field in the status element

Table 80 defines the Temperature Sensor threshold status element fields.

**Table 80 — Temperature Sensor threshold status element field definitions**

Field(s)	Description
HIGH CRITICAL THRESHOLD field HIGH WARNING THRESHOLD field LOW WARNING THRESHOLD field LOW CRITICAL THRESHOLD field	Compared to the TEMPERATURE field in the status element

Table 81 defines the Temperature Sensor control element.

**Table 81 — Temperature Sensor control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	RQST IDENT	RQST FAIL	Reserved					
2	Reserved							
3	Reserved							

The COMMON CONTROL field is defined in 7.2.2. When the DISABLE bit in the COMMON CONTROL field is set to one, the temperature sensor's output is ignored (i.e., not tested against any threshold

values. No noncritical, critical, or unrecoverable conditions are indicated because of the temperature values sensed). When the DISABLE bit is set to zero, the temperature sensor's output is not ignored.

The RQST IDENT bit and the RQST FAIL bit are defined in the Cooling element (see 7.3.5).

Table 82 defines the Temperature Sensor status element.

**Table 82 — Temperature Sensor status element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON STATUS							
1	IDENT	FAIL	Reserved					
2	TEMPERATURE							
3	Reserved				OT FAILURE	OT WARNING	UT FAILURE	UT WARNING

The COMMON STATUS field is defined in 7.2.3.

The IDENT bit and the FAIL bit are defined in the Power Supply element (see 7.3.4).

The TEMPERATURE field indicates the temperature at the sensor in degrees Celsius, offset by +20 °C. The range of the value expresses a temperature between –19 °C and +235 °C. A value of 00h is reserved.

An OT FAILURE (over temperature failure) bit set to one indicates that the temperature is above the safe operating temperature range or higher than the value indicated by the high critical threshold. An OT FAILURE bit set to zero indicates that the temperature is within the safe operating temperature range or below the value specified by the HIGH CRITICAL THRESHOLD field.

An OT WARNING (over temperature warning) bit set to one indicates that the temperature is above the normal operating temperature range or higher than the value indicated by the high warning threshold. An OT WARNING bit set to zero indicates that the temperature is within the normal operating temperature range or below the value specified by the HIGH WARNING THRESHOLD field.

A UT FAILURE (under temperature failure) bit set to one indicates that the temperature is below the safe operating temperature range or lower than the value indicated by the low critical threshold. A UT FAILURE bit set to zero indicates that the temperature is within the safe operating temperature range or above the value specified by the LOW CRITICAL THRESHOLD field.

A UT WARNING (under temperature warning) bit set to one indicates that the temperature is below the normal operating temperature range or lower than the value indicated by the low warning threshold. A UT WARNING bit set to zero indicates that the temperature is within the normal operating temperature range or above the value specified by the LOW WARNING THRESHOLD field.

### 7.3.7 Door Lock element

The Door Lock element manages a door lock.

Table 83 defines the Door Lock control element.

**Table 83 — Door Lock control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	RQST IDENT	RQST FAIL	Reserved					
2	Reserved							
3	Reserved							UNLOCK

The COMMON CONTROL field is defined in 7.2.2.

The RQST IDENT bit and the RQST FAIL bit are defined in the Cooling element (see 7.3.5).

An UNLOCK bit set to one specifies that the door latch be unlocked or remain unlocked. An UNLOCK bit set to zero specifies that the door latch be locked or remain locked.

Table 84 defines the Door Lock status element.

**Table 84 — Door Lock status element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON STATUS							
1	IDENT	FAIL	Reserved					
2	Reserved							
3	Reserved							UNLOCKED

The COMMON STATUS field is defined in 7.2.3.

The IDENT bit and the FAIL bit are defined in the Power Supply element (see 7.3.4).

An UNLOCKED bit set to one indicates that the door latch is unlocked. An UNLOCKED bit set to zero indicates that the door latch is locked or in its normal operating state.

### 7.3.8 Audible Alarm element

The Audible Alarm element manages an audible alarm.

Table 85 defines the Audible Alarm control element.

**Table 85 — Audible Alarm control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	RQST IDENT	RQST FAIL	Reserved					
2	Reserved							
3	Reserved	SET MUTE	Reserved	SET REMIND	TONE URGENCY CONTROL			
					INFO	NON-CRIT	CRIT	UNRECOV

The COMMON CONTROL field is defined in 7.2.2. When the DISABLE bit in the COMMON CONTROL field is set to one, the audible alarm shall be disabled and emit no sound regardless of the error condition

that exists. When the DISABLE bit is set to zero, the audible alarm is enabled and may emit sound when an error condition exists.

The RQST IDENT bit and the RQST FAIL bit are defined in the Cooling element (see 7.3.5).

A SET MUTE bit set to one specifies that the alarm be placed in the muted state. The alarm shall emit no sound when in the muted state. When the SET MUTE bit is set to zero, the alarm is set to the un-muted state and the tone appropriate to the most urgent condition present shall be generated. When the SET MUTE bit is set to one, the reminding tone is also muted.

A SET REMIND bit set to one specifies that the alarm emit a tone suitable for reminding the user that other tones are active. When the SET REMIND bit is set to zero, the alarm emits the tone appropriate to the most urgent condition that is present.

Each of the TONE URGENCY CONTROL bits requests that the audible alarm emit a tone of increasing urgency (bit 3, least urgent). If more than one bit is set to one, the tone that signals the most urgent of the selected conditions is activated.

The quality of each tone and the use of separate tones is vendor specific. The bits and tones may be set either by the TONE URGENCY CONTROL bits or by the enclosure services process. The TONE URGENCY CONTROL bits set by the enclosure are not affected by the SET MUTE bit or the SET REMIND bit, although the tone emitted by the alarm is modified by the bits.

If a new error condition occurs while the audible alarm is set in the remind or muted state, the state is cleared and the normal alarm conditions occur for that error condition, but not the previous error condition.

If all bits are set to zero, the audible alarm is silent until a new error condition occurs.

An INFO (informational condition tone urgency control) bit set to one specifies that the audible alarm emit a tone suitable to warn of an information condition. The INFO bit is set to zero to stop requesting the audible alarm to emit the tone.

A NON-CRIT (noncritical condition tone urgency control) bit set to one specifies that the audible alarm emit a tone suitable to warn of a noncritical condition. The NON-CRIT bit is set to zero to stop requesting the audible alarm to emit the tone.

A CRIT (critical condition tone urgency control) bit set to one specifies that the audible alarm emit a tone suitable to warn of a critical condition. The CRIT bit is set to zero to stop requesting the audible alarm to emit the tone.

An UNRECOV (unrecoverable condition tone urgency control) bit set to one specifies that the audible alarm emit a tone suitable to warn of an unrecoverable condition. The UNRECOV bit is set to zero to stop requesting the audible alarm to emit the tone.

Table 86 defines the Audible Alarm status element.

**Table 86 — Audible Alarm status element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON STATUS							
1	IDENT	FAIL	Reserved					
2	Reserved							
3	RQST MUTE	MUTED	Reserved	REMIND	TONE URGENCY INDICATOR			
					INFO	NON-CRIT	CRIT	UNRECOV

The COMMON STATUS field is defined in 7.2.3.

The IDENT bit and the FAIL bit are defined in the Power Supply element (see 7.3.4).

A RQST MUTE (request mute) bit set to one indicates that a panel control has been manipulated to request that the audible alarm be muted. A RQST MUTE bit set to zero indicates that the SET MUTE control bit has been set to one.

A MUTED bit set to one indicates that the audible alarm is in the muted state. A MUTED bit set to zero indicates that the audible alarm is in the un-muted state. No sound is emitted by the audible alarm when it is in the muted state.

A REMIND bit set to one indicates that the audible alarm is in the remind state. A REMIND bit set to zero indicates that the audible alarm is not in the remind state.

Each bit indicates a tone of increasing urgency (bit 3 is least urgent). If more than one bit is set to one, the tone that signals the most urgent of the indicated conditions is active.

If all bits are set to zero or if the MUTED bit is set to one, the audible alarm is silent. If the REMIND bit is set to one, the audible alarm tone is modified to the remind tone.

An INFO (information condition tone urgency indicator) bit set to one indicates that the audible alarm is emitting a tone suitable to warn of an information condition unless a more urgent tone is also indicated. An INFO bit set to zero indicates that the audible alarm is not emitting the corresponding tone.

A NON-CRIT (noncritical condition tone urgency indicator) bit set to one indicates that the audible alarm is emitting a tone suitable to warn of a noncritical condition unless a more urgent tone is also indicated. A NON-CRIT bit set to zero indicates that the audible alarm is not emitting the corresponding tone.

A CRIT (critical condition tone urgency indicator) bit set to one indicates that the audible alarm is emitting a tone suitable to warn of a critical condition unless a more urgent tone is also indicated. A CRIT bit set to zero indicates that the audible alarm is not emitting the corresponding tone.

An UNRECOV (unrecoverable condition tone urgency indicator) bit set to one indicates that the audible alarm is emitting a tone suitable to warn of an unrecoverable condition. An UNRECOV bit set to zero indicates that the audible alarm is not emitting the corresponding tone.

### 7.3.9 Enclosure Services Controller Electronics element

The Enclosure Services Controller Electronics element manages the processor circuitry used by the enclosure services process.

Table 87 defines the Enclosure Services Controller Electronics control element.

**Table 87 — Enclosure Services Controller Electronics control element**

Bit Byte	7	6	5	4	3	2	1	0
0	COMMON CONTROL							
1	RQST IDENT	RQST FAIL	Reserved					
2	Reserved							SELECT ELEMENT
3	Reserved							

The COMMON CONTROL field is defined in 7.2.2.

The RQST IDENT bit and the RQST FAIL bit are defined in the Cooling element (see 7.3.5).

A SELECT ELEMENT bit set to one specifies that the enclosure services process represented by the specified Enclosure Services Controller Electronics element be assigned to be the active enclosure services process. The active enclosure services process prepares all the status-type diagnostic