

---

---

**Refrigerated light hydrocarbon fluids —  
Measurement of liquid levels in tanks  
containing liquefied gases —  
Microwave-type level gauge**

*Hydrocarbures légers réfrigérés — Mesurage des niveaux de liquide  
dans les réservoirs contenant des gaz liquéfiés — Jauges de niveau à  
micro-ondes*

STANDARDSISO.COM : Click to view the PDF file ISO 13689:2001



**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

STANDARDSISO.COM : Click to view the full PDF of ISO 13689:2001

© ISO 2001

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.ch](mailto:copyright@iso.ch)  
Web [www.iso.ch](http://www.iso.ch)

Printed in Switzerland

**Contents**

Page

Foreword.....	iv
1 Scope .....	1
2 Normative reference .....	1
3 Terms and definitions .....	1
4 Function and construction of microwave-type level gauges.....	2
5 Performance.....	3
6 Installation.....	3
7 Initial verification of accuracy .....	3
8 Subsequent periodical verification of accuracy.....	3
Annex A (normative) Instructions on installation.....	6
Bibliography.....	7

STANDARDSISO.COM : Click to view the full PDF of ISO 13689:2001

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 3.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

International Standard ISO 13689 was prepared by Technical Committee ISO/TC 28, *Petroleum products and lubricants*, Subcommittee SC 5, *Measurement of light hydrocarbon fluids*.

Annex A forms a normative part of this International Standard.

STANDARDSISO.COM : Click to view the full PDF of ISO 13689:2001

# Refrigerated light hydrocarbon fluids — Measurement of liquid levels in tanks containing liquefied gases — Microwave-type level gauge

## 1 Scope

This International Standard specifies the essential requirements and verification procedures for microwave-type level gauges to be used for ship and shore tanks containing refrigerated light hydrocarbon fluids.

## 2 Normative reference

The following normative document contains provisions which, through reference in this text, constitute provisions of this International Standard. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent edition of the normative document indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

IEC 60079-10:1995, *Electrical apparatus for explosive gas atmospheres — Part 10: Classification of hazardous areas.*<sup>1)</sup>

## 3 Terms and definitions

For the purposes of this International Standard, the following terms and definitions apply.

### 3.1

#### **antenna**

generic term for equipment that radiates into, and receives from, the tank vapour space, electromagnetic energy in the microwave frequency band

### 3.2

#### **datum level**

reference level, equal to the zero level in the tank calibration table, from which liquid level  $L$  is calculated

### 3.3

#### **dead zone**

zone above the minimum measurable ullage

### 3.4

#### **deflection plate**

metal plate set obliquely near the tank bottom to avoid influence of microwave reflection from the bottom or any obstacles

NOTE A deflection plate may also be used to reduce unwanted reflections from the tank structure or fittings

1) Reference for level gauges in shore tanks and ships' tanks.

### 3.5

#### **hazardous area**

space where gas or vapour may form a flammable mixture, as described in IEC 60079-10

NOTE This is similar to gas-dangerous space on board the ships as described in the IMO IGC Code (1993).

### 3.6

#### **upper reference point**

basic point for measurement of ullage, set on the level-gauge centre-line near the gauge flange

NOTE The height of the upper reference point is the distance between the datum level and the upper reference point ( $H$  in Figure 1).

### 3.7

$L$

#### **liquid level**

distance between the liquid surface in a tank and the datum level

NOTE See Figure 1.

### 3.8

#### **microwave**

generic form for electromagnetic radiation, with wave length lying in the range 3 mm to 300 mm (equivalent to a frequency of 100 GHz to 1 GHz)

### 3.9

#### **microwave beam**

main directional beam formed by the electromagnetic signals radiated from the antenna into free space

### 3.10

#### **still pipe**

perforated metal pipe, extending throughout the height of the tank, used to reduce surface turbulence in the liquid that may cause fluctuations in the reflected signal

NOTE It may also be used to guide the microwave signal in difficult installation conditions

### 3.11

#### **ullage**

distance between the liquid surface in a tank and the upper reference point, measured along the vertical measurement axis

## 4 Function and construction of microwave-type level gauges

4.1 A microwave-type level gauge functions by using electromagnetic radiation determining the distance from its antenna to the liquid surface.

The distance is then subtracted from the height of the upper reference point and the level of liquid in the tank thereby computed and transmitted electronically to a point outside the tank.

4.2 A microwave-type level gauge consists of functional components comprising an antenna, microwave transceiver and other optional items.

Figures 1 and 2 show examples of arrangements.

4.3 The materials and construction of a microwave-type level gauge shall be such that it can operate safely and effectively under applicable environmental conditions for which it is intended.

**4.4** A microwave-type level gauge shall be of gastight construction in order to prevent the escape of vapour from the tank.

**4.5** All microwave-type level gauges shall be manufactured and installed in accordance with appropriate National and International electrical safety codes and standards (IMO, IEC, ISO, etc.). All level gauges shall be certified for use in the hazardous-area classification appropriate to their installation.

**NOTE** The design and installation of the microwave-type level gauges may be subject to the approval of the national measurement organizations and classification societies, who may have issued a general type approval for the design of the microwave-type level gauge for the particular service for which it is to be employed. The type approval is normally issued after the microwave-type level gauge has been subject to a specific series of tests and is subject to the microwave-type level gauge being installed in an approved manner. Type-approval tests may include the following: visual inspection, resistance, vibration, performance, humidity, dry heat, inclination, electromagnetic compatibility, and fluctuation in power supplies.

## 5 Performance

**5.1** Indication: minimum range display resolution shall not be greater than 1 mm.

**5.2** Maximum permissible error:  $\pm (3,3 + 0,08D)$  mm where  $D$  is the distance, in metres, from the upper reference point to the liquid surface.

**5.3** If the level gauge fails to meet the performance requirements of this clause, the cause shall be investigated. If the level gauge needs to be adjusted or components replaced, with the tank in service, it should be reverified in accordance with clause 8.

## 6 Installation

The microwave-type level gauge shall be installed in accordance with the manufacturer's instructions.

## 7 Initial verification of accuracy

After installation, accuracy of the level gauge shall be verified by means of an appropriate proven method under atmospheric temperature and pressure in the tank. The error shall not exceed that defined in 5.2.


After a tank is opened up for survey, the accuracy of the gauge should be rechecked using this method.

## 8 Subsequent periodical verification of accuracy

A means of verification shall be provided, whereby the level-gauge accuracy can be checked at high and low tank levels, with the tank in service.


The high-level verification point shall be capable of being used when the tank is fully loaded. The error shall not exceed that described in 5.2.

This procedure should be used following maintenance on the level gauge or as required by the sale and purchase agreement.



- |   |                       |   |                       |   |                    |   |                  |
|---|-----------------------|---|-----------------------|---|--------------------|---|------------------|
| a | Power source          | f | Level signal output   | k | Inside tank        | p | Deflection plate |
| b | Power supply unit     | g | Display               | l | Verification level | q | Datum level      |
| c | Transceiver unit      | h | Antenna               | m | Liquid surface     | r | Liquid level     |
| d | Computer unit         | i | Upper reference point | n | Verification level | s | Ullage           |
| e | Data transmitter unit | j | Outside tank          | o | Tank bottom        |   |                  |

Figure 1 — Example of installation with a still pipe including optional devices



- |   |                       |   |                       |   |                    |   |              |
|---|-----------------------|---|-----------------------|---|--------------------|---|--------------|
| a | Power source          | f | Level signal output   | k | Inside tank        | p | Liquid level |
| b | Power supply unit     | g | Display               | l | Microwave beam     | q | Ullage       |
| c | Transceiver unit      | h | Antenna               | m | Liquid surface     |   |              |
| d | Computer unit         | i | Upper reference point | n | Verification level |   |              |
| e | Data transmitter unit | j | Outside tank          | o | Datum level        |   |              |

Figure 2 — Example of installation without a still pipe including optional devices