
**Gaseous fire-extinguishing systems —
Physical properties and system
design —**

Part 5:
FK-5-1-12 extinguishant

*Systèmes d'extinction d'incendie utilisant des agents gazeux —
Propriétés physiques et conception des systèmes —*

Partie 5: Agent extincteur FK-5-1-12



STANDARDSISO.COM : Click to view the full PDF of ISO 14520-5:2016



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Characteristics and uses	1
4.1 General	1
4.2 Use of FK-5-1-12 systems	2
5 Safety of personnel	5
6 System design	5
6.1 Fill density	5
6.2 Superpressurization	6
6.3 Extinguishant quantity	6
7 Environmental properties	9

STANDARDSISO.COM : Click to view the full PDF of ISO 14520-5:2016

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 8, *Gaseous media and firefighting systems using gas*.

This second edition cancels and replaces the first edition (ISO 14520-5:2006), which has been technically revised with the following changes:

- corrected the purity specification in [Table 1](#);
- added reference to 34,5 bar and 50 bar systems in [6.1](#) and [6.2](#);
- added tables for 34,5 bar and 50 bar systems storage container characteristics data;
- added figures for pressure vs. temperature charts for 34,5 bar and 50 bar systems;
- added [Clause 7](#).

A list of all parts in the ISO 14520 series can be found on the ISO website.

Gaseous fire-extinguishing systems — Physical properties and system design —

Part 5: FK-5-1-12 extinguishant

1 Scope

This document contains specific requirements for gaseous fire-extinguishing systems, with respect to FK-5-1-12 extinguishant. It includes details of physical properties, specification, usage and safety aspects.

This document covers only systems operating at nominal pressures of 25 bar, 34,5 bar, 42 bar and 50 bar with nitrogen propellant. This does not preclude the use of other systems.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 14520-1, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 1: General requirements*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 14520-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

4 Characteristics and uses

4.1 General

Extinguishant FK-5-1-12 shall comply with the specification shown in [Table 1](#).

FK-5-1-12 is a clear, colourless, almost odourless, electrically non-conductive gas with a density approximately 11 times that of air.

The physical properties are shown in [Table 2](#).

FK-5-1-12 extinguishes fires mainly by physical means, but also by some chemical means.

Table 1 — Specification for FK-5-1-12

Property	Requirement
Purity	99,0 % mol/mol min.
Acidity	3×10^{-6} by mass, max.
Water content	0,001 % by mass, max.
Non-volatile residue	0,03 % by mass, max.
Suspended matter or sediment	None visible

Table 2 — Physical properties of FK-5-1-12

Property	Units	Value
Molecular mass	n/a	316,04
Boiling point at 1,013 bar (absolute)	°C	49,2
Freezing point	°C	-108,0
Critical temperature	°C	168,66
Critical pressure	bar	18,646
Critical volume	cc/mole	494,5
Critical density	kg/m ³	639,1
Vapour pressure 20 °C	bar abs	0,3260
Liquid density 20 °C	g/ml	1,616
Saturated vapour density 20 °C	kg/m ³	4,3305
Specific volume of superheated vapour at 1,013 bar and 20 °C	m ³ /kg	0,0719
Heat of vapourization at boiling point	KJ/kg	88,0
Chemical formula	CF ₃ CF ₂ C(O)CF(CF ₃) ₂	
Chemical name	Dodecafluoro-2-methylpentan-3-one	

4.2 Use of FK-5-1-12 systems

FK-5-1-12 total flooding systems may be used for extinguishing fires of all classes within the limits specified in ISO 14520-1:2015, Clause 4.

The extinguishant requirements per volume of protected space are shown in [Table 3](#) for various levels of concentration. These are based on methods shown in ISO 14520-1:2015, 7.6.

The extinguishing concentrations and design concentrations for heptane and Surface Class A hazards are shown in [Table 4](#). Concentrations for other fuels are shown in [Table 5](#) and inerting concentrations in [Table 6](#).

Table 3 — FK-5-1-12 total flooding quantity

Temperature <i>T</i> °C	Specific volume <i>S</i> m ³ /kg	FK-5-1-12 mass requirements per unit volume of protected space, <i>m/V</i> (kg/m ³)							
		Design concentration (by volume)							
		3 %	4 %	5 %	6 %	7 %	8 %	9 %	10 %
-20	0,0609	0,5077	0,6840	0,8640	1,0407	1,2357	1,4275	1,6236	1,8241
-15	0,0623	0,4965	0,6690	0,8450	1,0248	1,2084	1,3961	1,5879	1,7839
-10	0,0637	0,4859	0,6545	0,8268	1,0027	1,1824	1,3660	1,5537	1,7455
-5	0,0650	0,4756	0,6407	0,8094	0,9816	1,1575	1,3372	1,5209	1,7087
0	0,0664	0,4658	0,6275	0,7926	0,9613	1,1336	1,3096	1,4895	1,6734

Table 3 (continued)

Temperature <i>T</i> °C	Specific volume <i>S</i> m ³ /kg	FK-5-1-12 mass requirements per unit volume of protected space, <i>m/V</i> (kg/m ³)							
		Design concentration (by volume)							
		3 %	4 %	5 %	6 %	7 %	8 %	9 %	10 %
5	0,0678	0,4564	0,6148	0,7766	0,9418	1,1106	1,2831	1,4593	1,6395
10	0,0691	0,4473	0,6026	0,7612	0,9232	1,0886	1,2576	1,4304	1,6070
15	0,0705	0,4386	0,5909	0,7464	0,9052	1,0674	1,2332	1,4026	1,5757
20	0,0719	0,4302	0,5796	0,7322	0,8879	1,0471	1,2096	1,3758	1,5457
25	0,0733	0,4222	0,5688	0,7184	0,8713	1,0275	1,1870	1,3500	1,5167
30	0,0746	0,4144	0,5583	0,7052	0,8553	1,0086	1,1652	1,3252	1,4888
35	0,0760	0,4069	0,5482	0,6925	0,8399	0,9904	1,1442	1,3013	1,4620
40	0,0774	0,3997	0,5385	0,6802	0,8250	0,9728	1,1239	1,2783	1,4361
45	0,0787	0,3928	0,5291	0,6684	0,8106	0,9559	1,1043	1,2560	1,4111
50	0,0801	0,3860	0,5201	0,6570	0,7967	0,9395	1,0854	1,2345	1,3869
55	0,0815	0,3795	0,5113	0,6459	0,7833	0,9237	1,0671	1,2137	1,3636
60	0,0829	0,3733	0,5029	0,6352	0,7704	0,9084	1,0495	1,1936	1,3410
65	0,0842	0,3672	0,4947	0,6247	0,7578	0,8936	1,0324	1,1742	1,3191
70	0,0856	0,3613	0,4868	0,6148	0,7457	0,8793	1,0158	1,1554	1,2980
75	0,0870	0,3556	0,4791	0,6052	0,7339	0,8654	0,9998	1,1372	1,2775
80	0,0883	0,3501	0,4716	0,5958	0,7225	0,8520	0,9843	1,1195	1,2577
85	0,0897	0,3447	0,4644	0,5866	0,7115	0,8390	0,9692	1,1024	1,2385
90	0,0911	0,3395	0,4574	0,5778	0,7008	0,8263	0,9547	1,0858	1,2198
95	0,0925	0,3345	0,4507	0,5692	0,6904	0,8141	0,9405	1,0697	1,2014
100	0,0938	0,3296	0,4441	0,5609	0,6803	0,8022	0,9267	1,0540	1,1842

NOTE This information refers only to FK-5-1-12 and does not represent any other product containing dodecafluoromethylpentan-3-one as a component.

Symbols:

m/V is the agent mass requirements (kg/m³), i.e. mass, *m*, in kilograms of agent required per cubic metre of protected volume, *V*, to produce the indicated concentration at the temperature specified;

V is the net volume of hazard (m³), i.e. the enclosed volume minus the fixed structures impervious to extinguishant

$$m = \left(\frac{c}{100 - c} \right) \frac{V}{S}$$

T is the temperature (°C), i.e. the design temperature in the hazard area;

S is the specific volume (m³/kg); the specific volume of superheated FK-5-1-12 vapour at a pressure of 1,013 bar may be approximated by the formula

$$S = k_1 + k_2 T$$

where

$$k_1 = 0,0664$$

$$k_2 = 0,000274$$

c is the concentration (%), i.e. the volumetric concentration of FK-5-1-12 in air at the temperature indicated and a pressure of 1,013 bar absolute.

Table 4 — FK-5-1-12 reference extinguishing and design concentrations

Fuel	Extinguishment % by volume	Minimum design % by volume
Class B		
Heptane (cup burner)	4,5	5,9
Heptane (room test)	4,4	
Surface Class A		
Wood crib	3,4	5,3
PMMA	4,1	
PP	4,0	
ABS	4,0	
Higher Hazard Class A	See Note 4	5,6
NOTE 1 The extinguishment values for the Class B and the Surface Class A fuels are determined by testing in accordance with ISO 14520-1:2015, Annexes B and C.		
NOTE 2 The minimum design concentration for the Class B fuel is the higher value of the heptane cup burner or room test heptane extinguishment concentration multiplied by 1,3.		
NOTE 3 The minimum design concentration for Surface Class A fuel is the highest value of the wood crib, PMMA, PP or ABS extinguishment concentrations multiplied by 1,3. In the absence of any of the four extinguishment values, the minimum design concentration for Surface Class A is that of Higher Hazard Class A.		
NOTE 4 The minimum design concentration for Higher Hazard Class A fuels is the higher of the Surface Class A or 95 % of the Class B minimum design concentration.		
NOTE 5 See ISO 14520-1:2015, 7.5.1.3 for guidance on Class A fuels.		

In [Table 4](#), the extinguishing and design concentrations for room-scale test fires are for informational purposes only. Lower and higher extinguishing concentrations than those shown for room-scale test fires may be achieved and allowed when validated by test reports from internationally recognized laboratories.

Table 5 — FK-5-1-12 concentrations for other fuels

Fuel	Extinguishment % by volume	Minimum design % by volume
Acetone	4,5	5,9
Ethyl alcohol	5,5	7,2
Marine diesel	4,5	5,9
Methyl alcohol	6,5	8,5
Methyl ethyl ketone	4,5	5,9
n-heptane	4,5	5,9
Technical heptane	4,5	5,9
NOTE Extinguishing concentrations for all Class B fuels listed were derived in accordance with ISO 14520-1:2015, Annex B.		
Minimum design values have been increased to the minimum design concentration established for heptane in accordance with ISO 14520-1:2015, 7.5.1.		

Table 6 — FK-5-1-12 inerting and design concentrations

Fuel	Inertion %	Minimum design %
Methane	8,8	9,7
Propane	8,1	8,9
NOTE Determined in accordance with ISO 14520-1.		

5 Safety of personnel

Any hazard to personnel created by the discharge of FK-5-1-12 shall be considered in the design of the system.

Potential hazards can arise from the following:

- the extinguishant itself;
- the combustion products of the fire;
- the breakdown products of the extinguishant resulting from exposure to fire.

For minimum safety requirements, see ISO 14520-1:2015, Clause 5.

Toxicological information for FK-5-1-12 is shown in [Table 7](#).

Table 7 — Toxicological information for FK-5-1-12

Property	Value %
4 h LC ₅₀	>10 %
No observed adverse effect level (NOAEL)	10 %
Lowest observed adverse effect level (LOAEL)	>10 %
NOTE LC ₅₀ is the concentration lethal to 50 % of the rat population during a 4 h exposure.	

6 System design

6.1 Fill density

The fill density of the container shall not exceed the values shown in [Table 8](#) to [11](#) for 25 bar, 34,5 bar, 42 bar or 50 bar systems.

Exceeding the maximum fill density may result in the container becoming “liquid full”, with the effect that an extremely high rise in pressure occurs with small increases in temperature, which could adversely affect the integrity of the container assembly.

The relationships between pressure and temperature are shown in [Figure 1](#) for various levels of fill density.

Table 8 — 25 bar storage container characteristics for FK-5-1-12

Property	Unit	Value
Maximum fill density	kg/m ³	1 480
Maximum container working pressure at 50 °C	bar (gauge)	29
Superpressurization at 20 °C	bar (gauge)	25
NOTE Reference should be made to Figure 1 for further data on pressure/temperature relationships.		

Table 9 — 34,5 bar storage container characteristics for FK-5-1-12

Property	Unit	Value
Maximum fill density	kg/m ³	1 200
Maximum container pressure at 50 °C	bar (absolute)	48
Superpressurization at 20 °C	bar (absolute)	34,5
NOTE Reference should be made to Figure 2 for further data on pressure/temperature relationships.		

Table 10 — 42 bar storage container characteristics for FK-5-1-12

Property	Unit	Value
Maximum fill density	kg/m ³	1 440
Maximum container pressure at 50 °C	bar (absolute)	38
Superpressurization at 20 °C	bar (absolute)	42
NOTE Reference should be made to Figure 3 for further data on pressure/temperature relationships.		

Table 11 — 50 bar storage container characteristics for FK-5-1-12

Property	Unit	Value
Maximum fill density	kg/m ³	1 200
Maximum container pressure at 50 °C	bar (absolute)	57
Superpressurization at 21 °C	bar (absolute)	50
NOTE Reference should be made to Figure 4 for further data on pressure/temperature relationships.		

6.2 Superpressurization


Containers shall be superpressurized with nitrogen with a moisture content of not more than 60×10^{-6} by mass to an equilibrium pressure of 25 bar $^{+5}_0\%$, 34,5 bar $^{+5}_0\%$, 42 bar $^{+5}_0\%$ or 50 bar $^{+5}_0\%$ at a temperature of 20 °C.

6.3 Extinguishant quantity

The quantity of extinguishant shall be the minimum required to achieve the design concentration within the hazard volume at the minimum expected temperature, determined using [Table 3](#) and the method in ISO 14520-1:2015, 7.6.

The design concentrations shall be that specified for relevant hazards shown in [Table 4](#). This includes at least a 1,3 safety factor on the extinguishing concentration.

Consideration should be given to increasing this for particular hazards and seeking advice from the relevant authority.



Key

X temperature, °C

Y pressure, bar

Figure 1 — Temperature/pressure graph for FK- 5-1-12 superpressurized with nitrogen 25 bar at 20 °C

STANDARDSISO.COM : Click to view the full PDF of ISO 14520-5:2016