

First edition
2013-04-15

AMENDMENT 1
2019-04

Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —

Part 1:
Cooling seasonal performance factor

AMENDMENT 1

Climatiseurs à condenseur à air et pompes à chaleur air/air — Essais et méthodes de calcul des coefficients de performance saisonniers —

Partie 1: Coefficient de performance saisonnier de refroidissement (COPSR)

AMENDEMENT 1



Reference number
ISO 16358-1:2013/Amd.1:2019(E)

© ISO 2019

STANDARDSISO.COM : Click to view the full PDF of ISO 16358-1:2013/Amd 1:2019



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 6, *Testing and rating of air-conditioners and heat pumps*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

STANDARDSISO.COM : Click to view the full PDF of ISO 16358-1:2013/Amd 1:2019

Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —

Part 1: Cooling seasonal performance factor

AMENDMENT 1

Page 1, 1.2

Add “ and T3” after the words “the rating conditions are those specified under T1”.

Page 3, 3.13

Add “ or T3” after the words “cooling capacity at T1”.

Page 3, 3.14

Add “ or T3” after the words “electric power input at T1”.

Page 3, 3.15

Add “ or T3” after the words “capacity which is 50 % of cooling full capacity at T1”.

Page 3, 3.16

Add “ or T3” after the words “electric power input when operated at 50 % of cooling full capacity at T1”.

Page 3, 3.17

Add “ or T3” after the words “capacity at T1”.

Page 3, 3.18

Add “ or T3” electric power input at T1”.

Page 3, after 3.22

Add 3.23 and 3.24

3.23

T1 climate

standardized range of climate conditions for a moderate climate

3.24

T3 climate

standardized range of climate conditions for a hot climate

Page 3, Clause 4 Symbols

Add the following row after C_{CSE} row

C_D degradation coefficient

Add the following row after $P_{ful}(t_j)$ row

$P_{ful}(46)$ cooling full power input at T3 temperature condition W

Add the following row after $P_{haf}(t_j)$ row

$P_{haf}(46)$ cooling half power input at T3 temperature condition W

Add the following row after $P_{min}(t_j)$ row

$P_{min}(46)$ cooling minimum power input at T1 temperature condition W

Add the following row after $\phi_{ful}(t_j)$ row

$\phi_{ful}(46)$ cooling full capacity at T3 temperature condition W

Add the following row after $\phi_{haf}(t_j)$ row

$\phi_{haf}(46)$ cooling half capacity at T3 temperature condition W

Add the following row after $\phi_{min}(t_j)$ row

$\phi_{min}(46)$ cooling minimum capacity at T3 temperature condition W

Page 5, 5.2 Test conditions

Add

“for units rated for T1 climate and Table F.1 in Annex F for units rated for T3 climate”

after

“for calculation shall be as specified in Table 1”

Page 6, 5.3.2 Low temperature cooling capacity tests

Add

“for T1 climate or Table F.1 for T3 climate”

after

“default values as given in Table 1”

Page 7, 5.3.3 Low humidity cooling test and cyclic cooling test

Add

“for T1 climate or Table F.1 for T3 climate”

after

“default values as given in Table 1”

Page 7, Clause 6 Calculations

Add the following sentences and Table after the first sentence:

For units rated for T1 climate, calculations shall be made according to Clause 6 and for units rated for T3 climate, calculations shall be made according to F.2.

NOTE A calculation tool (spreadsheet) is available to perform all the calculations of Clause 6, given the individual test input. It is available at <https://standards.iso.org/iso/16358/-1/ed-1/en/amd/1>. The issuer is permitted to use the calculation tool in its original format without any modifications for the purpose specified in this document.

Table 2 shows the formulae used for T1 climate and T3 climate in order to read this document more easily.

Table 2 — Formulae used to calculate CSPF and FCSP for T1 climate and T3 climate

		T1 climate	T3 climate
	CSPF, FCSP	(1) and Annex B	(1) and Annex B
	Cooling load $L_c(t_j)$	(2) with $t_0 = 20\text{ °C}$ and $t_{100} = 35\text{ °C}$	(2) with $t_0 = 20\text{ °C}$ and $t_{100} = 46\text{ °C}$
Fixed	$\phi_{ful}(t_j)$	(3)	(F.1), (F.2)
	$P_{ful}(t_j)$	(4)	(F.3), (F.4)
	(CSTL), L_{CST}	(5)	(5)
	(CSEC), C_{CSE}	(6), (7), (8)	(6), (7), (8)
Two-stage	$\phi_{ful}(t_j)$	(3)	(F.1), (F.2)
	$\phi_{min}(t_j)$	(9)	(F.5), (F.6)
	$P_{ful}(t_j)$	(4)	(F.3), (F.4)
	$P_{min}(t_j)$	(10)	(F.7), (F.8)
	(CSTL), L_{CST}	(5)	(5)
	(CSEC), C_{CSE}	(11), (7), (12), (13), (4)	(11), (7), (12), (13), (4)
Multi-stage	$\phi_{ful}(t_j)$	(3)	(F.1), (F.2)
	$\Phi_{haf}(t_j)$	(14)	(F.9), (F.10)
	$\phi_{min}(t_j)$	(9)	(F.5), (F.6)
	$P_{ful}(t_j)$	(4)	(F.3), (F.4)
	$P_{haf}(t_j)$	(15)	(F.11), (F.12)
	$P_{min}(t_j)$	(10)	(F.7), (F.8)
	(CSTL), L_{CST}	(5)	(5)
	(CSEC), C_{CSE} when minimum capacity available	(16), (7), (17), (18), (19), (20), (4) (Annex E)	(16), (7), (17), (18), (19), (20), (4) (Annex E)
(CSEC), C_{CSE} when minimum capacity not available	(21), (7), (19), (20), (4) (Annex E)	(21), (7), (19), (20), (4) (Annex E)	

Table 2 (continued)

		T1 climate	T3 climate
Variable	$\phi_{ful}(t_j)$	(3)	(F.1), (F.2)
	$\Phi_{haf}(t_j)$	(14)	(F.9), (F.10)
	$\phi_{min}(t_j)$	(9)	(F.5), (F.6)
	$P_{ful}(t_j)$	(4)	(F.3), (F.4)
	$P_{haf}(t_j)$	(15)	(F.11), (F.12)
	$P_{min}(t_j)$	(10)	(F.7), (F.8)
	(CSTL), L_{CST}	(5)	(5)
	(CSEC), C_{CSE} when minimum capacity available	(16), (7), (22), (23), (24), (25), (26),(27),(4) (Annex E)	(16), (7), (22), (23), (24), (25), (26),(27),(4) (F.13), (F.14), (F.15), (F.16), (F.17), (F.18)
	(CSEC), C_{CSE} when minimum capacity is not available	(21), (7), (24), (25), (26),(27),(4) (Annex E)	(21), (7), (24), (25), (26),(27),(4) (F.15), (F.16), (F.17), (F.18)

Page 7, 6.2

Replace “Table 2 — Defined cooling load”

with

“Table 3 — Defined cooling load”

Page 7, 6.3

Replace

“Table 3 — Reference outdoor temperature bin distribution for T1 climate”

with “Table 4 — Reference outdoor temperature bin distribution for T1 climate”


Page 13, Clause 7 Test report

Add the following sentence at the end of the last sentence of the Clause.

“It shall be specified whether the CSPF is for T1 climate, T3 climate or a location specific temperature bin distribution.”

Annex A

Replace Figure A.1 — Cooling capacity, power input and cooling load for fixed capacity units, by the following figure:




Key

- X outdoor temperature
- Y1 capacity or load
- Y2 power input

Figure A.1 — Cooling capacity, power input and cooling load for fixed capacity units

Replace Figure A.2 — Cooling capacity, power input and cooling load for two-stage capacity units, by the following figure:

STANDARDSISO.COM : Click to view the full PDF of ISO 16358-1:2013/Amd 1:2019




Key
 X outdoor temperature
 Y1 capacity or load
 Y2 power input

Figure A.2 — Cooling capacity, power input and cooling load for two-stage capacity units

Replace Figure A.3 — Cooling capacity, power input and cooling load for multi-stage capacity units, by the following figure:

STANDARDSISO.COM : Click to view the full PDF of ISO 16358-1:2013/Amd 1:2019




Key

- X outdoor temperature
- Y1 capacity or load
- Y2 power input

Figure A.3 — Cooling capacity, power input and cooling load for multi-stage capacity units

Replace Figure A.4 — Cooling capacity, power input and cooling load and EER for variable capacity units, by the following figure:



Key
 X outdoor temperature
 Y1 capacity or load
 Y2 power input

Figure A.4 — Cooling capacity, power input and cooling load and EER for variable capacity units

Annex B

Page 19, B.2

Replace Table B.1 with the following table

Temperature condition	5 °C	10 °C	15 °C	20 °C
Weighting factor, T1 climate	0,05	0,13	0,27	0,55
Weighting factor, T3 climate	0,00	0,18	0,27	0,55

In the definition for H_{ia} add “for T1 climate or Table B.3 for T3 climate” after “as given in Table B.2”.

Page 19, B.3, second sentence

Add “and for T3 climate according to Annex F.”

after

“according to the main body of this document”.

Add “for T1 climate”

after

“Calculation of L_{CST} and C_{CSE} is”

Page 20, B.3

Add “for T1 climate or Table B.3 for T3 climate”

after

“cooling seasonal performance factor are shown in Table B.2”.

Add Table B.3 after Table B.2

Table B.3 — Default hours for T3 climate by mode for the calculation of reference total cooling seasonal performance factor

Unit	Active mode h	Inactive mode, H_{ia} h	Disconnected mode h
Cooling only unit and reversible unit	6 493	2 267	0

Annex C

Page 21, C.1

Replace the sentence “Testing condition for cyclic test is shown in Table C.1”

by

“Testing conditions for cyclic cooling tests are shown in Table C.1 for T1 climate and Table C.2 for T3 climate.”

Add new Table C.2.

Table C.2 — Temperature and humidity conditions for T3 climate cyclic cooling test

Test	Indoor temperature °C		Outdoor temperature °C	
	Dry-bulb	Wet-bulb	Dry-bulb	Wet-bulb
A test: Steady, dry coil	27	13,9 or less	35	—
B test: Cyclic, dry coil	27	13,9 or less	35	—

The entering air to the unit shall have a low enough moisture content so that no condensate forms on the indoor coil. (It is recommended that an indoor wet-bulb temperature of 13,9 °C or less be used.)

NOTE Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the A test.

Add this sentence

“For T1climate and T3 climate, duration of ON and OFF interval of cyclic operation test is shown in Table C.3”

after the new table C.2

Replace “Table C.2 — Duration of ON and OFF interval of cyclic operation test”
with

“Table C.3 — Duration of ON and OFF interval of cyclic operation test”

Page 22, C.2.2.1

Replace

“Table C.2”

with

“Table C.3”

in the sentence “Duration of ON and OFF interval shall be in accordance with Table C.2.”

Page 22, C.2.2.4, second paragraph

Replace

“Test tolerance of the dry-bulb temperature shall be $\pm 2,5^{\circ}\text{C}$ on the indoor side and $\pm 5^{\circ}\text{C}$ on the outdoor side as specified in ISO 5151, ISO 13253 and ISO 15042.”

with

“Variation of individual readings of the dry-bulb temperature shall be $\pm 2,5\text{ K}$ on the indoor side and $\pm 5\text{ K}$ on the outdoor side and variation of arithmetical mean values of the dry-bulb temperature shall be $\pm 1,5\text{ K}$ on both the indoor and outdoor side as specified in ISO 5151, ISO 13253 and ISO 15042.”

Page 23, C.2.2.4, fifth paragraph

Add “for T1 climate and Table C.2 for T3 climate” after “A test and B test of Table C.1”.

Annex E, Page 25

Replace Annex E label “(informative)” to “(normative)”.

Add the following sentence after the title

“For units rated for T1 climate the following calculations apply. See Annex F for units rated for T3 climate.”

Replace Formula (E.2) with “ $\varnothing_{\text{ful}}(t_j) = \varnothing_{\text{ful}}(35) + \frac{\varnothing_{\text{ful}}(29) - \varnothing_{\text{ful}}(35)}{(35 - 29)} \times (35 - t_j)$ ”

Add the following new Annex F.

Annex F (informative)

Test conditions and calculations of the cooling seasonal performance factor (CSPF) and total cooling seasonal performance factor (TCSPF) for hot climates

Refer to Annex B for calculation of TCSPF.

F.1 Test conditions

For hot climates, temperature conditions and humidity conditions as well as default values shall be calculated as specified in Table F.1.

Table F.1 — Temperature and humidity conditions and default values for cooling at T3 hot climate condition according to ISO 5151, ISO 13253, ISO 15042

Test	Characteristics	Fixed	Two-stage	Mul-ti-stage	Variable	Default value
Standard cooling capacity test Indoor DB 29 °C	Full capacity ϕ_{ful} (46) (W)	■	■	■	■	—
	Full power input P_{ful} (46) (W)					
WB 19 °C	Half capacity ϕ_{haf} (46) (W)	-	-	○	○	0,859 x ϕ_{haf} (35)
	Half power input P_{haf} (46) (W)					1,25 x P_{haf} (35)
Outdoor DB 46 °C	Minimum capacity ϕ_{min} (46) (W)	-	○	○	○	0,859 x ϕ_{min} (35)
	Minimum power input P_{min} (46) (W)					1,25 x P_{min} (35)
Medium cooling capacity test Indoor DB 27 °C	Full capacity ϕ_{ful} (35) (W)	■	■	■	■	-
	Full power input P_{ful} (35) (W)					
WB 19 °C	Half capacity ϕ_{haf} (35) (W)	-	-	■	■	-
	Half power input P_{haf} (35) (W)					
Outdoor DB 35 °C	Minimum capacity ϕ_{min} (35) (W)	-	■	○	○	-
	Minimum power input P_{min} (35) (W)					
Medium cooling capacity test Indoor DB 27 °C	Full capacity ϕ_{ful} (29) (W)	○	○	○	-	1,077 x ϕ_{ful} (35)
	Full power input P_{ful} (29) (W)					0,914 x P_{ful} (35)
WB 19 °C	Half capacity ϕ_{haf} (29) (W)	-	-	○	○	1,077 x ϕ_{haf} (35)
	Half power input P_{haf} (29) (W)					0,914 x P_{haf} (35)
Outdoor DB 29 °C	Minimum capacity ϕ_{min} (29) (W)	-	○	○	○	1,077 x ϕ_{min} (35)
	Minimum power input P_{min} (29) (W)					0,914 x P_{min} (29)
■ required test ○ optional test NOTE 1 If the medium capacity test is measured, min (35) test is conducted first. Min (46) or min(29) test may be measured or may be calculated by using default values. NOTE 2 Voltage(s) and frequenc(i)e(s) are as given in the three referenced standards. NOTE 3 In lieu of conducting a cyclic test at 35°C, the C_D from the 29°C cyclic test multiplied by 1,08 may be used.						

Table F.1 (continued)

Test	Characteristics	Fixed	Two-stage	Multi-stage	Variable	Default value
Low humidity and cyclic cooling Indoor DB 27 °C WB 16 °C or lower Outdoor DB 35 °C WB -	Degradation coefficient C_D	Full capacity	○	-	-	0,27
		Half capacity	-	-	○	0,27
		Minimum capacity	-	○	○	-
<p>■ required test ○ optional test</p> <p>NOTE 1 If the medium capacity test is measured, min (35) test is conducted first. Min (46) or min(29) test may be measured or may be calculated by using default values.</p> <p>NOTE 2 Voltage(s) and frequenc(i)e(s) are as given in the three referenced standards.</p> <p>NOTE 3 In lieu of conducting a cyclic test at 35°C, the C_D from the 29°C cyclic test multiplied by 1,08 may be used.</p>						

F.2 Calculations

The calculations shall be performed as per Clause 6, unless specified differently in this clause.

F.2.2 Defined cooling load

The defined cooling load $L_c(t_j)$ at outdoor temperature t_j shall be determined by Formula (2).

In Formula (2), $t_0 = 20$ and $t_{100} = 46$.

In case of setting other cooling load, refer to the setting method as described in Annex D.

F.2.3 Outdoor temperature bin distribution for cooling

Cooling seasonal performance factor (CSPF) for **T3 climate** shall be calculated at the reference climate condition in Table F.2.

The calculation of cooling seasonal performance factor may also be done for other climate conditions using different bin distribution under hot climate conditions.

Table F.2 — Reference outdoor temperature bin distribution for T3 climate

Bin number j	Outdoor temperature t_j °C	Fractional bin hours (informative)	Bin hours n_j	Reference bin hours (n_j)h
1	21	0,047	n_1	307
2	22	0,048	n_2	311
3	23	0,049	n_3	317
4	24	0,050	n_4	325
5	25	0,051	n_5	334
6	26	0,053	n_6	342
7	27	0,054	n_7	349
8	28	0,054	n_8	354
9	29	0,055	n_9	356
10	30	0,055	n_{10}	355

Table F.2 (continued)

Bin number j	Outdoor temperature t_j °C	Fractional bin hours (informative)	Bin hours n_j	Reference bin hours (n_j)h
11	31	0,054	n_{11}	351
12	32	0,053	n_{12}	344
13	33	0,051	n_{13}	332
14	34	0,049	n_{14}	317
15	35	0,046	n_{15}	299
16	36	0,043	n_{16}	277
17	37	0,039	n_{17}	252
18	38	0,035	n_{18}	225
19	39	0,030	n_{19}	195
20	40	0,025	n_{20}	165
21	41	0,021	n_{21}	133
22	42	0,016	n_{22}	103
23	43	0,011	n_{23}	73
24	44	0,007	n_{24}	47
25	45	0,004	n_{25}	24
26	46	0,001	n_{26}	6
			Total	6 493

NOTE The fractional bin hours are rounded to the closest one-thousandth.

The calculation of cooling performance factor may also be done for other climate conditions, e.g. instead of the reference climate a climate of a specific city.

In case the outdoor temperature is higher than 46 °C, the 100 % cooling load can be set based on that temperature without changing the test conditions in Table F.1. In case of setting other temperature bin distribution, refer to the setting method as described in Annex D.

F.2.4 Cooling seasonal characteristics of fixed speed capacity units

Operational performance at each test, which is used for calculation of seasonal performance factor, shall be in accordance with Table F.1.

F.2.4.1 Capacity characteristics against outdoor temperature

The capacity $\phi_{ful}(t_j)$ (W) of the equipment when it is operated for cooling at outdoor temperature t_j linearly changes depending on outdoor temperatures as shown in Figure F.1, and it is determined by Formula (F.1) and (F.2) from three characteristics, one at 46 °C, one at 35 °C and the other at 29 °C.

Lower temperature range $t_j \leq 35$ °C

$$\phi_{ful}(t_j) = \phi_{ful}(35) + \frac{\phi_{ful}(29) - \phi_{ful}(35)}{35 - 29} \times (35 - t_j) \quad (F.1)$$

Higher temperature range $t_j > 35$ °C

$$\phi_{ful}(t_j) = \phi_{ful}(46) + \frac{\phi_{ful}(35) - \phi_{ful}(46)}{46 - 35} \times (46 - t_j) \quad (F.2)$$

F.2.4.2 Power input characteristics against outdoor temperature

The power input $P_{ful}(t_j)$ (W) of the equipment when it is operated for cooling at outdoor temperature t_j linearly changes depending on outdoor temperatures as shown in Figure F.1, and it is determined by Formula (F.3) and (F.4) from three characteristics, one at 46 °C, one at 35 °C and the other at 29 °C.

Lower temperature range $t_j \leq 35$ °C

$$P_{ful}(t_j) = P_{ful}(35) + \frac{P_{ful}(29) - P_{ful}(35)}{35 - 29} \times (35 - t_j) \tag{F.3}$$

Higher temperature range $t_j > 35$ °C

$$P_{ful}(t_j) = P_{ful}(46) + \frac{P_{ful}(35) - P_{ful}(46)}{46 - 35} \times (46 - t_j) \tag{F.4}$$

F.2.4.3 Calculation of cooling seasonal total load (CSTL)

Cooling seasonal total load (CSTL), L_{CST} , shall be determined using Formula (5).

$L_C(t_j)$ shall be calculated by Formula (2), modified as described in Clause F.2.2.

$\phi_{ful}(t_j)$ shall be calculated by Formula (F.1) and (F.2).

F.2.5 Cooling seasonal characteristics of two-stage capacity units

Operational performance at each test, which is used for calculation of seasonal performance factor, shall be in accordance with Table F.1.

F.2.5.1 Capacity characteristics against outdoor temperature

The capacity $\phi_{ful}(t_j)$ (W) of the equipment when it is operated for cooling full capacity at outdoor temperature t_j are shown in Figure F.2 and calculated by Formula (F.1) and (F.2).

The capacity $\phi_{min}(t_j)$ (W) of the equipment when it is operated for cooling minimum capacity at outdoor temperature t_j shall be calculated by Formula (F.5) and (F.6) from three characteristics, one at 46 °C, one at 35 °C and the other at 29 °C.

Lower temperature range $t_j \leq 35$ °C

$$\phi_{min}(t_j) = \phi_{min}(35) + \frac{\phi_{min}(29) - \phi_{min}(35)}{35 - 29} \times (35 - t_j) \tag{F.5}$$

Higher temperature range $t_j > 35$ °C

$$\phi_{min}(t_j) = \phi_{min}(46) + \frac{\phi_{min}(35) - \phi_{min}(46)}{46 - 35} \times (46 - t_j) \tag{F.6}$$

F.2.5.2 Power input characteristics against outdoor temperature

The power input $P_{ful}(t_j)$ (W) of the equipment when it is operated for cooling full capacity at outdoor temperature t_j are shown in Figure F.2 and calculated by Formula (F.3) and (F.4).

The power input $P_{min}(t_j)$ (W) of the equipment when it is operated for cooling minimum capacity at outdoor temperature t_j shall be calculated by Formula (F.7) and (F.8) from three characteristics, one at 46 °C, one at 35 °C and the other at 29 °C.

Lower temperature range $t_j \leq 35$ °C

$$P_{min}(t_j) = P_{min}(35) + \frac{P_{min}(29) - P_{min}(35)}{35 - 29} \times (35 - t_j) \quad (F.7)$$

Higher temperature range $t_j > 35$ °C

$$P_{min}(t_j) = P_{min}(46) + \frac{P_{min}(35) - P_{min}(46)}{46 - 35} \times (46 - t_j) \quad (F.8)$$

F.2.6 Cooling seasonal characteristic of multistage capacity units

Operational performance at each test, which is used for calculation of seasonal performance factor, shall be in accordance with Table F.1.

F.2.6.1 Capacity characteristics against outdoor temperature

The capacity $\phi_{ful}(t_j)$ and $\phi_{min}(t_j)$ (W) of the equipment when it is operated for cooling full capacity at outdoor temperature t_j are shown in Figure F.3 and calculated by Formulas (F.1) and (F.2 and (F.5) and (F.6).

Formulas (F.9) and (F.10) show cooling half capacity characteristics at outdoor temperature t_j from three characteristics, one at 46 °C, one at 35 °C and the other at 29 °C.

Lower temperature range $t_j \leq 35$ °C

$$\phi_{haf}(t_j) = \phi_{haf}(35) + \frac{\phi_{haf}(29) - \phi_{haf}(35)}{35 - 29} \times (35 - t_j) \quad (F.9)$$

Higher temperature range $t_j > 35$ °C

$$\phi_{haf}(t_j) = \phi_{haf}(46) + \frac{\phi_{haf}(35) - \phi_{haf}(46)}{46 - 35} \times (46 - t_j) \quad (F.10)$$

F.2.6.2 Power input characteristics against outdoor temperature

The power input $P_{ful}(t_j)$ and $P_{min}(t_j)$ (W) of the equipment when it is operated for cooling full capacity at outdoor temperature t_j are shown in Figure F.3 and calculated by Formulas (F.3) and (F.4) and (F.7) and (F.8).

Formulas (F.11) and (F.12) show cooling half power input characteristics at outdoor temperature t_j .

Lower temperature range $t_j \leq 35$ °C

$$P_{haf}(t_j) = P_{haf}(35) + \frac{P_{haf}(29) - P_{haf}(35)}{35 - 29} \times (35 - t_j) \quad (F.11)$$

Higher temperature range $t_j > 35$ °C

$$P_{haf}(t_j) = P_{haf}(46) + \frac{P_{haf}(35) - P_{haf}(46)}{46 - 35} \times (46 - t_j) \quad (F.12)$$

F.2.7 Cooling seasonal characteristics of variable capacity units

Operational performance at each test, which is used for calculation of seasonal performance factor, shall be in accordance with Table F.1.

F.2.7.1 Capacity characteristics against outdoor temperature

The capacity $\phi_{ful}(t_j)$, $\phi_{haf}(t_j)$ and $\phi_{min}(t_j)$ (W) of the equipment when it is operated for cooling full capacity at outdoor temperature t_j are shown in Figure F.4 and calculated by Formulae (F.1) and (F.2), (F.9) and (F.10) and (F.5) and (F.6).

F.2.7.2 Power input characteristics against outdoor temperature

The power input $P_{ful}(t_j)$, $P_{haf}(t_j)$ and $P_{min}(t_j)$ (W) of the equipment when it is operated for cooling full capacity at outdoor temperature t_j are shown in Figure F.4 and calculated by Formulae (F.3) and (F.4), (F.11) and (F.12) and (F.7) and (F.8).

F.2.7.3 Calculation of cooling seasonal energy consumption (CSEC)

The cooling seasonal energy consumption shall be calculated as described in 6.7.4.

Relation of cooling capacity, power input and EER characteristics to cooling load at outdoor temperature t_j is shown in Figure F.4.

In Formula (22), t_p shall be calculated from Formulae (F.13) and (F.14):

Lower temperature range $t_j \leq 35$ °C

$$t_p = \frac{(35-29)\phi_{ful}(t_{100})t_0 + (35-29)\phi_{min}(35)(t_{100}-t_0) + 35(\phi_{min}(29) - \phi_{min}(35))(t_{100}-t_0)}{(35-29)\phi_{ful}(t_{100}) + (\phi_{min}(29) - \phi_{min}(35))(t_{100}-t_0)} \quad (F.13)$$

Higher temperature range $t_j > 35$ °C

$$t_p = \frac{(46-35)\phi_{ful}(t_{100})t_0 + (46-35)\phi_{min}(46)(t_{100}-t_0) + 46(\phi_{min}(35) - \phi_{min}(46))(t_{100}-t_0)}{(46-35)\phi_{ful}(t_{100}) + (\phi_{min}(35) - \phi_{min}(46))(t_{100}-t_0)} \quad (F.14)$$

In formulae (22), (24) and (26), t_c shall be calculated from (F.15) and (F.16):

Lower temperature range $t_j \leq 35$ °C

$$t_c = \frac{(35-29)\phi_{ful}(t_{100})t_0 + (35-29)\phi_{haf}(35)(t_{100}-t_0) + 35(\phi_{haf}(29) - \phi_{haf}(35))(t_{100}-t_0)}{(35-29)\phi_{ful}(t_{100}) + (\phi_{haf}(29) - \phi_{haf}(35))(t_{100}-t_0)} \quad (F.15)$$

Higher temperature range $t_j > 35$ °C