

---

---

**Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —**

**Part 2:  
Heating seasonal performance factor**

*Climatiseurs à condenseur à air et pompes à chaleur air/air — Essais et méthodes de calcul des coefficients de performance saisonniers —*

*Partie 2: Coefficient de performance saisonnier de chauffage (COPSC)*



STANDARDSISO.COM : Click to view the full PDF of ISO 16358-2:2013



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2013

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

	Page
Foreword .....	iv
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Symbols</b> .....	<b>4</b>
<b>5 Tests</b> .....	<b>7</b>
5.1 General .....	7
5.2 Test conditions .....	7
5.3 Test methods .....	9
<b>6 Calculations</b> .....	<b>10</b>
6.1 Heating seasonal performance factor (HSPF) and total heating seasonal performance factor (THSPF) .....	10
6.2 Defined heating load .....	10
6.3 Outdoor temperature bin distribution for heating .....	10
6.4 Heating seasonal characteristics of fixed capacity units .....	11
6.5 Heating seasonal characteristics of two-stage capacity units .....	13
6.6 Heating seasonal characteristics of multi-stage capacity units .....	15
6.7 Heating seasonal characteristics of variable capacity units .....	20
<b>7 Test report</b> .....	<b>24</b>
<b>Annex A (informative) Figures</b> .....	<b>26</b>
<b>Annex B (informative) Calculation of total heating seasonal performance factor (THSPF)</b> .....	<b>30</b>
<b>Annex C (normative) Testing and calculation method for degradation coefficient of cyclic operation</b> .....	<b>32</b>
<b>Annex D (informative) Calculating method for seasonal performance factor when setting a specific heating load</b> .....	<b>35</b>
<b>Annex E (informative) Calculating method for temperature when defined load line crosses each capacity line</b> .....	<b>36</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2. [www.iso.org/directives](http://www.iso.org/directives)

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received. [www.iso.org/patents](http://www.iso.org/patents)

Any trade name used in this document is information given for the convenience of users of this document and does not constitute an endorsement. Equivalent products can be used if they can be shown to lead to the same results.

The committee responsible for this document is ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 6, *Testing and rating of air-conditioners and heat pumps*.

The parts of ISO 16358 are given below:

- *Part 1: Cooling seasonal performance factor*
- *Part 2: Heating seasonal performance factor*
- *Part 3: Annual performance factor*

# Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —

## Part 2: Heating seasonal performance factor

### 1 Scope

**1.1** This part of ISO 16358 specifies the testing and calculating methods for seasonal performance factor of equipment covered by ISO 5151, ISO 13253 and ISO 15042. For the purposes of this part of ISO 16358, it is assumed that any make-up heating will be provided by electric heaters running concurrently with the heat pump.

**1.2** This part of ISO 16358 also specifies the seasonal performance test conditions and the corresponding test procedures for determining the seasonal performance factor of equipment, as specified in [1.1](#), under mandatory test conditions and is intended for use only in marking, comparison, and certification purposes.

**1.3** This part of ISO 16358 does not apply to the testing and rating of:

- a) water-source heat pumps or water-cooled air conditioners;
- b) portable units having a condenser exhaust duct;
- c) individual assemblies not constituting a complete refrigeration system; or
- d) equipment using the absorption refrigeration cycle.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5151, *Non-ducted air conditioners and heat pumps — Testing and rating for performance*

ISO 13253, *Ducted air-conditioners and air-to-air heat pumps — Testing and rating for performance*

ISO 15042, *Multiple split-system air-conditioners and air-to-air heat pumps — Testing and rating for performance*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5151, ISO 13253, ISO 15042 and the following apply.

#### 3.1

**defined heating load,  $L_h$**

heat defined as heating demand for a given outdoor temperature

**3.2**  
**make-up heating**

electric heat required to cover the deficiency of the heating capacity delivered by the heat pump for the heating load

**3.3**  
**heating seasonal total load**

**HSTL**

total annual amount of heat, including make-up heat, which is added to the indoor air when the equipment is operated for heating in active mode

**3.4**  
**heating seasonal energy consumption**

**HSEC**

total annual amount of energy consumed by the equipment, including make-up heat, when it is operated for heating in active mode

**3.5**  
**heating seasonal performance factor**

**HSPF**

ratio of the total annual amount of heat that the equipment, including make-up heat, can add to the indoor air when operated for heating in active mode to the total annual amount of energy consumed by the equipment during the same period

**3.6**  
**part load factor**

**PLF**

ratio of the performance when the equipment is cyclically operated to the performance when the equipment is continuously operated, at the same temperature and humidity conditions

**3.7**  
**degradation coefficient,  $C_D$**

coefficient that indicates efficiency loss caused by cyclic operation

**3.8**  
**fixed capacity unit**

equipment which does not have possibility to change its capacity

Note 1 to entry: to entry This definition applies to each cooling and heating operation individually.

**3.9**  
**two (2)-stage capacity unit**

equipment where the capacity is varied by two steps

Note 1 to entry: This definition applies to each cooling and heating operation individually.

**3.10**  
**multi-stage capacity unit**

equipment where the capacity is varied by 3 or 4 steps

Note 1 to entry: This definition applies to each cooling and heating operation individually.

**3.11**  
**variable capacity unit**

equipment where the capacity is varied by five or more steps to represent continuously variable capacity

Note 1 to entry: This definition applies to each cooling and heating operation individually.

**3.12****heating full-load operation**

operation with the equipment and controls configured for maximum continuous refrigeration capacity at H1 condition

Note 1 to entry: Unless otherwise regulated by the automatic controls of the equipment, all indoor units and compressors shall be functioning.

**3.13****heating extended-load operation**

operation of the equipment at maximum continuous refrigeration capacity at H2 condition

Note 1 to entry: Unless otherwise regulated by the automatic controls of the equipment, all indoor units and compressors shall be functioning.

**3.14****minimum-load operation**

operation of the equipment and controls at minimum continuous refrigeration capacity

Note 1 to entry: All indoor units shall be functioning

**3.15****standard heating full capacity**

heating capacity at H1 at full-load operating condition

**3.16****standard heating full power input**

electric power input at H1 at full-load operating condition

**3.17****standard heating half capacity**

capacity which is 50 % of heating full capacity at H1 condition with all indoor units functioning

**3.18****standard heating half power input**

electric power input when operated at 50 % of heating full capacity at H1 condition with all indoor units functioning

**3.19****standard heating minimum capacity**

capacity which is minimum heating capacity at H1 condition at the minimum-load operation

**3.20****standard heating minimum power input**

electric power input when operated at minimum heating capacity at H1 condition at the minimum-load operation

**3.21****standard heating extended capacity**

heating capacity when operated at H2 condition at the extended-load operation

**3.22****standard heating extended power input**

electric power input when operated at H2 condition at the extended-load operation

**3.23****total heating seasonal performance factor****THSPF**

ratio of the total annual amount of heat that the equipment, including make-up heat, can add to the indoor air to the total annual amount of energy consumed by the equipment, including the active, inactive and disconnected modes

3.24

**active mode**

mode corresponding to the hours with a heating demand of the building and whereby the heating function of the unit is switched on

3.25

**inactive mode**

mode corresponding to the hours when the unit is not operating to meet heating demand

Note 1 to entry: This mode may include the operation of a crankcase heater.

3.26

**disconnected mode**

mode corresponding to the hours when the unit is electrically disconnected from the main power supply

Note 1 to entry: Power consumption is zero.

**4 Symbols**

Symbol	Description	Unit
$C_{HSE}$	heating seasonal energy consumption (HSEC)	Wh
$C_{OP}(t)$	heating coefficient of performance (COP) at continuous outdoor temperature $t$	W/W
$C_{OP}(t_j)$	heating coefficient of performance (COP) at outdoor temperature $t_j$	W/W
$C_{OP, ext}(t_h)$	heating coefficient of performance (COP) when heating load is equal to non-frosting range heating extended capacity	W/W
$C_{OP, ext, f}(t_f)$	heating coefficient of performance (COP) when heating load is equal to frosting range heating extended capacity	W/W
$C_{OP, fe}(t_j)$	heating coefficient of performance (COP) in non-frosting variable operation between full and extended capacity at outdoor temperature $t_j$	W/W
$C_{OP, fe, f}(t_j)$	heating coefficient of performance (COP) in frosting variable operation between full and extended capacity at outdoor temperature $t_j$	W/W
$C_{OP, ful}(t_a)$	heating coefficient of performance (COP) when heating load is equal to non-frosting range heating full capacity	W/W
$C_{OP, ful, f}(t_g)$	heating coefficient of performance (COP) when heating load is equal to frosting range heating full capacity	W/W
$C_{OP, haf}(t_d)$	heating coefficient of performance (COP) when heating load is equal to non-frosting range heating half capacity	W/W
$C_{OP, haf, f}(t_e)$	heating coefficient of performance (COP) when heating load is equal to frosting range heating half capacity	W/W
$C_{OP, hf}(t_j)$	heating coefficient of performance (COP) in non-frosting variable operation between half and full capacity at outdoor temperature $t_j$	W/W
$C_{OP, hf, f}(t_j)$	heating coefficient of performance (COP) in frosting variable operation between half and full capacity at outdoor temperature $t_j$	W/W
$C_{OP, mh}(t_j)$	heating coefficient of performance (COP) in non-frosting variable operation between minimum and half capacity at outdoor temperature $t_j$	W/W
$C_{OP, mh, f}(t_j)$	heating coefficient of performance (COP) in frosting variable operation between minimum and half capacity at outdoor temperature $t_j$	W/W
$C_{OP, min}(t_q)$	heating coefficient of performance (COP) when heating load is equal to non-frosting range heating minimum capacity	W/W

Symbol	Description	Unit
$C_{OP, \min, f}(t_r)$	heating coefficient of performance (COP) when heating load is equal to frosting range heating minimum capacity	W/W
$F_{HSP}$	heating seasonal performance factor (HSPF)	–
$F_{PL}(t_j)$	part load factor (PLF) at outdoor temperature $t_j$	–
$F_{THSP}$	total heating seasonal performance factor (THSPF)	–
$L_{HST}$	heating seasonal total load (HSTL)	Wh
$L_h(t_j)$	defined heating load at outdoor temperature $t_j$	W
$n$	number of temperature bins	–
$n_j$	bin hours	h
$P(t)$	heating power input calculated by equation of $P(t_j)$ at continuous outdoor temperature $t$	W
$P(t_j)$	heating power input applicable to any capacity at outdoor temperature $t_j$	W
$P_{ext}(t_j)$	non-frosting range heating extended power input at outdoor temperature $t_j$	W
$P_{ext}(-7)$	heating extended power input at outdoor temperature $-7\text{ }^\circ\text{C}$	W
$P_{ext}(2)$	calculated heating extended power input at outdoor temperature $2\text{ }^\circ\text{C}$	W
$P_{ext, f}(t_j)$	frosting range heating extended power input at outdoor temperature $t_j$	W
$P_{ext, f}(2)$	heating extended power input at H2 temperature condition	W
$P_{fe}(t_j)$	heating power input in variable operation between full and extended capacity at outdoor temperature $t_j$	W
$P_{ful}(t_j)$	non-frosting range heating full power input at outdoor temperature $t_j$	W
$P_{ful}(7)$	heating full power input at H1 temperature condition	W
$P_{ful}(-7)$	heating full power input at outdoor temperature $-7\text{ }^\circ\text{C}$	W
$P_{ful}(2)$	calculated heating full power input at outdoor temperature $2\text{ }^\circ\text{C}$	W
$P_{ful, f}(t_j)$	frosting range heating full power input at outdoor temperature $t_j$	W
$P_{ful, f}(2)$	heating full power input at H2 temperature condition	W
$P_{haf}(t_j)$	non-frosting range heating half power input at outdoor temperature $t_j$	W
$P_{haf}(7)$	heating half power input at H1 temperature condition	W
$P_{haf}(-7)$	heating half power input at outdoor temperature $-7\text{ }^\circ\text{C}$	W
$P_{haf}(2)$	calculated heating half power input at outdoor temperature $2\text{ }^\circ\text{C}$	W
$P_{haf, f}(t_j)$	frosting range heating half power input at outdoor temperature $t_j$	W
$P_{haf, f}(2)$	heating half power input at H2 temperature condition	W
$P_{hf}(t_j)$	heating power input in variable operation between half and full capacity at outdoor temperature $t_j$	W
$P_{mf}(t_j)$	heating power input in second stage cyclic operation between minimum and full capacity at outdoor temperature $t_j$	W
$P_{mh}(t_j)$	heating power input in variable operation between minimum and half capacity at outdoor temperature $t_j$	W
$P_{\min}(t_j)$	non-frosting range heating minimum power input at outdoor temperature $t_j$	W
$P_{\min}(7)$	heating minimum power input at H1 temperature condition	W
$P_{\min}(-7)$	heating minimum power input at outdoor temperature $-7\text{ }^\circ\text{C}$	W
$P_{\min}(2)$	calculated heating minimum power input at outdoor temperature $2\text{ }^\circ\text{C}$	W

Symbol	Description	Unit
$P_{\min, f}(t_j)$	frosting range heating minimum power input at outdoor temperature $t_j$	W
$P_{\min, f}(2)$	heating minimum power input at H2 temperature condition	W
$P_{RH}(t_j)$	make-up heating energy at outdoor temperature $t_j$	Wh
$t$	general continuous outdoor temperature	°C
$t_j$	outdoor temperature corresponding to each temperature bin	°C
$t_a$	outdoor temperature when heating load is equal to non-frosting range heating full capacity	°C
$t_d$	outdoor temperature when heating load is equal to non-frosting range heating half capacity	°C
$t_e$	outdoor temperature when heating load is equal to frosting range heating half capacity	°C
$t_f$	outdoor temperature when heating load is equal to frosting range heating extended capacity	°C
$t_g$	outdoor temperature when heating load is equal to frosting range heating full capacity	°C
$t_h$	outdoor temperature when heating load is equal to non-frosting range heating extended capacity	°C
$t_q$	outdoor temperature when heating load is equal to non-frosting range heating minimum capacity	°C
$t_r$	outdoor temperature when heating load is equal to frosting range heating minimum capacity	°C
$X(t_j)$	ratio of load to capacity at outdoor temperature $t_j$	-
$X_{fe}(t_j)$	ratio of excess capacity over load to capacity difference between full and extended capacity at outdoor temperature $t_j$	-
$X_{hf}(t_j)$	ratio of excess capacity over load to capacity difference between half and full capacity at outdoor temperature $t_j$	-
$X_{mf}(t_j)$	ratio of excess capacity over load to capacity difference between minimum and full capacity at outdoor temperature $t_j$	-
$X_{mh}(t_j)$	ratio of excess capacity over load to capacity difference between minimum and half capacity at outdoor temperature $t_j$	-
$\phi(t)$	heating capacity calculated by equation of $\phi(t_j)$ at continuous outdoor temperature $t$	W
$\phi(t_j)$	heating capacity applicable to any capacity at outdoor temperature $t_j$	W
$\phi_{\text{ext}}(t_j)$	non-frosting range heating extended capacity at outdoor temperature $t_j$	W
$\phi_{\text{ext}}(-7)$	heating extended capacity at outdoor temperature -7 °C	W
$\phi_{\text{ext}}(2)$	calculated heating extended capacity at outdoor temperature 2 °C	W
$\phi_{\text{ext}, f}(t_j)$	frosting range heating extended capacity at outdoor temperature $t_j$	W
$\phi_{\text{ext}, f}(2)$	frosting range heating extended capacity at H2 temperature condition	W
$\phi_{\text{ful}}(t_j)$	non-frosting range heating full capacity at outdoor temperature $t_j$	W
$\phi_{\text{ful}}(7)$	heating full capacity at H1 temperature condition	W
$\phi_{\text{ful}}(-7)$	heating full capacity at outdoor temperature -7 °C	W
$\phi_{\text{ful}}(2)$	calculated heating full capacity at outdoor temperature 2 °C	W
$\phi_{\text{ful}, f}(t_j)$	frosting range heating full capacity at outdoor temperature $t_j$	W
$\phi_{\text{ful}, f}(2)$	frosting range heating full capacity at H2 temperature condition	W

Symbol	Description	Unit
$\phi_{\text{haf}}(t_j)$	non-frosting range heating half capacity at outdoor temperature $t_j$	W
$\phi_{\text{haf}}(7)$	heating half capacity at H1 temperature condition	W
$\phi_{\text{haf}}(-7)$	heating half capacity at outdoor temperature $-7\text{ }^\circ\text{C}$	W
$\phi_{\text{haf}}(2)$	calculated heating half capacity at outdoor temperature $2\text{ }^\circ\text{C}$	W
$\phi_{\text{haf}, f}(t_j)$	frosting range heating half capacity at outdoor temperature $t_j$	W
$\phi_{\text{haf}, f}(2)$	frosting range heating half capacity at H2 temperature condition	W
$\phi_{\text{min}}(t_j)$	non-frosting range heating minimum capacity at outdoor temperature $t_j$	W
$\phi_{\text{min}}(7)$	heating minimum capacity at H1 temperature condition	W
$\phi_{\text{min}}(-7)$	heating minimum capacity at outdoor temperature $-7\text{ }^\circ\text{C}$	W
$\phi_{\text{min}}(2)$	calculated heating minimum capacity at outdoor temperature $2\text{ }^\circ\text{C}$	W
$\phi_{\text{min}, f}(t_j)$	frosting range heating minimum capacity at outdoor temperature $t_j$	W
$\phi_{\text{min}, f}(2)$	frosting range heating minimum capacity at H2 temperature condition	W

## 5 Tests

### 5.1 General

These tests are additional to those in ISO 5151, ISO 13253 and ISO 15042.

The accuracy of the instruments used for tests shall conform to the test methods and uncertainties of measurements specified in ISO 5151, ISO 13253 and ISO 15042.

### 5.2 Test conditions

Temperature and humidity conditions as well as default values for calculation shall be as specified in [Table 1](#).

**Table 1 — Temperature and humidity conditions and default values for heating**

Test	Characteristics	Fixed	Two-stage	Multi-stage	Variable	Default value	
Standard heating capacity	Full capacity $\phi_{ful}(7)$ (W)	■	■	■	■		
	Full power input $P_{ful}(7)$ (W)						
Indoor DB 20°C WB 15°C Max.	Half capacity $\phi_{haf}(7)$ (W)	—	—	■	■		
	Half power input $P_{haf}(7)$ (W)						
Outdoor DB 7°C WB 6°C	Minimum capacity $\phi_{min}(7)$ (W)	—	■	○	○		
	Minimum power input $P_{min}(7)$ (W)						
Low temperature heating capacity	Extended capacity $\phi_{ext,f}(2)$ (W)	—	—	■ <sup>a</sup>	■ <sup>a</sup>		
	Extended power input $P_{ext,f}(2)$ (W)						
	Calculated extended capacity $\phi_{ext}(2)$ (W)	—	—	b	b	1,12 $\phi_{ext,f}(2)$	
	Calcu'd extended power input $P_{ext}(2)$ (W)						1,06 $P_{ext,f}(2)$
	Indoor DB 20°C WB 15°C Max.	Full capacity $\phi_{ful,f}(2)$ (W)	■ <sup>c</sup>	■ <sup>c</sup>	□ <sup>ac</sup>	□ <sup>ac</sup>	$\phi_{ful}(2)/1,12^d$
		Full power input $P_{ful,f}(2)$ (W)					
	Outdoor DB 2°C WB 1°C	Half capacity $\phi_{haf,f}(2)$ (W)	—	—	○ <sup>c</sup>	○ <sup>c</sup>	$\phi_{haf}(2)/1,12^d$
		Half power input $P_{haf,f}(2)$ (W)					$P_{haf}(2)/1,06^d$
Minimum capacity $\phi_{min,f}(2)$ (W)		—	○ <sup>c</sup>	—	—	$\phi_{min}(2)/1,12^d$	
Minimum power input $P_{min,f}(2)$ (W)						$P_{min}(2)/1,06^d$	
Extra-low temperature heating capacity	Extended capacity $\phi_{ext}(-7)$ (W)	—	—	○	○	0,734 $\phi_{ext}(2)$	
	Extended power input $P_{ext}(-7)$ (W)					0,877 $P_{ext}(2)$	
	Indoor DB 20°C WB 15°C Max.	Full capacity $\phi_{ful}(-7)$ (W)	○	○	○	○	0,64 $\phi_{ful}(7)$
		Full power input $P_{ful}(-7)$ (W)					0,82 $P_{ful}(7)$
	Outdoor DB -7°C WB -8°C	Half capacity $\phi_{haf}(-7)$ (W)	—	—	○	○	0,64 $\phi_{haf}(7)$
		Half power input $P_{haf}(-7)$ (W)					0,82 $P_{haf}(7)$
		Minimum capacity $\phi_{min}(-7)$ (W)	—	—	—	—	0,64 $\phi_{min}(7)$
Minimum power input $P_{min}(-7)$ (W)	0,82 $P_{min}(7)$						
Cyclic heating	Degradation coefficient $C_p$	Full capacity	○	—	—	—	0,25
		Half capacity	—	—	○	—	0,25
		Minimum capacity	—	○	○	—	0,25

■ required test.

○ optional test.

□ test required when there is not an extended mode.

<sup>a</sup> When the equipment has an extended mode, low temperature extended capacity measurement is mandatory and low temperature full capacity measurement is optional. When the equipment has not an extended mode, low temperature full capacity measurement is mandatory.

<sup>b</sup> This value shall be calculated using default value.

<sup>c</sup> When this value is measured,  $\phi_x(2)$  and/or  $P_x(2)$  shall not be calculated from this value, but the equations in footnote d shall be used instead.

<sup>d</sup> The following two equations apply to the full capacity, half capacity and minimum capacity data when  $\phi_{x,f}(2)$  and  $P_{x,f}(2)$  are calculated:

$$\phi_x(2) = \phi_x(-7) + \frac{\phi_x(7) - \phi_x(-7)}{7 - (-7)} \times (2 - (-7)), \quad P_x(2) = P_x(-7) + \frac{P_x(7) - P_x(-7)}{7 - (-7)} \times (2 - (-7))$$

NOTE Voltage(s) and frequency(ies) shall be as given in the three referenced standards.

### 5.3 Test methods

#### 5.3.1 Standard heating capacity tests

The standard heating capacity tests shall be conducted in accordance with Annex A of ISO 5151 and Annex B of ISO 13253 and ISO 15042. The heating capacity and effective power input shall be measured during the standard heating capacity tests.

The half capacity test shall be conducted at 50 % of full load operation. The test tolerance shall be  $\pm 5$  % of full load capacity for continuously variable equipment. For multi-stage equipment, if 50 % capacity is not achievable, then the test shall be conducted at the next step above 50 %.

The minimum capacity test shall be conducted at the lowest capacity control setting which allows steady-state operation of the equipment at the given test conditions.

If the minimum capacity tests are conducted, but if the required uncertainty of measurement specified in ISO 5151, ISO 13253 and ISO 15042 cannot be achieved, the alternative method of calculation shall be used. (Refer to [6.6.4](#) and [6.7.4](#).)

The manufacturer shall provide information on how to set the capacity if requested by the testing laboratories.

#### 5.3.2 Low temperature heating capacity test

The low temperature heating capacity test shall be conducted at H2 condition in accordance with Annex A of ISO 5151 and Annex B of ISO 13253 and ISO 15042. The heating capacity and effective power input shall be measured during the low temperature heating capacity test.

The half capacity test shall be conducted at 50 % of full load operation. The test tolerance shall be  $\pm 5$  % of full load capacity for continuously variable equipment. For multi-stage equipment, if 50 % capacity is not achievable, then the test shall be conducted at the next step above 50 %.

The minimum capacity test shall be conducted at the lowest capacity control setting which allows steady-state operation of the equipment at the given test conditions.

If the minimum capacity tests are conducted, but if the required uncertainty of measurement specified in ISO 5151, ISO 13253 and ISO 15042 cannot be achieved, the alternative method of calculation shall be used. (Refer to [6.6.4](#) and [6.7.4](#).)

The manufacturer shall provide information on how to set the capacity if requested by the testing laboratories.

#### 5.3.3 Extra-low temperature heating capacity test

The extra-low temperature heating capacity test shall be conducted at H3 condition in accordance with Annex A of ISO 5151 and Annex B of ISO 13253 and ISO 15042. The heating capacity and effective power input shall be measured during the extra-low temperature heating capacity test. If the test is not conducted, default values as given in [Table 1](#) shall be used.

The half capacity test shall be conducted at 50 % of full load operation. The test tolerance shall be  $\pm 5$  % of full load capacity for continuously variable equipment. For multi-stage equipment, if 50 % capacity is not achievable, then the test shall be conducted at the next step above 50 %.

The manufacturer shall provide information on how to set the capacity if requested by the testing laboratories.

#### 5.3.4 Cyclic heating test

The cyclic heating test shall be conducted in accordance with [Annex C](#). If the test is not conducted, default values as given in [Table 1](#) shall be used.

## 6 Calculations

### 6.1 Heating seasonal performance factor (HSPF) and total heating seasonal performance factor (THSPF)

Heating seasonal performance factor (HSPF),  $F_{HSP}$ , of the equipment shall be calculated by Formula (1).

$$F_{HSP} = \frac{L_{HST}}{C_{HSE}} \quad (1)$$

In case of calculating the total heating seasonal performance factor (THSPF), refer to [Annex B](#).

### 6.2 Defined heating load

The defined heating load shall be represented by a value and the assumption that it is linearly changing depending on the change in outdoor temperature.

Defined heating load which shall be used is shown in [Table 2](#).

**Table 2 — Defined heating load**

Parameter	Load zero (0)	Load 100 %
Heating load (W)	0	$0,82 \times \phi_{ful}(H1)$
Temperature(°C)	$t_0$	$t_{100}$

where  $t_{100}$  is the outdoor temperature at 100 % load and  $t_0$  is the outdoor temperature at 0 % load.

Reference values of defined heating load to be used shall be as follows:

$$t_0 = 17 \text{ °C and } t_{100} = 0 \text{ °C}$$

In case of setting other heating load, refer to the setting method as described in [Annex D](#).

Defined heating load  $L_h(t_j)$  at outdoor temperature  $t_j$ , which is necessary to calculate heating seasonal performance factor, shall be determined by Formula (2).

$$L_h(t_j) = \frac{\phi_{ful}(t_{100}) \times (t_0 - t_j)}{(t_0 - t_{100})} \quad (2)$$

where  $\phi_{ful}(t_{100})$  is the heating capacity at  $t_{100}$  at full-load operating conditions.

Ratio of the heating operational capacity at 0 °C in non-frosting condition to the standard heating capacity at 7 °C is assumed to be 0,82.

### 6.3 Outdoor temperature bin distribution for heating

Value of outdoor temperature and bin hours differ from region to region. If bin hours is set to a certain value for a certain region, the integrated value of heating load and electric energy consumption can be determined.

[Table 3](#) shows the reference outdoor temperature bin distribution.

**Table 3 — Reference outdoor temperature bin distribution for heating**

Bin number j	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Outdoor temperature $t_j$ °C	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3
Fractional bin hours	0	0	0	0	0	0	0	0	0	0,001	0,005	0,012	0,024	0,042
Bin hours $n_j$	$n_1$	$n_2$	$n_3$	$n_4$	$n_5$	$n_6$	$n_7$	$n_8$	$n_9$	$n_{10}$	$n_{11}$	$n_{12}$	$n_{13}$	$n_{14}$
Reference bin hours ( $n_j$ ) h	0	0	0	0	0	0	0	0	0	4	15	33	68	119
Bin number j	15	16	17	18	19	20	21	22	23	24	25	26	27	Total
Outdoor temperature $t_j$ °C	4	5	6	7	8	9	10	11	12	13	14	15	16	
Fractional bin hours	0,059	0,070	0,082	0,087	0,091	0,092	0,091	0,085	0,075	0,067	0,053	0,038	0,027	
Bin hours $n_j$	$n_{15}$	$n_{16}$	$n_{17}$	$n_{18}$	$n_{19}$	$n_{20}$	$n_{21}$	$n_{22}$	$n_{23}$	$n_{24}$	$n_{25}$	$n_{26}$	$n_{27}$	
Reference bin hours ( $n_j$ ) h	169	200	234	250	260	265	260	245	215	192	151	110	76	2 866

Bin hours of each outdoor temperature may be calculated by multiplying the fractional bin hours by the total annual heating hours if the fractional bin hours are applicable.

In case of setting other outdoor temperature bin distribution, refer to the setting method as described in [Annex D](#).

## 6.4 Heating seasonal characteristics of fixed capacity units

Operational performance at each test, which is necessary to calculate the heating seasonal performance factor, shall be in accordance with [Table 1](#).

### 6.4.1 Capacity characteristics against outdoor temperature

Frosting occurs in a range of outdoor temperature from 5,5 °C to -7 °C. It is assumed that decrease rates in heating capacity and electric power input due to defrost operation are the biggest when operated at 5,5 °C, then become smaller as outdoor temperature goes down, and reach zero (0) at -7 °C.

- a) In case that outdoor temperature is in non-frosting temperature range ( $t_j \leq -7^\circ\text{C}$  or  $5,5^\circ\text{C} \leq t_j$ ):

Capacity  $\phi_{\text{ful}}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall linearly change depending on outdoor temperatures in the non-frosting temperature range, as shown in [Figure A.1](#) in [Annex A](#), and be determined by Formula (3).

$$\phi_{\text{ful}}(t_j) = \phi_{\text{ful}}(-7) + \frac{\phi_{\text{ful}}(7) - \phi_{\text{ful}}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (3)$$

- b) In case that outdoor temperature is in frosting temperature range ( $-7^\circ\text{C} < t_j < 5,5^\circ\text{C}$ ):

Capacity  $\phi_{\text{ful},f}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall linearly change depending on outdoor temperatures in the frosting temperature range, as shown in [Figure A.1](#) in [Annex A](#), and be determined by Formula (4).

$$\phi_{\text{ful},f}(t_j) = \phi_{\text{ful}}(-7) + \frac{\phi_{\text{ful},f}(2) - \phi_{\text{ful}}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (4)$$

### 6.4.2 Power input characteristics against outdoor temperature

- a) Electric power input  $P_{\text{ful}}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall linearly change depending on outdoor temperatures in the non-frosting temperature range, as shown in [Figure A.1](#) in [Annex A](#), and be determined by Formula (5).

$$P_{\text{ful}}(t_j) = P_{\text{ful}}(-7) + \frac{P_{\text{ful}}(7) - P_{\text{ful}}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (5)$$

- b) Electric power input  $P_{\text{ful,f}}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall linearly change depending on outdoor temperatures in the frosting temperature range, as shown in [Figure A.1](#) in [Annex A](#), and be determined by Formula (6).

$$P_{\text{ful,f}}(t_j) = P_{\text{ful}}(-7) + \frac{P_{\text{ful,f}}(2) - P_{\text{ful}}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (6)$$

### 6.4.3 Calculation of heating seasonal total load (HSTL)

Heating seasonal total load (HSTL),  $L_{\text{HST}}$ , shall be calculated by Formula (7).

$$L_{\text{HST}} = \sum_{j=1}^n L_h(t_j) \times n_j \quad (7)$$

### 6.4.4 Calculation of heating seasonal energy consumption (HSEC)

Heating seasonal energy consumption (HSEC),  $C_{\text{HSE}}$ , shall be determined using Formula (8) from the total sum of heating energy consumption at each outdoor temperature  $t_j$ .

$$C_{\text{HSE}} = \sum_{j=1}^n \frac{X(t_j) \times P(t_j) \times n_j}{F_{\text{PL}}(t_j)} + \sum_{j=1}^n P_{\text{RH}}(t_j) \times n_j \quad (8)$$

When load is rather large as compared to heating capacity, make-up heating by the electric heater shall be added.

Operation factor  $X(t_j)$  shall be calculated by Formula (9).

$$X(t_j) = \frac{L_h(t_j)}{\phi(t_j)} \quad (9)$$

Part load factor (PLF),  $F_{\text{PL}}(t_j)$ , shall be calculated by Formula (10) using degradation coefficient  $C_D$ .

$$F_{\text{PL}}(t_j) = 1 - C_D (1 - X(t_j)) \quad (10)$$

When  $L_h(t_j) > \phi(t_j)$ ,  $X(t_j) = F_{\text{PL}}(t_j) = 1$ .

Make-up heat  $P_{\text{RH}}(t_j)$  shall be calculated by Formula (11).

$$P_{\text{RH}}(t_j) = L_h(t_j) - \phi(t_j) \quad (11)$$

- a) Non-frosting temperature range ( $t_j \leq -7$  °C or  $5,5$  °C  $\leq t_j$ )

- 1) Cyclic operation ( $L_h(t_j) \leq \phi_{\text{ful}}(t_j)$ )

$$P_{\text{RH}}(t_j) = 0$$

$$\phi(t_j) = \phi_{\text{ful}}(t_j) \text{ in Formula (9)}$$

$$P(t_j) = P_{\text{ful}}(t_j).$$

- 2) Full capacity operation ( $L_h(t_j) > \phi_{\text{ful}}(t_j)$ )

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ful}(t_j) \text{ in Formula (11)}$$

$$P(t_j) = P_{ful}(t_j).$$

b) Frosting temperature range ( $-7\text{ °C} < t_j < 5,5\text{ °C}$ )

1) Cyclic operation ( $L_h(t_j) \leq \phi_{ful,f}(t_j)$ )

$$P_{RH}(t_j) = 0$$

$$\phi(t_j) = \phi_{ful,f}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{ful,f}(t_j).$$

2) Full capacity operation ( $L_h(t_j) > \phi_{ful,f}(t_j)$ )

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ful}(t_j) \text{ in Formula (11).}$$

$$P(t_j) = P_{ful}(t_j).$$

## 6.5 Heating seasonal characteristics of two-stage capacity units

Coefficients shown in [Table 1](#) may be used for each characteristic.

### 6.5.1 Capacity characteristics against outdoor temperature

Capacities  $\phi_{ful}(t_j)$  and  $\phi_{min}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined by Formulae (3) and (12), respectively.

$$\phi_{min}(t_j) = \phi_{min}(-7) + \frac{\phi_{min}(7) - \phi_{min}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (12)$$

Capacities  $\phi_{ful,f}(t_j)$  and  $\phi_{min,f}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined by Formulae (4) and (13), respectively.

$$\phi_{min,f}(t_j) = \phi_{min,f}(-7) + \frac{\phi_{min,f}(2) - \phi_{min,f}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (13)$$

### 6.5.2 Power input characteristics against outdoor temperature

Electric power input  $P_{ful}(t_j)$  and  $P_{min}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined from Formulae (5) and (14), respectively.

$$P_{min}(t_j) = P_{min}(-7) + \frac{P_{min}(7) - P_{min}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (14)$$

Electric power input  $P_{ful,f}(t_j)$  and  $P_{min,f}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined from Formulae (6) and (15), respectively.

$$P_{min,f}(t_j) = P_{min,f}(-7) + \frac{P_{min,f}(2) - P_{min,f}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (15)$$

### 6.5.3 Calculation of heating seasonal total load (HSTL)

Heating seasonal total load (HSTL),  $L_{HST}$ , shall be calculated by Formula (7).

6.5.4 Calculation of heating seasonal energy consumption (HSEC)

Heating seasonal energy consumption (HSEC),  $C_{HSE}$ , shall be calculated by Formula (16).

$$C_{HSE} = \sum_{j=1}^n \frac{X(t_j) \times P(t_j) \times n_j}{F_{PL}(t_j)} + \sum_{j=1}^n P_{mf}(t_j) \times n_j + \sum_{j=1}^n P_{ful}(t_j) \times n_j + \sum_{j=1}^n P_{RH}(t_j) \times n_j \quad (16)$$

The relation of heating capacity characteristics and energy consumption characteristics to heating load at outdoor temperature  $t_j$  is shown in [Figure A.2](#) in [Annex A](#).

a) Non-frosting temperature range ( $t_j \leq -7 \text{ }^\circ\text{C}$  or  $5,5 \text{ }^\circ\text{C} \leq t_j$ )

1) First stage cyclic operation ( $L_h(t_j) \leq \phi_{min}(t_j)$ )

$$P_{mf}(t_j) = P_{ful}(t_j) = P_{RH}(t_j) = 0 \text{ in Formula (16).}$$

$$\phi(t_j) = \phi_{min}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{min}(t_j).$$

2) Second stage cyclic operation ( $\phi_{min}(t_j) < L_h(t_j) \leq \phi_{ful}(t_j)$ )

$$P(t_j) = P_{ful}(t_j) = P_{RH}(t_j) = 0 \text{ in Formula (16).}$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{mf}(t_j) = X_{mf}(t_j) \times P_{min}(t_j) + (1 - X_{mf}(t_j)) \times P_{ful}(t_j) \quad (17)$$

$$X_{mf}(t_j) = \frac{\phi_{ful}(t_j) - L_h(t_j)}{\phi_{ful}(t_j) - \phi_{min}(t_j)} \quad (18)$$

3) Full capacity operation ( $L_h(t_j) > \phi_{ful}(t_j)$ )

$$P(t_j) = P_{mf}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ful}(t_j) \text{ in Formula (11).}$$

$$P(t_j) = P_{ful}(t_j).$$

b) Frosting temperature range ( $-7 \text{ }^\circ\text{C} < t_j < 5,5 \text{ }^\circ\text{C}$ )

1) First stage cyclic operation ( $L_h(t_j) \leq \phi_{min, f}(t_j)$ )

$$P_{mf}(t_j) = P_{ful}(t_j) = P_{RH}(t_j) = 0 \text{ in Formula (16).}$$

$$\phi(t_j) = \phi_{min, f}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{min, f}(t_j).$$

2) Second stage cyclic operation ( $\phi_{min, f}(t_j) < L_h(t_j) \leq \phi_{ful, f}(t_j)$ )

$$P(t_j) = P_{ful}(t_j) = P_{RH}(t_j) = 0 \text{ in Formula (16).}$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{mf}(t_j) = X_{mf}(t_j) \times P_{min, f}(t_j) + (1 - X_{mf}(t_j)) \times P_{ful, f}(t_j) \quad (19)$$

$$X_{mf}(t_j) = \frac{\phi_{ful, f}(t_j) - L_h(t_j)}{\phi_{ful, f}(t_j) - \phi_{min, f}(t_j)} \quad (20)$$

3) Full capacity operation ( $L_h(t_j) > \phi_{ful, f}(t_j)$ )

$$P(t_j) = P_{mf}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$\phi(t_j) = \phi_{ful, f}(t_j)$  in Formula (11).

$$P_{ful}(t_j) = P_{ful, f}(t_j)$$

## 6.6 Heating seasonal characteristics of multi-stage capacity units

### 6.6.1 Capacity characteristics against outdoor temperature

Capacities  $\phi_{ful}(t_j)$ ,  $\phi_{min}(t_j)$ ,  $\phi_{ext}(t_j)$  and  $\phi_{haf}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined by Formulae (3), (12), (21) and (22), respectively.

$$\phi_{ext}(t_j) = \phi_{ext}(-7) + \frac{\phi_{ext}(2) - \phi_{ext}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (21)$$

$$\phi_{haf}(t_j) = \phi_{haf}(-7) + \frac{\phi_{haf}(7) - \phi_{haf}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (22)$$

Capacities  $\phi_{ful, f}(t_j)$ ,  $\phi_{min, f}(t_j)$ ,  $\phi_{ext, f}(t_j)$  and  $\phi_{haf, f}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined by Formulae (4), (13), (23) and (24), respectively.

$$\phi_{ext, f}(t_j) = \phi_{ext, f}(-7) + \frac{\phi_{ext, f}(2) - \phi_{ext, f}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (23)$$

$$\phi_{haf, f}(t_j) = \phi_{haf, f}(-7) + \frac{\phi_{haf, f}(7) - \phi_{haf, f}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (24)$$

### 6.6.2 Power input characteristics against outdoor temperature

Electric power input  $P_{ful}(t_j)$ ,  $P_{min}(t_j)$ ,  $P_{ext}(t_j)$  and  $P_{haf}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined from Formulae (5), (14), (25) and (26), respectively.

$$P_{ext}(t_j) = P_{ext}(-7) + \frac{P_{ext}(2) - P_{ext}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (25)$$

$$P_{haf}(t_j) = P_{haf}(-7) + \frac{P_{haf}(7) - P_{haf}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (26)$$

Electric power input  $P_{ful, f}(t_j)$ ,  $P_{min, f}(t_j)$ ,  $P_{ext, f}(t_j)$  and  $P_{haf, f}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined from Formulae (6), (15), (27) and (28), respectively.

$$P_{ext, f}(t_j) = P_{ext, f}(-7) + \frac{P_{ext, f}(2) - P_{ext, f}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (27)$$

$$P_{haf, f}(t_j) = P_{haf, f}(-7) + \frac{P_{haf, f}(7) - P_{haf, f}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (28)$$

### 6.6.3 Calculation of heating seasonal total load (HSTL)

Heating seasonal total load (HSTL),  $L_{HST}$ , shall be calculated by Formula (7).

**6.6.4 Calculation of heating seasonal energy consumption (HSEC)**

When the minimum capacity data are available, then the heating seasonal energy consumption (HSEC),  $C_{HSE}$ , shall be calculated by Formula (29).

$$C_{HSE} = \sum_{j=1}^n \frac{X(t_j) \times P(t_j) \times n_j}{F_{PL}(t_j)} + \sum_{j=1}^n P_{mh}(t_j) \times n_j + \sum_{j=1}^n P_{hf}(t_j) \times n_j + \sum_{j=1}^n P_{fe}(t_j) \times n_j + \sum_{j=1}^n P_{ext}(t_j) \times n_j + \sum_{j=1}^n P_{RH}(t_j) \times n_j \quad (29)$$

When the minimum capacity data are not available, then the heating seasonal energy consumption (HSEC),  $C_{HSE}$ , shall be calculated alternatively by Formula (30).

$$C_{HSE} = \sum_{j=1}^n \frac{X(t_j) \times P(t_j) \times n_j}{F_{PL}(t_j)} + \sum_{j=1}^n P_{hf}(t_j) \times n_j + \sum_{j=1}^n P_{fe}(t_j) \times n_j + \sum_{j=1}^n P_{ext}(t_j) \times n_j + \sum_{j=1}^n P_{RH}(t_j) \times n_j \quad (30)$$

The relation of heating capacity characteristics and energy consumption characteristics to heating load at outdoor temperature  $t_j$  is shown in [Figure A.3](#) in [Annex A](#).

**6.6.4.1 In case of calculation using Formula (29)**

a) Non-frosting temperature range ( $t_j \leq -7 \text{ °C}$  or  $5,5 \text{ °C} \leq t_j$ )

1) First stage cyclic operation ( $L_h(t_j) \leq \phi_{min}(t_j)$ )

$$P_{mh}(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$\phi(t_j) = \phi_{min}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{min}(t_j).$$

2) Second stage cyclic operation ( $\phi_{min}(t_j) < L_h(t_j) \leq \phi_{haf}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{mh}(t_j) = X_{mh}(t_j) \times P_{min}(t_j) + (1 - X_{mh}(t_j)) \times P_{haf}(t_j) \quad (31)$$

$$X_{mh}(t_j) = \frac{\phi_{haf}(t_j) - L_h(t_j)}{\phi_{haf}(t_j) - \phi_{min}(t_j)} \quad (32)$$

3) Third stage cyclic operation ( $\phi_{haf}(t_j) < L_h(t_j) \leq \phi_{ful}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{hf}(t_j) = X_{hf}(t_j) \times P_{haf}(t_j) + (1 - X_{hf}(t_j)) \times P_{ful}(t_j) \quad (33)$$

$$X_{hf}(t_j) = \frac{\phi_{ful}(t_j) - L_h(t_j)}{\phi_{ful}(t_j) - \phi_{haf}(t_j)} \quad (34)$$

4) Fourth stage cyclic operation ( $\phi_{ful}(t_j) < L_h(t_j) \leq \phi_{ext}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0 \text{ in Formula (29).}$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{fe}(t_j) = X_{fe}(t_j) \times P_{ful}(t_j) + (1 - X_{fe}(t_j)) \times P_{ext}(t_j) \quad (35)$$

$$X_{fe}(t_j) = \frac{\phi_{ext}(t_j) - L_h(t_j)}{\phi_{ext}(t_j) - \phi_{ful}(t_j)} \quad (36)$$

For units not having the extended capacity operation,

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ful}(t_j) \text{ in Formula (11).}$$

$$P_{fe}(t_j) = P_{ful}(t_j).$$

- 5) Extended capacity operation ( $L_h(t_j) > \phi_{ext}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ext}(t_j) \text{ in Formula (11)}$$

For units not having the extended capacity operation, the calculation is not necessary.

- b) Frosting temperature range ( $-7 \text{ °C} < t_j < 5,5 \text{ °C}$ )

- 1) First stage cyclic operation ( $L_h(t_j) \leq \phi_{min, f}(t_j)$ )

$$P_{mh}(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$\phi(t_j) = \phi_{min, f}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{min, f}(t_j).$$

- 2) Second stage cyclic operation ( $\phi_{min, f}(t_j) < L_h(t_j) \leq \phi_{haf, f}(t_j)$ )

$$P(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{mh}(t_j) = X_{mh}(t_j) \times P_{min, f}(t_j) + (1 - X_{mh}(t_j)) \times P_{haf, f}(t_j) \quad (37)$$

$$X_{mh}(t_j) = \frac{\phi_{haf, f}(t_j) - L_h(t_j)}{\phi_{haf, f}(t_j) - \phi_{min, f}(t_j)} \quad (38)$$

- 3) Third stage cyclic operation ( $\phi_{haf, f}(t_j) < L_h(t_j) \leq \phi_{ful, f}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{hf}(t_j) = X_{hf}(t_j) \times P_{haf, f}(t_j) + (1 - X_{hf}(t_j)) \times P_{ful, f}(t_j) \quad (39)$$

$$X_{hf}(t_j) = \frac{\phi_{ful, f}(t_j) - L_h(t_j)}{\phi_{ful, f}(t_j) - \phi_{haf, f}(t_j)} \quad (40)$$

- 4) Fourth stage cyclic operation ( $\phi_{ful, f}(t_j) < L_h(t_j) \leq \phi_{ext, f}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{fe}(t_j) = X_{fe}(t_j) \times P_{ful,f}(t_j) + (1 - X_{fe}(t_j)) \times P_{ext,f}(t_j) \quad (41)$$

$$X_{fe}(t_j) = \frac{\phi_{ext,f}(t_j) - L_h(t_j)}{\phi_{ext,f}(t_j) - \phi_{ful,f}(t_j)} \quad (42)$$

For units not having the extended capacity operation,

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ful,f}(t_j) \text{ in Formula (11).}$$

$$P_{fe}(t_j) = P_{ful,f}(t_j).$$

- 5) Extended capacity operation ( $L_h(t_j) > \phi_{ext,f}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ext,f}(t_j) \text{ in Formula (11).}$$

$$P_{ful}(t_j) = P_{ful,f}(t_j)$$

For units not having the extended capacity operation, the calculation is not necessary.

#### 6.6.4.2 In case of calculation using Formula (30)

- a) Non-frosting temperature range ( $t_j \leq -7^\circ\text{C}$  or  $5,5^\circ\text{C} \leq t_j$ )

- 1) First stage cyclic operation ( $L_h(t_j) \leq \phi_{haf}(t_j)$ )

$$P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$\phi(t_j) = \phi_{haf}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{haf}(t_j).$$

- 2) Second stage cyclic operation ( $\phi_{haf}(t_j) < L_h(t_j) \leq \phi_{ful}(t_j)$ )

$$P(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{hf}(t_j) \text{ shall be calculated using Formula (33).}$$

$$X_{hf}(t_j) \text{ shall be calculated using Formula (34).}$$

- 3) Third stage cyclic operation ( $\phi_{ful}(t_j) < L_h(t_j) \leq \phi_{ext}(t_j)$ )

$$P(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0 \text{ in Formula (30).}$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$P_{fe}(t_j) \text{ shall be calculated using Formula (35).}$$

$$X_{fe}(t_j) \text{ shall be calculated using Formula (36).}$$

For units not having the extended capacity operation,

$$P(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ful}(t_j) \text{ in Formula (11).}$$

$$P_{fe}(t_j) = P_{ful}(t_j).$$

- 4) Extended capacity operation ( $L_h(t_j) > \phi_{ext}(t_j)$ )

$$P(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ext}(t_j) \text{ in Formula (11).}$$

$$P(t_j) = P_{ext}(t_j).$$

For units not having the extended capacity operation, the calculation is not necessary.

- b) Frosting temperature range ( $-7 \text{ °C} < t_j < 5,5 \text{ °C}$ )

- 1) First stage cyclic operation ( $L_h(t_j) \leq \phi_{haf, f}(t_j)$ )

$$P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$\phi(t_j) = \phi_{haf, f}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{haf, f}(t_j).$$

- 2) Second stage cyclic operation ( $\phi_{haf, f}(t_j) < L_h(t_j) \leq \phi_{ful, f}(t_j)$ )

$$P(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$P_{hf}(t_j)$  shall be calculated using Formula (39).

$X_{hf}(t_j)$  shall be calculated using Formula (40).

- 3) Third stage cyclic operation ( $\phi_{ful, f}(t_j) < L_h(t_j) \leq \phi_{ext, f}(t_j)$ )

$$P(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$P_{fe}(t_j)$  shall be calculated using Formula (41).

$X_{fe}(t_j)$  shall be calculated using Formula (42).

For units not having the extended capacity operation,

$$P(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ful, f}(t_j) \text{ in Formula (11).}$$

$$P_{fe}(t_j) = P_{ful, f}(t_j).$$

- 4) Extended capacity operation ( $L_h(t_j) > \phi_{ext, f}(t_j)$ )

$$P(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ext, f}(t_j) \text{ in Formula (11).}$$

$$P_{\text{ful}}(t_j) = P_{\text{ful},f}(t_j)$$

For units not having the extended capacity operation, the calculation is not necessary.

## 6.7 Heating seasonal characteristics of variable capacity units

Coefficients shown in [Table 1](#) may be used for each characteristic.

### 6.7.1 Capacity characteristics against outdoor temperature

Capacities  $\phi_{\text{ful}}(t_j)$ ,  $\phi_{\text{min}}(t_j)$ ,  $\phi_{\text{ext}}(t_j)$  and  $\phi_{\text{haf}}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined by Formulae (3), (12), (21) and (22), respectively.

Capacities  $\phi_{\text{ful},f}(t_j)$ ,  $\phi_{\text{min},f}(t_j)$ ,  $\phi_{\text{ext},f}(t_j)$  and  $\phi_{\text{haf},f}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined by Formulae (4), (13), (23) and (24), respectively.

### 6.7.2 Power input characteristics against outdoor temperature

Electric power input  $P_{\text{ful}}(t_j)$ ,  $P_{\text{min}}(t_j)$ ,  $P_{\text{ext}}(t_j)$  and  $P_{\text{haf}}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined from Formulae (5), (14), (25) and (26), respectively.

Electric power input  $P_{\text{ful},f}(t_j)$ ,  $P_{\text{min},f}(t_j)$ ,  $P_{\text{ext},f}(t_j)$  and  $P_{\text{haf},f}(t_j)$  (W) of the equipment when it is operated for heating at outdoor temperature  $t_j$  shall be determined from Formulae (6), (15), (27) and (28), respectively.

### 6.7.3 Calculation of heating seasonal total load (HSTL)

Heating seasonal total load (HSTL),  $L_{\text{HST}}$ , shall be calculated by Formula (7).

### 6.7.4 Calculation of heating seasonal energy consumption (HSEC)

The relation of heating capacity characteristics and energy consumption characteristics to heating load at outdoor temperature  $t_j$  is shown in [Figure A.4](#) in [Annex A](#).

When the minimum capacity data are available, then the heating seasonal energy consumption (HSEC),  $C_{\text{HSE}}$ , shall be calculated by Formula (29).

When the minimum capacity data are not available, then the heating seasonal energy consumption (HSEC),  $C_{\text{HSE}}$ , shall be calculated alternatively by Formula (30).

#### 6.7.4.1 In case of calculation using Formula (29)

a) Non-frosting temperature range ( $t_j \leq -7^\circ\text{C}$  or  $5,5^\circ\text{C} \leq t_j$ )

1) Cyclic operation ( $L_h(t_j) \leq \phi_{\text{min}}(t_j)$ )

$$P_{\text{mh}}(t_j) = P_{\text{hf}}(t_j) = P_{\text{fe}}(t_j) = P_{\text{ext}}(t_j) = P_{\text{RH}}(t_j) = 0$$

$$\phi(t_j) = \phi_{\text{min}}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{\text{min}}(t_j).$$

2) Variable capacity operation between minimum and half capacity ( $\phi_{\text{min}}(t_j) < L_h(t_j) \leq \phi_{\text{haf}}(t_j)$ )

$$P(t_j) = P_{\text{hf}}(t_j) = P_{\text{fe}}(t_j) = P_{\text{ext}}(t_j) = P_{\text{RH}}(t_j) = 0$$

$$X(t_j) = F_{\text{PL}}(t_j) = 1$$

$C_{\text{OP}}(t)$ , Coefficient of Performance (COP) at outdoor temperature  $t$ , shall be determined by the following:

$$C_{OP}(t) = \frac{\phi(t)}{P(t)} \quad (43)$$

It is assumed that COP linearly changes depending on outdoor temperature when the capacity of equipment changes continuously.

$$C_{OP,mh}(t_j) = C_{OP,haf}(t_d) + \frac{C_{OP,min}(t_q) - C_{OP,haf}(t_d)}{t_q - t_d} \times (t_j - t_d) \quad (44)$$

$t_d$  is outdoor temperature when heating load is equal to heating half capacity (refer to [Annex E](#)).

$C_{OP,haf}(t_d)$  shall be calculated from Formula (43), where,  $\phi(t) = \phi_{haf}(t_d)$  and  $P(t) = P_{haf}(t_d)$ .

$t_q$  is outdoor temperature when heating load is equal to heating minimum capacity (refer to [Annex E](#)).

$C_{OP,min}(t_q)$  shall be calculated from Formula (43), where,  $\phi(t) = \phi_{min}(t_q)$  and  $P(t) = P_{min}(t_q)$ .

$P_{mh}(t_j)$  shall be calculated from Formula (45).

$$P(t_j) = \frac{L_h(t_j)}{C_{OP}(t_j)} \quad (45)$$

where  $C_{OP}(t_j) = C_{OP,mh}(t_j)$ .

- 3) Variable capacity operation between half and full capacity ( $\phi_{haf}(t_j) < L_h(t_j) \leq \phi_{ful}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$C_{OP}(t)$ , Coefficient of Performance (COP) at outdoor temperature  $t$ , shall be determined by Formula (43).

It is assumed that COP linearly changes depending on outdoor temperature when the capacity of equipment changes continuously.

$$C_{OP,hf}(t_j) = C_{OP,ful}(t_a) + \frac{C_{OP,haf}(t_d) - C_{OP,ful}(t_a)}{t_d - t_a} \times (t_j - t_a) \quad (46)$$

$t_a$  is outdoor temperature when heating load is equal to heating full capacity (refer to [Annex E](#)).

$C_{OP,ful}(t_a)$  shall be calculated from Formula (43), where,  $\phi(t) = \phi_{ful}(t_a)$  and  $P(t) = P_{ful}(t_a)$ .

$t_d$  is outdoor temperature when heating load is equal to heating half capacity (refer to [Annex E](#)).

$C_{OP,haf}(t_d)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{haf}(t_d)$  and  $P(t) = P_{haf}(t_d)$ .

$P_{hf}(t_j)$  shall be calculated from Formula (45), where  $C_{OP}(t_j) = C_{OP,hf}(t_j)$ .

- 4) Full capacity or variable capacity operation between full and extended capacity ( $\phi_{ful}(t_j) < L_h(t_j) \leq \phi_{ext}(t_j)$ )

For units not having the extended capacity operation,

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$\phi(t_j) = \phi_{ful}(t_j)$  in Formula (11).

$$P_{fe}(t_j) = P_{ful}(t_j).$$

If there is an extended mode,  $P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$ .

$$X(t_j) = F_{PL}(t_j) = 1$$

$$C_{OP, fe}(t_j) = C_{OP, ext}(t_h) + \frac{C_{OP, ful}(t_a) - C_{OP, ext}(t_h)}{t_a - t_h} \times (t_j - t_h) \quad (47)$$

$t_h$  is outdoor temperature when heating load is equal to heating extended capacity (refer to [Annex E](#)).

$C_{OP, ext}(t_h)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{ext}(t_h)$  and  $P(t) = P_{ext}(t_h)$ .

$t_a$  is outdoor temperature when heating load is equal to heating full capacity (refer to [Annex E](#)).

$C_{OP, ful}(t_a)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{ful}(t_a)$  and  $P(t) = P_{ful}(t_a)$ .

$P_{fe}(t_j)$  shall be calculated from Formula (45), where  $C_{OP}(t_j) = C_{OP, fe}(t_j)$ .

5) Extended capacity operation ( $L_h(t_j) > \phi_{ext}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ext}(t_j) \text{ in Formula (11).}$$

For units not having the extended capacity operation, the calculation is not necessary.

b) Frosting temperature range ( $-7 \text{ }^\circ\text{C} < t_j < 5,5 \text{ }^\circ\text{C}$ )

1) Cyclic operation ( $L_h(t_j) \leq \phi_{min, f}(t_j)$ )

$$P_{mh}(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$\phi(t_j) = \phi_{min, f}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{min, f}(t_j).$$

2) Variable capacity operation between minimum and half capacity ( $\phi_{min, f}(t_j) < L_h(t_j) \leq \phi_{haf, f}(t_j)$ )

$$P(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$C_{OP, mh, f}(t_j) = C_{OP, haf, f}(t_e) + \frac{C_{OP, min, f}(t_r) - C_{OP, haf, f}(t_e)}{t_r - t_e} \times (t_j - t_e) \quad (48)$$

$t_r$  is outdoor temperature when heating load is equal to heating minimum capacity with frosting operation (refer to [Annex E](#)).

$C_{OP, min, f}(t_r)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{min, f}(t_r)$  and  $P(t) = P_{min, f}(t_r)$ .

$t_e$  is outdoor temperature when heating load is equal to heating half capacity with frosting operation (refer to [Annex E](#)).

$C_{OP, haf, f}(t_e)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{haf, f}(t_e)$  and  $P(t) = P_{haf, f}(t_e)$ .

$P_{mh}(t_j)$  shall be calculated from Formula (45), where  $C_{OP}(t_j) = C_{OP, mh, f}(t_j)$ .

3) Variable capacity operation between half and full capacity ( $\phi_{haf, f}(t_j) < L_h(t_j) \leq \phi_{ful, f}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$C_{OP}(t)$ , Coefficient of Performance (COP) at outdoor temperature  $t$ , shall be determined by Formula (43).

It is assumed that COP linearly changes depending on outdoor temperature when the capacity of equipment changes continuously.

$$C_{OP, hf, f}(t_j) = C_{OP, ful, f}(t_g) + \frac{C_{OP, haf, f}(t_e) - C_{OP, ful, f}(t_g)}{t_e - t_g} \times (t_j - t_g) \quad (49)$$

$t_g$  is outdoor temperature when heating load is equal to heating full capacity with frosting operation (refer to [Annex E](#)).

$C_{OP, ful, f}(t_g)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{ful, f}(t_g)$  and  $P(t) = P_{ful, f}(t_g)$ .

$t_e$  is outdoor temperature when heating load is equal to heating half capacity with frosting operation (refer to [Annex E](#)).

$C_{OP, haf, f}(t_e)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{haf, f}(t_e)$  and  $P(t) = P_{haf, f}(t_e)$ .

$P_{hf}(t_j)$  shall be calculated from Formula (45), where  $C_{OP}(t_j) = C_{OP, hf, f}(t_j)$ .

- 4) Full capacity or variable capacity operation between full and extended capacity ( $\phi_{ful, f}(t_j) < L_h(t_j) \leq \phi_{ext, f}(t_j)$ )

For units not having the extended capacity operation,

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ful, f}(t_j) \text{ in Formula (11).}$$

$$P_{fe}(t_j) = P_{ful, f}(t_j).$$

$$\text{If there is an extended mode, } P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0.$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$C_{OP, fe, f}(t_j) = C_{OP, ext, f}(t_f) + \frac{C_{OP, ful, f}(t_g) - C_{OP, ext, f}(t_f)}{t_g - t_f} \times (t_j - t_f) \quad (50)$$

$t_f$  is outdoor temperature when heating load is equal to heating extended capacity with frosting operation (refer to [Annex E](#)).

$C_{OP, ext, f}(t_f)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{ext, f}(t_f)$  and  $P(t) = P_{ext, f}(t_f)$ .

$t_g$  is outdoor temperature when heating load is equal to heating full capacity with frosting operation (refer to [Annex E](#)).

$C_{OP, ful, f}(t_g)$  shall be calculated from Formula (43), where  $\phi(t) = \phi_{ful, f}(t_g)$  and  $P(t) = P_{ful, f}(t_g)$ .

$P_{fe}(t_j)$  shall be calculated from Formula (45), where  $C_{OP}(t_j) = C_{OP, fe, f}(t_j)$ .

- 5) Extended capacity operation ( $L_h(t_j) > \phi_{ext, f}(t_j)$ )

$$P(t_j) = P_{mh}(t_j) = P_{hf}(t_j) = P_{fe}(t_j) = 0$$

$$X(t_j) = F_{PL}(t_j) = 1$$

$$\phi(t_j) = \phi_{ext, f}(t_j) \text{ in Formula (11).}$$

$$P_{ful}(t_j) = P_{ful, f}(t_j)$$

For units not having the extended capacity operation, the calculation is not necessary.

**6.7.4.2 In case of calculation using Formula (30)**

a) Non-frosting temperature range ( $t_j \leq -7\text{ °C}$  or  $5,5\text{ °C} \leq t_j$ )

1) Cyclic operation ( $L_h(t_j) \leq \phi_{haf}(t_j)$ )

$$P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$\phi(t_j) = \phi_{haf}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{haf}(t_j).$$

2) Variable capacity operation between half and full capacity ( $\phi_{haf}(t_j) < L_h(t_j) \leq \phi_{ful}(t_j)$ )

6.7.4.1 a) 3) shall apply.

3) Full capacity or variable capacity operation between full and extended capacity ( $\phi_{ful}(t_j) < L_h(t_j) \leq \phi_{ext}(t_j)$ )

6.7.4.1 a) 4) shall apply.

4) Extended capacity operation ( $L_h(t_j) > \phi_{ext}(t_j)$ )

6.7.4.1 a) 5) shall apply.

b) Frosting temperature range ( $-7\text{ °C} < t_j < 5,5\text{ °C}$ )

1) Cyclic operation ( $L_h(t_j) \leq \phi_{haf, f}(t_j)$ )

$$P_{hf}(t_j) = P_{fe}(t_j) = P_{ext}(t_j) = P_{RH}(t_j) = 0$$

$$\phi(t_j) = \phi_{haf, f}(t_j) \text{ in Formula (9).}$$

$$P(t_j) = P_{haf, f}(t_j).$$

2) Variable capacity operation between half and full capacity ( $\phi_{haf, f}(t_j) < L_h(t_j) \leq \phi_{ful, f}(t_j)$ )

6.7.4.1 b) 3) shall apply.

3) Full capacity or variable capacity operation between full and extended capacity ( $\phi_{ful, f}(t_j) < L_h(t_j) \leq \phi_{ext, f}(t_j)$ )

6.7.4.1 b) 4) shall apply.

4) Extended capacity operation ( $L_h(t_j) > \phi_{ext, f}(t_j)$ )

6.7.4.1 b) 5) shall apply.

**7 Test report**

The test report shall include:

- a) the type of unit;
- b) the list of mandatory test points performed, and the resulting capacity and COP values;
- c) the list of optional test points performed, and the resulting capacity and COP values;
- d) the default values used;
- e) for multi-split systems, a combination of indoor units and an outdoor unit.


For variable capacity units, frequency settings for each performed test shall also be indicated.

The heating seasonal performance factor (HSPF) shall be declared with three significant digits, with reference to the reference defined heating load and to the reference outdoor temperature bin distribution used.

STANDARDSISO.COM : Click to view the full PDF of ISO 16358-2:2013


## Annex A (informative)

### Figures



- Key**
- X outdoor temperature
  - Y1 capacity or load
  - Y2 power input


**Figure A.1** — Heating capacity, power input and load for fixed capacity units



**Key**


- X outdoor temperature
- Y1 capacity or load
- Y2 power input

**Figure A.2** — Heating capacity, power input and load for two-stage capacity units



**Key**  
 X outdoor temperature  
 Y1 capacity or load  
 Y2 power input

Figure A.3 — Heating capacity, power input and load for multi-stage capacity units



- Key**
- X outdoor temperature
  - Y1 capacity or load
  - Y2 power input
  - Y3 coefficient of performance (COP)

**Figure A.4 — Heating capacity, power input, load and COP for variable capacity units**

## Annex B (informative)

### Calculation of total heating seasonal performance factor (THSPF)

#### B.1 General

This annex applies to heating only units and reversible units.

#### B.2 Measurement of the electric power consumption during the inactive mode

The unit shall be electrically connected to the main power source after shut-down for 6 h. Indoor and outdoor temperature of 20 °C condition shall be reached. The power consumption shall be measured for one hour after the temperature conditions are stabilized. The same test is repeated with the temperature condition of 5 °C, 10 °C and then 15 °C with the stabilization period of 2 h between each test. As a reference case, each power consumption value shall be weighted by weighting factors in [Table B.1](#) and then integrated to obtain a weighted average inactive power consumption,  $P_{ia}$ . The calculation of inactive power may also be undertaken for other climate conditions and operating schedules.

NOTE If the results of the tests at 20 °C and 5 °C are within 5 % or 1 W, then the tests at 15 °C and 10 °C are not mandatory. The average value of these results is used for the four considered temperature conditions.

**Table B.1 — Default weighting factors for determination of reference inactive energy consumption**

Temperature condition	5 °C	10 °C	15 °C	20 °C
Weighting factor	0,05	0,13	0,27	0,55

Inactive energy consumption (IAEC) shall be calculated by Formula (B.1).

$$C_{IAE} = H_{ia} \times P_{ia} \tag{B.1}$$

where

$C_{IAE}$  is the inactive energy consumption;

$H_{ia}$  is the number of hours of inactive mode as given in [Table B.2](#);

$P_{ia}$  is the weighted average power consumption.

#### B.3 Calculation of total heating seasonal performance factor (THSPF)

Total heating seasonal performance factor (THSPF),  $F_{THSP}$ , shall be calculated by Formula (B.2).

$$F_{THSP} = \frac{L_{HST}}{C_{HSE} + C_{IAE}} \tag{B.2}$$

Calculation of  $L_{HST}$  and  $C_{HSE}$  is according to the main body of this part of ISO 16358.

Inactive energy consumption (IAEC),  $C_{IAE}$ , shall be calculated by Formula (B.1).

The default mode hours for the calculation of reference total heating seasonal performance factor are shown in [Table B.2](#). The calculation of total heating seasonal performance factor may also be undertaken for other distributions of mode hours.

**Table B.2 — Default hours by mode for the calculation of reference total heating seasonal performance factor**

Unit	Active mode h	Inactive mode, $H_{ia}$ h	Disconnected mode h
Heating only unit	2 866	4 077	1 817
Reversible unit	2 866 (Cooling operation: 1 817)	4 077	0

STANDARDSISO.COM : Click to view the full PDF of ISO 16358-2:2013