
**Heat recovery ventilators and energy
recovery ventilators — Method of test
for performance**

*Ventilateurs-récupérateurs de chaleur et ventilateurs-récupérateurs
d'énergie — Méthode d'essai des performances*

STANDARDSISO.COM : Click to view the full PDF of ISO 16494:2014



STANDARDSISO.COM : Click to view the full PDF of ISO 16494:2014



COPYRIGHT PROTECTED DOCUMENT

© ISO 2014

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

| | Page |
|----------------------------------------------------------------------------------------------------------------------------------------|-----------|
| Foreword | v |
| 1 Scope | 1 |
| 2 Normative references | 1 |
| 3 Terms and definitions | 1 |
| 4 Symbols and abbreviated terms | 5 |
| 5 Airflow test | 6 |
| 5.1 General conditions..... | 6 |
| 5.2 Ducted heat recovery ventilators and energy recovery ventilators..... | 6 |
| 5.3 Unducted heat recovery ventilators and energy recovery ventilators..... | 9 |
| 6 Tracer gas tests | 9 |
| 6.1 General conditions..... | 9 |
| 6.2 Temperature conditions..... | 9 |
| 6.3 Preconditions..... | 9 |
| 6.4 Airflow conditions..... | 9 |
| 6.5 Unit operating voltage and frequency..... | 9 |
| 6.6 Tracer gas measurement methods..... | 9 |
| 7 Determination of efficiency | 10 |
| 7.1 General conditions..... | 10 |
| 7.2 Temperature and humidity conditions: inlets to ventilator..... | 10 |
| 7.3 Preconditions..... | 10 |
| 7.4 Airflow conditions..... | 10 |
| 7.5 Static pressure conditions: ducted heat and energy recovery ventilators..... | 11 |
| 7.6 Static pressure conditions: unducted heat and energy recovery ventilators..... | 11 |
| 7.7 Unit operating voltage and frequency..... | 11 |
| 7.8 Thermal performance measurement..... | 11 |
| 8 Performance calculations | 11 |
| 8.1 Performance calculations: ducted ventilators..... | 11 |
| 8.2 Performance calculations: unducted ventilators..... | 11 |
| 8.3 Unit Exhaust Air Transfer Ratio (UEATR)..... | 11 |
| 8.4 Net supply airflow..... | 12 |
| 8.5 Gross effectiveness..... | 13 |
| 8.6 Coefficient of energy (COE)..... | 14 |
| 8.7 Effective work (EW)..... | 15 |
| 9 Test results | 16 |
| Annex A (normative) Airflow measurement method for both ducted and unducted ventilators | 17 |
| Annex B (normative) Decay method for measurement of net supply airflow | 19 |
| Annex C (normative) Unit exhaust air transfer ratio measurement methods | 21 |
| Annex D (normative) Thermal performance measurement | 25 |
| Annex E (informative) Example data collection and reporting sheets | 28 |
| Annex F (normative) Required instrument uncertainty | 36 |
| Annex G (informative) Construction of plenums for connection to inlets or outlets not designed for connection of ductwork | 37 |
| Bibliography | 38 |

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 6, *Testing and rating of air-conditioners and heat pumps*.

Heat recovery ventilators and energy recovery ventilators — Method of test for performance

1 Scope

This International Standard prescribes a method of testing the ventilation and energy related performance of heat recovery ventilators (HRVs) and energy recovery ventilators (ERVs) that do not contain any supplemental heating (except for defrost), cooling, humidification or dehumidification components.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3966:2008, *Measurement of fluid flow in closed conduits — Velocity area method using Pitot static tubes*

ISO 5167-1:2003, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements*

ISO 5801:2007, *Industrial fans — Performance testing using standardized airways*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

outdoor airflow

OA

volume of outside air entering the ventilator

Note 1 to entry: Indicated in [Figure 1](#) as 1.

Note 2 to entry: Also referred to as 'entering supply air'.

3.2

supply airflow

SA

outside air after passing through the ventilator

Note 1 to entry: Indicated in [Figure 1](#) as 2.

Note 2 to entry: Also referred to as 'leaving supply air'.

3.3

return (extract) airflow

RA

indoor air entering the ventilator

Note 1 to entry: Indicated in [Figure 1](#) as 3.


Note 2 to entry: Also referred to as 'entering exhaust air'.

**3.4
exhaust airflow
EA**

indoor air after passing through the ventilator

Note 1 to entry: Indicated in [Figure 1](#) as 4.

Note 2 to entry: Also referred to as 'leaving exhaust air'.



Key

- 1 outdoor airflow (OA) (entering)
- 2 supply airflow (SA) (leaving)
- 3 return airflow (RA) (entering)
- 4 exhaust airflow (EA) (leaving)
- 5 ventilator
- 6 indoor side
- 7 outdoor side

Figure 1 — Schematic numbering of airflows for heat and energy recovery ventilators

**3.5
station**

location in the test apparatus at which conditions such as temperature, humidity, pressure, or airflow are measured

Note 1 to entry: These locations are identified as “station 1”, “station 2”, “station 3” and “station 4” for each of the airflows indicated in [Figure 1](#).

**3.6
coefficient of energy
COE**

total exchanged energy between the airstreams plus the power value of moving air, divided by the power input

Note 1 to entry: The equation for determining the coefficient of energy is given in [8.6](#).

**3.7
rating points**

sets of supply and return airflows, static pressures at inlets and outlets, and speed control setting, achieved during the airflow performance measurement, at which thermal performance tests (and exhaust air transfer tests, if applicable) are performed

3.8
effective work
EW

total exchanged energy between the airstreams plus the power value of moving air minus the power input

Note 1 to entry: The equation for determining the effective work is given in [8.7](#).

Note 2 to entry: Effective work is expressed in W.

3.9
power value of moving air

rate of pressure energy and kinetic energy of the air delivered by the ventilator

Note 1 to entry: The equation that determines the power value of moving air is given in [8.6.1](#).

Note 2 to entry: Power value of moving air is expressed in J/s for P_{vma} .

3.10
gross effectiveness

measured effectiveness, not adjusted for leakage, motor heat gain, or heat transfer through the unit casing

Note 1 to entry: The sensible, latent or total gross effectiveness of an HRV or ERV, at equal airflows, is described in [8.5](#).

3.11
maximum rated airflow

the largest supply and return airflows, specified by the manufacturer, at which an airflow test is performed

Note 1 to entry: For ventilators with speed control devices, different maximum rated airflows may be defined for each speed control setting at which the test is performed.

3.12
minimum rated airflow

the smallest supply and return airflows, specified by the manufacturer, at which an airflow test is performed

Note 1 to entry: For ventilators with speed control devices, different minimum rated airflows may be defined for each speed control setting at which the test is performed.

3.13
net supply airflow

portion of the leaving supply airflow that originated as entering supply airflow

Note 1 to entry: The net supply airflow is represented by the variable Q_{SAnet} , measured in m^3/s .

Note 2 to entry: The equations for determining net supply airflow are given in [8.4.1](#) (ducted units) and [8.4.2](#) (unducted units).

3.14
net supply airflow ratio

ratio determined by dividing net supply airflow by supply airflow

Note 1 to entry: Expressed as a percentage, and described in [8.4.1](#) and [8.4.2](#).

3.15
speed control device

device incorporated into the ventilator which controls the speed of the fan

3.16
standard air

dry air with a density of $1,2 \text{ kg/m}^3$

Note 1 to entry: These conditions approximate dry air at 20°C and $101,325 \text{ kPa}$ absolute.

3.17

static pressure differential

absolute difference between inlet static pressure and outlet static pressure for each of the two airstreams

EXAMPLE Static pressures measured at $|X_2-X_1|$, or $|X_4-X_3|$.

3.18

thermal performance measurement

test procedure which measures the temperature and humidity of the supply air when a ventilator is operating with the outside air and return air at specific psychrometric conditions

3.19

unit exhaust air transfer ratio

UEATR

tracer gas concentration difference between the supply airflow and the outdoor airflow divided by the tracer gas concentration difference between the return airflow and the outdoor airflow, at a specified airflow

Note 1 to entry: The equation for UEATR is given in [8.3](#).

Note 2 to entry: UEATR is expressed as a percentage.

3.20

ventilator

self contained unit that includes fans to move air through the heat/energy exchanger

3.21

energy recovery ventilator

ERV

ventilator which is designed to transfer both heat and moisture between two isolated airstreams

3.22

fresh air mass flow rate

qm_2

leaving supply mass airflow rate at station 2

3.23

heat recovery ventilator

HRV

ventilator which is designed to transfer only heat between two isolated airstreams

3.24

unducted ventilator

heat recovery ventilator or energy recovery ventilator which is not intended for connection of ducts to any of the airflow inlets or outlets except for model specific exterior termination systems as defined in [3.27](#)

3.25

ducted ventilator

heat recovery ventilator or energy recovery ventilator which is intended for connection of ducts to one or more of the airflow inlets or outlets and intended to address a range of static pressure differentials from the duct(s)

3.26

duct

insulated or uninsulated closed passage for air that is installed as part of the ventilation system in lengths determined by the needs of application, and is separate, prior to installation from exterior terminations such as weather hoods

3.27

model-specific exterior termination system

weather hoods, fittings and through-wall penetrations designed by the ventilator manufacturer specifically for installation with a specific model of ventilator, that comprise the complete passageway connecting the ventilators outside air inlet and/or exhaust air outlet to the ventilator

3.28

net supply mass flow rate
 $qm_{2,net}$

portion of the leaving supply mass airflow rate at station 2 that originated as entering supply mass flow rate at station 1, accounting for *UEATR*

Note 1 to entry: Per the equation in [8.6.1](#) and [8.6.2](#).

4 Symbols and abbreviated terms

| Symbol | Definition | Units |
|--------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| C_i | Initial tracer gas concentration in the test chamber (average of all measurement points) | |
| C_o | Tracer gas concentration in outdoor air (OA) | |
| C_{OA} | Tracer gas concentration at outdoor air inlet (station 1) | |
| C_p | Specific heat at supply airflow | kJ/kg K |
| C_{RA} | Tracer gas concentration at return air inlet (station 3) | |
| C_{SA} | Tracer gas concentration at supply air outlet (station 2) | |
| C_t | Tracer gas concentration in the test chamber after t hours (average of all measurement points) | |
| h_1 | Enthalpy of the air at station 1 | kJ/kg of dry air |
| h_2 | Enthalpy of the air at station 2 | kJ/kg of dry air |
| qm_2 | Fresh air mass flow rate | kg/s |
| $qm_{2,net}$ | Net supply mass flow rate | kg/s |
| NSAR | Net supply airflow ratio | % |
| P_{aux} | Input power to any other electrical components in the ventilator | W |
| P_{em} | Input power to all electric motors in the ventilator | W |
| P_{in} | Input power to ventilator | W |
| P_{vma} | Power value of moving air | J/s |
| Q | Gross airflow | m ³ /s |
| Q_1 | Average of the three calculated overall airflow rates with the unit under test in operation as described in B.2.1.1 and B.2.1.2 | m ³ /s |
| Q_2 | Average of the three calculated natural airflow rates of the test chamber with the ventilator removed as described in B.2.2.1 and B.2.2.2 | m ³ /s |
| Q_i | Airflow rate calculated using the data from a test 'i' as described in B.2.1.1 , B.2.1.2 , B.2.2.1 and B.2.2.2 | m ³ /s |
| Q_{SA} | Supply airflow | m ³ /s |
| Q_{SAnet} | Net supply airflow | m ³ /s |
| ps_n | External static pressures at the inlet(s) or outlet(s) | Pa |
| t | Length of time elapsed since the start of test unit operation | s |
| T_1 | Temperature of the outdoor airflow at station 1 | K |
| T_2 | Temperature of the supply airflow at station 2 | K |

| Symbol | Definition | Units |
|------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------|
| UEATR | Unit exhaust air transfer ratio | % |
| V | Air volume in the test chamber | m ³ |
| v_s | Specific volume of the supply air | m ³ /kg |
| x | Dry-bulb temperature (for sensible effectiveness); or absolute humidity ratio (for latent effectiveness); or total enthalpy (for total effectiveness). | °C kg water/kg dry air J/kg |
| ϵ | Effectiveness | |

5 Airflow test

5.1 General conditions

All tested equipment within the scope of this International Standard shall have the airflows determined in accordance with the following provisions:

5.1.1 Temperature conditions

When measuring airflow, the laboratory ambient conditions shall be 20 ± 15 °C and 30 to 95 % RH. Laboratory ambient temperature during the test shall be recorded and reported.

5.1.2 Speed control setting

The ventilator shall be tested using the manufacturer specified speed control settings. Speed control settings shall not be adjusted during the test.

5.1.3 Unit operating voltage and frequency

The power supply voltage at the operating unit shall be within ± 2 % of the rated voltage. The power supply frequency at the operating unit shall be within ± 1 % of the rated frequency.

5.2 Ducted heat recovery ventilators and energy recovery ventilators


5.2.1 Airflows measured

The gross airflow shall be measured and recorded at station 2 (Supply Airflow) and at station 3 (Return Airflow) as shown in [Figure 1](#), under the static pressure conditions indicated in [5.2.2](#).

5.2.2 Static pressure conditions

5.2.2.1 In order to properly characterize the performance of the unit, the ventilator shall be tested at specified maximum rated and minimum rated airflows and at a minimum of three additional, approximately evenly spaced intermediate airflows between the maximum rated airflow and minimum rated airflow. This gives a minimum of five test points as shown in [Figure 2](#). The airflow test points must be reached by adjusting the test apparatus to change the static pressure differential. If the ventilator is equipped with a speed control device, it shall not be adjusted during this test. Input power in watts shall be measured and recorded at each test point.

5.2.2.2 Any inlet or outlet which is not designed for duct connection shall be maintained at an average value of $0 \pm 2,5$ Pa, static pressure for all test points. However, if the ventilator is designed for installation with model-specific exterior termination system as defined in [3.27](#), that system shall be installed.

**Key**

- 1 P-Q curve (supply airflow)
- 2 P-Q curve (return airflow)
- 3 minimum rated airflow
- 4 maximum rated airflow

Figure 2 Representative chart of airflow performance

5.2.2.3 Static pressure measurement requirements

When testing for airflow, the requirements of 5.2.2.3 a) or 5.2.2.3 b) shall apply.


a) Only for units tested in a ducted setup:

- 1) For the maximum and minimum rated airflows the absolute value of static pressure at inlet (ps_1) and outlet (ps_2) shall be equal within 10 Pa or 5 %, whichever is greater, of the larger of the measured values of ps_1 or ps_2 , except as noted in [5.2.2.2](#).
- 2) The absolute value of static pressure at inlet (ps_3) and outlet (ps_4) shall be equal, within 10 Pa or 5 %, whichever is greater, of the larger of the measured values of ps_3 and ps_4 , except as noted in [5.2.2.2](#).
- 3) For each intermediate test point, the absolute value of static pressures at each inlet and outlet (ps_1 , ps_2 , ps_3 and ps_4) shall be equal within 10 Pa or 5 %, whichever is greater, of the largest of the measured value of ps_1 , ps_2 , ps_3 or ps_4 , except as noted in [5.2.2.2](#).

b) Only for units tested in a two room setup:

- 1) For all tests the value of static pressure at inlet (ps_1) and inlet (ps_3) shall be ≤ 0 Pa, and (ps_1) and (ps_3) shall be equal within 10 Pa, or 5 %, whichever is greater, of the larger of the measured values of ps_1 or ps_3 .

- 2) The value of static pressure at the outlets (ps_2) and (ps_4) shall be equal, within 10 Pa, or 5 %, whichever is greater, of the larger measured value of ps_2 or ps_4 , except as noted in [5.2.2.2](#).



Key

- 1 P-Q curves
- 2 minimum rated airflows
- 3 maximum rated airflows

NOTE Each of the individual P-Q curves shown here is generated at a different speed control setting. In this example, the ventilator either has just five discrete speed control settings, or has a continuously-variable speed control. See [5.2.2.4](#). For simplification, in this example only the supply air P-Q curves are shown.

Figure 3 — Representative chart of multispeed/variable speed ventilator airflow performance

5.2.2.4 For units with speed controls, additional airflow tests must be performed at the alternate speed settings. If the speed control device setting is infinitely variable, the test as described in [5.2.2.1](#) shall be performed separately at a minimum of five speed control settings, including the highest and lowest speed control setting and a minimum of three additional approximately evenly spaced speed control settings between the highest and lowest settings.

5.2.2.5 If supply and return airflows cannot be measured simultaneously, static pressures at all four stations at the time of measurement of the second airflow must be equal within ± 10 Pa, or 5 % of the larger of the measured static pressures, whichever is greater, to the static pressures at the time of measurement of the first airflow.

5.2.3 Airflow measurement methods for ducted heat recovery and energy recovery ventilators

Airflow measurement methods are given in [Annex A](#).

5.3 Unducted heat recovery ventilators and energy recovery ventilators

5.3.1 Airflows measured

The net supply airflow shall be determined. Input power, in watts, shall be measured and recorded.

5.3.2 Static pressure conditions

The effective/net airflow shall be determined with the static pressures at all inlets and outlets equal within $\pm 2,5$ Pa.

5.3.3 Airflow measurement methods for unducted heat recovery and energy recovery ventilators

Net supply airflow measurement methods are given in [Annex B](#) for the decay method. Alternately, the net supply airflow for unducted ventilators may be measured at points 2 and 3, by the methods given in [Annex A](#) and [Annex C](#), and the Formula in [8.4.1](#) provided that appropriate plenums are constructed around the inlets and outlets as indicated in [Annex G](#). If the ventilator is designed for installation with model-specific exterior termination systems as defined in [3.18](#), that system shall be installed.

6 Tracer gas tests

6.1 General conditions

All heat recovery ventilators and energy recovery ventilators within the scope of this International Standard shall have the unit exhaust air transfer rate and the net supply airflow rate or net supply airflow volume determined in accordance with the provisions of this clause of this International Standard.

Tracer gas tests at other airflows and static pressure regimes may also be performed.

6.2 Temperature conditions

During tracer gas tests the laboratory ambient conditions shall be 20 ± 15 °C and 30 to 95 % RH.

6.3 Preconditions

Airstreams shall be held at lab ambient temperature and humidity conditions and must remain stable for the duration of the tracer gas test. Test(s) shall be performed until tracer gas levels have stabilized.

6.4 Airflow conditions

Tracer gas testing shall be performed at the same static pressures, and at the same speed control setting used for the thermal performance measurement as required by sections [5.2.2.2](#), [5.2.2.3](#) and [5.2.2.4](#) in accordance with the setup type (ducted or two-room) chosen for the tracer gas testing.

6.5 Unit operating voltage and frequency

The power supply voltage at the operating unit shall be within ± 2 % of the rated voltage. The power supply frequency at the operating unit shall be within ± 1 % of the rated frequency.

6.6 Tracer gas measurement methods

Tracer gas measurement methods are given in [Annex B](#) or [Annex C](#).

7 Determination of efficiency

7.1 General conditions

All equipment within the scope of this International Standard shall have the gross effectiveness, the coefficient of energy and the effective work determined in accordance with the provisions of this International Standard and rated at one or more of the heating and/or cooling conditions specified in [Table 1](#) and/or [Table 2](#).

7.2 Temperature and humidity conditions: inlets to ventilator

Tests at cooling conditions shall be carried out under the conditions given in one or more of the columns T1 through T4 in [Table 1](#). Tests at heating conditions shall be carried out under the conditions given in one or more of the columns T5 through T7 in [Table 2](#).

Table 1 — Conditions of test for coefficient of energy and effective work test (cooling)

| Parameter | | Standard test conditions | | | |
|---------------------------------|----------|--------------------------|----|----|----|
| | | T1 | T2 | T3 | T4 |
| Temperature of outside air (°C) | dry-bulb | 35 | | | |
| | wet-bulb | 23 | 24 | 31 | 24 |
| Temperature of return air (°C) | dry-bulb | 21 | 24 | 27 | 27 |
| | wet-bulb | 15 | 17 | 20 | 19 |

Note: Allowable variation of readings are given in [Table E.2](#).

Table 2 — Conditions of test for coefficient of energy and effective work test (heating)

| Parameter | | Standard test conditions | | |
|---------------------------------|----------|--------------------------|----|----|
| | | T5 | T6 | T7 |
| Temperature of outside air (°C) | dry-bulb | 2 | 5 | 7 |
| | wet-bulb | 1 | 3 | 6 |
| Temperature of return air (°C) | dry-bulb | 21 | 20 | 20 |
| | wet-bulb | 14 | 15 | 12 |

Note: Allowable variation of readings are given in [Table E.2](#).

7.3 Preconditions

The test room reconditioning apparatus and the equipment under test shall be operated until equilibrium conditions are attained, satisfying the tolerances given in [Table E.2](#) over 30 continuous minutes. Capacity test data are taken during the last 15 min of this stability period.

7.4 Airflow conditions

7.4.1 Required rating point

Thermal performance measurements shall be performed at least at one rating point, maximum rated airflow at maximum fan speed.

7.4.2 Alternate rating points

Thermal performance measurements shall be performed with the supply airflow and return airflow volumes equal, within 0,0006 m³/s plus 1 %, of the airflows measured during the airflow test. Alternately, if the thermal performance measurement equipment does not include airflow measurement devices,

thermal performance measurements shall be performed with the inlet and outlet static pressures within 5 Pa or 2 %, whichever is greater, of those measured during the airflow test at the applicable rating point, and with the speed control at the same setting.

7.5 Static pressure conditions: ducted heat and energy recovery ventilators

Thermal performance measurements shall be performed with the static pressures at inlets and outlets controlled as required by sections [5.2.2.2](#), [5.2.2.3](#) and [5.2.2.4](#) in accordance with the setup type (ducted or two-room) chosen for the thermal performance measurements.

7.6 Static pressure conditions: unducted heat and energy recovery ventilators

The thermal performance measurements shall be performed with the static pressures at all inlets and outlets equal within $\pm 2,5$ Pa.

7.7 Unit operating voltage and frequency

The power supply voltage at the operating unit shall be within ± 2 % of the rated voltage. The power supply frequency at the operating unit shall be within ± 1 % of the rated frequency.

7.8 Thermal performance measurement

Thermal performance measurement methods are given in [Annex D](#).

8 Performance calculations

8.1 Performance calculations: ducted ventilators

Performance calculations for ducted ventilators are calculated based upon the average measured values taken during the testing period and shall include:

- a) Unit exhaust air transfer ratio (UEATR) (See [8.3](#) and [Annex C](#))
- b) Net supply airflow (See [8.4.1](#) and [Annex A](#))
- c) Gross effectiveness (See [8.5](#) and [Annex D](#))
- d) Coefficient of energy (See [8.6.1](#) and [Annex D](#))
- e) Effective work (see [8.7.1](#) and [Annex D](#))

8.2 Performance calculations: unducted ventilators

Performance calculations for unducted ventilators are calculated based upon the average measured values taken during the testing period and shall include:

- a) Net supply airflow (see [8.4.2](#) and [Annex B](#))
- b) Gross effectiveness (See [8.5](#) and [Annex D](#))
- c) Coefficient of energy (See [8.6.2](#) and [Annex D](#))
- d) Effective work (See [8.7.2](#) and [Annex D](#))

8.3 Unit Exhaust Air Transfer Ratio (UEATR)

$$UEATR = \frac{C_{SA} - C_{OA}}{C_{RA} - C_{OA}} \times 100$$

where

- UEATR is the unit exhaust air transfer ratio (%);
- C_{SA} is the tracer gas concentration at supply air outlet (station 2);
- C_{OA} is the tracer gas concentration at outdoor air inlet (station 1);
- C_{RA} is the tracer gas concentration at return air inlet (station 3).

8.4 Net supply airflow

8.4.1 Net supply airflow: ducted units

Net supply airflow for ducted units shall be calculated as follows:

$$Q_{SANet} = \frac{NSAR}{100} \times Q_{SA}$$

where

- Q_{SANet} is the net supply airflow (m³/s);
- Q_{SA} is the supply airflow (m³/s);
- NSAR is the net supply airflow ratio (%).

where

$$NSAR = 100 - UEATR$$

and UEATR is the unit exhaust air transfer ratio (%).

8.4.2 Net supply airflow: unducted units

Net supply airflow for unducted units as defined in [Annex B](#) shall be calculated as follows:

$$Q_{SANet} = Q_1 - Q_2$$

$$Q_i = \frac{V}{t} \ln \frac{(C_i - C_o)}{(C_t - C_o)}$$

where, when corrected to standard temperature and density:

- Q_{SAnet} is the net supply airflow (m^3/s);
- Q_1 is the average of the three calculated overall airflow rates with the unit under test in operation as described in [B.2.1.1](#) and [B.2.1.2](#) (m^3/s);
- Q_2 is the average of the three calculated natural airflow rates of the test chamber with the ventilator removed as described in [B.2.2.1](#) and [B.2.2.2](#) (m^3/s);
- Q_i is the airflow rate calculated using the data from a test 'i' as described in [B.2.1.1](#), [B.2.1.2](#), [B.2.2.1](#) and [B.2.2.2](#) (m^3/s);
- V is the air volume in the test chamber (m^3);
- t is the length of time elapsed since the start of test unit operation (s);
- C_i is the initial tracer gas concentration in the test chamber (average of all measurement points)
- C_o is the tracer gas concentration in outdoor air (OA);
- C_t is the tracer gas concentration in the test chamber after t seconds (average of all measurement points).

8.5 Gross effectiveness

The gross sensible, latent or total effectiveness of a HRV or ERV at test conditions is described by the following equation:

$$\varepsilon = \frac{(x_1 - x_2)}{(x_1 - x_3)}$$

where x equals one of the following for the test condition under consideration:

- x is the dry-bulb temperature (for sensible effectiveness), $^{\circ}\text{C}$; or
- x is the absolute humidity ratio (for latent effectiveness), $\text{kg water}/\text{kg dry air}$; or
- x is the total enthalpy (for total effectiveness), J/kg .

8.6 Coefficient of energy (COE)

8.6.1 Coefficient of energy: ducted ventilators

The coefficient of energy (COE) of a ducted ventilator is described by the following equation:

$$\text{COE}_{\text{ducted}} = \frac{(|qm_{2,\text{net}}(h_2 - h_1)| \times 1000) + P_{\text{vma}}}{(P_{\text{in}})}$$

where

h_1 is the enthalpy of the air at station 1 (kJ/kg of dry air);

h_2 is the enthalpy of the air at station 2 (kJ/kg of dry air);

$qm_{2,\text{net}}$ is the net supply mass flow rate at station 2 (kg/s);

P_{vma} is the power value of moving air (J/s);

P_{in} is the input power to ventilator (W).

and

$$qm_{2,\text{net}} = qm_2 \left(1 - \frac{\text{UEATR}}{100} \right)$$

and

$$P_{\text{vma}} = \left(\sum_{n=1}^4 |ps_n + pv_n| \right) 2qm_{2,\text{net}}v_s$$

where

v_s is the specific volume of the supply air (m³/kg);

ps_n is the external static pressures at the inlet(s) and outlet(s) (Pa);

pv_n is the dynamic pressure at the inlet(s) and outlet(s) (Pa).

and

$$P_{\text{in}} = P_{\text{em}} + P_{\text{aux}}$$

where

P_{em} is the input power to all electric motors in the ventilator (W);

P_{aux} is the input power to any other electrical components in the ventilator (W).

8.6.2 Coefficient of energy: unducted ventilators

The coefficient of energy (COE) of an unducted ventilator is described by the following equation

$$\text{COE}_{\text{unducted}} = \frac{|qm_{2,\text{net}}(h_2 - h_1)| \times 1000}{(P_{\text{in}})}$$

where

h_1 is the enthalpy of the air at station 1 (kJ/kg of dry air);

h_2 is the enthalpy of the air at station 2 (kJ/kg of dry air);

$qm_{2,\text{net}}$ is the net supply mass flow rate (kg/s);

P_{in} is the input power to ventilator (W).

and

$$qm_{2,\text{net}} = qm_2 \left(1 - \frac{\text{UEATR}}{100} \right)$$

and

$$P_{\text{in}} = P_{\text{em}} + P_{\text{aux}}$$

where

P_{em} is the input power to all electric motors in the ventilator (W);

P_{aux} is the input power to any other electrical components in the ventilator (W).

8.7 Effective work (EW)

8.7.1 Effective work: ducted ventilators

The effective work (EW) of a ducted ventilator is described by the following equation:

$$\text{EW} = P_{\text{in}} \times (\text{COE}_{\text{ducted}} - 1) = (|qm_{2,\text{net}}(h_2 - h_1)| \times 1000) + P_{\text{vma}} - P_{\text{in}}$$

8.7.2 Effective work: unducted ventilators

The effective work (EW) of an unducted ventilator is described by the following equation:

$$\text{EW}_{\text{unducted}} = P_{\text{in}} \times (\text{COE}_{\text{unducted}} - 1) = (|qm_{2,\text{net}}(h_2 - h_1)| \times 1000) - P_{\text{in}}$$

8.7.3 When moisture transfer is not of interest or does not occur: the following substitution can be made in either COE or EW:

$$|h_2 - h_1| = C_p |T_2 - T_1|$$

or

$$|h_2 - h_1| = |C_{p2} \cdot T_2 - C_{p1} \cdot T_1|$$

where

- C_p is the specific heat at supply airflow (kJ/kg K);
- T_1 is the temperature of the outdoor airflow at station 1 (K);
- T_2 is the temperature of the supply airflow at station 2 (K).

9 Test results

All measurements made under this standard need to be reported together in order to accurately characterize ventilator performance. Sample data collection and reporting worksheets are provided in informative [Annex E](#).

STANDARDSISO.COM : Click to view the full PDF of ISO 16494:2014

Annex A (normative)

Airflow measurement method for both ducted and unducted ventilators


A.1 Test equipment

A.1.1 Unit shall be equipped with ductwork, airflow measurement devices, and pressure balancing means as shown in [Figure A.1](#).

A.1.2 Static pressure controllers shall be provided as necessary to balance the static pressures at the inlets and outlets as prescribed. Static pressure controllers may include dampers and or speed-controllable blowers. The static pressure controllers must be air tight if they are located between the ventilator and the airflow measuring apparatus.

A.1.3 Static pressure measurement devices shall be located so as to accurately characterize the static pressures at the inlets and outlets of the ventilator. Appropriate measurement devices are further defined in ISO 3966, ISO 5167-1, and ISO 5801.

A.1.4 The airflow shall be measured according to ISO 3966, ISO 5167-1, ISO 5221 and ISO 5801 shall be expressed in standard m^3/s .



Key

- 1 outdoor airflow
- 2 supply airflow
- 3 return airflow
- 4 exhaust airflow
- 5 ventilator
- 6 static pressure control apparatus

- 7 static pressure measuring apparatus
- 8 airflow measuring apparatus

NOTE Simultaneous measurement of supply and return airflow is preferred; however, at least one airflow measuring apparatus must be in use as per [5.2.2.5](#).

Figure A.1 — Arrangement for airflow measurement

[Figure A.1](#) shows the basic measurement principle.

STANDARDSISO.COM : Click to view the full PDF of ISO 16494:2014

Annex B (normative)

Decay method for measurement of net supply airflow


B.1 Measurement equipment

B.1.1 Tracer gas, sampling equipment, room volume and gas concentration levels shall be selected so as to be capable of accurately measuring the unit performance.

B.1.2 Three sampling pipes shall be installed inside the test chamber, in three vertical positions around the centre of the chamber.

B.1.3 The inner wall material of the test chamber shall not be gas permeable or gas absorbent.

B.1.4 The air tightness of the test chamber shall be 0,3 or less natural air change per hour.



Key

- 1 outdoor airflow (OA) (entering)
- 2 supply airflow (SA) (leaving)
- 3 return air (RA) (entering)
- 4 exhaust air (EA) (leaving)
- 5 ventilator
- 6 test chamber
- 7 indoor side
- 8 outdoor side
- 9 indoor sampling pipes
- 10 outdoor sampling pipes

Figure B.1 — Basic measurement principle for sample measurement equipment setup (decay method) for net supply airflow measurement of unducted units

B.2 Measurement procedure

Tracer gas concentration measurement shall be as follows:

B.2.1 Determination of overall room air change rate with ventilator in operation: Install the ventilator, complete with all model-specific exterior termination systems and/or grilles, as shown in [Figure B.1](#).

B.2.1.1 Measurement of initial concentration of tracer gas: Fill the test chamber with the tracer gas, and verify that the concentration level is uniform throughout the chamber by measuring the concentration in at least three locations. The ventilator shall not be operating. The tracer gas concentration shall be such that tracer gas will be measurable after 30 min of operation of the unit under test.

B.2.1.2 Measurement of concentrations of tracer gas during the test: The ventilator shall be started at time zero. Measure and record the concentration of tracer gas at time zero, 10 min, 20 min and 30 min after the start of the test.

B.2.1.3 The test as described in [B.2.1.1](#) and [B.2.1.2](#) shall be performed three times.

B.2.2 Determination of natural air change rate with ventilator not in operation. Remove the test unit, and seal the unit installation opening.

B.2.2.1 Measurement of initial concentration of tracer gas: Fill the test chamber with the tracer gas, and verify that the concentration level is uniform throughout the chamber by measuring the concentration in at least three locations. The tracer gas concentration shall be such that tracer gas will be measurable after 30 min of natural ventilation of the chamber.

B.2.2.2 Measurement of concentrations of tracer gas during the test: Measure and record the concentration of tracer gas at time zero, 10 min, 20 min and 30 min after the start of the test.

B.2.2.3 The test as described in [B.2.2.1](#) and [B.2.2.2](#) shall be performed three times.

Annex C (normative)

Unit exhaust air transfer ratio measurement methods

C.1 Test equipment

Unit shall be equipped with ductwork, and static pressure controllers. Tracer gas, sampling equipment, room volume and gas concentration levels shall be selected so as to be capable of accurately measuring the unit internal and external leakages.

All test equipment arrangements can be divided into two categories: ducted test facilities and two-room test facilities.

C.1.1 The tracer gas generation equipment shall be designed to provide a stable concentration of tracer gas that is uniform in the chamber or duct to which the tracer gas is introduced.

C.1.2 Measurement equipment shall be provided at each location where tracer gas concentration must be measured such that:

1. tracer gas concentration readings are taken at a minimum of three representative locations or
2. by a means of collecting and transporting air samples from these multiple locations to the analyser (i.e. a sampling grid).

This equipment shall meet the following requirements (mixing devices may be necessary to meet these requirements):

- a) a gas chromatograph analyser or an alternative instrument with the accuracy required by [Annex F](#); if the analyser will be sequentially measuring the tracer gas concentration in samples from more than one of the stations, then either the data or the sample from the beginning of each sample measurement period should be purged until the concentration readings have stabilized;
- b) a means of injecting a tracer gas that is nontoxic, identifiable, measureable and inert. Common tracer gases include, but are not limited to SF₆ and CO₂; and
- c) the tracer gas concentrations at each sample point shall be within $\pm 5\%$ of the mean when taken simultaneously or within $\pm 2\%$ of the mean if taken at different times.

C.1.3 Ducts and other components of the test equipment shall not be permeable to or absorbent of the tracer gas.

C.1.4 Ducts and other components of the test equipment shall not allow air leakage.

C.1.5 Static pressures shall be measured according to ISO 3966, ISO 5167-1, and ISO 5801.

C.2 General procedures

C.2.1 Extreme care shall be taken to ensure that dilution does not occur in the sampling system.

C.2.2 The injection concentration of the tracer gas shall be sufficient that a unit exhaust air transfer ratio of 0,25 % can be measured by the device being used.

C.3 Procedure for ventilators intended for installation in a conditioned space


These tests determine the total amount of leakage inside the unit from the return air (x_3) to the fresh air (x_2) and from the surrounding room to the fresh air (x_2).

C.3.1 Testing by injection of tracer gas into outside air (OA)

C.3.1.1 A tracer gas shall be injected into a turbulent region upstream of Station 1 (see [Figure C.1](#)).

C.3.1.2 Air samples shall be drawn from Stations 1, 2 and 3 to determine the concentration of the tracer gas.

C.3.1.3 Unit exhaust air transfer ratio shall be determined.



Key

- | | |
|---------------------------------------|-------------------------------|
| 1 outdoor airflow | 9 tracer gas sampler |
| 2 supply airflow | 10 tracer gas source |
| 3 return airflow | 11 air mixer |
| 4 exhaust airflow | 12 air conditioning apparatus |
| 5 ventilator | 13 make up air inlet |
| 6 static pressure control apparatus | 14 supply air outlet |
| 7 static pressure measuring apparatus | 15 test facility |
| 8 airflow measuring apparatus | |


Figure C.1 — Basic measurement principle schematic for ducted UEATR measurement system for ventilators intended for installation in a conditioned space

C.3.2 Testing by tracer gas injected into indoor chamber

C.3.2.1 A tracer gas shall be injected into the inside room (see [Figure C.2](#)).

C.3.2.2 Air samples shall be drawn from Stations 1, 2 and 3 to determine the concentration of the tracer gas.

C.3.2.3 Unit exhaust air transfer ratio (UEATR) shall be determined.



Key

- | | |
|---------------------------------------|-------------------------------|
| 1 outdoor airflow | 9 tracer gas sampler |
| 2 supply airflow | 10 tracer gas source |
| 3 return airflow | 11 air mixer |
| 4 exhaust airflow | 12 air conditioning apparatus |
| 5 ventilator | 13 make up air inlet |
| 6 static pressure control apparatus | 14 supply air outlet |
| 7 static pressure measuring apparatus | 15 "indoor" test facility |
| 8 airflow measuring apparatus | 16 "outdoor" test facility |

Figure C.2 — Basic measurement principle schematic for two-room UEATR measurement system for ventilators intended for installation in a conditioned space, with tracer gas introduced into "Indoor" chamber


C.4 Procedure for ventilators intended for installation in outdoors space

This test determines the amount of leakage inside the unit from the return air to the fresh air.

C.4.1 A tracer gas shall be injected a turbulent region upstream of Station 3 or into the inside room.

C.4.2 Air samples shall be drawn from Stations 1, 2, and 3 to determine the concentration of the tracer gas (see [Figure C.3](#)).

C.4.3 Unit exhaust air transfer ratio shall be determined.



Key

- | | |
|---------------------------------------|-------------------------------|
| 1 outdoor airflow | 9 tracer gas sampler |
| 2 supply airflow | 10 tracer gas source |
| 3 return airflow | 11 air mixer |
| 4 exhaust airflow | 12 air conditioning apparatus |
| 5 ventilator | 13 make up air inlet |
| 6 static pressure control apparatus | 14 supply air outlet |
| 7 static pressure measuring apparatus | 15 test facility |
| 8 airflow measuring apparatus | |

Figure C.3 — Basic measurement principle schematic for ducted UEATR measurement system for ventilators intended for installation outdoors

Annex D (normative)

Thermal performance measurement

D.1 Test equipment

D.1.1 When measuring thermal performance as per [Figure D.1](#), the laboratory ambient conditions shall be 20 ± 10 °C and 30 to 95 % RH. Laboratory ambient temperature during the test shall be recorded and reported.


D.1.2 Unit shall be equipped with ductwork, static pressure measurement devices, and pressure balancing means as shown in schematic [Figures D.1, D.2](#) and [D.3](#). Temperature and humidity at all the measurement stations shall be recorded during the testing period at a rate of not less than once per minute. Once the unit is at steady-state, operation, including preconditioning as per [6.3](#), shall continue until at least 30 measurements have been recorded over a period of at least 15 min. Construction of plenums required to connect these devices to unducted inlets or outlets is described in [D.2](#). Informative [Annex G](#) shows an example of plenum construction.

D.1.3 Static pressures shall be measured according to ISO 3966, ISO 5167-1, and ISO 5801.

D.1.4 Airflow shall be measured according to ISO 3966, ISO 5167-1, and ISO 5801 and shall be expressed in standard m³/s.

D.1.5 Ducts connected to ventilator inlets and outlets shall be of the dimensions specified by the manufacturer.

D.1.6 The ducts shall be thermally insulated to minimize heat leakage between the equipment inlet or outlet and the temperature measuring instruments, so that the test results are not changed by the effects of surrounding temperatures.




Key

- | | |
|-------------------------------------|--------------------------------------------------|
| 1 outdoor airflow | 9 air mixer |
| 2 supply airflow | 10 air conditioning apparatus |
| 3 return airflow | 11 relief inlet/outlet |
| 4 exhaust airflow | 12 temperature and humidity measuring instrument |
| 5 ventilator | 15 test facility |
| 6 static pressure control apparatus | |

- 7 static pressure measuring apparatus
- 8 airflow measuring apparatus

NOTE Airflow measurement devices are optional. Temperature and humidity measurement and mixing station at EA are optional.

Figure D.1 — Basic measurement principle schematic for ducted thermal performance measurement setup




Key

- | | |
|---------------------------------------|--------------------------------------------------|
| 1 outdoor airflow | 8 airflow measuring apparatus |
| 2 supply airflow | 9 air mixer |
| 3 return airflow | 10 air conditioning apparatus |
| 4 exhaust airflow | 11 temperature and humidity measuring instrument |
| 5 ventilator | 12 "outdoor" test facility |
| 6 static pressure control apparatus | 13 "indoor" test facility |
| 7 static pressure measuring apparatus | |

NOTE Airflow measurement devices (not shown) are optional. Mixing station and temperature and humidity measurement at EA are optional.

Figure D.2 — Basic measurement principle schematic for two-room thermal performance measurement for ventilators intended for installation in a conditioned space



Key

- | | |
|---------------------------------------|--------------------------------------------------|
| 1 outdoor airflow | 8 airflow measuring apparatus |
| 2 supply airflow | 9 air mixer |
| 3 return airflow | 10 air conditioning apparatus |
| 4 exhaust airflow | 11 temperature and humidity measuring instrument |
| 5 ventilator | 12 "outdoor" test facility |
| 6 static pressure control apparatus | 13 "indoor" test facility |
| 7 static pressure measuring apparatus | |

NOTE Airflow measurement devices are optional. Mixing station and temperature and humidity measurement at EA are optional.

Figure D.3 — Basic measurement principle schematic for two-room thermal performance measurement for ventilators intended for installation outside

D.2 Test performance

D.2.1 Verify that the difference between the highest and the lowest temperatures inside the duct at the temperature measurement location will not be more than 0,3K. Provide a mixing device upstream of the temperature measurement location if necessary to meet this requirement.

Annex E (informative)

Example data collection and reporting sheets

DATA TO BE COLLECTED AND CALCULATED RESULTS FOR AIRFLOW MEASUREMENT per [Annex A](#)

| | | AIRFLOW PERFORMANCE: DATA COLLECTED <small>NOTE 1</small> | | | | | Units |
|-----------------------------------------------------------------|-----------------------------|-----------------------------------------------------------|---------|---------|---------|------------------|-------|
| | | Point 1 (Max) | Point 2 | Point 3 | Point 4 | Point 5 (Min) | |
| Temperature (Dry bulb) <small>NOTE 2</small> | T_2 <small>NOTE 3</small> | | | | | | (°C) |
| | T_3 | | | | | | (°C) |
| Temperature (Wet bulb) | TW_2 | | | | | | (°C) |
| | TW_3 | | | | | | (°C) |
| Barometric pressure, Lab Ambient | P_{bar} | | | | | | (kPa) |
| Static Pressures <small>NOTE 4</small> | ps_1 | | | | | | (Pa) |
| | ps_2 | | | | | | (Pa) |
| | ps_3 | | | | | | (Pa) |
| | ps_4 | | | | | | (Pa) |
| Delta P at Nozzles, or Velocity Pressures <small>NOTE 5</small> | ΔP_2 | | | | | | (Pa) |
| | ΔP_3 | | | | | | (Pa) |
| Static Pressures Before Nozzles <small>NOTE 5</small> | psN_2 | | | | | | (Pa) |
| | psN_3 | | | | | | (Pa) |
| Input Voltage <small>NOTE 6</small> | V | | | | | | (V) |
| Input Power | W | | | | | | (W) |
| Input Current | A | | | | | | (A) |
| Input Frequency <small>NOTE 6</small> | f | | | | | | (Hz) |
| Speed Control Setting <small>NOTE 7</small> | | | | | | | () |

NOTE 1 Point 1 is the Maximum Rated Airflow. Point 5 is the Minimum Rated Airflow. If the unit has multiple Speed Control Settings, the Airflow Performance Test is repeated to characterize unit airflow at the different Speed Control Settings.

NOTE 2 Psychrometric conditions are measured in order to determine mass flow rates and equivalent volumetric flow rates at standard density.

NOTE 3 Subscripts indicate station(s) at which measurements are taken.

NOTE 4 Measured relative to lab atmospheric pressure. Static pressures are to be controlled within specific tolerances.

NOTE 5 Depending on the method of airflow measurement, other data might need to be collected.

NOTE 6 To be controlled within tolerances.

NOTE 7 Speed is not measured. Control Setting (if any) is recorded.

| | | AIRFLOW PERFORMANCE: CALCULATED RESULTS NOTE 8 | | | | | Units |
|-------------------------------|--------------|------------------------------------------------|---------|---------|---------|---------------|---------------------|
| | | Point 1 (Max) | Point 2 | Point 3 | Point 4 | Point 5 (Min) | |
| Supply Airflow | Q_{SA} | | | | | | (m ³ /s) |
| Return Airflow | Q_3 | | | | | | (m ³ /s) |
| Static Pressure Differentials | $ps_{ 2-1 }$ | | | | | | (Pa) |
| | $ps_{ 4-3 }$ | | | | | | (Pa) |

NOTE 8 Point 1 is the Maximum Rated Airflow. Point 5 is the Minimum Rated Airflow

DATA TO BE COLLECTED AND CALCULATED RESULTS FOR NET SUPPLY AIRFLOW MEASUREMENT BY DECAY METHOD per Annex B

| | | DATA COLLECTED WITH VENTILATOR RUNNING NOTE 9 | | | Units |
|-------------------------------------------------------------|----------------|-----------------------------------------------|--------|--------|-------|
| | | Test 1 NOTE 10 | Test 2 | Test 3 | |
| Ambient Temperature (Dry bulb) NOTE 11 | T_a | | | | (°C) |
| Ambient Temperature (Wet bulb) | TW_a | | | | (°C) |
| Barometric pressure, Lab Ambient | $P_{bar,a}$ | | | | (kPa) |
| Barometric pressure, Chamber | $P_{bar,c}$ | | | | (kPa) |
| Tracer Gas Concentration in Chamber " $C_i @ t_n$ " NOTE 12 | $C_i @ t_0$ | | | | (ppm) |
| | $C_i @ t_{10}$ | | | | (ppm) |
| | $C_i @ t_{20}$ | | | | (ppm) |
| | $C_i @ t_{30}$ | | | | (ppm) |
| Tracer Gas Concentration in Outdoor Air " $C_o @ t_n$ " | $C_o @ t_0$ | | | | (ppm) |
| | $C_o @ t_{10}$ | | | | (ppm) |
| | $C_o @ t_{20}$ | | | | (ppm) |
| | $C_o @ t_{30}$ | | | | (ppm) |
| Input Voltage NOTE 13 | V | | | | (V) |
| Input Power | W | | | | (W) |
| Input Current | A | | | | (A) |
| Input Frequency NOTE 13 | f | | | | (Hz) |
| Speed Control Setting NOTE 14 | - | | | | () |

NOTE 9 If the unit has multiple Speed Control Settings, the Airflow Performance Test is repeated to characterize unit airflow at the different Speed Control Settings.

NOTE 10 For any one Speed Control Setting, the Test Procedure is repeated three times.

NOTE 11 Psychrometric conditions are measured in order to determine mass flow rates and equivalent volumetric flow rates at standard density.

NOTE 12 Subscript n indicates the time in minutes after beginning the test at which the measurement is taken.

Note 13 To be controlled within tolerances.

Note 14 Speed is not measured. Control Setting (if any) is recorded.

| | | DATA COLLECTED WITH VENTILATOR REMOVED | | | |
|-------------------------------------------------------------|----------------|----------------------------------------|--------|--------|-------------------|
| | | Test 1 NOTE 15 | Test 2 | Test 3 | Units |
| Ambient Temperature (Dry bulb) NOTE 16 | T_a | | | | (°C) |
| Ambient Temperature (Wet bulb) | $T_{W,a}$ | | | | (°C) |
| Barometric pressure, Lab Ambient | $P_{bar,a}$ | | | | (kPa) |
| Barometric pressure, Chamber | $P_{bar,c}$ | | | | (kPa) |
| Tracer Gas Concentration in Chamber " $C_i @ t_n$ " NOTE 17 | $C_i @ t_0$ | | | | (ppm) |
| | $C_i @ t_{10}$ | | | | (ppm) |
| | $C_i @ t_{20}$ | | | | (ppm) |
| | $C_i @ t_{30}$ | | | | (ppm) |
| Tracer Gas Concentration in Outdoor Air " $C_o @ t_n$ " | $C_o @ t_0$ | | | | (ppm) |
| | $C_o @ t_{10}$ | | | | (ppm) |
| | $C_o @ t_{20}$ | | | | (ppm) |
| | $C_o @ t_{30}$ | | | | (ppm) |
| Chamber Volume | V | | | | (m ³) |

NOTE 15 With the ventilator removed, the Test Procedure is repeated three times.

NOTE 16 Psychrometric conditions are measured in order to determine mass flow rates and equivalent volumetric flow rates at standard density.

NOTE 17 Subscript n indicates the time in minutes after beginning the test at which the measurement is taken.

| | | NET SUPPLY AIRFLOW: CALCULATED RESULTS | | | | | |
|----------------------------|-------------|----------------------------------------|---------|---------|---------|---------------|---------------------|
| | | Point 1 (Max) | Point 2 | Point 3 | Point 4 | Point 5 (Min) | Units |
| Net Supply Airflow NOTE 18 | Q_{SAnet} | | | | | | (m ³ /s) |

Note 18 Calculated per [8.4.2](#).

DATA TO BE COLLECTED AND CALCULATED RESULTS FOR UEATR MEASUREMENT per Annex C

| | | TRACER GAS TEST: DATA COLLECTED NOTE 19 | | | | | |
|---------------------------------------------------|---------------------|-----------------------------------------|--------|--------|--------|--------|-------|
| | | Test 1 | Test 2 | Test 3 | Test 4 | Test 5 | Units |
| Static Pressures NOTE 20 | p_{s1} NOTE 21 | | | | | | (Pa) |
| | p_{s2} | | | | | | (Pa) |
| | p_{s3} | | | | | | (Pa) |
| | p_{s4} | | | | | | (Pa) |
| Tracer Gas Concentration NOTE 22 | C_{in} | | | | | | (ppm) |
| | C_{out} | | | | | | (ppm) |
| | C_{back} | | | | | | (ppm) |
| Barometric pressure, Lab Ambient, average NOTE 23 | $P_{bar,AVE}$ | | | | | | (kPa) |
| Barometric pressure, Lab Ambient, maximum NOTE 23 | $P_{bar,MAX}$ | | | | | | (kPa) |
| Temperature, Lab Ambient, average NOTE 23 | T_1 NOTE 20 | | | | | | (°C) |
| Temperature, Lab Ambient, maximum NOTE 23 | T_1 NOTE 20 | | | | | | (°C) |
| Speed Control Setting NOTE 24 | - | | | | | | () |

NOTE 19 The unit must be tested for EATR at each of the same static pressures and speed control settings at which the Thermal Performance tests were performed. Static pressures are to be controlled to within specific tolerances.

NOTE 20 Measured relative to lab atmospheric pressure. Static pressures are to be controlled within specific tolerances.

NOTE 21 Subscripts indicate station(s) at which measurements are taken.

NOTE 22 Locations of C_{in} , C_{out} , and C_{back} depend on intended installation type: indoor, rooftop, or thru-wall.

NOTE 23 Measured and recorded only to confirm stability of conditions during test.

NOTE 24 Speed is not measured. Control Setting (if any) is recorded.

| | | TRACER GAS TEST: CALCULATED RESULTS | | | | | |
|-----------------------------------------|-------|-------------------------------------|--------|--------|--------|--------|-------|
| | | Test 1 | Test 2 | Test 3 | Test 4 | Test 5 | Units |
| Unit Exhaust Air Transfer Ratio NOTE 25 | UEATR | | | | | | (%) |

NOTE 25 Calculated per 8.3.

DATA TO BE COLLECTED AND CALCULATED RESULTS FOR EFFICIENCY MEASUREMENTS per Annex D

| | | THERMAL PERFORMANCE: DATA COLLECTED NOTE 26 | | | | | |
|------------------------|------------------|---------------------------------------------|--------|--------|--------|--------|-------|
| | | Test 1 | Test 2 | Test 3 | Test 4 | Test 5 | Units |
| Temperature (Dry bulb) | T_1 NOTE 27 | | | | | | (°C) |
| | T_2 | | | | | | (°C) |
| | T_3 | | | | | | (°C) |
| Temperature (Wet bulb) | TW_1 | | | | | | (°C) |
| | TW_2 | | | | | | (°C) |
| | TW_3 | | | | | | (°C) |