

---

---

**Accessible design — Shape and colour of a flushing button and a call button, and their arrangement with a paper dispenser installed on the wall in public restroom**

*Conception accessible — Forme et couleur d'un bouton de rinçage et d'un bouton d'appel, et leur combinaison avec un distributeur de papier installé sur le mur de toilettes publiques*

STANDARDSISO.COM : Click to view the full PDF of ISO 19026:2015



STANDARDSISO.COM : Click to view the full PDF of ISO 19026:2015



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
copyright@iso.org  
www.iso.org

# Contents

	Page
Foreword .....	iv
Introduction .....	v
<b>1 Scope .....</b>	<b>1</b>
<b>2 Normative references .....</b>	<b>1</b>
<b>3 Terms and definitions .....</b>	<b>1</b>
<b>4 Figuration of a flushing button and a call button .....</b>	<b>2</b>
<b>5 Colour and contrast of a flushing button and a call button .....</b>	<b>2</b>
5.1 Colours of buttons .....	2
5.2 Contrast between the colours of a flushing button and a call button and the surrounding colours .....	2
<b>6 Arrangement of a flushing button, a call button, and a paper dispenser .....</b>	<b>2</b>

STANDARDSISO.COM : Click to view the full PDF of ISO 19026:2015

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 173, *Assistive products for persons with disability*, Subcommittee SC 7, *Accessible design*.

## Introduction

Regarding public restrooms, products for the facility have been improved and new functions have been added in toilet compartments which make public restrooms more accessible to users. On the other hand, types of operating buttons have been diversified and they are placed in random locations. Also, operating methods have been diversified and the difficulty of discrimination and the use of the buttons have been raised as an issue. As users use toilet compartments alone in most cases unless s/he needs an attendant, it is impossible to ask someone the whereabouts of a flushing button and a call button or ask for help. Especially, persons with visual disabilities have difficulty to find a flushing button and a call button when the arrangement of these buttons differs with places. This problem is not limited only to persons with disabilities, but also to older persons. This International Standard aims to solve problems which older persons and persons with disabilities encounter when they use public restrooms.

STANDARDSISO.COM : Click to view the full PDF of ISO 19026:2015

[STANDARDSISO.COM](https://standardsiso.com) : Click to view the full PDF of ISO 19026:2015

# Accessible design — Shape and colour of a flushing button and a call button, and their arrangement with a paper dispenser installed on the wall in public restroom

## 1 Scope

This International Standard specifies shapes and colours of a flushing button and a call button of lavatory which are installed on the wall and their arrangement with a paper dispenser. This International Standard is only applicable in case of installing a flushing button and/or a call button on the wall of seat-type lavatory in public restrooms (general toilet compartments and toilet compartments with various functions) used by an unspecified large number of people, except restrooms with a big paper holder where it is difficult to place a flushing button and a call button above the holder, and Type A toilet with lateral transfer from both sides of ISO 21542.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 21542:2011, *Building construction — Accessibility and usability of the built environment*

## 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

### 3.1

#### **public restroom**

restroom used by an unspecified large number of people, installed in highly public buildings and facilities such as railroad stations, airports, parks, assembly halls, hospitals, department stores, hotels, and offices

### 3.2

#### **general toilet compartment**

compartment set up with seat-type lavatory without special consideration for wheelchair users

### 3.3

#### **toilet compartment with various functions**

large compartment set up with seat-type lavatory with consideration for wheelchair users and babies and/or small children

### 3.4

#### **flushing button**

push-button switch of toilet flushing equipment

### 3.5

#### **call button**

push-button switch for assistance alarm

### 3.6

#### **paper dispenser**

equipment to house toilet paper

## 4 Figuration of a flushing button and a call button

The figuration of a flushing button shall be a round or oval shape. The figuration of a call button shall be easily distinguishable from the flushing button (for example, quadrangle, rectangle, or triangle) by touch. The sizes of a flushing button and a call button shall be easy to push by a finger, as well as a palm or top of a hand.

The height of a button should be stuck out from the surrounding surface so that persons with visual disabilities can recognize the button by the touch.

## 5 Colour and contrast of a flushing button and a call button

The colours of a flushing button and a call button and its contrast with the surrounding colours are defined as follows.

NOTE The surrounding mentioned in this International Standard is the area adjacent to a flushing button and a call button.

### 5.1 Colours of buttons

The colours of a flushing button and a call button shall be different enough to be distinguishable from each other.

NOTE A call button is usually coloured in red because it is used for the purpose of assistance alarm.

### 5.2 Contrast between the colours of a flushing button and a call button and the surrounding colours

The contrast between the colours of a flushing button and a call button and the surrounding colours shall be retained. (See visual contrast in ISO 21542:2011, B.7).

## 6 Arrangement of a flushing button, a call button, and a paper dispenser

Arrangement of a flushing button, a call button, and a paper dispenser is defined as follows:

- a) a flushing button, a call button, and a paper dispenser shall be arranged in a way that most users can operate and users with visual disabilities can recognize easily. Various postures such as sitting and standing shall be taken into consideration;
- b) a flushing button, a call button, and a paper dispenser shall be arranged in a group on either side of the wall;
- c) a flushing button shall be installed on the upper side of a paper dispenser. A call button shall be placed at the same height as a flushing button and placed toward the rear of a toilet seat;
- d) a flushing button, a call button, and a paper dispenser should be established in the position that satisfies the conditions given in [Figure 1](#) and [Table 1](#);
- e) if other pieces of equipment such as a handrail, a remote controller for washing equipment with warm water, and/or a wash basin are installed on the same surface of the wall with a flushing button, a call button, and a paper dispenser, those pieces of equipment shall be arranged in a way that they do not interfere the use and operation of a flushing button, a call button, and a paper dispenser;
- f) even if the dimensions do not conform to [Figure 1](#) and [Table 1](#) due to the figuration of a paper dispenser or the surface condition of the side wall of the compartment, the positional relationship described in c) shall be maintained;
- g) another call button or a pull cord should be placed at the minimum height of 100 mm and towards the front side of the flushing button in places where users can operate it easily even in a fallen posture.