

---

---

**Multilayer piping systems for hot and  
cold water installations inside  
buildings —**

**Part 1:  
General**

*Systèmes de canalisations multicouches pour installations d'eau  
chaude et froide à l'intérieur des bâtiments —*

*Partie 1: Généralités*

STANDARDSISO.COM : Click to view the full PDF of ISO 21003-1:2008



**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

STANDARDSISO.COM : Click to view the full PDF of ISO 21003-1:2008



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2008

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

**Contents**

Page

Foreword.....	iv
Introduction .....	v
1 Scope .....	1
2 Normative references .....	2
3 Terms and definitions.....	3
3.1 Definitions related to construction .....	3
3.2 Definitions related to geometry.....	4
3.3 Definitions related to service conditions .....	4
3.4 Definitions related to materials .....	5
3.5 Definitions related to material characteristics.....	5
3.6 Definitions related to temperature .....	5
4 Symbols and abbreviated terms .....	6
4.1 Symbols .....	6
4.2 Abbreviated terms .....	7
5 Classification of service conditions .....	7
6 Material .....	8
6.1 General.....	8
6.2 Influence on water intended for human consumption.....	8
Annex A (normative) List of reference product standards .....	9
Bibliography .....	10

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 21003-1 was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 2, *Plastics pipes and fittings for water supplies*.

ISO 21003 consists of the following parts, under the general title *Multilayer piping systems for hot and cold water installations inside buildings*:

- *Part 1: General*
- *Part 2: Pipes*
- *Part 3: Fittings*
- *Part 5: Fitness for purpose of the system*
- *Part 7: Guidance for the assessment of conformity* [Technical Specification]

NOTE ISO 21003 does not include a Part 4: *Ancillary equipment*, or a Part 6: *Guidance for installation*.

## Introduction

The system standard of which this is Part 1 specifies the requirements for a multilayer piping system.

The multilayer piping system is intended to be used for hot and cold water installations inside buildings.

In respect of potentially adverse effects on the quality of water intended for human consumption caused by the products covered by ISO 21003:

- no information is provided as to whether the products may be used without restriction in any of the member states of the EU or EFTA;
- it should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of these products remain in force.

Requirements and test methods for components of the piping system are specified in ISO 21003-2 and ISO 21003-3. Characteristics relating to fitness for purpose (mainly for joints) are covered in ISO 21003-5. ISO/TS 21003-7 gives guidance on the assessment of conformity.

This part of ISO 21003 specifies the general aspects of multilayer piping systems.

For ancillary equipment, separate standards can apply.

Guidance on installation of plastics piping systems made from various materials intended to be used for hot and cold water installations is given in ENV 12108.

Other system standards which, at the date of publication of this part of ISO 21003, had been published for plastics piping systems used for the same application are listed in Annex A.

STANDARDSISO.COM : Click to view the full PDF of ISO 21003-1:2008

# Multilayer piping systems for hot and cold water installations inside buildings —

## Part 1: General

### 1 Scope

This part of ISO 21003 specifies the general aspects of multilayer piping systems intended to be used for hot and cold water installations inside buildings for the conveyance of water — whether or not the water is intended for human consumption (domestic systems) or heating systems — under specified design pressures and temperatures appropriate to the class of application (see Table 1).

ISO 21003 is a reference product standard (see 3.4.3). It is applicable to multilayer pipes, fittings, their joints, and also to joints with components made of other plastics and non-plastics materials intended to be used for hot and cold water installations. This part of ISO 21003 is intended for use only in conjunction with all the other parts of ISO 21003.

ISO 21003 applies only to multilayer pipes with their inner layer made of plastics.

It covers a range of service conditions (application classes) and design pressures. It is not applicable for values of design temperature,  $T_D$ , maximum design temperature,  $T_{max}$ , and malfunction temperature,  $T_{mal}$ , in excess of those in Table 1.

NOTE 1 It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into account their particular requirements and any relevant national regulations and installation practices or codes.

The polymeric materials used for the stress-designed layers are the following: polybutylene (PB), polyethylene of raised temperature resistance (PE-RT), crosslinked polyethylene (PE-X), polypropylene (PP) and chlorinated poly(vinyl chloride) (PVC-C).

The PE-X used shall be fully crosslinked and shall comply with the requirements of the relevant reference product standard (ISO 15875).

NOTE 2 For the purposes of ISO 21003, crosslinked polyethylene (PE-X) as well as adhesives are considered as thermoplastic materials.

Solid-wall pipes with thin outer layers (applied as protection layers or barrier layers, for instance) are not covered by ISO 21003 but are specified in the Amendments to ISO 15874-2, ISO 15875-2 and ISO 15876-2. The total thickness of such outer layers, including the thickness of the adhesives used, shall be  $\leq 0,4$  mm.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3, *Preferred numbers — Series of preferred numbers*

ISO 472, *Plastics — Vocabulary*

ISO 1043-1, *Plastics — Symbols and abbreviated terms — Part 1: Basic polymers and their special characteristics*

ISO 15874-1, *Plastics piping systems for hot and cold water installations — Polypropylene (PP) — Part 1: General*

ISO 15874-2, *Plastics piping systems for hot and cold water installations — Polypropylene (PP) — Part 2: Pipes*

ISO 15874-3, *Plastics piping systems for hot and cold water installations — Polypropylene (PP) — Part 3: Fittings*

ISO 15874-5, *Plastics piping systems for hot and cold water installations — Polypropylene (PP) — Part 5: Fitness for purpose of the system*

ISO 15875-1, *Plastics piping systems for hot and cold water installations — Crosslinked polyethylene (PE-X) — Part 1: General*

ISO 15875-2, *Plastics piping systems for hot and cold water installations — Crosslinked polyethylene (PE-X) — Part 2: Pipes*

ISO 15875-3, *Plastics piping systems for hot and cold water installations — Crosslinked polyethylene (PE-X) — Part 3: Fittings*

ISO 15875-5, *Plastics piping systems for hot and cold water installations — Crosslinked polyethylene (PE-X) — Part 5: Fitness for purpose of the system*

ISO 15876-1, *Plastics piping systems for hot and cold water installations — Polybutylene (PB) — Part 1: General*

ISO 15876-2, *Plastics piping systems for hot and cold water installations — Polybutylene (PB) — Part 2: Pipes*

ISO 15876-3, *Plastics piping systems for hot and cold water installations — Polybutylene (PB) — Part 3: Fittings*

ISO 15876-5, *Plastics piping systems for hot and cold water installations — Polybutylene (PB) — Part 5: Fitness for purpose of the system*

ISO 15877-1, *Plastics piping systems for hot and cold water installations — Chlorinated poly(vinyl chloride) (PVC-C) — Part 1: General*

ISO 15877-2, *Plastics piping systems for hot and cold water installations — Chlorinated poly(vinyl chloride) (PVC-C) — Part 2: Pipes*

ISO 15877-3, *Plastics piping systems for hot and cold water installations — Chlorinated poly(vinyl chloride) (PVC-C) — Part 3: Fittings*

ISO 15877-5, *Plastics piping systems for hot and cold water installations — Chlorinated poly(vinyl chloride) (PVC-C) — Part 5: Fitness for purpose of the system*

ISO 21003-2, *Multilayer piping systems for hot and cold water installations inside buildings — Part 2: Pipes*

ISO 21003-3, *Multilayer piping systems for hot and cold water installations inside buildings — Part 3: Fittings*

ISO 21003-5, *Multilayer piping systems for hot and cold water installations inside buildings — Part 5: Fitness for purpose of the system*

ISO/TS 21003-7, *Multilayer piping systems for hot and cold water installations inside buildings — Part 7: Guidance for the assessment of conformity*

ISO 22391-1, *Plastics piping systems for hot and cold water installations — Polyethylene of raised temperature resistance (PE-RT) — Part 1: General*

ISO 22391-2, *Plastics piping systems for hot and cold water installations — Polyethylene of raised temperature resistance (PE-RT) — Part 2: Pipes*

ISO 22391-3, *Plastics piping systems for hot and cold water installations — Polyethylene of raised temperature resistance (PE-RT) — Part 3: Fittings*

ISO 22391-5, *Plastics piping systems for hot and cold water installations — Polyethylene of raised temperature resistance (PE-RT) — Part 5: Fitness for purpose of the system*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 3 and ISO 472, and the following, apply.

#### 3.1 Definitions related to construction

##### 3.1.1

##### **multilayer pipe**

pipe comprised of different stress-designed layers

##### 3.1.2

##### **multilayer M-pipe**

pipe comprised of polymeric stress-designed layers and one or more metallic stress-designed layers (e.g. PE-Xb/Al/PE-Xb or PE-RT/Al/PE-Xb)

NOTE The wall thickness of the pipe consists of at least 60 % of polymeric material.

##### 3.1.3

##### **multilayer P-pipe**

pipe comprised of more than one polymeric stress-designed layer (e.g. PVC-C/PE-Xb or PE-Xb/EVOH/PE-Xb)

NOTE Pipes consisting of one polymeric stress-designed layer and an outer polymeric layer which is not stress-designed are covered by the appropriate reference product standard (see Annex A).

##### 3.1.4

##### **inner layer**

layer in contact with the fluid which is conveyed

##### 3.1.5

##### **outer layer**

layer exposed to the outer environment

**3.1.6**

**embedded layer**

layer between the outer and inner layers

**3.1.7**

**application layer**

layer which provides a specific property linked to the conditions of use of the pipe

**3.2 Definitions related to geometry**

**3.2.1**

**nominal diameter**

$d_n$   
specified outside diameter, in millimetres, assigned to a nominal size (DN/OD or DN/ID)

**3.2.2**

**outside diameter**

$d_e$   
outside diameter measured through the pipe cross-section at any point on the pipe, or the spigot end of a fitting, rounded up to the nearest 0,1 mm

**3.2.3**

**inside diameter**

$d_i$   
inside diameter measured through the pipe cross-section at any point on the pipe, rounded up to the nearest 0,1 mm

**3.2.4**

**wall thickness**

$e$   
measured wall thickness at any point around the circumference of a component, rounded up to the nearest 0,1 mm

**3.2.5**

**minimum wall thickness**

$e_{\min}$   
minimum value of the measured wall thickness at any point around the circumference of a component, rounded up to the nearest 0,1 mm

**3.2.6**

**metal layer standard dimension ratio**

$SDR_m$   
outside diameter of the metal layer of a pipe divided by the wall thickness of the metal layer

**3.2.7**

**polymeric layer standard dimension ratio**

$SDR_p$   
outside diameter of the polymeric layer of a pipe divided by the wall thickness of the polymeric layer

**3.3 Definitions related to service conditions**

**3.3.1**

**overall service (design) coefficient**

$C$   
overall coefficient, with a value greater than one, which takes into consideration service conditions as well as properties of the components of a piping system other than those represented in the lower confidence limit,  $P_{LPL}$

### 3.4 Definitions related to materials

#### 3.4.1

##### **virgin material**

material, in a form such as granules or powder, that has not been subjected to use or processing other than that required for its manufacture and to which no reprocessible or recyclable material has been added

#### 3.4.2

##### **own reprocessible material**

single material prepared from rejected unused pipes and fittings, including trimmings from the production of pipes and fittings, that will be reprocessed in a manufacturer's plant after having been previously processed by the same manufacturer by a method such as moulding or extrusion and for which the complete formulation is known

#### 3.4.3

##### **reference product standard**

International Standard or draft International Standard, prepared by ISO/TC 138/SC 2, applicable to non-multilayer pipes, to which this International Standard can refer for clauses related to the materials, components (e.g. fittings) and fitness for purpose of the system

#### 3.4.4

##### **stress-designed polymeric layer**

polymeric layer which is designed to be stress-bearing

NOTE The material used in such layers is restricted to those in the reference product standards (see Annex A).

### 3.5 Definitions related to material characteristics

#### 3.5.1

##### **application class**

class related to a typical field of application and a design period of 50 years

NOTE The classification is taken from ISO 10508.

#### 3.5.2

##### **design pressure**

$p_D$

highest pressure related to the circumstances for which the system has been designed and is intended to be used

NOTE The design pressure,  $p_D$ , is equal to the maximum design pressure, MDP, as specified in EN 806-1.

#### 3.5.3

##### **long-term pressure strength**

##### **lower confidence limit of the predicted hydrostatic pressure**

$p_{LPL}$

quantity, with the dimensions of pressure, which represents the 97,5 % (one-sided) lower confidence limit of the predicted hydrostatic pressure at a temperature  $T$  and time  $t$

### 3.6 Definitions related to temperature

#### 3.6.1

##### **design temperature**

$T_D$

temperature, or a combination of temperatures, of the conveyed water related to the circumstances for which the system has been designed

#### 3.6.2

##### **maximum design temperature**

$T_{max}$

highest design temperature,  $T_D$ , occurring for short periods only

### 3.6.3

#### malfunction temperature

$T_{\text{mal}}$   
highest temperature that can be reached when the control limits are exceeded

NOTE This may occur during a total of up to 100 h over a period of 50 years.

### 3.6.4

#### cold water

water at a temperature of up to approximately 25 °C

NOTE For design purposes, 20 °C is used.

## 4 Symbols and abbreviated terms

### 4.1 Symbols

$d_i$	inside diameter
$d_e$	outside diameter
$d_n$	nominal diameter
$e_n$	nominal wall thickness
$e_{\text{min}}$	minimum wall thickness
$F_{\text{pull}}$	adhesive strength
$p_C$	calculated value of the pressure (in bars) of the pipe construction corresponding to time to failure/test temperature in accordance with ISO 21003-2
$p_{CD}$	calculated value of the design pressure (in bars) of the pipe construction, determined for the appropriate service condition class from data obtained in accordance with ISO 21003-2
$p_F$	hydrostatic test pressure (in bars) to be applied to the assembly during the test period
$p_D$	design pressure (in bars)
$p_{LPL}$	long-term pressure strength (lower confidence limit of the predicted hydrostatic pressure)
$T$	temperature
$T_D$	design temperature
$T_{\text{mal}}$	malfunction temperature
$T_{\text{max}}$	maximum design temperature
$t$	time
$\sigma$	hydrostatic stress
$\sigma_F$	hydrostatic stress (in megapascals) for the fitting body material, determined for the appropriate service condition class from data obtained in accordance with the reference product standard or ISO 9080
$\sigma_{DF}$	design stress (in megapascals) for the fitting body material, determined for the appropriate service condition class from data obtained in accordance with the reference product standard or ISO 9080

## 4.2 Abbreviated terms

For the purposes of this document, the abbreviated terms given in ISO 1043-1 apply.

## 5 Classification of service conditions

The performance requirements for multilayer piping systems conforming to ISO 21003 are specified for four different application classes as shown in Table 1.

For any application, the selection of the applicable class conforming to Table 1 shall be agreed by the parties concerned. Each application class shall be combined with a design pressure,  $p_D$ , of 4 bar, 6 bar, 8 bar or 10 bar, as applicable (1 bar = 0,1 MPa).

**Table 1 — Classification of service conditions**

Application class	Design temperature $T_D$ °C	Time <sup>b</sup> at $T_D$ years	$T_{max}$ °C	Time at $T_{max}$ years	$T_{mal}$ °C	Time at $T_{mal}$ h	Typical field of application
1 <sup>a</sup>	60	49	80	1	95	100	Hot water supply (60 °C)
2 <sup>a</sup>	70	49	80	1	95	100	Hot water supply (70 °C)
4 <sup>b</sup>	20 plus cumulative	2,5	70	2,5	100	100	Underfloor heating and low-temperature radiators
	40 plus cumulative	20					
	60	25					
5 <sup>b</sup>	20 plus cumulative	14	90	1	100	100	High-temperature radiators
	60 plus cumulative	25					
	80	10					
<sup>a</sup> A country may select either class 1 or class 2 in conformity with its national regulations.							
<sup>b</sup> Where more than one design temperature for time and associated temperature appears for any class, they should be aggregated. "Plus cumulative" in the table implies a temperature profile of the mentioned temperature over time (e.g. the design temperature profile for 50 years for class 5 is 20 °C for 14 years followed by 60 °C for 25 years, 80 °C for 10 years, 90 °C for 1 year and 100 °C for 100 h).							
NOTE For values of $T_D$ , $T_{max}$ and $T_{mal}$ in excess of those in the table, this International Standard does not apply.							

All systems which satisfy the conditions specified in Table 1 shall also be suitable for conveyance of cold water for a period of 50 years at a temperature of 20 °C and a design pressure of 10 bar.

All heating installations shall only use water or treated water as the transfer fluid.

## 6 Material

### 6.1 General

The material characteristics of stress-designed materials shall be evaluated in accordance with the reference product standard.

### 6.2 Influence on water intended for human consumption

All materials of the multilayer piping system, when in contact with water which is intended for human consumption, shall not affect the quality of the drinking water and shall be in compliance with national regulations.

STANDARDSISO.COM : Click to view the full PDF of ISO 21003-1:2008