

---

---

**Cryogenic vessels — Pressure-relief  
accessories for cryogenic service —**

Part 1:  
**Reclosable pressure-relief valves**

*Réipients cryogéniques — Dispositifs de sécurité pour le service  
cryogénique —*

*Partie 1: Soupapes refermables*

STANDARDSISO.COM : Click to view the full PDF of ISO 21013-1:2008



**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

STANDARDSISO.COM : Click to view the full PDF of ISO 21013-1:2008



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2008

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

Foreword.....	iv
<b>1</b> <b>Scope</b> .....	<b>1</b>
<b>2</b> <b>Normative references</b> .....	<b>1</b>
<b>3</b> <b>Terms and definitions</b> .....	<b>2</b>
<b>4</b> <b>Requirements</b> .....	<b>3</b>
<b>4.1</b> <b>General</b> .....	<b>3</b>
<b>4.2</b> <b>Design</b> .....	<b>3</b>
<b>4.2.1</b> <b>Design temperature</b> .....	<b>3</b>
<b>4.2.2</b> <b>Drainage</b> .....	<b>3</b>
<b>4.2.3</b> <b>Stem guiding</b> .....	<b>3</b>
<b>4.2.4</b> <b>Inserts</b> .....	<b>3</b>
<b>4.2.5</b> <b>Sublimating fluids service</b> .....	<b>3</b>
<b>4.2.6</b> <b>Electric continuity</b> .....	<b>3</b>
<b>4.2.7</b> <b>Set pressure</b> .....	<b>3</b>
<b>4.2.8</b> <b>Minimum shell thickness</b> .....	<b>3</b>
<b>4.3</b> <b>Materials</b> .....	<b>4</b>
<b>4.3.1</b> <b>General</b> .....	<b>4</b>
<b>4.3.2</b> <b>Metallic materials</b> .....	<b>4</b>
<b>4.3.3</b> <b>Non-metallic materials</b> .....	<b>4</b>
<b>4.3.4</b> <b>Corrosion resistance</b> .....	<b>4</b>
<b>4.3.5</b> <b>Gas material compability</b> .....	<b>5</b>
<b>4.3.6</b> <b>Acetylene compatibility</b> .....	<b>5</b>
<b>5</b> <b>Qualification and Testing</b> .....	<b>5</b>
<b>5.1</b> <b>Type approval</b> .....	<b>5</b>
<b>5.1.1</b> <b>Verification of the design</b> .....	<b>5</b>
<b>5.1.2</b> <b>Model number</b> .....	<b>5</b>
<b>5.2</b> <b>Type approval tests</b> .....	<b>5</b>
<b>5.2.1</b> <b>Ambient condition tests</b> .....	<b>5</b>
<b>5.2.2</b> <b>Cryogenic tests</b> .....	<b>6</b>
<b>5.2.3</b> <b>Alternate cryogenic tests</b> .....	<b>7</b>
<b>5.3</b> <b>Production testing</b> .....	<b>7</b>
<b>6</b> <b>Determination of the certified coefficient of discharge (<math>K_{dr}</math>)</b> .....	<b>7</b>
<b>7</b> <b>Set pressure tolerances</b> .....	<b>8</b>
<b>8</b> <b>Re-seating pressure</b> .....	<b>8</b>
<b>9</b> <b>Cleanliness</b> .....	<b>8</b>
<b>10</b> <b>Marking</b> .....	<b>8</b>
<b>10.1</b> <b>Marking on the body of the pressure-relief valve</b> .....	<b>8</b>
<b>10.2</b> <b>Marking on an identification plate</b> .....	<b>8</b>
<b>11</b> <b>Sealing</b> .....	<b>9</b>
<b>Bibliography</b> .....	<b>10</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 21013-1 was prepared by Technical Committee ISO/TC 220, *Cryogenic vessels*.

ISO 21013 consists of the following parts, under the general title *Cryogenic vessels — Pressure-relief accessories for cryogenic service*:

- *Part 1: Reclosable pressure-relief valves*
- *Part 2: Non-reclosable pressure-relief devices*
- *Part 3: Sizing and capacity determination*

# Cryogenic vessels — Pressure-relief accessories for cryogenic service —

## Part 1: Reclosable pressure-relief valves

### 1 Scope

This International Standard specifies the requirements for the design, manufacture and testing of pressure relief valves for cryogenic service, i.e. for operation with cryogenic fluids in addition to operation at temperatures from ambient to cryogenic. It is a requirement of this International Standard that the valves comply with ISO 4126-1; in the event of different requirements, this International Standard takes precedence.

This International Standard is restricted to valves not exceeding a size of DN 150 designed to relieve single-phase vapours or gases. A valve may be specified, constructed and tested such that it is suitable for use with more than one gas or with mixtures of gases.

NOTE This part of ISO 21013 does not provide methods for determining the capacity of relief valve(s) for a particular cryogenic vessel. Such methods are provided in ISO 21013-3.

### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4126-1, *Safety devices for protection against excessive pressure — Part 1: Safety valves*

ISO 11114-1, *Transportable gas cylinders — Compatibility of cylinder and valve materials with gas contents — Part 1: Metallic materials*

ISO 11114-2, *Transportable gas cylinders — Compatibility of cylinder and valve materials with gas contents — Part 2: Non-metallic materials*

ISO 15761, *Steel gate, globe and check valves for sizes DN 100 and smaller, for the petroleum and natural gas industries*

ISO 20421-1, *Cryogenic vessels — Large transportable vacuum-insulated vessels — Part 1: Design, fabrication, inspection, and testing*

ISO 21009-1, *Cryogenic vessels — Static vacuum-insulated vessels — Part 1: Design, fabrication, inspection, and tests*

ISO 21010, *Cryogenic vessels — Gas/materials compatibility*

ISO 21028-1, *Cryogenic vessels — Toughness requirements for materials at cryogenic temperature — Part 1: Temperatures below — 80 °C*

ISO 21028-2, *Cryogenic vessels — Toughness requirements for materials at cryogenic temperature — Part 2: Temperatures between –80 °C and –20 °C*

ISO 21029-1, *Cryogenic vessels — Transportable vacuum insulated vessels of not more than 1 000 litres volume — Part 1: Design, fabrication, inspection and tests*

ISO 23208:2005, *Cryogenic vessels — Cleanliness for cryogenic service*

ASME B16.34-2004, *Valves — Flanged, Threaded, and Welding end*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

#### 3.1

##### DN

##### nominal size

alphanumeric designation of size for components of a pipe work system, which is used for reference purposes

NOTE 1 It comprises the letters DN followed by a dimensionless whole number which is indirectly related to the physical size, in millimetres, of the bore or outside diameter of the end connections.

NOTE 2 Adapted from ISO 6708.

#### 3.2

##### pressure

pressure for which the value is equal to the algebraic difference between the absolute pressure and the atmospheric pressure

NOTE This is also known as gauge pressure.

#### 3.3

##### rated minimum temperature

lowest temperature for which the pressure relief valve is rated by the manufacturer

#### 3.4

##### valve category A

relief valve type which passed the test of the repeatability of seat tightness at re-seat for 1 000 cycles

NOTE The procedure for the seat-tightness test is described in 5.2.1.2.

#### 3.5

##### valve category B

relief valve type which passed the test of the repeatability of seat tightness at re-seat for 20 cycles

NOTE The procedure for the seat-tightness test is described in 5.2.1.2.

#### 3.6

##### cryogenic fluid

fluid defined as cryogenic fluid in ISO 21029-1, or ISO 21009-1, or ISO 20421-1

NOTE This includes totally evaporated liquids and supercritical fluids.

#### 3.7

##### rated pressure

##### PR

maximum pressure difference between the inside and outside of any pressure-retaining boundary for which it is designed to be operated at 20 °C

NOTE The PR of the valve is the lowest PR of any component of the valve.

## 4 Requirements

### 4.1 General

The valve shall satisfy all the requirements of ISO 4126-1 except in the event of different requirements, where this part of ISO 21013 takes precedence.

### 4.2 Design

#### 4.2.1 Design temperature

The valve shall be suitable for operation at all temperatures between the rated minimum temperature and +65 °C within the intended pressure range.

#### 4.2.2 Drainage

Unless otherwise specified in the purchase order, the valve shall avoid accumulation of water within it, even when the expected outlet connection is fitted.

#### 4.2.3 Stem guiding

The design of guiding shall avoid malfunction of the valve due to deposition and freezing of atmospheric moisture on and within the valve during normal operation. The valve shall be sufficiently robust such that the effectiveness of the guiding can not be defeated by normal handling.

#### 4.2.4 Inserts

Where a disc soft-insert is used to ensure leak-tight shut off, the design shall be such as to prevent cold flow of the insert to a degree that results in the valve failing to operate correctly.

#### 4.2.5 Sublimating fluids service

Where the valve is specified as suitable for service with products that, when vented at valve operating conditions, condense from gas or vapour directly to solid, e.g. CO<sub>2</sub>, the design shall be such as to avoid the valve failing to operate correctly due to deposition of solid product within the valve body or its outlet.

#### 4.2.6 Electric continuity

For valves in flammable fluids service, the maximum electrical resistance shall not exceed 1 000 Ω with no more than 28 V between the ports in order to ensure electrical continuity to prevent build-up of static electricity.

#### 4.2.7 Set pressure

Set pressure of the valve shall not exceed its PR.

#### 4.2.8 Minimum shell thickness

The minimum shell thickness shall be as specified in ISO 15761 or ASME B16.34 for the pressure rating and size of the valve.

## 4.3 Materials

### 4.3.1 General

Materials shall be in conformance with an internationally recognized standard and be compatible with the fluid. Galling, frictional heating, and galvanic corrosion shall also be considered in the selection of materials. Materials shall also be oxygen compatible if relevant (see 4.3.5.1).

Materials not listed in an internationally recognized standard shall be controlled by the manufacturer of the pressure-relief valve by a specification ensuring control of chemical content and physical properties, and quality at least equivalent to an internationally recognized standard. A test certificate providing the chemical content and physical property test results shall be provided with the pressure-relief valve.

### 4.3.2 Metallic materials

**4.3.2.1** Metallic materials to be used in the construction of cryogenic valves shall meet the requirements of ISO 21028-1 or ISO 21028-2 as appropriate for the rated minimum temperature.

**4.3.2.2** These requirements apply only to the valve parts exposed to low temperatures in normal service. Metallic materials which do not exhibit ductile/brittle transition, and non ferrous materials which can be shown to have no ductile/brittle transition do not require additional impact tests.

**4.3.2.3** Forged, rolled, wrought, and fabricated valve components from raw materials from these processes need not be impact tested if the rated minimum temperature is higher than the ductile/brittle transition range temperatures of the material. Castings meeting the requirements of one of the applicable mandatory Appendices I and IV or II and III for Forgings and Rolled or Wrought Material of ASME B16.34 need not be impact tested if the rated minimum temperature is higher than the ductile/brittle transition range temperatures of the material. At least one randomly selected valve body material (including bonnet, if applicable) from each production-lot castings not meeting the requirements of 4.3.2.3 shall be impact tested at the rated minimum temperature.

### 4.3.3 Non-metallic materials

Non-metallic materials are well established only for use for inserts on the disc or seat to provide leak tightness across the seat when the valve is closed. If such materials are to be used for structural parts, they shall have the properties appropriate to the application and be in conformance with ISO 21028-1 or ISO 21028-2, as appropriate to the rated minimum temperature.

Non-metallic materials shall also:

- have mechanical properties that will allow the valve to pass the type approval test defined in 5.1.3.3;
- be resistant to sunlight, weather and aging;
- be compliant to section 4.3.5.

### 4.3.4 Corrosion resistance

In addition to resistance to normal atmospheric corrosion, particular care must be taken to ensure that the valve can not be rendered inoperative by accumulation of corrosion products. Some copper alloys are susceptible to stress corrosion cracking, consequently careful consideration shall be given before selection of these materials for components under stress.

### 4.3.5 Gas material compability

#### 4.3.5.1 Oxygen compatibility

If the rated minimum temperature is equal to or below the boiling point of air or the valve is intended for service with oxygen or oxidizing products, the materials in contact with liquid air or oxidizing products shall be oxygen compatible in accordance with ISO 21010.

#### 4.3.5.2 Hydrogen

For hydrogen service, the requirements of ISO 11114-1 and ISO 11114-2 apply.

#### 4.3.6 Acetylene compatibility

Metallic materials shall contain less than 70 % copper if specified for use with mixtures containing acetylene.

## 5 Qualification and Testing

### 5.1 Type approval

#### 5.1.1 Verification of the design

A valve from the first production batch of each size and design shall be inspected and tested to ensure that the valve is in compliance with the design documentation and the requirements of this standard. The sample valve shall pass the tests as described in 5.2. The design of the valve shall have complied with the requirements of ISO 4126-1 as applicable.

#### 5.1.2 Model number

A unique model number shall be assigned to the valve which passed the type approval requirements.

### 5.2 Type approval tests

#### 5.2.1 Ambient condition tests

##### 5.2.1.1 Operating and flow characteristics tests

The tests shall be performed in accordance with the requirements of ISO 4126-1. The leak rate shall not exceed  $3 \times 10^{-3} \text{ Cm}^3\text{S}^{-1}$  (standard conditions)  $\times$  DN at 90 % of the set pressure.

##### 5.2.1.2 Test of the repeatability of seat tightness at re-seat

Adjustment or maintenance of the sample relief valves is not permitted during these tests. The relief valves tested in 5.2.1.1 above shall be tested additionally such that each Category A valve is lifted and re-seated a minimum of 1 000 times. The valves shall then be re-tested in accordance with 5.2.1.1 and shall meet the appropriate tolerances and limits and the leak rate shall not exceed  $6 \times 10^{-3} \text{ Cm}^3\text{S}^{-1}$  (standard conditions)  $\times$  DN at 90 % of the set pressure.

For category B valves the number of cycles is reduced to 20.

## 5.2.2 Cryogenic tests

### 5.2.2.1 General

Adjustment or maintenance of the sample relief valves is not permitted during these tests.

### 5.2.2.2 Test set up

Each relief valve tested in 5.2.1.1 and 5.2.1.2 shall be subjected to a cryogenic test. The sample relief valve shall be connected to a reservoir, containing a cryogenic fluid, which may be controlled to achieve and maintain a pressure in excess of set pressure. The reservoir should be fitted with a proven pressure protection system with a set pressure in excess of the sample. The reservoir shall be of a design which ensures that the cryogenic fluid relieved by the sample valve will be at a temperature which does not exceed by more than 30 °C the rated minimum temperature of the relief valve.

The orientation of the valve during the test shall be in accordance with the installation instructions on the manufacturer's data sheet. If the manufacturer specifies more than one acceptable orientation of the valve then the cryogenic testing shall be repeated for each orientation. The valve shall be fitted with any outlet pipe which the manufacturer has specified as necessary for the satisfactory operation of the valve.

If the valve to be tested has such a large capacity that, in the event of it releasing its full capacity suddenly and in an uncontrolled manner, this can create a serious hazard to the people or equipment around (for example by the reaction force or the noise created), it is acceptable to place a restricting orifice plate between the reservoir and the valve to be tested in order to limit the maximum capacity.

### 5.2.2.3 Test medium

The test cryogenic fluid shall be selected from those for which the valve is to be approved and shall be that which has the lowest equilibrium temperature at a pressure of 1 bar absolute. Alternatively the test fluid within the reservoir may be liquid nitrogen irrespective of the rated minimum temperature of the valve. In the case where the valve is intended to relieve a fluid that can condense from gas or vapour directly to solid, e.g. CO<sub>2</sub>, at a relieving pressure and temperature within the range for which the valve is to be approved, the valve must in addition be tested with this fluid at a pressure and temperature where the fluid will readily condense from gas or vapour directly to solid.

For low test pressures, the natural "boil-off" vapour from the cryogenic liquid may be enough to generate the required pressure. For higher pressures, it is acceptable to pressurize the vessel with high pressure gas. In this case, the gas can be identical to the cryogenic fluid used in the reservoir, or another fluid with a lower equilibrium temperature compatible with the cryogenic fluid in the reservoir.

### 5.2.2.4 Operational testing

#### 5.2.2.4.1 General

All tests shall be completed sequentially and there shall be no delay between tests. Specified times have a tolerance of  $\pm 1$  min. The sample valve shall open without restriction and re-seat audibly leak tight within its specified pressure tolerances throughout the following tests.

If agreed between the relevant parties, water spraying may be eliminated during operational testing if an assessment of the operational characteristics of the valve reveals that the valve operation is unaffected by rain. The assessment shall be done by reviewing drawings and any other suitable information.

#### 5.2.2.4.2 Test 1 — Effect of rainwater if deposited on or retained in the valve when warm

The sample valve shall be sprayed externally from above and on all sides with water from a horticultural watering can rose or alternative device that will simulate heavy rainfall for a period of 3 min. The water spray shall then be removed and the sample valve permitted to drain for a period of 5 min.

If the intended installation of the valve is such that no water can accumulate in the outlet of the valve (refer to 4.2.2), the outlet of the valve shall be kept free of water during spraying.

Immediately thereafter the pressure shall be raised in the cryogenic reservoir to the valve set pressure to open and close the valve at least 5 times. The time between 2 openings shall be recorded. No variation of set pressure ( $\pm 4\%$  tolerance) is allowed. At the end of the test, the valve should be left closed at 90 % of set pressure for 5 min. After this period, the leak rate at the valve outlet shall not exceed  $3 \text{ mm}^3\text{S}^{-1} \text{ DN}$ . There should be no visible or audible leakage at any other location on the valve.

#### 5.2.2.4.3 Test 2 — Effect of rainwater if deposited on or retained in the valve when cold

After successful completion of test 1, the pressure shall be raised in the cryogenic reservoir to the valve set pressure to open and close the valve at least 5 times. While the sample valve is cycling it shall be sprayed externally from above and on all sides with water from a horticultural watering can rose or alternative device that will simulate heavy rainfall. No variation of set pressure ( $\pm 3\%$  tolerance) is allowed. At the end of the test, the valve should be left closed at 90 % of set pressure for 5 min, while still maintaining the external water spraying. After this period the leak rate at the valve outlet shall not exceed  $3 \text{ mm}^3\text{S}^{-1} \text{ DN}$ . There should be no visible or audible leakage at any other location on the valve.

If the intended installation of the valve is such that no water can accumulate in the outlet of the valve (refer to 4.2.2), the outlet of the valve shall be kept free of water during spraying.

### 5.2.3 Alternate cryogenic tests

#### 5.2.3.1 General

Valves which will not let water and ice in through the assembly and which will be required to be protected from accumulation of water and ice by adding 5.2.3 to type approval number may use the alternate cryogenic tests instead of those specified in 5.2.2.

**(1) Set Pressure** The sample relief valve shall be connected to a pressure source which may be controlled to achieve and maintain a pressure in excess of set pressure plus over pressure of the valve. Install the valve with its inlet connected to the pressure source in a chamber filled with a liquid at the minimum rated temperature of the valve. Alternately, a temperature of  $-196\text{ }^\circ\text{C}$  may be used. Allow at least 15 min or until the liquid stops boiling to cool down the valve. Increase the input pressure until the valve opens. Note the opening pressure. Repeat the test two more times. The opening pressures shall be within the set pressure tolerances given in Clause 7.

**(2) Seat leakage** Mechanically hold the valve open to a travel equivalent to what will be caused by an inlet pressure of 110 % of set pressure. When the open valve has cooled down, slowly close the valve and remove it from the cooling liquid. Pressurize the inlet up to 90 % of set pressure and measure the seat leakage every 10 min up to 30 min. The leakage rate after 30 min shall not exceed  $6 \times 10^{-3} \text{ Cm}^3\text{S}^{-1}$  (standard conditions)  $\times \text{DN}$  at 90 % of the set pressure.

### 5.3 Production testing

It shall be performed in accordance with the requirements of Clause 6 of ISO 4126-1. Where a pressure test is required the test medium shall be clean water for hydraulic tests or dry oil-free air or an inert gas such as nitrogen for pneumatic tests. Pneumatic testing is recommended. But if water is used as a test medium, the valve must be thoroughly dried after the test, taking particular care about any recesses and pockets.

## 6 Determination of the certified coefficient of discharge ( $K_{dr}$ )

The performance of the safety valve shall be determined in accordance with ISO 4126-1.

The maximum value of the certified coefficient of discharge ( $K_{dr}$ ) on individual tests shall not exceed 0,90.

## 7 Set pressure tolerances

Set pressure tolerances of pressure relief valves shall not exceed 0,15 bar for pressures up to and including 5 bar and  $\pm 3\%$  of set pressure for pressures above 5 bar.

## 8 Re-seating pressure

The value of inlet static pressure at which the disc (plug) re-establishes contact with the seat or at which lift becomes zero shall not be less than 90 % of the set pressure of the pressure-relief valve.

## 9 Cleanliness

Before assembly of the valve, all parts shall be clean such that they satisfy the requirements of ISO 23208.

The assembled valve shall satisfy the requirements of ISO 23208.

## 10 Marking

### 10.1 Marking on the body of the pressure-relief valve

Marking on the body may be integral with the body or on a plate securely fitted on the body. The following minimum information shall be marked on the body of all pressure-relief valves:

- a) size designation of inlet;
- b) material of the body;
- c) manufacturer's name or trade mark;
- d) an arrow sign ( $\uparrow$ ) showing the direction of flow, where the inlet and outlet connections have the same dimensions or the same pressure rating;
- e) rated pressure (PR).

### 10.2 Marking on an identification plate

The following minimum information shall be given on an identification plate securely attached to the pressure-relief valve:

- a) the limiting operating temperature(s), in degrees Celsius or Kelvin, for which the valve has been designed;
- b) set pressure, in bar or pascals;
- c) the designation ISO 21013-1 with the letter B in case of category B valve;
- d) type approval number of valve or model number of valve and 5.2.3;
- e) a unique serial number that allows identification of the individual valve and 5.2.3 if alternate cryogenic tests were used for type approval;
- f) the date when the final production acceptance test of the fully assembled valve was completed and the valve was sealed;