

INTERNATIONAL STANDARD

**ISO
4422**

First edition
1990-09-15

AMENDMENT 1
1992-11-01

Pipes and fittings made of unplasticized poly(vinyl chloride) (PVC-U) for water supply — Specifications

AMENDMENT 1

*Tubes et raccords en poly(chlorure de vinyle) non plastifié (PVC-U) pour l'adduction
d'eau — Spécifications*

AMENDEMENT 1



Reference number
ISO 4422 : 1990/Amd.1 : 1992 (E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Amendment 1 to International Standard ISO 4422 : 1990 was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Sub-Committee SC 2, *Plastics pipes and fittings for water supplies*.

© ISO 1992

All rights reserved. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Organization for Standardization
Case postale 56 • CH-1211 Genève 20 • Switzerland

Printed in Switzerland

Pipes and fittings made of unplasticized poly(vinyl chloride) (PVC-U) for water supply — Specifications

● AMENDMENT 1

Page 2

Clause 2

Add the following normative reference:

“ISO/TR 9852 : — 2), *Unplasticized poly(vinyl chloride) (PVC-U) pipes — Dichloromethane resistance temperature — Test method.*”

Page 7

Subclause 6.2.1.3

— Add the following sentence at the end of the first paragraph:

● “One such alternative method, also using dichloromethane, is given in ISO/TR 9852.”

— Add the following sentence at the end of the second paragraph:

“When the test is carried out in accordance with ISO/TR 9852, there shall be no attack on any part of the pipe surface at $15\text{ °C} \pm 1\text{ °C}$.”

— Delete footnote 4.