
**Acoustics — Rating of sound insulation
in buildings and of building elements —**

Part 1:

Airborne sound insulation

AMENDMENT 1: Rounding rules related
to single number ratings and single number
quantities

*Acoustique — Évaluation de l'isolement acoustique des immeubles et
des éléments de construction —*

Partie 1: Isolement aux bruits aériens

*AMENDEMENT 1: Règles d'arrondissement associées aux évaluations
de numéro simple et aux quantités de numéro simple*



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

STANDARDSISO.COM : Click to view the full PDF of ISO 717-1:1996/Amd 1:2006

© ISO 2006

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to ISO 717-1:1996 was prepared by the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building products and of buildings* in collaboration with ISO Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

Introduction

The existing texts on rounding of data in ISO 717-1 and ISO 717-2 are not very precise and lead to different interpretations, especially when implemented numerically in computer software.

This amendment to ISO 717-1:1996 gives more precise instructions through the following:

- modification of the first paragraph of 4.4, Method of comparison, and the addition of footnote 3;
- modification of both paragraphs of 4.5, Calculation of spectrum adaptation terms, and the renumbering of existing footnotes;
- modification of Tables C.1 and C.2.
- addition of a Bibliography.

STANDARDSISO.COM : Click to view the full PDF of ISO 717-1:1996/Amd 1:2006

Acoustics — Rating of sound insulation in buildings and of building elements —

Part 1: Airborne sound insulation

AMENDMENT 1: Rounding rules related to single number ratings and single number quantities

Page 1, Clause 2:

Replace “ISO 140-4:—¹)” with “ISO 140-4:1998”. Delete footnote 1.

Replace “ISO 140-5:—²)” with “ISO 140-5:1998”. Delete footnote 2.

Page 7, 4.4, first sentence:

Replace the first sentence with the following:

To evaluate the results of a measurement made in accordance with ISO 140-3, ISO 140-4, ISO 140-5, ISO 140-9 and ISO 140-10 in one-third-octave bands (or octave bands), the measurement data shall be given to one decimal place¹). Shift the relevant reference curve in increments of 1 dB towards the measured curve until the sum of unfavourable deviations is as large as possible but not more than 32,0 dB (measurement in 16 one-third-octave bands) or 10,0 dB (measurement in 5 octave bands).

Insert new footnote 1 as follows:

1) The different parts of ISO 140 state that the results shall be reported “to one decimal place”. However, if the octave or one-third-octave values have been reported with more than one decimal digit, the values shall be reduced to one decimal place before use in the calculation of the single number rating. This is done by taking the value in tenths of dB closest to the reported values: $XX.XYZZZ\dots$ is rounded to $XX.X$ if Y is less than 5 and to $XX.X + 0,1$ if Y is equal to or greater than 5. Software developers should ensure that this reduction applies to the true input values and not only to the displayed precision (as shown on the screen or printed on paper). Generally this can be implemented by the following sequence of instructions: multiply the (positive) number $XX.XYZZZ\dots$ by 10 and add 0,5, take the integer part and then divide the result by 10. For further details see ISO 31-0.

Page 7, 4.5, following the equation:

Replace the definition of X_i with the following:

X_i the sound reduction index, R_i , or apparent sound reduction index, R'_i , or normalized sound level difference, $D_{n,i}$, or standardized sound level difference, $D_{nT,i}$, at the measuring frequency, i , given to one decimal place.

Page 8, 4.5, second paragraph:

Replace first sentence and the first part of the second sentence of the second paragraph with the following:

Calculate the quantity, $X_{A,i}$, with sufficient accuracy and round the result to an integer ²). The resulting spectrum adaptation term is an integer by definition and shall be identified in accordance with the spectrum used, as follows:

In the first sentence of the second paragraph, renumber footnote 3) as footnote 2) and replace the text of the original footnote 3 with the following:

2) $XX, YZZZ\dots$ is rounded to XX if Y is less than 5 and to $XX + 1$ if Y is greater than or equal to 5. For further details see ISO 31-0. Software implementers should be aware that calculation of the spectrum adaptation terms involves floating-point calculations that are never exact and may incur rounding errors. In some rare cases this may lead to a difference of + 1 dB or - 1 dB in the final result. In order to avoid rounding errors, it is strongly recommended to use the highest possible machine accuracy available for floating-point representation and mathematical operations.

Page 14, Annex C:

Replace Table C.1 with the following:

Table C.1 — Measurements in the specified frequency range 100 Hz to 3 150 Hz

Frequency Hz	R_i dB	Reference values shifted by - 22 dB dB	Unfavourable deviation dB	Spectrum No. 1 dB	$L_{i1} - R_i$ dB	$10^{(L_{i1} - R_i)/10}$ $\times 10^{-5}$	Spectrum No. 2 dB	$L_{i2} - R_i$ dB	$10^{(L_{i2} - R_i)/10}$ $\times 10^{-5}$
100	20,4	11	—	- 29	- 49,4	1,148...	- 20	- 40,4	9,120...
125	16,3	14	—	- 26	- 42,3	5,888...	- 20	- 36,3	23,442...
160	17,7	17	—	- 23	- 40,7	8,511...	- 18	- 35,7	26,915...
200	22,6	20	—	- 21	- 43,6	4,365...	- 16	- 38,6	13,803...
250	22,4	23	0,6	- 19	- 41,4	7,244...	- 15	- 37,4	18,197...
315	22,7	26	3,3	- 17	- 39,7	10,715...	- 14	- 36,7	21,379...
400	24,8	29	4,2	- 15	- 39,8	10,471...	- 13	- 37,8	16,595...
500	26,6	30	3,4	- 13	- 39,6	10,964...	- 12	- 38,6	13,803...
630	28,0	31	3,0	- 12	- 40,0	10,000	- 11	- 39,0	12,589...
800	30,5	32	1,5	- 11	- 41,5	7,079...	- 9	- 39,5	11,220...
1 000	31,8	33	1,2	- 10	- 41,8	6,606...	- 8	- 39,8	10,471...
1 250	32,5	34	1,5	- 9	- 41,5	7,079...	- 9	- 41,5	7,079...
1 600	33,4	34	0,6	- 9	- 42,4	5,754...	- 10	- 43,4	4,570...
2 000	33,0	34	1,0	- 9	- 42,0	6,309...	- 11	- 44,0	3,981...
2 500	31,0	34	3,0	- 9	- 40,0	10,000	- 13	- 44,0	3,981...
3 150	25,5	34	8,5	- 9	- 34,5	35,481...	- 15	- 40,5	8,912...
$\text{sum} = 31,8 < 32$ $R_w = 52 - 22 \text{ dB} = 30 \text{ dB}$				$\text{sum} = 147,6199\dots \times 10^{-5}$ $- 10 \lg \text{sum} = 28,308\dots$ $C = 28 - 30 \text{ dB} = - 2 \text{ dB}$			$\text{sum} = 206,0636\dots \times 10^{-5}$ $- 10 \lg \text{sum} = 26,859\dots$ $C_{tr} = 27 - 30 \text{ dB} = - 3 \text{ dB}$		