
International Standard



7201

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

Fire protection — Fire extinguishing media — Halogenated hydrocarbons

Protection contre l'incendie — Agents extincteurs — Hydrocarbures halogénés

First edition — 1982-09-15

STANDARDSISO.COM : Click to view the full PDF of ISO 7201:1982

UDC 614.842.612 : 661.723

Ref. No. ISO 7201-1982 (E)

Descriptors : fire protection, extinguishing installations, hydrocarbons, halohydrocarbons, specifications.

Price based on 5 pages

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards institutes (ISO member bodies). The work of developing International Standards is carried out through ISO technical committees. Every member body interested in a subject for which a technical committee has been set up has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council.

International Standard ISO 7201 was developed by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, and was circulated to the member bodies in January 1981.

It has been approved by the member bodies of the following countries :

Belgium	Iraq	South Africa, Rep. of
Brazil	Israel	Spain
Canada	Japan	Sri Lanka
Denmark	Korea, Rep. of	Sweden
Egypt, Arab Rep. of	Netherlands	Switzerland
France	New Zealand	United Kingdom
Germany, F.R.	Norway	USA
Hungary	Poland	USSR
India	Portugal	

The member bodies of the following countries expressed disapproval of the document on technical grounds :

Australia
Italy

Fire protection — Fire extinguishing media — Halogenated hydrocarbons

0 Introduction

0.1 This International Standard is one of a series giving specifications for fire extinguishing media in common use and which are in need of standardization for fire fighting purposes. These specifications are designed to establish that the medium in question has at least a minimum useful fire extinguishing capability and can therefore be reasonably sold for fire extinguishing purposes.

0.2 Requirements for media used in particular equipment will form the subject of future International Standards.

0.3 The annexes to this International Standard provide important information on, and give recommendations relating to, the safety and use of halons, and they should be read carefully by all concerned with these media. They do not, however, form part of the specification.

1 Scope and field of application

This International Standard specifies requirements for the following halogenated hydrocarbons for use as fire extinguishing media :

- a) halon 1211 [bromochlorodifluoromethane (CF_2ClBr)];
- b) halon 1301 [bromotrifluoromethane (CF_3Br)].

Other halons may be considered at a later date once their safe and effective use has been demonstrated.

This International Standard does not deal with the conditions of use of these products in fire fighting equipment. Such equipment (portable fire extinguishers, fixed installations, etc.) will be dealt with in future International Standards.

2 References

ISO 1393, *Liquid halogenated hydrocarbons for industrial use — Determination of acidity — Titrimetric method.*

ISO 2210, *Liquid halogenated hydrocarbons for industrial use — Determination of residue on evaporation.*

ISO 3427, *Gaseous halogenated hydrocarbons (liquified gases) — Taking of a sample.*

3 Definition

For the purpose of this International Standard, the following definition applies.

halon : A halogenated hydrocarbon used as a fire extinguishing medium.

NOTE — The following numbering system is used to identify halons. The word "halon" is followed by a number, usually of four digits, giving, in turn, the number of carbon, fluorine, chlorine and bromine atoms. Terminal zeros are omitted. Thus halon 1211 is bromochlorodifluoromethane (CF_2ClBr) and halon 1301 is bromotrifluoromethane (CF_3Br).

4 Requirements

Halons 1211 and 1301 shall comply with the requirements of table 1, when tested by the appropriate method of test specified in clause 6.

Table 1 — Requirements

Property	Requirement	
	Halon 1211	Halon 1301
Purity, % (mol/mol) min.	99,0	99,6
Acidity, ppm by mass, max.	3,0	3,0
Water content, ppm by mass, max.	20	10
High boiling impurities, % (m/m) max.	0,01	0,01
Halogen ion	Passes test	Passes test
Inert gases in vapour phase, % (mol/mol) max.	Not applicable	1,5
Suspended matter or sediment	None visible	None visible

5 Sampling

Samples of halons shall be taken from the manufacturer's shipping container. When halons are in the liquid phase (see clause 6), the samples shall be taken adopting the method specified in ISO 3427.¹⁾

1) The sampling bottle should be capable of safely resisting the vapour pressure of the sample at the highest temperature that could be encountered.

6 Methods of test

6.1 General

For all tests except that for inert gases in the vapour phase (see 6.7), the sample shall be taken from the liquid phase.

6.2 Purity

Determine the purity by gas-liquid chromatography, using generally accepted laboratory techniques.

6.3 Acidity

Determine the acidity by the method specified in ISO 1393 with the following modifications to the procedure.

6.3.1 Test portion

Take 50 g of the sample and bubble it through 100 ml of distilled water.

6.3.2 Determination

Begin with 10 ml of slurry comprising crushed ice and distilled water.

6.4 Water content

Determine the water content by the orthodox Karl Fischer method or by any other method giving equivalent results.

6.5 High-boiling impurities

Determine the high-boiling impurities by the method specified in ISO 2210, or by any other method giving equivalent results, with the following modifications for halon 1301 only.

6.5.1 Apparatus

6.5.1.1 Use a Goetz tube, of capacity 100 ml.

6.5.1.2 Use a temperature-controlled cabinet.

6.5.2 Procedure

Set the temperature of the cabinet (6.5.1.2) to 0 ± 2 °C.

6.6 Halogen ion

Mix 5 g of the sample with 5 ml of absolute methanol containing several drops of a saturated methanolic silver nitrate (AgNO_3) solution. The resulting solution shall exhibit no turbidity or precipitation of silver halide.

6.7 Inert gases in vapour phase

Determine inert gases by vapour-phase chromatography, using generally accepted laboratory techniques.

6.8 Suspended matter or sediment

Examine the liquid phase of the sample visually.

7 Packaging and labelling

7.1 Halons shall be shipped and stored in containers which will not alter the medium or be detrimentally affected by it.

NOTE — The containers may need to comply with national regulations.

7.2 Containers shall be marked with the following information :

- a) supplier's name and address;
- b) "Halon 1211" or "Halon 1301", as appropriate;
- c) package identification number;
- d) the number of this International Standard, i.e. ISO 7201;
- e) recommended storage precautions.

Annex A

General properties

(This annex does not form part of the standard.)

A.1 Physical properties

Halon 1211 is a colourless, faintly sweet-smelling gas. Halon 1301 is an odourless gas. A number of their other more important physical properties are given in table 2.

A.2 Electrical conductivity

Halons 1211 and 1301 have a very low electrical conductivity. In many cases they can be used to extinguish fires involving live electrical equipment, but this, to a significant extent, may depend on the circumstances, particularly the method of discharge. In case of doubt, reference should be made to the instructions on the fire extinguishing equipment to be used.

A.3 Effects on materials

Halons 1211 and 1301 are stable and inert to most common construction materials. Manufacturers' test data should be consulted for effects on specific materials.

NOTE — During fire extinguishing, decomposition products will be produced which are potentially corrosive. Concentrations are usually low and problems can be avoided by ventilation of the area.

A.4 Toxicology

Information on the toxicology of halons 1211 and 1301 is given in annex D.

Table 2 — Physical properties of halons 1211 and 1301

Property	Halon 1211	Halon 1301
Relative molecular mass	165,38	148,93
Boiling point at 1,013 bar*, °C	-4,0	-57,8
Freezing point, °C	-160,5	-168,0
Critical temperature, °C	153,8	67,0
Critical pressure, bar	42,06	39,6
Critical volume, m ³ /kg	0,001 41	0,001 34
Critical density, kg/m ³	713	745
Vapour pressure		
at 20 °C, bar	2,53	14,63
at 60 °C, bar	7,20	34,58
Liquid density at 20 °C, kg/m ³	1 830	1 575
Saturated vapour density at 20 °C, kg/m ³	17,4	115,6
Specific volume of superheated vapour at 1,013 bar and 20 °C, m ³ /kg	0,145	0,159

* 1 bar = 10⁵ Pa