

First edition
2005-11-01

AMENDMENT 1
2009-05-01

Fire detection and alarm systems —

Part 11:
Manual call points

AMENDMENT 1

Systèmes de détection et d'alarme d'incendie —

Partie 11: Déclencheurs manuels d'alarme

AMENDEMENT 1

STANDARDSISO.COM : Click to view the full PDF of ISO 7240-11:2005/Amd 1:2009



Reference number
ISO 7240-11:2005/Amd.1:2009(E)

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

 **COPYRIGHT PROTECTED DOCUMENT**

© ISO 2009

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to ISO 7240-11:2005 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

STANDARDSISO.COM : Click to view the full PDF of ISO 7240-11:2005/Amd.1:2009

STANDARDSISO.COM : Click to view the full PDF of ISO 7240-11:2005/Amd 1:2009

Fire detection and alarm systems —

Part 11: Manual call points

AMENDMENT 1

Foreword, page iv

Add the following parts in appropriate numerical order:

- *Part 8: Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor*
- *Part 16: Sound system control and indicating equipment*
- *Part 19: Design, installation, commissioning and service of sound systems for emergency purposes*
- *Part 28: Fire protection control equipment*

Foreword, page v

Replace the two lines of text following “The following parts are under development:” with the following:

- *Part 17: Short-circuit isolators*
- *Part 18: Input/output devices*
- *Part 20: Aspirating smoke detectors*
- *Part 24: Sound system loudspeakers*
- *Part 25: Components using radio links*
- *Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*

4.7.2.2, page 6


Replace the existing text with the following:

The dimension, a , of the front face shall be not less than 85 mm and not greater than 150 mm (see Figure 1).

The dimensions, b_1 and b_2 , of a rectangular operating face shall be not less than 34 mm and not greater than $0,8a$ (see Figure 1).


The vertical offset, c , of the operating face shall be not greater than $0,16a$ (see Figure 1).

The manual call point shall be designed so that it is capable of being mounted, in accordance with the manufacturer's instructions, with the front face at least 15 mm proud of the surrounding surface.



a) Example of a square operating face

b) Example of a rectangular operating face



c) Example of a round operating face

Key

- 1 front face
- 2 operating face

a $85 \text{ mm} \leq a \leq 150 \text{ mm}$

b, b_x $34 \text{ mm} \leq b_x \leq 0,8a$, for $x = 1$ or 2 ; a subscript is used only if the two dimensions are different

c offset $c \leq 0,16a$

Figure 1 — Manual call point examples