



INTERNATIONAL STANDARD ISO 7240-15:2004
TECHNICAL CORRIGENDUM 1

Published 2005-09-01

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

Fire detection and alarm systems —
Part 15:
Multisensor fire detectors

TECHNICAL CORRIGENDUM 1

Systèmes de détection et d'alarme d'incendie —

Partie 15: Détecteurs d'incendie multicapteurs

RECTIFICATIF TECHNIQUE 1

Technical Corrigendum 1 to ISO 7240-15 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

Title:

Change the part title to the following:

Point type fire detectors using scattered light, transmitted light or ionization sensors in combination with a heat sensor

Page 56, N.1:

Change the amount of decalin from 70 g to 170 g.

Page 56, N.4:

Change "10 °C" to "6 K".

ICS 13.220.20

Ref. No. ISO 7240-15:2004/Cor.1:2005(E)

© ISO 2005 – All rights reserved

Published in Switzerland