

TECHNICAL REPORT

**Information technology – Generic cabling –
Introduction to the MICE environmental classification**

STANDARDSISO.COM : Click to view the full PDF of ISO/IEC TR 29106:2007



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2007 ISO/IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about ISO/IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

STANDARDSISO.COM : Click to view the full PDF of ISO/IEC TR 29106:2007

TECHNICAL REPORT –TYPE 3

**Information technology – Generic cabling –
Introduction to the MICE environmental classification**

STANDARDSISO.COM : Click to view the full PDF of ISO/IEC TR 29106:2007

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

F

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Reference documents.....	5
3 Terms, definitions and abbreviations	6
3.1 Terms and definitions	6
3.2 Abbreviations	6
4 Application of environmental classification.....	6
4.1 MICE.....	6
4.2 Channel environment	6
4.3 Component selection.....	7
5 MICE system	10
5.1 General.....	10
5.2 Mechanical environment.....	10
5.3 Ingress protection and climatic environment.....	11
5.4 Chemical environment.....	13
5.5 Electromagnetic environment	15
Bibliography.....	16
Figure 1 – Example of variation of the environment along an industrial premises cabling channel.....	7
Figure 2 – The local environment.....	7
Table 1 – Details of environmental classification.....	8
Table 2 – Derivation of boundaries for mechanical criteria in Table 1.....	10
Table 3 – Derivation of boundaries for ingress protection criteria in Table 1.....	11
Table 4 – Derivation of boundaries for climatic criteria in Table 1.....	11
Table 5 – Derivation of boundaries for chemical criteria in Table 1.....	13
Table 6 – Derivation of boundaries for electromagnetic criteria in Table 1.....	15

STANDARDSISO.COM · Click to view the full PDF of ISO/IEC TR 29106:2007

INFORMATION TECHNOLOGY – GENERIC CABLING – INTRODUCTION TO THE MICE ENVIRONMENTAL CLASSIFICATION

FOREWORD

- 1) ISO (International Organization for Standardization) and IEC (International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards. Their preparation is entrusted to technical committees; any ISO and IEC member body interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with ISO and IEC also participate in this preparation.
- 2) In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1. Draft International Standards adopted by the joint technical committee are circulated to national bodies for voting. Publication as an International Standard requires approval by at least 75 % of the national bodies casting a vote.
- 3) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO member bodies.
- 4) IEC, ISO and ISO/IEC publications have the form of recommendations for international use and are accepted by IEC and ISO member bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC, ISO and ISO/IEC publications is accurate, IEC or ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 5) In order to promote international uniformity, IEC and ISO member bodies undertake to apply IEC, ISO and ISO/IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any ISO/IEC publication and the corresponding national or regional publication should be clearly indicated in the latter.
- 6) ISO and IEC provide no marking procedure to indicate their approval and cannot be rendered responsible for any equipment declared to be in conformity with an ISO/IEC publication.
- 7) All users should ensure that they have the latest edition of this publication.
- 8) No liability shall attach to IEC or ISO or its directors, employees, servants or agents including individual experts and members of their technical committees and IEC or ISO member bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication of, use of, or reliance upon, this ISO/IEC publication or any other IEC, ISO or ISO/IEC publications.
- 9) Attention is drawn to the reference documents cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 10) Attention is drawn to the possibility that some of the elements of this Technical Report, type 3 may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC and ISO technical committees is to prepare International Standards. In exceptional circumstances, ISO/IEC JTC 1 or a subcommittee may propose the publication of a technical report of one of the following types:

- type 1, when the required support cannot be obtained for the publication of an International Standard, despite repeated efforts;
- type 2, when the subject is still under technical development or where, for any other reason, there is the future but not immediate possibility of an agreement on an International Standard;
- type 3, when the technical committee has collected data of a different kind from that which is normally published as an International Standard, for example 'state of the art'.

ISO/IEC 29106, which is a Technical Report of type 3, has been prepared by subcommittee 25: Interconnection of information technology equipment, of ISO/IEC joint technical committee 1: Information technology.

Technical reports of types 1 and 2 are subject to review within three years of publication to decide whether they can be transformed into International Standards. Technical reports of type 3 do not necessarily have to be reviewed until the data they provide are considered to be no longer valid or useful.

This Technical Report of type 3 has been approved by vote of the member bodies, and the voting results may be obtained from the address given on the second title page.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

STANDARDSISO.COM : Click to view the full PDF of ISO/IEC TR 29106:2007

INFORMATION TECHNOLOGY – GENERIC CABLING – INTRODUCTION TO THE MICE ENVIRONMENTAL CLASSIFICATION

1 Scope

This Technical Report acts as an introduction to the concepts used to develop the MICE environmental classification system used in cabling standards developed by ISO/IEC. It also provides detailed explanation of the sources used to define the boundaries of MICE classifications.

2 Reference documents

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC 11801, *Information technology – Generic cabling for customer premises*

ISO/IEC 15018, *Information technology – Generic cabling for homes*

ISO/IEC 24702, *Information technology – Generic cabling – Industrial premises*

IEC 60068-2-5:1975, *Environmental testing – Part 2: Tests. Test Sa: Simulated solar radiation at ground level*

IEC 60654-4:1987 *Operating conditions for industrial-process measurement and control equipment. Part 4: Corrosive and erosive influences*

IEC 60721-1, *Classification of environmental conditions – Part 1: Environmental parameters and their severities*

IEC 60721-3-3, *Classification of environmental conditions – Part 3-3: Classification of groups of environmental parameters and their severities - Stationary use at weatherprotected locations*

IEC 61000-2-5, *Electromagnetic compatibility (EMC) – Part 2: Environment – Section 5: Classification of electromagnetic environments. Basic EMC publication*

IEC 61000-6-1, *Electromagnetic compatibility (EMC) – Part 6-1: Generic standards – Immunity for residential, commercial and light-industrial environments*

IEC 61000-6-2, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity for industrial environments*

IEC 61131-2, *Programmable controllers – Part 2: Equipment requirements and tests*

IEC 61326:2001, *Electrical equipment for measurement, control and laboratory use – EMC requirements*

IEC 61918, *Industrial communication networks – Installation of communication networks in industrial premises*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this Technical Report the definitions of the applicable generic cabling standards ISO/IEC 11801, ISO/IEC 15018 and ISO/IEC 24702 apply.

3.2 Abbreviations

For the purposes of this Technical Report the abbreviations of the applicable generic cabling standards ISO/IEC 11801, ISO/IEC 15018 and ISO/IEC 24702 apply.

4 Application of environmental classification

4.1 MICE

The term MICE referenced in generic cabling standards produced by ISO/IEC¹ relates to the classification of the environment of the cabling channel.

There are four primary environmental criteria used to classify an environment:

- the M element, defining the mechanical characteristics of the environment;
- the I element, defining the ingress protection characteristics of the environment;
- the C element, defining the climatic and chemical characteristics of the environment;
- the E element, defining the electromagnetic characteristics of the environment.

Each of the four primary environmental criteria are further divided into specific parameters and levels for those parameters. The MICE classification for a given location is therefore defined as $M_a I_b C_c E_d$ where a, b, c and d are the individual sub-classifications (levels) for the M, I, C and E criteria respectively.

The suffixes for the four primary environmental criteria are either 1, 2 or 3. For example, the most benign environment is described as $M_1 I_1 C_1 E_1$ whereas the most harsh environment within the scope of this standard would be defined as $M_3 I_3 C_3 E_3$.

4.2 Channel environment

The applicable MICE classification may vary along the length of the cabling channel. As shown in the industrial premises cabling example of Figure 1, the ingress protection characteristics of the environment in the automation area and at the automation island are different from, and more severe than, those characteristics on the factory floor or in the telecommunications room.

¹ The documents prepared by subcommittee 25 of ISO/IEC joint technical committee 1: Information technology.




Figure 1 – Example of variation of the environment along an industrial premises cabling channel

The environment to be classified is that local to the cabling. Where no environmental protection is provided to the cabling, the classification of the local environment is also that of the overall environment at that location.

However, where technical or economic restrictions preclude the use of components compatible with the overall environment, mitigation or isolation techniques may be applied to modify one or more of the M, I, C or E environments local to the cabling in order to allow appropriate components to be installed.

The mitigation or isolation techniques typically involve the use of alternative pathways and/or pathway systems as shown in Figure 2.




Figure 2 – The local environment

4.3 Component selection

The components used within a channel should be selected to be compatible with the MICE classification of the channel at the point where the components are to be installed.

Table 1, taken from ISO/IEC 24702:2006, shows the parameters used to classify the local environment under the M, I, C and E criteria. While the classification of an environment is determined by the most demanding parameter within each criteria group, the selection of components may reflect the specific demands of all the parameters within the group, including those that may be less demanding than the overall classification of the environment.

The MICE classification system is intended to address approximately 80 % of the environments to which cabling may be subjected. There are some environments beyond the boundaries of $M_3I_3C_3E_3$. Such environments are beyond the scope of this Technical Report and require special handling.

Table 1 – Details of environmental classification

Mechanical	M₁	M₂	M₃
Shock/bump (see a))			
Peak acceleration	40 ms ⁻²	100 ms ⁻²	250 ms ⁻²
Vibration			
Displacement amplitude (2 Hz to 9 Hz)	1,5 mm	7,0 mm	15,0 mm
Acceleration amplitude (9 Hz to 500 Hz)	5 ms ⁻²	20 ms ⁻²	50 ms ⁻²
Tensile force	See b)	See b)	See b)
Crush	45 N over 25 mm (linear) min.	1 100 N over 150 mm (linear) min.	2 200 N over 150 mm (linear) min.
Impact	1 J	10 J	30 J
Bending, flexing and torsion	See b)	See b)	See b)
Ingress	I₁	I₂	I₃
Particulate ingress (dia. max.)	12,5 mm	50 µm	50 µm
Immersion	None	Intermittent liquid jet ≤ 12,5 l/min ≥ 6,3 mm jet > 2,5 m distance	Intermittent liquid jet ≤ 12,5 l/min ≥ 6,3 mm jet > 2,5 m distance and immersion (≤ 1 m for ≤ 30 minutes)
Climatic and chemical	C₁	C₂	C₃
Ambient temperature	-10 °C to +60 °C	-25 °C to +70 °C	-40 °C to +70 °C
Rate of change of temperature	0,1 °C per minute	1,0 °C per minute	3,0 °C per minute
Humidity	5 % to 85 % (non-condensing)	5 % to 95 % (condensing)	5 % to 95 % (condensing)
Solar radiation	700 Wm ⁻²	1 120 Wm ⁻²	1 120 Wm ⁻²
Liquid pollution (see c))			
Contaminants	Concentration × 10 ⁻⁶	Concentration × 10 ⁻⁶	Concentration × 10 ⁻⁶
Sodium chloride (salt/sea water)	0	<0,3	<0,3
Oil (dry-air concentration) (for oil types see b))	0	<0,005	<0,5
Sodium stearate (soap)	None	>5 × 10 ⁴ aqueous non-gelling	>5 × 10 ⁴ aqueous gelling
Detergent	None	ffs	ffs
Conductive materials	None	Temporary	Present
Gaseous pollution (see b))			
Contaminants	Mean/Peak (Concentration × 10 ⁻⁶)	Mean/Peak (Concentration × 10 ⁻⁶)	Mean/Peak (Concentration × 10 ⁻⁶)
Hydrogen sulphide	<0,003/<0,01	<0,05/<0,5	<10/<50
Sulphur dioxide	<0,01/<0,03	<0,1/<0,3	<5/<15
Sulphur trioxide (ffs)	<0,01/<0,03	<0,1/<0,3	<5/<15
a) Bump: the repetitive nature of the shock experienced by the channel shall be taken into account. b) This aspect of environmental classification is installation-specific and should be considered in association with IEC 61918 and the appropriate component specification. c) A single dimensional characteristic, i.e. Concentration × 10 ⁻⁶ , was chosen to unify limits from different standards.			

Climatic and chemical (continued)	C ₁	C ₂	C ₃
Chlorine wet (>50 % humidity)	<0,000 5/<0,001	<0,005/<0,03	<0,05/<0,3
Chlorine dry (<50 % humidity)	<0,002/<0,01	<0,02/<0,1	<0,2/<1,0
Hydrogen chloride	-/<0,06	<0,06/<0,3	<0,6/3,0
Hydrogen fluoride	<0,001/<0,005	<0,01/<0,05	<0,1/<1,0
Ammonia	<1/<5	<10/<50	<50/<250
Oxides of Nitrogen	<0,05/<0,1	<0,5/<1	<5/<10
Ozone	<0,002/<0,005	<0,025/<0,05	<0,1/<1
Electromagnetic	E ₁	E ₂	E ₃
Electrostatic discharge – Contact (0,667 µC)	4 kV	4 kV	4 kV
Electrostatic discharge – Air (0,132 µC)	8 kV	8 kV	8 kV
Radiated RF – AM	3 V/m at (80 MHz to 1 000 MHz) 3 V/m at ((1 400 MHz to 2 000 MHz) 1 V/m at (2 000 MHz to 2 700 MHz)	3 V/m at (80 MHz to 1 000 MHz) 3 V/m at ((1 400 MHz to 2 000 MHz) 1 V/m at (2 000 MHz to 2 700 MHz)	10 V/m at (80 MHz to 1 000 MHz) 3 V/m at ((1 400 MHz to 2 000 MHz) 1 V/m at (2 000 MHz to 2 700 MHz)
Conducted RF	3 V at 150 kHz to 80 MHz	3 V at 150 kHz to 80 MHz	10 V at 150 kHz to 80 MHz
EFT/B (comms)	500 V	1 000 V	1 000 V
Surge (transient ground potential difference) – signal, line to earth	500 V	1 000 V	1 000 V
Magnetic field (50/60 Hz)	1 Am	3 Am ⁻¹	30 Am ⁻¹
Magnetic field (60 Hz to 20 000 Hz)	ffs	ffs	ffs
<p>a) Bump: the repetitive nature of the shock experienced by the channel shall be taken into account.</p> <p>b) This aspect of environmental classification is installation-specific and should be considered in association with IEC 61918 and the appropriate component specification.</p> <p>c) A single dimensional characteristic, i.e. concentration × 10⁻⁶, was chosen to unify limits from different standards.</p>			

5 MICE system

5.1 General

The MICE concept is provided for the use of designers and planners to allow the specification of components to be purchased and/or protection (mitigation or isolation) required respectively.

Table 1 is not a basis for testing the local environment and neither is it a series of environmental criteria for the testing of components used within those environments. However, the limits describing the MICE classification system are in many cases based upon existing standards.

5.2 Mechanical environment

Table 2 shows the derivation of the boundaries used in Table 1.

Table 2 – Derivation of boundaries for mechanical criteria in Table 1

Mechanical	M ₁	M ₂	M ₃
Shock/bump ^a			
Peak acceleration	40 ms ⁻²	100 ms ⁻²	250 ms ⁻²
Vibration			
Displacement amplitude (2 Hz to 9 Hz)	1,5 mm	7,0 mm	15,0 mm
Acceleration amplitude (9 Hz to 500 Hz)	5 ms ⁻²	20 ms ⁻²	50 ms ⁻²
Shock/bump/vibration (source material)	IEC 60721-3-3 Class 3M2	<IEC 60721-3-3 Class 3M6	IEC 60721-3-3 Class 3M8
Crush	45 N over 25 mm (linear) min.	1 100 N over 150 mm (linear) min.	2 200 over 150 mm (linear) min.
Impact	1 J	10 J	30 J
^a Bump: the repetitive nature of the shock experienced by the channel shall be taken into account.			

From IEC 60721-3-3:

3M1 applies to locations with insignificant vibration and shock.

In addition to the conditions covered by 3M1, 3M2 applies to locations with vibration of low significance (products mounted on light structures subject to negligible vibration).

In addition to the conditions covered by 3M5, 3M6 applies to locations where the level of vibration is high (e.g. close to heavy machines).

In addition to the conditions covered by 3M7, 3M8 applies to locations where the level of vibration is extremely high (e.g. products mounted on power hammers).

5.3 Ingress protection and climatic environment

Table 3 and Table 4 shows the derivation of the boundaries used in Table 1.

Table 3 – Derivation of boundaries for ingress protection criteria in Table 1

Ingress	I ₁	I ₂	I ₃
Particulate ingress (dia. max.)	12,5 mm	50 µm	50 µm
Immersion	None	Intermittent liquid jet ≤12,5 l/min ≥6,3 mm jet >2,5 m distance	Intermittent liquid jet ≤12,5 l/min ≥6,3 mm jet >2,5 m distance and immersion (≤1 m for ≤30 min)

Table 4 – Derivation of boundaries for climatic criteria in Table 1

Climatic	C ₁	C ₂	C ₃
Ambient temperature	-10 °C to +60 °C	-25 °C to +70 °C	-40 °C to +70 °C
	Existing ISO/IEC 11801	IEC 60721-3-3 Class 3K8H	IEC 60721-3-3 Class 3K7
Rate of change of temperature	0,1 °C per minute	1,0 °C per minute	3,0 °C per minute
	IEC 60721-3-3 Class 3K1	IEC 60721-3-3 Class 3K7	IEC 61131-2
Humidity	5 % to 85 % (non-condensing)	5 % to 95 % (condensing)	5 % to 95 % (condensing)
	IEC 60721-3-3 Class 3K3	IEC 60721-3-3 Class 3K4	IEC 60721-3-3 Class 3K5
Solar radiation	700 Wm ⁻²	1 120 Wm ⁻²	1 120 Wm ⁻²
	IEC 60721-3-3 Class 3K3 – 3K6	IEC 60721-3-3 Class 3K7. IEC 60068-2-5:1975 contains a table covering wavelengths from UV to IR that totals 1 120 Wm ⁻² .	

From IEC 60721-3-3:

3K1 applies to fully air-conditioned enclosed locations. Air temperature and humidity control is used continuously to maintain the required conditions. Installed products may be exposed to attenuated solar radiation and to movements of surrounding air due to draughts from the air-conditioning system. They are not subjected to heat radiation, condensed water, precipitation, water from sources other than rain, or formation of ice. These conditions may be found in a room of such construction that a confined range of temperature and humidity may be maintained.

In addition to the conditions covered by 3K1, 3K2 applies to continuously temperature-controlled enclosed locations. Humidity is not controlled. Heating, cooling or humidification is used where necessary to maintain the required conditions, especially where there is a large difference between them and the open air-climate. Installed products may be exposed to solar radiation and to heat radiation. They may be subject to movements of surrounding air due to draughts in buildings. These conditions may be found in manned offices, workshops and other rooms for special applications.

In addition to the conditions covered by 3K2, 3K3 applies to continuously temperature-controlled enclosed locations. Humidity is not controlled. Heating or cooling is used where necessary to maintain the required conditions, especially where there is a large difference between them and the open air-climate. These conditions may be found in normal living or

working areas, e.g. living rooms, rooms for general use (theatres, restaurants, etc.), offices, shops, workshops for electronic assemblies and other electrotechnical products, telecommunications centres, storage rooms for valuable and sensitive products.

In addition to the conditions covered by 3K3, 3K4 applies to temperature-controlled enclosed locations with a wide range of relative humidity. Humidity is not controlled. Installed products may be subject to condensed water and to water from sources other than rain. These conditions may be found in certain living or working areas, e.g. kitchens, bathrooms, workshops with processes producing high humidity, certain cellars, ordinary storage rooms, stables, garages. For the more humid open-air climates they may also be found in living rooms and rooms for general use.

In addition to the conditions covered by 3K4, 3K5 applies to enclosed locations having neither temperature nor humidity control. Heating may be used to raise low temperatures, especially where there is a large difference between them and the open air-climate. A product may be subject to the formation of ice. These conditions may be found in some entrances and staircases of buildings, garages, cellars, certain workshops, buildings in factories and industrial process plants, certain telecommunications buildings, ordinary storage rooms for frost-resistant products, farm buildings, etc.

In addition to the conditions covered by 3K4, 3K6, 3K7 and 3K8H apply to weather-protected locations having neither temperature nor humidity control. The locations may have openings to the open-air. The climatic conditions may be affected by the open-air climate and the type of building. Installed products may be exposed to solar radiation. They may also be subject to wind-driven precipitation including snow. These conditions may be found in some entrances of buildings, some garages, in sheds, shacks, lofts, telephone booths, buildings in factories and industrial process plants, unattended equipment stations, unattended buildings for telecommunications purposes, ordinary storage rooms for frost-resistant products, farm buildings etc.

5.4 Chemical environment

Table 5 shows the derivation of the boundaries used in Table 1.

Table 5 – Derivation of boundaries for chemical criteria in Table 1

Chemical	C ₁	C ₂	C ₃
Liquid pollution (see Note) Contaminants	Concentration × 10 ⁻⁶	Concentration × 10 ⁻⁶	Concentration × 10 ⁻⁶
Sodium chloride (salt/sea water)	0	<0,3	<0,3
	IEC 60721-1		
Oil (dry-air concentration)	0	<0,005	<0,5
Sodium stearate (soap)	None	5 × 10 ⁴ aqueous non-gelling	>5 × 10 ⁴ aqueous gelling
Detergent	None	ffs	ffs
Conductive materials	None	Temporary	Present
Gaseous pollution (see Note) Contaminants	Mean/Peak (Concentration × 10 ⁻⁶)	Mean/Peak (Concentration × 10 ⁻⁶)	Mean/Peak (Concentration × 10 ⁻⁶)
Hydrogen sulphide	<0,003/<0,01	<0,05/<0,5	<10/<50
	The limits are taken from IEC 60654-4:1987 for the environmental descriptions Class 1, 2 and 3. They are within the same region as those in IEC 60721-3-3, A.1:1994 for the environmental descriptions 3C1, 3C2 and 3C4. NOTE For comparison the values in IEC 60721-3-3, A.1:1994 have been converted from mg·cm ⁻³ using the STP density = 1.539.		
Sulphur dioxide	<0,01/<0,03	<0,1/<0,3	<5/<10
	The limits are taken from IEC 60654-4:1987 for the environmental descriptions Class 1, 2 and 3, with the exception of Class 3 (max. <15). They are identical to the environmental descriptions IEC 60721-3-3, A.1:1994 for the environmental descriptions 3C1 and 3C2 and within the same region for the environmental description 3C4 (mean <4,5, max. <14). NOTE For comparison the values in IEC 60721-3-3, A.1:1994 have been converted from mg·cm ⁻³ using the STP density = 2.927.		
Sulphur trioxide (ffs)	<0,01/<0,03	<0,1/<0,3	<5/<15
	There are no limits in IEC 60654-4:1987 or IEC 60721-3-3.		
Chlorine wet (>50 % humidity)	<0,000 5/<0,001	<0,005/<0,03	<0,05/<0,3
	The limits are taken from IEC 60654-4:1987 for the environmental descriptions Class 1, 2 and 3. There are no limits in IEC 60721-3-3.		
Chlorine dry (<50 % humidity)	<0,002/<0,01	<0,02/<0,1	<0,2/<1,0
	The limits are taken from IEC 60654-4:1987 for the environmental descriptions Class 1, 2 and 3. They are within the same region as those in IEC 60721-3-3, A.1:1994 for the environmental descriptions 3C1, 3C2 and 3C4. NOTE For comparison the values in IEC 60721-3-3, A.1:1994 have been converted from mg·cm ⁻³ using the STP density = 3.124.		
Hydrogen chloride	-/<0,06	<0,06/<0,3	<0,6/3,0
	There are no limits in IEC 60654-4:1987. The limits are taken from IEC 60721-3-3, A.1:1994 for the environmental descriptions 3C1, 3C2 and 3C4. NOTE For comparison the values in IEC 60721-3-3, A.1:1994 have been converted from mg·cm ⁻³ using the STP density = 1.639.		
NOTE A single dimensional characteristic, i.e. Concentration × 10 ⁻⁶ , was chosen to unify limits from different standards.			

Chemical	C ₁	C ₂	C ₃
Hydrogen fluoride	<0,001/<0,005	<0,01/<0,05	<0,1/<1,0
	The limits are taken from IEC 60654-4:1987 for the environmental descriptions Class 1, 2 and 3. They are within the same region as those in IEC 60721-3-3, A.1:1994 for the environmental descriptions 3C1, 3C2 and 3C4. NOTE For comparison the values in IEC 60721-3-3, A.1:1994 have been converted from mg·cm ⁻³ using the STP density = 0.901.		
Ammonia	<1/<5	<10/<50	<50/<250
	The limits are taken from IEC 60654-4:1987 for the environmental descriptions Class 1, 2 and 3. They are within the same region as those in IEC 60721-3-3, A.1:1994 for the environmental descriptions 3C2, 3C3 and 3C4. NOTE For comparison the values in IEC 60721-3-3 A.1:1994 have been converted from mg·cm ⁻³ using the STP density = 0.771.		
Oxides of Nitrogen	<0,05/<0,1	<0,5/<1	<5/<10
	The limits are taken from IEC 60654-4:1987 for the environmental descriptions Class 1, 2 and 3. They are within the same region as those in IEC 60721-3-3 A.1:1994 for the environmental descriptions 3C1, 3C2 and 3C4. NOTE For comparison the values in IEC 60721-3-3 A.1:1994 have been converted from mg·cm ⁻³ using the STP density = 1.350 (averaged on NO, NO ₂ and NO ₃).		
Ozone	<0,002/<0,005	<0,025/<0,05	<0,1/<1
	The limits are taken from IEC 60654-4:1987 for the environmental descriptions Class 1, 2 and 3. They are within the same region as those in IEC 60721-3-3, A.1:1994 for the environmental descriptions 3C2, 3C3 and 3C4. NOTE For comparison the values in IEC 60721-3-3 A.1:1994 have been converted from mg·cm ⁻³ using the STP density = 2.144.		
NOTE A single dimensional characteristic, i.e. Concentration × 10 ⁻⁶ , was chosen to unify limits from different standards.			

From IEC 60654-4:1987:

Class 1: Environments sufficiently well controlled so that corrosion is not a factor in determining corrosion.

Class 2: Environments where the effects of corrosion are measurable and may be a factor in determining equipment reliability.

Class 3: Environments where there is a high probability that corrosive attack will occur.

From IEC 60721-3-3:

3C1R applies to locations with stringently monitored and controlled atmosphere (clean room category).

In addition to the conditions covered by 3C1L, 3C1R applies to locations where the atmosphere is continuously controlled.

In addition to the conditions covered by 3C1R, 3C1 applies to locations in rural and some urban areas with low industrial activities and moderate traffic. Contamination may be increased in urban areas in winter due to heating methods. Salt mist may be present in sheltered locations of coastal areas.

In addition to the conditions covered by 3C1, 3C2 applies to locations with normal levels of contaminants experienced in urban areas with scattered industrial activities or heavy traffic.