

(R) Synchro, Control Transformer, Type 16CTB4b

FSC 5990

**RATIONALE**

This Revision consists of a 5 (five) year review, which provides updates to current format and references

**NOTICE**

This specification is approved for use by all Departments and Agencies of the Department of Defense. The requirements for acquiring the Synchros described herein shall consist of this specification and the latest issue of SAE AS20708.

SAENORM.COM : Click to view the full PDF of as20708-25a

SAE Technical Standards Board Rules provide that: "This report is published by SAE to advance the state of technical and engineering sciences. The use of this report is entirely voluntary, and its applicability and suitability for any particular use, including any patent infringement arising therefrom, is the sole responsibility of the user."

SAE reviews each technical report at least every five years at which time it may be reaffirmed, revised, or cancelled. SAE invites your written comments and suggestions.

Copyright © 2011 SAE International

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, without the prior written permission of SAE.

**TO PLACE A DOCUMENT ORDER:** Tel: 877-606-7323 (inside USA and Canada)  
Tel: +1 724-776-4970 (outside USA)  
Fax: 724-776-0790  
Email: CustomerService@sae.org  
http://www.sae.org

**SAE WEB ADDRESS:**

**SAE values your input. To provide feedback  
on this Technical Report, please visit  
<http://www.sae.org/technical/standards/AS20708/25A>**

## 1. SCOPE

This specification covers the detail requirements for control transformer synchro, type 16CTB4b, 90 volt, 400 cycle.

## 2. APPLICABLE DOCUMENTS

The following publications form a part of this document to the extent specified herein. The latest issue of SAE publications shall apply. The applicable issue of the other publications shall be the issue in effect on the date of the purchase order. In the event of conflict between the text of this document and references cited herein, the text of this document takes precedence. Nothing in this document, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

### 2.1 SAE Publications

Available from SAE International, 400 Commonwealth Drive, Warrendale, PA 15096-0001, Tel: 877-606-7323 (inside USA and Canada) or 724-776-4970 (outside USA), [www.sae.org](http://www.sae.org).

AS20708      Synchros, General Specification For

### 2.2 U. S. Government Publications

Available from the Document Automation and Production Service (DAPS), Building 4/D, 700 Robbins Avenue, Philadelphia, PA 19111-5094, Tel: 215-697-6257, <http://assist.daps.dla.mil/quicksearch/>.

## COMMERCIAL ITEM DESCRIPTION

A-A-208      Ink, Marking, Stencil, Opaque (Porous and Non-porous Surfaces)

## DRAWINGS

### BUREAU OF ORDNANCE (CAGE 10001)

643019      Clamp Assembly

643090      Washer, Drive

644594      Nut

LD 255268      Stock Material for Precision Instrument Components

(Copies of these documents required by contractors in connection with specific acquisition functions may be obtained from the procuring activity at [DSCC.cddwgs@dla.mil](mailto:DSCC.cddwgs@dla.mil), or as directed by the contracting officer.)

## 3. QUALIFICATION

Except when first article testing are required, synchros covered by this specification shall be a product which has been tested and qualified in accordance with SAE AS20708.

First article sample: Pending issuance of a Qualified Products List (Q.P.L.), a sample of the synchros to be furnished under this specification shall be subjected to the first article tests as specified in SAE AS20708.

#### 4. REQUIREMENTS

All requirements shall be in accordance with SAE AS20708 except as otherwise specified herein.

Salt spray requirement: Not applicable.


Design and construction: The synchro shall be of the design, construction, and physical dimensions specified in Figure 1, and shall be complete, including all hardware shown and identified thereon.

Performance requirements: The values applicable to the synchro shall be as specified in Table 1.

TABLE 1 - SYNCHRO, CONTROL TRANSFORMER, TYPE 16CTB4b

Requirement	Unit	Value
Frequency	Cycles	400
Primary voltage (nominal)	Volts	90
Primary current (maximum)	Milliamps	24
Primary power (maximum)	Watts	0.35
Transformation ratio $\pm 2\%$		0.735
Electrical error (maximum)	Minutes	10
Null voltage total (maximum)	Millivolts	60
Fundamental component of null voltage (maximum)	Millivolts	40
Friction torque (maximum)	Ounce-inches	0.05
Phase shift	Degrees	8.0 (lead)
Primary impedance ( $Z_p$ )	Ohms	<u>1/</u>
Secondary impedance ( $Z_s$ )	Ohms	<u>1/</u>

1/ As specified by the Bureau of Ordnance.



DATA ELEMENT	SPLINE 1/	GEAR 2/
TEETH	21	96
PITCH	120	72
PITCH DIAMETER	0.175 +0.000 -0.002	1.3333 +0.0000 -0.0005
OUTSIDE DIAMETER	0.1872 +0.0000 -0.0005	1.3611 +0.0000 -0.0005
PRESSURE ANGLE	20°	20°
ROOT DIAMETER MAX.	0.155	1.2959
TOOTH FORM	FULL DEPTH INVOLUTE	FULL DEPTH INVOLUTE

1/ The end function of this spline is for positive rotational fastenings. It is not to be used as a gear.

2/ The Outer Diameter (O.D.) of this gear shall be concentric with respect to the 1.3120 diameter collar, within 0.0015. The shaft shall be locked to the outer housing and the shaft mark shall be in line with the outer housing arrow.

FIGURE 1 – SYNCHRO, CONTROL TRANSFORMER TYPE 16CTB4B