



UL 1047

STANDARD FOR SAFETY

Isolated Power Systems Equipment

ULNORM.COM : Click to view the full PDF of UL 1047 2025

[ULNORM.COM](https://ulnorm.com) : Click to view the full PDF of UL 1047 2025

ULSE INC. COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM ULSE INC.

UL Standard for Safety for Isolated Power Systems Equipment, UL 1047

Seventh Edition, Dated March 26, 2025

SUMMARY OF TOPICS

This new Seventh Edition of ANSI/UL 1047 dated March 26, 2025 incorporates editorial updates from the February 21, 2025 proposal(s) bulletin. Other editorial updates include renumbering and reformatting to align with current style.

The revised requirements are substantially in accordance with Proposal(s) on this subject dated February 21, 2025.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

ULNORM.COM : Click to view the full PDF of UL 1047 2025

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 1047 2025

MARCH 26, 2025



ANSI/UL 1047-2025

1

UL 1047

Standard for Isolated Power Systems Equipment

First Edition – August, 1976
Second Edition – December, 1990
Third Edition – March, 1995
Fourth Edition – September, 2003
Fifth Edition – October, 2010
Sixth Edition – October, 2015

Seventh Edition

March 26, 2025

This ANSI/UL Standard for Safety consists of the Seventh Edition.

The most recent designation of ANSI/UL 1047 as an American National Standard (ANSI) occurred on March 26, 2025. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to ULSE at any time. Proposals should be submitted via a Proposal Request in the Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

© 2025 ULSE Inc. All rights reserved.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 1047 2025

CONTENTS

INTRODUCTION

1	Scope	5
2	Glossary	5
3	Components	6
4	Units of Measurement	6
5	Referenced Publications	7

CONSTRUCTION

6	General	7
7	Enclosure	8
8	Ventilation	8
9	Connections for Wiring Systems	9
10	Corrosion Protection	9
11	Bases – Insulating Material	10
12	Mounting of Parts	10
13	Current-Carrying Parts	12
14	Permanently Connected Equipment	13
15	Field-Wiring Terminals and Leads	13
16	Cord-Connected Equipment	15
	16.1 General	15
	16.2 Strain relief	15
	16.3 Bushings	16
17	X-Ray Equipment	16
18	Wall Modular Units	16
19	Internal Wiring	17
20	Separation of Circuits	18
	20.1 Factory installed	18
	20.2 Field-installed Class 2	18
21	Field-Wiring Space	19
	21.1 General	19
	21.2 Wire bending space	19
22	Spacings	22
23	Isolation Transformers	25
24	Line Isolation Monitor	26
25	Overcurrent Protection	27
26	Switches	27
27	Receptacles	27
28	Grounding Jacks and Cord Assemblies	28
29	Reference Grounding Bus	28

PERFORMANCE

30	Regulation	31
31	Temperature	31
32	Leakage Current	34
33	Dielectric Voltage-Withstand	41
34	Stability	41
35	Strength of Insulating Base and Supports	42
36	Abnormal Operation	42
37	Push-Back Relief	42

MANUFACTURING AND PRODUCTION TESTS

38 Production-Line Dielectric Voltage-Withstand42
39 Production-Line Grounding Continuity.....44

RATING

40 Details.....44

MARKING

41 Details.....44

ULNORM.COM : Click to view the full PDF of UL 1047 2025

INTRODUCTION

1 Scope

1.1 These requirements cover isolated power systems equipment rated 600 Vac or less, intended for installation and use in nonhazardous areas in health care facilities in accordance with the requirements in Article 517 of the National Electrical Code, NFPA 70, and in the Standard for Health Care Facilities, NFPA 99.

1.2 These requirements cover isolated power centers, either cord-connected or permanently wired, consisting of a distribution panel that incorporates an isolation transformer, one or more isolated ungrounded secondary circuits terminating in integrally mounted grounding-type receptacles, a reference grounding bus bar, and line isolation monitor. Isolated power centers may have provision for connection of grounding conductors to remote grounding jacks, the room bonding points, and patient equipment grounding points. A permanently wired isolated power center may also have provision for connection to remote receptacles or indicators.

1.3 These requirements cover convertible system units that facilitate a temporary conversion of the power supply for a power center from a grounded supply to an isolated supply.

1.4 These requirements cover isolated power panelboards that incorporate the same features as permanently wired isolated power centers except that:

- a) They may be supplied from remote isolation transformers; and
- b) The secondary isolated circuits are intended to be connected by conduit to remotely located receptacles.

1.5 These requirements cover wall modular units containing isolated power systems.

1.6 These requirements cover cord-connected isolated power centers, and panels intended to supply x-ray equipment only.

2 Glossary

2.1 For the purpose of this Standard the following definitions apply.

2.2 **CONVERTIBLE SYSTEM UNIT** – An enclosed assembly incorporating an isolation transformer and line isolation monitor with interconnecting cord assemblies that facilitate temporary conversion of the power supply for a power center from a grounded supply to an isolated supply. The unit is intended for use only with the specific power centers for which it has been designed.

2.3 **FIELD-WIRING TERMINAL** – A terminal to which a supply or other wire can be connected by an installer in the field is a field-wiring terminal unless a lead is provided as part of a pressure terminal connector, or other means for making the connection is factory-assembled to the wire.

2.4 **LINE ISOLATION MONITOR** – A test instrument designed to continually check the balanced and unbalanced impedance from each line of an isolated circuit to ground and equipped with a built-in test circuit to actuate an alarm without adding to the leakage current.

2.5 **MOMENTARY RATING** – A rating based on an operating interval that does not exceed 5 seconds.

2.6 PATIENT EQUIPMENT GROUNDING POINT – A jack or terminal bus that serves as the collection point for redundant grounding of electric appliances serving a patient vicinity or for grounding other items in order to eliminate electromagnetic interference problems.

2.7 REFERENCE GROUNDING POINT – A terminal bus that is an extension of the equipment grounding bus and is a convenient collection point for grounding all electric appliances, equipment, and exposed conductive surfaces in a patient vicinity.

2.8 ROOM BONDING POINT – A grounding terminal bus that serves as the collection point for grounding exposed metal or conductive building surfaces in a room.

2.9 WALL MODULAR UNIT – A factory-built wall section or sections typically containing various combinations of gas outlets, lighting fixtures, clocks, intercommunication units, and the like for use in, within, or as part of health-care facilities. Only units containing isolated power systems equipment are covered by this Standard. Grounded power circuits that are physically segregated and separated may also be included.

3 Components

3.1 A component of a product covered by this Standard shall:

- a) Comply with the requirements for that component as specified in this Standard;
- b) Be used in accordance with its rating(s) established for the intended conditions of use; and
- c) Be used within its established use limitations or conditions for acceptability.

3.2 A component of a product covered by this Standard is not required to comply with a specific component requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this Standard; or
- b) Is superseded by a requirement in this Standard; or
- c) Is separately evaluated when forming part of another component, provided the component is used in accordance with its established ratings and limitations.

3.3 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

3.4 A component that is also intended to perform other functions such as overcurrent protection, ground-fault circuit-interruption, surge suppression, any other similar functions, or any combination thereof, shall comply additionally with the requirements of the applicable standard(s) that cover devices that provide those functions.

4 Units of Measurement

4.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.