



UL 2238

STANDARD FOR SAFETY

Cable Assemblies and Fittings for
Industrial Control and Signal
Distribution

ULNORM.COM : Click to view the PDF of UL 2738 2024

UL Standard for Safety for Cable Assemblies and Fittings for Industrial Control and Signal Distribution, UL 2238

Third Edition, Dated October 2, 2018

Summary of Topics

This revision of ANSI/UL 2238 dated December 5, 2024 includes Overload/Resistance to Arcing testing for either AC or DC General Use Disconnecting under load conditions; [24A.4](#), [24A.4A](#), [24A.5](#), [24A.5A](#), and [40.1.6](#)

Text that has been changed in any manner or impacted by ULSE's electronic publishing system is marked with a vertical line in the margin.

The revised requirements are substantially in accordance with Proposal(s) on this subject dated November 1, 2024.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

ULNORM.COM : Click to view the full PDF of UL 2238 2024

OCTOBER 2, 2018
(Title Page Reprinted: December 5, 2024)



ANSI/UL 2238-2024

1

UL 2238

Standard for Cable Assemblies and Fittings for Industrial Control and Signal

Distribution

First Edition – February, 2009
Second Edition – May, 2011

Third Edition

October 2, 2018

This ANSI/UL Standard for Safety consists of the Third Edition including revisions through December 5, 2024.

The most recent designation of ANSI/UL 2238 as an American National Standard (ANSI) occurred on December 5, 2024. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to ULSE at any time. Proposals should be submitted via a Proposal Request in the Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

© 2024 ULSE Inc. All rights reserved.

ULNORM.COM Click to view the full PDF of UL 2138 2024

CONTENTS

INTRODUCTION

1	Scope	7
2	Glossary	8
3	References	10
3A	Referenced Publications	10
4	Components	12
5	Units of Measurement	12

CONSTRUCTION

6	Accessibility of Uninsulated Live Parts	12
	6.1 General	12
	6.2 Valve fittings	14
7	Insulating Materials	14
	7.1 General	14
	7.2 Flammability	14
	7.3 Electrical properties	15
	7.4 Thermal properties	17
8	Live Parts	18
9	Grounding and Dead-Metal Parts	18
10	Terminals	19
11	Strain Relief and Cord Entries	20
12	Spacings	21
13	Assembly	21
	13.1 General	21
	13.2 Polarization	22
	13.3 Mating and interchangeability	22
	13.4 Fittings	22
	13.5 Identification and wiring	22
14	Enclosure	23
15	Cable Assemblies	24
	15.1 General	24
	15.2 Flexible cord or cable	24
16	Mounting	24
17	Outdoor Use	24

PERFORMANCE

18	General	25
19	Mold Stress-Relief Distortion Test	26
20	Moisture Absorption Resistance Test	27
21	Dielectric Voltage-Withstand Test	27
22	Insulation Resistance Test	28
23	Conductor Secureness Test	28
24	Strain-Relief Test	29
	24.1 Cord-to-fitting test	29
	24.2 Feeder-tap cable systems test	29
24A	Overload Test	30
25	Temperature Test	31
25A	Resistance to Arcing Test	32
26	Current-Cycling and Vibration Test	32
	26.1 General	32

26.2	Current-cycling before vibration test	33
26.3	Vibration test	33
26.4	Current-cycling after vibration test	33
26.5	Calculations	33
27	Jacket Retention Test	33
28	Polarization Test	34
29	Adhesion Test	34
30	Environmental Enclosure Tests	34
31	Grounding Impedance Test	34
32	Fault Current Test	35
33	Cable Pullout Test (For Pin Type or Insulation Displacement Type Terminals)	35
34	Creep Test (For Pin Type or Insulation Displacement Type Terminals)	36
35	Comparative Tracking Index Test	36
36	Glow Wire Test	36
37	High-Current Arc Resistance to Ignition Test	36
37.1	General	36
37.2	Strength of insulation base test	37
37.3	Grounding (bonding) path current test	37
37.4	Assembly test	38
37.5	Accelerating aging tests	38
37.6	PVC compounds and copolymers	39
37.7	Crushing test for valve connectors only	39
37.8	Impact test for valve connectors only	39
37.9	Low temperature test for valve connectors only	40
37.10	Tests for permanence of flag type cord or cable tag	40
37.11	Tests for permanence of wrap around cord or cable label	41
37.12	Test conditions	42

MANUFACTURING AND PRODUCTION TESTS

38	Dielectric Voltage-Withstand Test	43
----	---	----

RATINGS

39	General	44
----	---------------	----

MARKINGS

40	Details	44
40.1	General	44
40.2	Feeder-tap cable systems	46
40.3	Field assembled cable system	47

INSTRUCTIONS

41	Installation and Operating Instructions	47
41.1	General	47
41.2	Wiring information – field wiring terminals	48

SUPPLEMENT SA – Short Circuit Current Rated (SCCR) Cable Assemblies and Fittings for Industrial Control and Signal Distribution

INTRODUCTION

SA1	Scope	51
-----	-------------	----

SA2	Glossary	51
SA3	General.....	51

CONSTRUCTION

SA4	General.....	51
SA4.1	General.....	51
SA4.2	Short circuit current ratings	51

PERFORMANCE

SA5	Short-Circuit Withstand Test	51
SA5.1	General.....	51
SA5.2	Protective devices.....	52
SA5.3	Calibration of test circuits.....	55
SA5.4	Alternating-current circuits	55
SA5.5	Available current of 10,000 A or less	56
SA5.6	Available current of 10,000 A	57
SA5.7	Instrumentations for test currents above 10,000 A	58
SA5.8	Direct current circuits.....	60
SA5.9	Calibration characteristics for protective device	61

MARKINGS

SA6	Details	63
-----	---------------	----

APPENDIX A

Standards for Components	65
--------------------------------	----

ULNORM.COM : Click to view the full PDF of UL 2738 2024

INTRODUCTION

1 Scope

1.1 These requirements cover devices intended for inter-connection of equipment, sensors, and actuators in remote-control, signaling, and power-limited circuits. Included are cable assemblies and fittings, feeder-tap cable systems, feed-through connectors, multi-outlet fittings, panel-mount fittings, and splitters. These devices are rated not more than 60 A and not more than 600 V.

1.1.1 These devices are not intended for disconnect means and are marked as described in [40.1.6](#).

1.1.2 Devices may be investigated for use as a disconnecting means under load conditions, if so requested and the device complies with the overload, temperature, resistance to arcing and dielectric voltage withstand testing as described in [Table 18.1](#).

1.2 This standard also contains Supplement [SA](#) – Short Circuit Current Rated (SCCR) Cable Assemblies and Fittings for Industrial Control and Signal Distribution.

1.3 Unless otherwise noted, all devices are intended for indoor use.

1.4 These devices are for use on alternating current, direct current, or both.

1.5 The cable assembly fittings and panel-mount fittings are intended to be installed in accordance with the manufacturer's installation instructions. The cable assembly fittings are intended to be assembled or molded on flexible cord.

1.6 Each type of device covered by this standard is described in generic terms where practicable. Reference to use locations identified in the National Electrical Code or specific applications are omitted unless they are required for the identification of the device type. Such additional information is included in the applicable standards for the end-use product involved or in markings for the device.

1.7 This standard does not cover male-to-male cable assemblies with the exception of Class 2 circuits.

1.8 This standard does not directly apply to the following but may supplement other applicable standards:

a) Devices produced integrally with flexible cord or cable that are covered by the Standard for Cord Sets and Power-Supply Cords, UL 817;

b) Devices intended for connection to the branch circuit, such as attachment plugs, cord connectors, receptacles, inlets, and outlets, that are covered by the Standard for Attachment Plugs and Receptacles, UL 498;

c) Devices solely intended for direct connection to the branch circuit in accordance with the National Electrical Code, NFPA 70, and that are provided with contacts of the pin and sleeve type, covered by the Standard for Plugs, Receptacles, and Cable Connectors, of the Pin and Sleeve Type, UL 1682;

d) Devices intended to interconnect industrial machinery and to be installed in accordance with the Electrical Standard for Industrial Machinery, NFPA 79 that are covered by the Outline of Investigation for Multi-point Interconnection Power Cable Assemblies For Industrial Machinery, UL 2237;

e) Connectors intended for use in Data, Signal, Control and Power Applications within and between electrical equipment and intended for factory assembly as covered by the Standard for Component

Connectors for Use in Data, Signal, Control and Power Applications, UL 1977; and the Standard for Telephone Equipment, UL 1459, or the Standard for Communications Circuit Accessories, UL 1863;

1.9 Fittings and devices that employ surge protective devices and/or circuitry to provide surge protection of internal functionality, in addition to complying with the requirements of this standard, shall also comply with the construction and performance requirements for Type 4 component assemblies or for Type 5 components, as appropriate, in accordance with the Standard for Surge Protective Devices, UL 1449.

1.10 Fittings and devices that are intended to provide surge protection of connected equipment and wiring, in addition to the requirements of this standard, shall also be evaluated to the requirements (including ratings and markings) for either Type 2 or Type 3 (surge protective devices) applications in accordance with the Standard for Surge Protective Devices, UL 1449.

2 Glossary

2.1 For the purpose of this standard the following definitions apply.

2.2 CABLE ASSEMBLY – A length of flexible cord or cable with an male cable fitting as a line fitting and a female cable fitting as a load fitting.

2.2A CLASS 2 CIRCUIT – A control circuit supplied from a source having limited voltage (30 V rms (42 V peak) or less, such as from the secondary of a Class 2 transformer, and rated for use with Class 2 remote-control or signaling circuits. The potential shall not be greater than 15V rms (21.2 V peak) under conditions where wet access may occur, including products identified for use outdoors.

2.3 CORD or CABLE TAG – An adhesive backed label that is wrapped around the cord or cable and secured to itself forming a flag that protrudes from the cord or cable. A label without adhesive that is secured to the cord or cable using a securement strap such as a cable tie is also consider a cord tag.

2.4 CURRENT-CARRYING CONDUCTOR – A cord conductor excluding both the grounding conductor and the neutral conductor.

2.5 ENCLOSURE – That part of the device that renders inaccessible all or any parts of the device that otherwise present a risk of electric shock, propagate of flame initiated by electrical disturbances occurring within, or both.

2.6 FEEDER-TAP CABLE SYSTEM – A connector provided with field-wiring terminals for feed-through connection to power-limited tray cable or other appropriate cable and either a female connector to connect to a cable assembly or field-wiring terminals to connect to flexible cord.

2.7 FEED-THROUGH CONNECTOR – A male and female device directly connected through the pins or contacts. This device is not assembled on a cable or conductor.

2.8 FEMALE CABLE FITTING – A female contact device intended to be molded or assembled to flexible cord to make an electrical connection to a male cable fitting or an inlet.

2.9 GROUNDED CONDUCTOR – The circuit conductor that is intentionally grounded.

2.10 GROUNDING-CONDUCTOR PATH – A path between the grounding pin or contact and the grounding terminal.

2.11 INLET – A male contact device intended to be mounted on equipment where the conductors are internal to the equipment to provide an integral means for the connection of a female cable fitting.

2.12 INSULATION, BASIC – Insulation applied to live parts to provide basic protection against a risk of electric shock. This insulation does not necessarily include insulation used exclusively for functional purposes.

2.13 INSULATION, FUNCTIONAL – The insulation necessary for the proper functioning of the fitting and for basic protection against a risk of electric shock. This includes all parts relied upon to support live parts in place, all internal barriers necessary to maintain spacing, and the outlet face portion of all female fittings.

2.14 MALE CABLE FITTING – A male contact device intended to be molded or assembled to a flexible cord or cable to make an electrical connection to a female panel-mount fitting, a female cable fitting, or outlet.

2.15 OUTLET – A female contact device intended to be mounted on equipment where the conductors are internal to the equipment to provide an integral means for the connection of a male cable fitting.

2.16 POLARIZED DEVICE – A device constructed for connection to a mating fitting only in the position that connects related poles of an electrical circuit.

2.17 SMALL PARTS – A small part is considered to be not more than 0.122 in^3 (2 cm^3) in volume.

2.18 SPLITTER – A male fitting that terminates in two or more outlets or that terminates in two or more female cable fittings.

2.19 TERMINAL, INSULATION-DISPLACEMENT – A terminal having a contacting member that forces the conductor insulation aside and presses to contact the current-carrying conductor.

2.20 TERMINAL, PIN TYPE (INSULATION-PIERCING) – A terminal having a contact pin that punctures the conductor insulation to contact the current-carrying conductor.

2.21 TERMINAL, PRESSURE WIRE – A terminal that establishes a connection between one or more conductors and a terminal plate by means of mechanical pressure without the use of solder. The terminal is one of the following types:

a) Clamp-type – A terminal in which the conductor is held under a pressure plate or saddle clamp by one or more screws. This type of terminal may be provided in combination with a wire-binding screw terminal.

b) Setscrew-type – A terminal in which the pressure is applied by the end of the screw bearing on the conductor, either directly or through a wire-protecting pad.

2.22 TERMINAL, WIRE-BINDING SCREW – A terminal in which the conductor is bent around the screw and is clamped directly under the head of the screw when it is tightened.

2.23 TERMINAL, CRIMP TYPE – A terminal in which an electro-mechanical connection is made between the terminal lug and a conductor by compressing the lug onto the conductors.

2.24 UNIT CONTAINER – The smallest carton, package, or container, in which a fitting is packaged. A unit container may contain more than one fitting if the devices are not intended to be removed from the container for individual sale.

2.25 VALVE FITTING – A male or female fitting contact device intended to be molded or assembled to a flexible cord or cable or assembled to conduit and is intended to be connected or assembled to a valve.

2.26 WRAP AROUND CORD or CABLE LABEL – An adhesive backed label that wraps around the cord or cable and adheres to the cord or cable itself or the wrap around label.

3 References

3.1 Deleted

3A Referenced Publications

3A.1 Any undated reference to a code or standard appearing in the requirements of this Standard shall be interpreted as referring to the latest edition of that code or standard.

3A.2 The following publications are referenced in this Standard:

ASTM D570, *Standard Test Method for Water Absorption of Plastics*

ASTM E230/ASTM E230M, *Standard Specification for Temperature-Electromotive Force (emf) Tables for Standardized Thermocouples*

ASTM G152, *Standard Practice for Operating Open Flame Carbon Arc Light Apparatus for Exposure of Nonmetallic Materials*

ASTM G153, *Standard Practice for Operating Enclosed Carbon Arc Light Apparatus for Exposure of Nonmetallic Materials*

NFPA 70, *National Electrical Code*

NFPA 79, *Electrical Standard for Industrial Machinery*

UL 50, *Enclosures for Electrical Equipment, Non-Environmental Considerations*

UL 50E, *Enclosures for Electrical Equipment, Environmental Considerations*

UL 62, *Flexible Cords and Cables*

UL 94, *Tests for Flammability of Plastic Materials for Parts in Devices and Appliances*

UL 224, *Extruded Insulating Tubing*

UL 248-1, *Low-Voltage Fuses – Part 1: General Requirements*

UL 248-2, *Low-Voltage Fuses – Part 2: Class C Fuses*

UL 248-3, *Low-Voltage Fuses – Part 3: Class CA and CB Fuses*

UL 248-4, *Low-Voltage Fuses – Part 4: Class CC Fuses*

UL 248-5, *Low-Voltage Fuses – Part 5: Class G Fuses*

UL 248-6, *Low-Voltage Fuses – Part 6: Class H Non-Renewable Fuses*

UL 248-7, *Low-Voltage Fuses – Part 7: Class H Renewable Fuses*

UL 248-8, *Low-Voltage Fuses – Part 8: Class J Fuses*

UL 248-9, *Low-Voltage Fuses – Part 9: Class K Fuses*

UL 248-10, *Low-Voltage Fuses – Part 10: Class L Fuses*

UL 486A-486B, *Wire Connectors*

UL 486E, *Equipment Wiring Terminals for Use with Aluminum and/or Copper Conductors*

UL 498, *Attachment Plugs and Receptables*

UL 508, *Industrial Control Equipment*

UL 510, *Polyvinyl Chloride, Polyethylene and Rubber Insulating Tape*

UL 514B, *Conduit, Tubing, and Cable Fittings*

UL 746A, *Polymeric Materials – Short Term Property Evaluations*

UL 746B, *Polymeric Materials – Long Term Property Evaluations*

UL 746C, *Polymeric Materials – Use in Electrical Equipment Evaluations*

UL 758, *Appliance Wiring Material*

UL 796, *Printed-Wiring Boards*

UL 817, *Cord Sets and Power-Supply Cords*

UL 969, *Marking and Labeling Systems*

UL 969A, *Marking and Labeling Systems – Flag Labels, Flag Tags, Wrap-Around Labels and Related Products*

UL 1059, *Terminal Blocks*

UL 1449, *Surge Protective Devices*

UL 1459, *Telephone Equipment*

UL 1682, *Plugs, Receptables, and Cable Connectors of the Pin and Sleeve Type*

UL 1863, *Communications-Circuit Accessories*

UL 1977, *Component Connectors for Use in Data, Signal, Control and Power Applications*

UL 2237, *Multi-Point Interconnection Power Cable Assemblies for Industrial Machinery*

UL 2238, Cable Assemblies and Fittings for Industrial Control and Signal Distribution

4 Components

4.1 Except as indicated in [4.2](#), a component of a product covered by this standard shall comply with the requirements for that component. See Appendix [A](#) for a list of standards covering components used in the products covered by this standard.

4.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

4.3 A component shall be used in accordance with its rating established for the intended conditions of use.

4.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

5 Units of Measurement

5.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

CONSTRUCTION

6 Accessibility of Uninsulated Live Parts

6.1 General

6.1.1 Uninsulated live parts, other than exposed wiring terminals, and internal wiring shall not be accessible to contact by the probe illustrated in [Figure 6.1](#). The probe is to be applied with a force of 3 lbf (13.3 N). The probe is to be rotated, changed in configuration, or angled; before, during, and after application.

Exception: A device having exposed Class 2 output contacts or pins that may be contacted during normal operation or servicing need not be tested.

