



UL 346

STANDARD FOR SAFETY

Waterflow Indicators for Fire Protective Signaling Systems

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 346 2025

ULNORM.COM : Click to view the full PDF of UL 346 2025

UL Standard for Safety for Waterflow Indicators for Fire Protective Signaling Systems, UL 346

Fifth Edition, Dated June 30, 2005

Summary of Topics

This revision of ANSI/UL 346 dated February 26, 2025 includes updates to the Electronic Installation Instructions; [39.1](#), [39.3](#), [39.4](#), and [39.5](#).

Text that has been changed in any manner or impacted by ULSE's electronic publishing system is marked with a vertical line in the margin.

The new and revised requirements are substantially in accordance with Proposal(s) on this subject dated January 24, 2025.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 346 2025

JUNE 30, 2005
(Title Page Reprinted: February 26, 2025)



ANSI/UL 346-2025

1

UL 346

Standard for Waterflow Indicators for Fire Protective Signaling Systems

First Edition – July, 1975
Second Edition – September, 1979
Third Edition – September, 1988
Fourth Edition – May, 1994

Fifth Edition

June 30, 2005

This ANSI/UL Standard for Safety consists of the Fifth Edition including revisions through February 26, 2025.

The most recent designation of ANSI/UL 346 as an American National Standard (ANSI) occurred on February 26, 2025. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to ULSE at any time. Proposals should be submitted via a Proposal Request in the Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

© 2025 ULSE Inc. All rights reserved.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 346 2025

CONTENTS

INTRODUCTION

1	Scope	5
2	General	5
	2.1 Units of measurement	5
	2.2 Components	5
	2.3 Undated references	5
3	Glossary	5

CONSTRUCTION

4	General	6
	4.1 Installation	6
	4.2 Retard feature	6
	4.3 Working pressures	6
	4.4 Mounting positions	7
5	Enclosure	7
	5.1 General	7
	5.2 Cast metal enclosures	7
	5.3 Sheet metal enclosures	8
	5.4 Nonmetallic enclosures	8
6	Electric Shock	9
7	Drain Holes	9
8	Protection Against Corrosion	9
9	Field Wiring Connections	10
	9.1 Field wiring terminals and leads	10
	9.2 Field wiring compartment	11
	9.3 Grounded supply terminal and leads	11
	9.4 Strain relief	11
10	Grounding and Bonding for Grounding	11
11	Internal Wiring	12
	11.1 General	12
	11.2 Wireways	13
	11.3 Bushings	13
	11.4 Splices	13
12	Components	13
	12.1 Adjustments and stops	13
	12.2 Barriers	14
	12.3 Coil windings	14
	12.4 Current-carrying parts	14
	12.5 Insulating materials	14
	12.6 Metallic components	15
	12.7 Nonmetallic components	15
	12.8 Mounting of parts	15
	12.9 Tamper protection	16
	12.10 Operating mechanisms	16
	12.11 Printed wiring boards	16
	12.12 Switches	17
13	Spacings	17
14	Servicing and Maintenance	18

PERFORMANCE

15	General	18
	15.1 Test units	18
	15.2 Test voltages	19
	15.3 Test samples and data	19
16	Normal Operation Test.....	20
	16.1 General.....	20
	16.2 Coded waterflow indicators.....	21
	16.3 Noncoded waterflow indicators	22
17	Calibration Test – Retard Feature	22
18	Endurance Test – Retard Feature	22
19	Overload and Endurance Test	22
20	Temperature Test	23
21	Electrical Transient Tests	25
	21.1 General.....	25
	21.2 Supply line transients	26
	21.3 Input/output circuit transients (low-voltage appliances)	26
22	Dielectric Voltage-Withstand Test	26
23	Electric Shock Current Test	27
24	Corrosion Test.....	31
25	Abnormal Tests	31
26	Burnout Test	31
27	Tests of Polymeric Materials	32
	27.1 Air-oven aging test.....	32
	27.2 Flame test	32
	27.3 Immersion test.....	33
28	Flexing Test (Vane Assembly)	33
29	Impact Test	33
30	Tests of Elastomeric Materials	34
	30.1 Oven aging test	34
	30.2 Hardness measurement	34
	30.3 Immersion test (saddle gasket)	34
31	Immersion Test (Indicator Assembly)	34
32	Sensitivity Test	35
33	Hydraulic Friction Loss Test.....	37
34	Surge Test	37
35	Hydrostatic Strength Test.....	37

MANUFACTURING AND PRODUCTION TESTS

36	Introduction.....	38
	36.1 General.....	38
	36.2 Sensitivity and retard calibration test	38
	36.3 Hydrostatic strength test.....	38
37	Production-Line Dielectric Voltage-Withstand Test	38

MARKING

38	General	39
39	Instructions and Installation Drawings	40

INTRODUCTION

1 Scope

1.1 These requirements cover vane type waterflow indicators intended for use in fire protective signaling systems to be employed in ordinary indoor locations, in accordance with the National Fire Alarm Code, NFPA 72.

1.2 Waterflow indicators covered by these requirements include sizes 3/4 inch and larger. The indicator sizes refer to the nominal inside diameter of the main sprinkler pipe or tubing on which they are installed.

1.3 A vane type waterflow indicator is an assembly of a mechanism having electrical contacts arranged to transmit a coded or noncoded signal when the vane, located in the supply pipe (riser) of a sprinkler system, is moved by the flow of water in the pipe. This flow is normally caused by the opening of one or more sprinkler heads resulting from a fire condition. The signaling contacts are intended to be connected to circuits of private fire protective signaling systems.

1.4 These requirements do not cover pressure-operated waterflow indicators.

2 General

2.1 Units of measurement

2.1.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

2.2 Components

2.2.1 Except as indicated in [2.2.2](#), a component of a product covered by this standard shall comply with the requirements for that component.

2.2.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

2.2.3 A component shall be used in accordance with its rating established for the intended conditions of use.

2.2.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

2.3 Undated references

2.3.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

3 Glossary

3.1 For the purpose of this standard, the following definitions apply.