



---

# UL 441

## STANDARD FOR SAFETY

### Gas Vents

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 441 2019

[ULNORM.COM](https://ULNORM.COM) : Click to view the full PDF of UL 441 2019

UL Standard for Safety for Gas Vents, UL 441

Eleventh Edition, Dated April 8, 2016

**Summary of Topics**

***This revision to ANSI/UL 441 dated August 28, 2019 is being issued to update the title page to reflect the most recent designation as a Reaffirmed American National Standard (ANS). No technical changes have been made.***

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The requirements are substantially in accordance with Proposal(s) on this subject dated June 28, 2019.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

ULNORM.COM : Click to view the full PDF of UL 441 2019

No Text on This Page

[ULNORM.COM](http://ULNORM.COM) : Click to view the full PDF of UL 441 2019

**APRIL 8, 2016**  
(Title Page Reprinted: August 28, 2019)



**ANSI/UL 441-2006 (R2019)**

1

## **UL 441**

### **Standard for Gas Vents**

First Edition – September, 1958  
Second Edition – January, 1969  
Third Edition – January, 1971  
Fourth Edition – July, 1973  
Fifth Edition – July, 1979  
Sixth Edition – March, 1986  
Seventh Edition – September, 1991  
Eighth Edition – October, 1994  
Ninth Edition – January, 1996  
Tenth Edition – March, 2010

### **Eleventh Edition**

**April 8, 2016**

This ANSI/UL Standard for Safety consists of the Eleventh Edition including revisions through August 28, 2019.

The most recent designation of UL 441 as a Reaffirmed American National Standard (ANS) occurred on August 19, 2019. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

The Department of Defense (DoD) has adopted UL 441 on September 16, 1991. The publication of revised pages or a new edition of this Standard will not invalidate the DoD adoption.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

**COPYRIGHT © 2019 UNDERWRITERS LABORATORIES INC.**

No Text on This Page

[ULNORM.COM](http://ULNORM.COM) : Click to view the full PDF of UL 441 2019

## CONTENTS

### INTRODUCTION

1 Scope .....	5
2 Components .....	5
3 Units of Measurement .....	6
4 Undated References .....	6
5 Glossary .....	6

### CONSTRUCTION

6 Materials .....	7
7 Assembly .....	9
8 Caps .....	11
9 Firestops .....	11
10 Spacers .....	11
11 Joints .....	12
12 Radiation Shields .....	12
13 Roof Assemblies .....	13
14 Roof Jacks .....	13
15 Fittings .....	13
16 Sizes .....	13
17 Support Assembly .....	14

### PERFORMANCE

18 General .....	14
19 Test Installation .....	15
19.1 General .....	15
19.2 Type B vents – Form I test structure .....	26
19.3 Type B vents – Form II test structure .....	26
19.4 Type BW vents – Form III test structure .....	27
19.5 Type B Gas vent roof jacks – Forms IV and V test structures .....	27
19.6 Type BW gas vent roof jacks – Form VI test structure .....	28
20 Temperature Measurement .....	28
21 Temperature Test – Structures .....	33
21.1 General .....	33
21.2 Test type BW gas vent or roof jack test structure Forms III and VI .....	35
22 Temperature Test – Gas-Vent Pipe Surfaces .....	35
23 Draft Loss and Wind Effects Test .....	36
24 Vertical Support Test .....	37
25 Strength Test .....	37
25.1 General .....	37
25.2 Impact test .....	38
25.3 Longitudinal force test .....	40
26 Wind Load Test .....	40
27 Rain Test .....	42
28 Crushing Test of Nonmetallic Flue-Gas Conduit .....	45
29 Resistance to Action of Acids Test of Nonmetallic Flue-Gas Conduit .....	46
30 Freezing and Thawing Test of Water-Absorptive Nonmetallic Materials .....	46
31 Cemented Joint Test of Flue-Gas Conduit .....	47

32 Sulfuric Acid Extraction Test for Porcelain-Coated Steel Used for Flue-Gas Conduit . . . . .47

**MARKING**

33 General . . . . .48

**INSTRUCTIONS**

34 Installation Instructions . . . . .49

*ULNORM.COM : Click to view the full PDF of UL 441 2019*

## INTRODUCTION

### 1 Scope

1.1 These requirements cover Types B and BW gas vents and Types B and BW gas vent roof jacks intended for venting gas appliances equipped with draft hoods to burn only gas. Type B vents are also intended for use with other Category I appliances that specify they are for use with Type B gas vents.

1.2 The gas vents covered by these requirements are intended for installation in accordance with the National Fire Protection Association Standards for Chimneys, Fireplaces, Vents, and Solid-Fuel Burning Appliances, NFPA 211 the National Fuel Gas Code, NFPA 54, the Department of Housing and Urban Development Mobile Home Construction and Safety Standards, Chapter II of 24 CFR, Part 280, the International Mechanical Code, and the Uniform Mechanical Code.

### 2 Components

2.1 Except as indicated in 2.2, a component of a product covered by this standard shall comply with the requirements for that component.

2.2 A component need not comply with a specific requirement that:

- a) Involves a feature or characteristic not needed in the application of the component in the product covered by this standard; or
- b) Is superseded by a requirement in this standard.

2.3 A component shall be used in accordance with its recognized rating established for the intended conditions of use.

2.4 Specific components are recognized as being incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions for which they have been recognized.

ULNORM.COM . Click to view the full PDF of UL 441 2019

### 3 Units of Measurement

3.1 If a value for measurement is followed by a value in other units in parentheses, the second value may be only approximate. The first stated value is the requirement.

### 4 Undated References

4.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

### 5 Glossary

5.1 For the purpose of this standard, the following definitions apply.

5.2 **CATEGORY I APPLIANCE** – An appliance that operates with a nonpositive vent static pressure and with a vent gas temperature that avoids excessive condensate production in the vent.

5.3 **COMBUSTIBLE MATERIAL** – Material made of or surfaced with wood, compressed paper, plant fibers, or other material that ignites and burns, as applied to materials adjacent to or in contact with heat-producing appliances, chimney connectors and vent connectors, steam and hot water pipes, and warm air ducts. Such material shall be identified as combustible even though flameproofed, fire-retardant treated, or plastered.

5.4 **NONCOMBUSTIBLE MATERIAL** – A material that, in the form in which it is used and under the conditions anticipated, does not ignite, burn, support combustion, or release flammable vapors when subjected to fire or heat.

5.5 **ROOF JACK** – A factory-built assembly for conveying flue gases through a roof and that includes a flue gas passageway, an insulating means, flashing, and a cap.

5.6 **TYPE B GAS VENT** – A gas vent for venting gas appliances with draft hoods and other Category I gas appliances listed for use with Type B gas vents.

5.7 **TYPE BW GAS VENT** – A gas vent for venting gas-fired vented wall furnaces.

## CONSTRUCTION

### 6 Materials

6.1 A gas-vent and a roof-jack part shall be made of noncombustible corrosion-resistant materials. Metals shall not be used in combinations that result in galvanic action at any location within the assembly.

6.2 The minimum thickness of sheet metal, including any coatings, shall be as referenced in Table 6.1 unless otherwise specified.

6.3 Aluminum alloys containing more than 1.0 percent magnesium shall not be used when the reflectivity of the material is utilized to reduce the risk of fire.

6.4 A flue-gas conveying conduit shall be of a material having durability and resistance to corrosion and heat equivalent to that of Type 1100 aluminum, Series 300 or Types 430 and 446 stainless steel, or porcelain-coated steel complying with the requirements contained herein. Except as noted in 6.5, parts in contact with flue gases or flue gas-air mixtures, or subject to condensation, shall be of material having durability and resistance to corrosion and heat equivalent to Type 1100 aluminum or Series 300 or Types 430 and 446 stainless steel.

**Table 6.1**  
**Minimum metal thickness**

	Inch	(mm)
Aluminum alloys (1100, 3003) – inner pipe	0.012	(0.30)
Aluminum alloys (1100, 3003) – other than inner pipe	0.016	(0.41)
Steel	0.016	(0.41)
Galvanized steel (G90 coating class)	0.018	(0.46)
Aluminum-coated steel (0.40 ounces per square foot)	0.018	(0.46)
Stainless steel (Type 430)	0.012	(0.30)

6.5 An outer casing or other structural part shall be of stainless steel, galvanized steel, or aluminum-coated steel when:

- a) Deterioration or corrosion of the part results in the venting system to collapse or otherwise increase the risk of injury to persons;
- b) The part adjoins firestopping material; or
- c) The part is subject to condensation.

*Exception: This requirement does not apply to the flue-gas conveying conduit or other parts in contact with flue-gases or flue-gas air mixtures. See 6.4.*