



UL 497A

STANDARD FOR SAFETY

Secondary Protectors for
Communications Circuits

ULNORM.COM : Click to view the full PDF of UL 497A 2019

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 497A 2019

UL Standard for Safety for Secondary Protectors for Communications Circuits, UL 497A

Third Edition, Dated March 20, 2001

Summary of Topics

This revision of ANSI/UL 497A, dated October 17, 2019, includes the addition of reference UL 62368-1 as an alternative to UL 60950-1.

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The revised requirements are substantially in accordance with Proposal(s) on this subject dated July 26, 2019.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 497A 2019

MARCH 20, 2001
(Title Page Reprinted: October 17, 2019)



ANSI/UL 497A-2019

1

UL 497A

Standard for Secondary Protectors for Communications Circuits

First Edition – January, 1990
Second Edition – January, 1996

Third Edition

March 20, 2001

This ANSI/UL Standard for Safety consists of the Third Edition including revisions through October 17, 2019.

The most recent designation of ANSI/UL 497A as an American National Standard (ANSI) occurred on October 1, 2019. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2019 UNDERWRITERS LABORATORIES INC.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 497A 2019

CONTENTS

INTRODUCTION

1	Scope	5
2	General	5
	2.1 Components	5
	2.2 Units of measurement	6
	2.3 Undated references	6
3	Glossary	6

CONSTRUCTION

4	General	9
5	Product Assembly	9
6	Enclosures	10
	6.1 General	10
	6.2 Enclosure top openings	13
	6.3 Enclosure side openings	13
	6.4 Enclosure bottom openings	16
7	Internal Materials	16
8	Accessibility and Electric Shock	17
9	Mechanical Assembly	23
10	Protection Against Corrosion	23
11	Cords	24
	11.1 Strain relief	24
	11.2 Bushings	24
12	Current-Carrying Parts	25
13	Internal Wiring	25
	13.1 General	25
	13.2 Splices and connections	25
14	Interconnecting Cords and Cables	26
	14.1 General	26
	14.2 Separation of circuits	26
	14.3 Terminal and connectors	27
15	Insulating Material	27
16	Printed-Circuit Board	27
17	Overcurrent (Overload) Devices	28
18	Spacings	28

RISK OF INJURY TO PERSONS

19	General	29
20	Modular Jacks	29
21	Sharp Edges	30
22	Stability	30
23	Protection of Service Personnel	31

PERFORMANCE

24	General	31
25	Breakdown Voltage Measurement Test	35
26	Impulse Voltage Measurement Test	36
27	Overvoltage Test	36

27.1	General	36
27.2	Test method.....	40
28	Endurance Conditioning	42
29	Component Temperature Test	43
30	Drop Test.....	45
31	Impact Test.....	46
32	Crush Test	46
33	Strain Relief Test.....	46
34	Leakage Current Test	47
35	Dielectric Voltage-Withstand Test	48
36	Rain Test	49
37	Maximum Moment Measurement Test	52
38	Weatherometer and Micro Tensile Strength Test.....	52
39	Thermal Aging and Flame Test.....	53
40	Electric Shock Current Test.....	53

MANUFACTURING AND PRODUCTION-LINE TEST

41	Dielectric Voltage-Withstand Test	57
----	---	----

MARKING

42	General	59
43	Installation Instructions	60
44	Instruction Manual.....	60

APPENDIX A

Standards for Components	65
--------------------------------	----

APPENDIX B – INFORMATION RELATING TO THE TESTING LABORATORY DIELECTRIC VOLTAGE-WITHSTAND TEST (TYPE TEST) AND THE PRODUCTION-LINE DIELECTRIC VOLTAGE-WITHSTAND TEST (ROUTINE TEST)

B1	Purpose	66
B2	Testing Laboratory Dielectric Voltage-Withstand Test (Type Test)	66
B3	Production-Line Dielectric Voltage-Withstand Test (Routine Test)	66
B4	Production-Line Dielectric Voltage-Withstand Tester Performance (Sensitivity).....	67
B4.1	General.....	67
B4.2	Voltage Regulation (For the 1-Second Factory Test Only)	68

INTRODUCTION

1 Scope

1.1 These requirements cover secondary protectors for use in single- or multiple-pair-type communications circuits that are intended to be installed in accordance with Article 800 of the National Electrical Code, ANSI/NFPA 70.

1.2 Secondary protectors are intended to be used in the protected side of telecommunications networks that have an operating rms voltage to ground less than 150 volts and installed or used in accordance with the National Electrical Code, NFPA 70.

1.3 These requirements do not cover telephone protectors that are covered by the Standard for Protectors for Paired-Conductor Communications Circuits, UL 497. These requirements do not cover telephone equipment such as telephone answering devices, residential telephone instruments, telephone dialers, cordless telephones, key systems, and private-branch exchange equipment that is covered by the Standard for Information Technology Equipment – Safety – Part 1: General Requirements, UL 60950-1 or the Standard for Audio/Video, Information and Communication Technology Equipment – Part 1: Safety Requirements, UL 62368-1.

1.4 These requirements do not cover cellular telephones or other receiver/transmitter-type devices. Equipment of this type is covered by one of the following Standards:

- Standard for Audio, Video and Similar Electronic Apparatus – Safety Requirements, UL 60065
- Standard for Information Technology Equipment – Safety – Part 1: General Requirements, UL 60950-1; or
- Standard for Audio/Video, Information and Communication Technology Equipment – Part 1: Safety Requirements, UL 62368-1.

1.5 These requirements may be used, directly or by reference, to investigate portions of other equipment not classified as telecommunications equipment accessories and that may be connected to a telecommunications network, insofar as they may be applicable to such equipment.

1.6 These requirements do not cover wires and cables intended to be permanently installed in a building in accordance with Article 800 of the National Electrical Code, NFPA 70.

1.7 A product that contains features, characteristics, components, materials, or systems new or different from those covered by the requirements in this standard, and that involves a risk of fire or of electric shock or injury to persons shall be evaluated using appropriate additional component and end-product requirements to maintain the level of safety as originally anticipated by the intent of this standard. A product whose features, characteristics, components, materials, or systems conflict with specific requirements or provisions of this standard does not comply with this standard. Revision of requirements shall be proposed and adopted in conformance with the methods employed for development, revision, and implementation of this standard.

2 General

2.1 Components

2.1.1 Except as indicated in [2.1.2](#), a component of a product covered by this standard shall comply with the requirements for that component. See Appendix [A](#) for a list of standards covering components used in the products covered by this standard.

2.1.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

2.1.3 A component shall be used in accordance with its rating established for the intended conditions of use.

2.1.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

2.2 Units of measurement

2.2.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

2.2.2 Unless otherwise indicated, all voltage and current values specified in this standard are root-mean-square (rms).

2.3 Undated references

2.3.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

3 Glossary

3.1 For the purpose of this standard the following definitions apply.

3.2 EARTH GROUND – A conducting connection, whether intentional or unintentional, between an electrical circuit or electrical equipment and the earth, or to some conducting body that serves in place of the earth.

3.3 ELECTRICAL ENERGY – HIGH CURRENT LEVELS (POWER SUPPLIES) – Electrical energy that is capable of causing damage or risk of injury to persons (other than by electric shock) is determined to exist when, between a live part and an adjacent dead-metal part or between live parts of opposite polarity, there exists a potential of not less than 30 volts rms or 42.4 volts peak (AC or DC) and either:

- a) An available continuous power level of not less than 250 volt-amperes or
- b) A reactive energy level of not less than 20 joules.

For example, a tool or other metal short-circuiting a component can cause a burn or a fire when enough energy is available at the component to vaporize, melt, or more than warm the metal.

3.4 ENCLOSURE – The word "enclosure" refers only to parts that house or cover:

- a) Uninsulated live parts that involve a risk of electric shock or
- b) Parts that involve a risk of fire, electrical energy/high-current levels, or injury to persons.

An enclosure may be an integral part of a component, a separate item or part of an outer cabinet.

3.5 FIELD-WIRING TERMINAL – A terminal to which a telephone circuit may be connected by an installer in the field. A field-wiring terminal may consist of a screw-type terminal, quick-connect insulation stripping system, or plug/jack arrangement.

3.6 FIXED OR STATIONARY EQUIPMENT – Equipment that is not easily moved, and is intended to be moved from one place to another only when de-energized. Fixed equipment is usually fastened or secured to a building.

3.7 GROUNDING – Establishing an intentional electrically conductive connection between an electrical circuit or electrical equipment and the earth ground or to some conducting body that serves in place of the earth.

3.8 LONGITUDINAL VOLTAGE – (May also be called Common Mode Voltage) When applied to telecommunications conductors, the voltage common to both tip and ring conductors, or the connection points of such conductors, as measured with regard to earth ground.

3.9 METALLIC VOLTAGE – (May also be called Differential Mode Voltage) When applied to telecommunications conductors, the voltage as measured between tip and ring conductors, of the same telecommunications pair, or the connection points of such tip and ring conductors, with no reference to earth ground.

3.10 NETWORK OPERATING VOLTAGES – Telecommunications networks normally operate at voltages of 56.5 volts DC or less, unless the source impedance is over 1600 ohms. For equipment connected to a single tip and ring pair, alerting and test voltages higher than 56.5 volts are intermittent and will be present over less than 1 percent of the usage of the equipment. Some telecommunications equipment, such as PBX and Key systems, may have a greater percentage of usage or operate at a higher voltage (such as T type lines). Maximum ringing voltages may not exceed 150 volts as defined by Article 725 of the National Electrical Code for Class 2 and 3 circuits.

3.11 NONPROTECTED SIDE – The portion of the loop circuit that rests on the central office or outside plant side of the primary telephone protector installed by the operating telephone company. The fault current limitation is subject to the breakdown voltage characteristics of the primary protector and its coordinated fusing system with the bridge or fuse wire with which the protector is intended to be used.

3.12 PORTABLE EQUIPMENT – Equipment that is easily moved and can be carried or conveyed by hand. Portable equipment is usually hand-held or hand-supported.

3.13 PRIMARY PROTECTOR – A voltage-limiting protector complying with the Standard for Protectors for Paired-Conductor Communications Circuits, UL 497.

3.14 PRODUCT – This term refers to all types of telephone equipment and appliances that will be used in residential, commercial, and industrial environments.

3.15 PROTECTED SIDE – Refers to that portion of the loop circuit that rests on the customer premises side of the primary telephone protector and is limited to short and long term current requirements for secondary protectors.

3.16 RISK OF ELECTRIC SHOCK – The risk that a person encounters when exposed to uninsulated live parts of a product that have a voltage and current sufficient to cause an electric shock, as defined in Accessibility and Electric Shock, Section 8.

3.17 RISK OF FIRE – The risk that a fire may occur as a result of equipment or component failure or the application of specified test conditions. A risk of fire is determined to exist at any component unless an

investigation of the circuit delivering power to that component complies with the power limitations criteria cited in this standard.

3.18 RISK OF INJURY TO PERSONS – A condition that is capable of occurring when one or more of the following exist:

- a) When power-operated moving parts such as gears and linkages are accessible during intended operation and are capable of causing a cut or laceration.
- b) When sharp edges, burrs, or projections are present that results in injury during use or servicing.
- c) When the stability of a product is such that it results in injury to persons. See Stability, Section [22](#).
- d) When there is risk that a part of the body could become endangered or that clothing could become entangled by a moving part resulting in an injury.
- e) When uninsulated live parts involving risk of electrical-energy/high-current levels are accessible to personnel. See Accessibility and Electric Shock, Section [8](#).
- f) When contact with accessible live parts can cause an involuntary reaction where the consequence of the reaction is a high risk of injury. See Accessibility and Electric Shock, Section [8](#).
- g) When, during operation, the product propels missiles or other objects that may result in injury to persons.

3.19 TELECOMMUNICATIONS – Any transmission or reception of information such as signals, images, written text, or sounds, by electronic means.

3.20 TELECOMMUNICATIONS LINE CORD – The flexible cord used to connect a telephone set or other telecommunications devices to the telecommunications line at the network interface or modular jacks within the loop circuit. The cord may have male locking-type modular connectors on one or both ends for a plug-in arrangement or may have spade terminals on either or both ends for screw-type connections.

3.21 TELECOMMUNICATIONS LINE CORD EXTENSION – A telecommunications line cord that has a male connector on one end and a female connector on the other end.

3.22 TELECOMMUNICATIONS NETWORK – The interconnection of communications lines and switching equipment for providing communications service.

3.23 TELECOMMUNICATIONS NETWORK INTERFACE DEVICE – A piece of equipment that provides a point of interconnection between the telephone company communications facilities and terminal equipment, wiring, and protective apparatus at a subscriber's premises. The network interface or demarcation point is located on the subscriber's side of the telephone company's protector, or the equivalent thereof in cases where the protector is not employed, as provided under local telephone company's reasonable and nondiscriminatory standard operating practices. Network interface devices may contain the telephone primary protector within the unit.

3.24 TELECOMMUNICATIONS (TELEPHONE) EQUIPMENT – A device intended to be connected to a telecommunications network and used for receiving or transmitting information, or both, along the network.

3.25 TELEPHONE BRANCH CIRCUIT – The circuit that consists of a single pair conductor wire run in parallel with the main loop circuit. The junction point of the two circuits is usually contained in a cross-connect terminal block, network interface device assembly, or multi-output RJ11 type jack assembly.

3.26 TIP AND RING WIRES (TELEPHONE SWITCHING SYSTEMS) – A pair of conductors associated with the transmission portions of circuits and apparatus. Tip or ring designation of the individual conductors may be arbitrary except when applied to cord-type switchboard wiring in which case the conductors are designated according to their association with tip or ring contact of the jack and plug.

3.27 TOOL – Any means, other than manual manipulation, required to open an enclosure of a device.

3.28 USER SERVICING – Any form of servicing that can be performed by personnel other than those who are trained to maintain the equipment. User servicing is limited to user's access area. Some examples of user servicing are:

- a) The installation of accessories by means of separable connectors such as modular connectors, attachment plugs and receptacles and
- b) The changing or replacement of accessory boards, lamps, fuses and resetting of circuit breakers.

3.29 USER'S ACCESS AREA – All external surface areas and all internal areas that can be entered without the use of a tool, and all areas that the user is instructed to enter whether or not tools are required to gain access.

CONSTRUCTION

4 General

4.1 A secondary protector shall be constructed so that it will be durable for its intended installation and use, as determined by compliance with the performance requirements of this standard.

4.2 A secondary protector shall include overcurrent protection which will fuse, limit, or extinguish at currents less than the current-carrying capacity of indoor communications wire, cable or terminal equipment. Any overvoltage protection or grounding connection shall be connected on the equipment terminal side of the secondary protector overcurrent protection system.

4.3 A product shall employ materials that are intended for the particular use, as determined by the performance requirements of this standard.

4.4 Metals shall not be used in such combination as to cause galvanic action that will result in a risk of fire, electric shock, or injury to persons.

4.5 When breakage or deterioration of a part such as an enclosure, a frame, a guard, or the like can result in a risk of injury to persons, the part shall be constructed to meet the demand of expected loading conditions.

5 Product Assembly

5.1 A product shall be factory-built as a complete assembly and shall include all the essential components required for its intended function when installed (used) as intended. The product may be shipped from the factory as two or more subassemblies.

5.2 A product may be shipped from the factory unassembled, or disassembled to the degree required to facilitate shipment, when all of the following conditions are met:

- a) All of the parts are furnished by the manufacturer;

- b) Upon assembly, grounding continuity is provided where required between the field-assembled components;
- c) The product is constructed so that field assembly can be accomplished without requiring drilling, cutting, threading, or any alteration other than the attachment of field-installed electrical conduit or raceway;
- d) The relationship between separate parts is established at the time of manufacture, and is not dependent upon installation personnel;
- e) Detailed step-by-step installation instructions are packaged with the product; and
- f) All protective guards and other features intended to reduce the risk of fire, electric shock, or injury to persons are factory installed wherever possible.

6 Enclosures

6.1 General

6.1.1 An enclosure shall have the strength and rigidity required to resist the abuses to which the product will be subjected during intended use, without resulting in:

- a) A risk of fire, electric shock, or injury to persons due to total or partial collapse, with resulting reduction of spacings to less than required or
- b) Loosening, displacement or exposure of parts or other defects.

6.1.2 An enclosure or guard of sheet metal shall have a minimum thickness in accordance with [Table 6.1](#) or [Table 6.2](#), whichever applies.

Table 6.1
Minimum thickness of sheet metal for electrical enclosures carbon steel or stainless steel

Without supporting frame ^a		With supporting frame or equivalent reinforcing ^a		Minimum thickness uncoated,		Minimum thickness metal coated,			
Maximum width ^b , inches	Maximum length ^c , inches	Maximum width ^b , inches	Maximum length ^c , inches	inch [MSG]	(mm)	inch [GSG]	(mm)		
4.0	(10.2)	Not limited	6.25	(15.9)	Not limited	0.020	(0.51)	0.023	(0.58)
4.75	(12.1)	5.75	(14.6)	6.75	(17.1)	8.25	(21.0)	[24]	[24]
6.0	(15.2)	Not limited	9.5	(24.1)	Not limited	0.026	(0.66)	0.029	(0.74)
7.0	(17.8)	8.75	(22.2)	10.0	(25.4)	12.5	(31.8)	[22]	[22]
8.0	(20.3)	Not limited	12.0	(30.5)	Not limited	0.032	(0.81)	0.034	(0.86)
9.0	(22.9)	11.5	(29.2)	13.0	(33.0)	16.0	(40.6)	[20]	[20]
12.5	(31.8)	Not limited	19.5	(49.5)	Not limited	0.042	(1.07)	0.045	(1.14)
14.0	(35.6)	18.0	(45.7)	21.0	(53.3)	25.0	(63.5)	[18]	[18]
18.0	(45.7)	Not limited	27.0	(68.6)	Not limited	0.053	(1.35)	0.056	(1.42)
20.0	(50.8)	25.0	(63.5)	29.0	(73.7)	36.0	(91.4)	[16]	[16]
22.0	(55.9)	Not limited	33.0	(83.8)	Not limited	0.060	(1.52)	0.063	(1.60)
25.0	(63.5)	31.0	(78.7)	35.0	(88.9)	43.0	(109.2)	[15]	[15]

Table 6.1 Continued on Next Page

Table 6.1 Continued

Without supporting frame ^a		With supporting frame or equivalent reinforcing ^a		Minimum thickness uncoated,		Minimum thickness metal coated,	
Maximum width ^b , inches (cm)	Maximum length ^c , inches (cm)	Maximum width ^b , inches (cm)	Maximum length ^c , inches (cm)	inch (mm) [MSG]	inch (mm) [MSG]	inch (mm) [GSG]	inch (mm) [GSG]
25.0 (63.5)	Not limited	39.0 (99.1)	Not limited	0.067 (1.70)		0.070 (1.78)	
29.0 (73.7)	36.0 (91.4)	41.0 (104.1)	51.0 (129.5)	[14]		[14]	
33.0 (83.8)	Not limited	51.0 (129.5)	Not limited	0.080 (2.03)		0.084 (2.13)	
38.0 (96.5)	47.0 (119.4)	54.0 (137.2)	66.0 (167.6)	[13]		[13]	
42.0 (106.7)	Not limited	64.0 (162.6)	Not limited	0.093 (2.36)		0.097 (2.46)	
47.0 (119.4)	59.0 (149.9)	68.0 (172.7)	84.0 (213.4)	[12]		[12]	
52.0 (132.1)	Not limited	80.0 (203.2)	Not limited	0.108 (2.74)		0.111 (2.82)	
60.0 (152.4)	74.0 (188.0)	84.0 (213.4)	103.0 (261.6)	[11]		[11]	
63.0 (160.0)	Not limited	97.0 (246.4)	Not limited	0.123 (3.12)		0.126 (3.20)	
73.0 (185.4)	90.0 (228.6)	103.0 (261.6)	127.0 (322.6)	[10]		[10]	

NOTE – Sheet steel for an enclosure intended for outdoor use (watertight) shall be at least 0.036 inch (0.91 mm) thick when zinc-coated and at least 0.032 inch (0.81 mm) thick when uncoated.

^a A supporting frame is a structure of angle or channel or a folded rigid section of sheet metal that is rigidly attached to and has essentially the same outside dimensions as the enclosure surface and that has sufficient torsional rigidity to resist the bending moments that may be applied via the enclosure surface when it is deflected. A structure that is as rigid as one built with a frame of angles or channels is considered to have equivalent reinforcing. Constructions considered to be without supporting frames include:

- 1) A single sheet with single formed flanges (formed edges),
- 2) A single sheet that is corrugated or ribbed, and
- 3) An enclosure surface loosely attached to a frame, such as by spring clips.

^b The width is the smaller dimension of a rectangular sheet metal piece that is part of an enclosure. Adjacent surfaces of an enclosure may have supports in common and be made of a single sheet.

^c For panels that are not supported along one side (for example, side panels of boxes) the length of the unsupported side shall be limited to the dimensions specified unless the side in question is provided with a continuous flange at least 1/2 inch (12.7 mm) wide.

**Table 6.2
Minimum thickness of sheet metal for electrical enclosures aluminum, copper, or brass**

Without supporting frame ^a		With supporting frame or equivalent reinforcing ^a		Minimum thickness in inches (mm)
Maximum width ^b , inches (cm)	Maximum length ^c , inches (cm)	Maximum width ^b , inches (cm)	Maximum length ^c , inches (cm)	
3.0 (7.6)	Not limited	7.0 (17.8)	Not limited	0.023 (0.58)
3.5 (8.9)	4.0 (10.2)	8.5 (21.6)	9.5 (24.1)	
4.0 (10.2)	Not limited	10.0 (25.4)	Not limited	0.029 (0.74)
5.0 (12.7)	6.0 (15.2)	10.5 (26.7)	13.5 (34.3)	
6.0 (15.2)	Not limited	14.0 (35.6)	Not limited	0.036 (0.91)
6.5 (16.5)	8.0 (20.3)	15.0 (38.1)	18.0 (45.7)	
8.0 (20.3)	Not limited	19.0 (48.3)	Not limited	0.045 (1.14)

Table 6.2 Continued on Next Page