



UL 729

STANDARD FOR SAFETY

Oil-Fired Floor Furnaces

ULNORM.COM : Click to view the full PDF of UL 729 2016

ULNORM.COM : Click to view the full PDF of UL 729 2016

UL Standard for Safety for Oil-Fired Floor Furnaces, UL 729

Sixth Edition, Dated August 29, 2003

Summary of Topics

This revision of ANSI/UL 729 is being issued to reaffirm approval as an American National Standard. No changes in requirements are involved.

The revisions are substantially in accordance with Proposal(s) on this subject dated September 30, 2016.

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

ULNORM.COM : Click to view the full PDF of UL 729 2016

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 729 2016

AUGUST 29, 2003
(Title Page Reprinted: November 22, 2016)



ANSI/UL 729-2008 (R2016)

1

UL 729

Standard for Oil-Fired Floor Furnaces

First Edition – May, 1955
Second Edition – July, 1974
Third Edition – March, 1976
Fourth Edition – December, 1987
Fifth Edition – December, 1994

Sixth Edition

August 29, 2003

This ANSI/UL Standard for Safety consists of the Sixth edition including revisions through November 22, 2016.

The most recent designation of ANSI/UL 729 as a Reaffirmed American National Standard (ANS) occurred on November 22, 2016. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2016 UNDERWRITERS LABORATORIES INC.

ULNORM.COM. Click to view the full PDF of UL 729 2016

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 729 2016

CONTENTS

INTRODUCTION

1 Scope	7
2 General	7
3 Glossary	7
3A Undated References	12
4 Components	12

CONSTRUCTION – MECHANICAL

5 Assembly	12
6 Servicing	14
7 Moving Parts	14
8 Disposal of Combustion Products	15
9 Casing	15
10 Support	16
11 Radiation Shield	17
12 Materials in an Air Handling Compartment	17
13 Air Filter	18
14 Combustion Chamber	18
15 Radiator	18
16 Heating Surface Joints	18
17 Baffles	19
18 Flue Collar	20
19 Damper and Draft Regulator	20
20 Field Wiring System Connections	20

CONSTRUCTION – ELECTRICAL

21 Controls	21
21.1 Application	21
21.2 Limit control	22
21.3 Primary safety control	23
22 Field Wiring	23
22.1 General	23
22.2 Leads and terminals	24
23 Internal Wiring	26
23.1 General	26
23.2 Methods	27
23.3 Short circuit protection	30
24 Separation of Circuits	30
25 Bonding for Grounding	31
26 Servicing and Adjustment	32B
27 Electrical Components	34
28 Mounting of Electrical Components	34
29 Electrical Enclosures	35
29.1 General	35
29.2 Doors and covers	38
30 Motors and Motor Overload Protection	40

31	Switches and Controllers	44
32	Capacitors	44
33	Electrical Insulating Material	45
34	Spacings – High-Voltage Circuits	45
35	Spacings – Low-Voltage Circuits	46
36	Accessibility of Uninsulated Live Parts, Film-Coated Wire, and Moving Parts	47

PERFORMANCE

37	General	53
38	Test Installation	53
38.1	Enclosure	53
38.2	Chimney connector	57
39	Instrumentation	57
39.1	Draft measurement	57
39.2	Fuel input measurement	58
39.3	Power measurement	58
39.4	Speed measurement	58
39.5	Temperature measurement	58
40	Initial Test Conditions	62
40.1	General	62
40.2	Furnace equipped with mechanical atomizing burner	63
40.3	Furnace equipped with vaporizing burner	63
41	Combustion Test – Burner and Furnace	63
42	Limit Control Cutout Test	64
43	Continuity of Operation Test	64
44	Temperature Tests	65
45	Maximum Register Temperature Test	69
46	Continuous-Operation Temperatures Test	69
47	Blocked Register Test	69
48	Blocked Inlet Test	70
49	Fan Failure Test	71
50	Fan Motor Failure Test	72
51	Seepage and Burnoff Test	72
52	Register Strength Test	73
53	Short-Circuit Test	73
54	Dielectric Voltage-Withstand Test	75
55	Adhesive Secureness Test for Insulating Materials	76
56	Flammability Tests for Materials in Air Handling Compartments	76
57	Strain Relief Test	77
58	Bonding-Conductor Test	77
59	Torque Test on Screws and Bolts	78

MANUFACTURING AND PRODUCTION TESTS

60	General	79
----	---------	----

MARKING

61	General	80
----	---------	----

INSTRUCTIONS

62 Operating and Installation Instructions82

APPENDIX A

Standards for Components..... A1

ULNORM.COM : Click to view the full PDF of UL 729 2016

This page intentionally left blank.

ULNORM.COM : Click to view the full PDF of UL 729 2016

INTRODUCTION

1 Scope

1.1 These requirements apply to oil-fired floor furnaces.

1.2 Requirements for the installation and use of oil-burning equipment are included in the Standard for the Installation of Oil-Burning Equipment, ANSI/NFPA 31. Requirements for the installation of oil-burning equipment are also included in codes such as the International Mechanical Code and the Uniform Mechanical Code.

1.2 revised October 1, 2008

1.3 A product that contains features, characteristics, components, materials, or systems new or different from those covered by the requirements in this standard, and that involves a risk of fire or of electric shock or injury to persons shall be evaluated using appropriate additional component and end-product requirements to maintain the level of safety as originally anticipated by the intent of this standard. A product whose features, characteristics, components, materials, or systems conflict with specific requirements or provisions of this standard does not comply with this standard. Revision of requirements shall be proposed and adopted in conformance with the methods employed for development, revision, and implementation of this standard.

2 General

2.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

3 Glossary

3.1 For the purpose of this standard, the following definitions apply.

3.2 AIR SHUTTER – An adjustable device for varying the size of the air inlet or inlets regulating primary or secondary air, or both.

3.3 ANTIFLOODING DEVICE – A primary safety control which causes the fuel flow to be shut off upon a rise in fuel level or upon receiving excess fuel, and which operates before excessive discharge of fuel can occur.

3.4 APPLIANCE FLUE – The flue passages within the appliance.

3.5 AUTOMATICALLY LIGHTED APPLIANCE – An appliance in which fuel in the main burner is turned on and ignited automatically.

3.6 BAFFLE – An object placed in an appliance to direct the flow of air or flue gases.

3.7 BASE – The main supporting frame or structure of the furnace, exclusive of legs.

3.8 BURNER – A device for the final conveyance of fuel and air to the combustion zone.

3.9 BURNER, MANUALLY LIGHTED – A burner in which fuel to the main burner is turned on only by hand and ignited under supervision.

3.10 BURNER, MECHANICAL ATOMIZING – A power-operated burner that prepares and delivers the fuel and all or part of the air by mechanical process in controllable quantities for combustion. Some examples are air atomizing, high- and low-pressure atomizing, horizontal and vertical rotary atomizing, and vertical rotary wall-flame burners.

3.11 BURNER, MECHANICAL DRAFT – A burner that includes a power-driven fan, blower, or other mechanism as the principal means for supplying air for combustion.

3.12 BURNER, NATURAL DRAFT – A burner that principally depends upon the natural draft created in the flue to induce into the burner the air required for combustion.

3.13 BURNER, VAPORIZING – A burner consisting of a fuel-vaporizing bowl or other receptacle to which liquid fuel may be fed in controllable quantities; the heat of combustion is used to vaporize the fuel, with provision for admitting air and mixing it with the fuel vapor in combustible proportions.

3.14 CASING – An enclosure forming the outside of the appliance, no parts of which are likely to be subjected to intense heat.

3.15 CENTRAL HEATING APPLIANCE – A stationary indirect-fired vented appliance comprising the following categories: boilers, central furnaces, floor furnaces, and recessed heaters. A floor mounted unit heater to be connected to a duct system is categorized also as a central heating appliance.

3.16 CHIMNEY CONNECTOR – The pipe that connects a solid or liquid fuel-burning appliance to a chimney.

3.17 COMBUSTIBLE MATERIAL – Combustible material as pertaining to materials adjacent to or in contact with heat-producing appliances, chimney connectors and vent connectors, refers to material made of or surfaced with wood, compressed paper, plant fibers, or other material that will ignite and burn. Such material is to be considered as combustible even though flameproofed, fire-retardant treated, or plastered.

3.18 COMBUSTION – The rapid oxidation of fuel accompanied by the production of heat or heat and light.

3.19 COMBUSTION CHAMBER – The portion of an appliance within which combustion occurs.

3.20 COMBUSTION (FLAME) SAFEGUARD – A safety combustion control.

3.21 CONSTANT LEVEL VALVE – A device that maintains a constant level of fuel in a reservoir for delivery to the burner.

3.22 CONTROL – A device intended to regulate the fuel, air, water, or electrical supply to the controlled equipment. It may be automatic, semiautomatic, or manual.

3.23 CONTROL, LIMIT – An automatic safety control responsive to changes in liquid level, pressure, or temperature, for limiting the operation of the controlled equipment.

3.24 CONTROL, SAFETY – An automatic control, including a relay, switch, or other auxiliary equipment used in conjunction therewith to form a safety control system that is intended to reduce the likelihood of operation of the controlled equipment that may result in a risk of fire or injury to persons.

3.25 CONTROL, PRIMARY SAFETY – An automatic safety control intended to reduce the likelihood of abnormal discharge of fuel at the burner in case of ignition failure or flame failure.

3.26 CONTROL, SAFETY COMBUSTION – A primary safety control responsive directly to flame properties, sensing the presence of flame and causing fuel to be shut off in event of flame failure.

3.27 DAMPER – A valve or plate for regulating draft or flow of flue gases. A damper is generally considered as being located on the downstream side of the combustion chamber, usually in a flue passage of the appliance or in the chimney connector.

3.28 DAMPER, AUTOMATICALLY OPERATED – A damper operated by an automatic control.

3.29 DAMPER, MANUALLY OPERATED – An adjustable damper manually set and locked in the position intended to be used.

3.30 DRAFT – The differential in static pressure available, between any two locations, to provide the energy potential for the moving of either air for combustion, products of combustion, or both through a fuel-burning heat-exchanging apparatus.

3.31 DRAFT REGULATOR – A device that functions to maintain a desired draft in the appliance by automatically reducing the chimney draft to the desired value.

3.32 ELECTRICAL CIRCUITS:

a) High-Voltage Circuit – A circuit involving a potential of not more than 600 volts and having circuit characteristics in excess of those of a low-voltage circuit.

b) Low-Voltage Circuit – A circuit that involves a potential of not more than 30 volts rms alternating-current (42.4 volts peak) or direct current and supplied by:

1) A primary battery,

2) A Class 2 transformer, or

3) A combination of transformer and fixed impedance that, as a unit, complies with all the performance requirements for a Class 2 transformer.

A circuit derived from a high-voltage circuit by connecting resistance in series with the supply circuit as a means of limiting the voltage and current is not considered to be a low-voltage circuit.

c) Safety Control Circuit – A circuit involving one or more safety controls.

3.33 EXCESS AIR – Air that passes through the combustion area and the appliance flues in excess of that which is required for complete combustion.

3.34 FLUE COLLAR – That portion of an appliance constructed for attachment of the chimney connector.

3.35 FLUE GASES – Combustion products and excess air.

3.36 FUEL OIL – Any hydrocarbon oil defined by Specifications for Fuel Oils, ANSI/ASTM D396.

3.36 revised October 1, 2008

3.37 FURNACE, FLOOR – A completely self-contained, indirect-fired unit furnace having integral plenums, warm air outlet, and cold air return and intended to be inserted into and suspended from the floor of the space being heated. The furnace takes air for combustion from outside this space and has a means for observing the flame and lighting the appliance from such space.

a) Gravity Type Floor Furnace – A floor furnace depending primarily on circulation of air by gravity. This category also includes floor furnaces equipped with booster-type fans which do not materially restrict circulation of air by gravity flow when such fans are not in operation.

b) Fan Type Floor Furnace – A floor furnace equipped with a fan which provides the primary means for circulation of air.

3.38 HEAT EXCHANGER, DIRECT – A heat exchanger in which heat generated in the combustion chamber of the appliance is transferred directly through walls of the appliance to the heating medium, such as air, steam, or water, and held in close contact with the combustion chamber walls. A direct heat exchanger is a self-contained combustion and heat transfer device.

3.39 HEAT EXCHANGER, INDIRECT – A heat exchanger which encloses or contains a heating medium (such as air, steam, or water), the heat from which is transferred to another heating medium separately contained in close contact with or directed through the heat exchanger.

3.40 HEATING SURFACES – A surface that transmits heat directly from flame or flue gases to the medium to be heated.

3.41 INDIRECT FIRED APPLIANCE – An appliance constructed so that combustion products or flue gases are not mixed in the appliance with the medium to be heated and provided with a flue collar.

3.42 LINER – See Radiation Shield – 3.48.

3.43 MAINTENANCE – The periodic tasks usually performed to operate and maintain an appliance, such as air, fuel, pressure, and temperature regulation, cleaning, lubrication, resetting of controls, and the like. Repair and replacement of parts other than those expected to be renewed periodically is not considered as maintenance. Some examples of maintenance are:

- a) Cleaning or replacing nozzles, atomizers, and pilots.
- b) Setting ignition electrodes.
- c) Cleaning strainers or replacing strainer or filter elements.
- d) Resetting safety control.
- e) Replacing igniter cable.

3.44 MANUALLY LIGHTED APPLIANCE – An appliance in which fuel to the main burner is turned on only by hand and ignited under supervision.

3.45 OIL-FIRED FLOOR FURNACE – A heating furnace equipped with one or more oil burners, safety controls, electrical equipment, and related equipment, manufactured for assembly as a complete unit.

3.46 PILOT – A flame that is utilized to ignite the fuel at the main burner or burners.

3.47 PRIMARY AIR – The air that is introduced into a burner and mixed with the fuel before it reaches the ignition zone.

3.48 RADIATION SHIELD – A separate panel or panels interposed between heating surfaces and adjacent objects to reduce heat transmission by radiation.

3.49 RADIATOR – An auxiliary heat transfer surface within the casing, connected between the combustion chamber and the flue collar.

3.50 READILY ACCESSIBLE – Capable of being reached easily and quickly for operation, adjustment, and inspection.

3.51 SAFETY CONTROL – See Control, Safety – 3.24.

3.52 SECONDARY AIR – The air externally supplied to the flame at or beyond the point of ignition.

3.53 SPECIAL PARTS AND TOOLS – Those parts and tools that are not available on the open retail market.

3.54 THERMOSTAT – An automatic control actuated by temperature change to maintain temperatures between predetermined limits.

3.55 VALVE, MANUAL OIL SHUTOFF – A manually operated valve in the oil line for the purpose of completely turning on or shutting off the oil supply to the burner.

3.56 VALVE, OIL CONTROL – An automatically or manually operated device consisting essentially of an oil valve for controlling the fuel supply to a burner.

a) Metering (Regulating) Valve – An oil control valve for regulating burner input.

b) Safety Shutoff Valve – A normally closed valve of the ON and OFF type, without any bypass to the burner, that is actuated by a safety control or by an emergency device.

3.57 VENTED APPLIANCE – An indirect fired appliance provided with a flue collar to accommodate a flue pipe for conveying flue gases to the outside air.

3A Undated References

3A.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

3A.1 added October 1, 2008

4 Components

4.1 Except as indicated in 4.2, a component of a product covered by this standard, including the oil burner and its primary safety control as assembled as part of a furnace assembly, shall comply with the requirements for that component. See Appendix A for a list of standards covering components generally used in the products covered by this standard.

4.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

4.3 A component shall be used in accordance with its rating established for the intended conditions of use.

4.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

CONSTRUCTION – MECHANICAL

5 Assembly

5.1 A furnace shall be intended for installation as a single assembly and shall include all the essential components necessary for its intended function when installed. The furnace may be shipped as two or more subassemblies.

5.2 A floor furnace, if not assembled by the manufacturer as a unit, shall be arranged in major subassemblies. Except as indicated in 5.3, each subassembly shall be capable of being incorporated into the final assembly without requiring alteration, cutting, drilling, threading, welding, or similar tasks by the installer. Two or more subassemblies which must bear a definite relationship to each other for the intended installation or operation of the floor furnace shall be:

- a) Arranged and constructed to permit them to be incorporated into the complete assembly, in the correct relationship with each other, without need for alteration or alignment; or
- b) Assembled, tested, and shipped from the factory as a single assembly.

5.3 In accordance with 5.2, major subassemblies of a floor furnace are considered to be the:

- a) Burner;
- b) Heat exchanger, including its base, combustion chamber, casing, and safety controls;
- c) Blower assembly, including the base, filters, and casing; and

ULNORM.COM : Click to view the full PDF of UL 729 2016

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 729 2016

- d) Blower motor if not included as part of the blower assembly.

A wiring harness may be packaged with one of the major subassemblies. Cutting or drilling required for the attachment of a return air plenum, the installation of an optional filter rack, or the provision of a return air opening in the furnace casing is deemed to conform to 5.2. If a return air opening is to be cut in the casing panel by the installer, suitable instructions and a template shall be furnished with the furnace, or the corners of the opening shall be embossed in knockout form.

5.4 A radiation shield or baffle employed to reduce the likelihood of excessive temperature shall be:

- a) Assembled as part of the furnace;
- b) Part of a subassembly that must be attached to the furnace for its intended operation; or
- c) Constructed so that the furnace cannot be assembled for operation without first attaching a required shield or baffle in its intended position.

5.5 The construction of a floor furnace shall be such that, for any typical installation, the alteration or removal of a baffle, insulation, or a radiation shield needed to reduce the likelihood of excessive temperatures is not required.

5.6 Parts of a floor furnace which must be removed for installation shall be assembled to the furnace in a manner to permit easy removal, without dismantling factory wiring, and replacement. See 5.2 – 5.5.

5.7 A floor furnace shall be constructed to provide a constant circulation of heated air at all times during intended operation.

5.8 A floor furnace with a single warm air register shall not be equipped with a shutter to restrict the flow of warm air from the furnace.

5.9 A floor furnace having two warm air registers equipped with a shutter shall be such that only one or a fraction of one warm air register may be closed at one time.

5.10 Except for the attachment of a return air duct, there shall be no opening in the casing of a floor furnace for admission of circulating air below the floor level unless applicable performance requirements are met with such an opening closed or open.

5.11 A furnace shall be constructed so that parts requiring attention or manipulation by the user during typical use can be easily operated.

5.12 Adjustable or movable parts should be provided with locking devices to reduce the risk of shifting.

5.13 Any external door providing access into the combustion chamber of a furnace is to fit tightly and be constructed in a manner to resist displacement by a jarring or pressure created during intended use. A door shall be self-closing or arranged so that it must be closed to replace the floor register.