



UL 854

STANDARD FOR SAFETY

Service-Entrance Cables

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 854 2024

ULNORM.COM : Click to view the full PDF of UL 854 2024

UL Standard for Safety for Service-Entrance Cables, UL 854

Twelfth Edition, Dated January 10, 2020

Summary of Topics

This revision of ANSI/UL 854 dated July 2, 2024 includes the following changes:

- Gasoline and Oil Resistant Markings, Revised [42.1](#) and [42.2](#) to Add PRI, PRII and GRI, GRII.***

Text that has been changed in any manner or impacted by ULSE's electronic publishing system is marked with a vertical line in the margin.

The revised requirements are substantially in accordance with Proposal(s) on this subject dated May 10, 2024.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 854 2024

JANUARY 10, 2020
(Title Page Reprinted: July 2, 2024)



ANSI/UL 854-2024

1

UL 854

Standard for Service-Entrance Cables

First Edition – April, 1937
Second Edition – October, 1966
Third Edition – March, 1969
Fourth Edition – July, 1971
Fifth Edition – June, 1975
Sixth Edition – June, 1979
Seventh Edition – February, 1987
Eighth Edition – May, 1991
Ninth Edition – May, 1996
Tenth Edition – December, 1999
Eleventh Edition – October, 2004

Twelfth Edition

January 10, 2020

This ANSI/UL Standard for Safety consists of the Twelfth Edition including revisions through July 2, 2024.

The most recent designation of ANSI/UL 854 as an American National Standard (ANSI) occurred on July 2, 2024. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

The Department of Defense (DoD) has adopted UL 854 on April 23, 1984. The publication of revised pages or a new edition of this Standard will not invalidate the DoD adoption.

Comments or proposals for revisions on any part of the Standard may be submitted to ULSE at any time. Proposals should be submitted via a Proposal Request in ULSE's Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 854 2024

CONTENTS

INTRODUCTION

1	Scope	7
2	General	8
	2.1 Units of measurement	8
	2.2 Undated reference	9
3	Terms	9

CONSTRUCTION

4	Materials	9
5	General	9

CONDUCTORS

6	Metal	9
	6.1 General	9
	6.2 Copper	10
	6.3 Copper-clad aluminum	10
	6.4 Aluminum	10
7	Metal Coating	10
8	Conductor Diameter and Cross-Sectional Area	11
9	Joints	11
10	Resistance	11
11	Separator	11
12	Sizes of Insulated Conductors	12
13	Stranding	12

INSULATION AND INDIVIDUAL JACKET

14	Details	12
----	---------------	----

ASSEMBLY OF JACKETED MULTIPLE-CONDUCTOR TYPE USE AND USE-2 CABLES AND OF TYPE SE CABLE

15	Conductors	21
16	Fillers	23
17	Overall Covering	23
	17.1 General	23
	17.2 Jacket	24
	17.3 Tape and finish	25

ASSEMBLY OF COVERLESS MULTIPLE-CONDUCTOR TYPE USE AND USE-2 CABLES

18	Details	26
----	---------------	----

ASSEMBLY OF SUBMERSIBLE PUMP CABLES

19	Details	29
----	---------------	----

PERFORMANCE

20	Flame Test of Cable.....	31
21	Flexibility Test of Cable at Low Temperature	31
22	Cold-Impact Test	31
23	Impact-Resistance Test of Single-Conductor Type USE and USE-2 Cables	31
24	Crushing-Resistance Tests of Single-Conductor Type USE and USE-2 Cables	32
25	Overload Test of Single-Conductor Type USE and USE-2 Cables	35
26	Overload Test of Conductors in Jacketed, Multiple-Conductor Type USE and USE-2 Cables...	35
27	Overload Test of Uninsulated Conductor in Type SE Cable	36
28	Continuity Test	36
29	Dielectric Voltage-Withstand Test(s).....	37
30	Sunlight-Resistance Tests.....	38
	30.1 Insulation	38
	30.2 Jacket.....	39
	30.3 Test Method	39
31	Vertical-Tray Flame Test (Type SE).....	39
32	Low-Temperature Pulling-Through-Joists Test	39
33	Oil-Resistance Tests (Single- and multiple-conductor Types USE and USE-2)	43
34	Gasoline- and Oil-Resistance Tests (Single conductor Types USE and USE-2)	44

IDENTIFICATION**REPETITION OF PRINTING**

35	Intervals	44
----	-----------------	----

POLARITY

36	General	44
----	---------------	----

MARKING

37	Cable as a Whole	45
	37.1 Identification of organization and manufacturer	45
	37.2 Identification of factory	45
	37.3 Methods of identification.....	45
	37.4 Authorized surface marking	46
	37.5 Surface, tag, reel, or carton marking not to be used	46
38	Insulated Conductors.....	46
	38.1 No identification required.....	46
	38.2 Only factory identification required	47
	38.3 Organization and factory identification required	47
39	Date of Manufacture	47
	39.1 General.....	47

CABLE TYPE

40	General	47
41	Style.....	48
42	Oil- and Gasoline and Oil-Resistant	49

SIZES AND NUMBER OF CONDUCTORS

43 General49
44 Compact-Stranded Copper Conductors49

ALUMINUM AND COPPER-CLAD ALUMINUM CONDUCTORS

45 General49

VOLTAGE

46 General50

SHIPPING LENGTHS

47 General50

ULNORM.COM : Click to view the full PDF of UL 854 2024

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 854 2024

INTRODUCTION

1 Scope

1.1 These requirements cover Type USE and USE-2 (below-ground) and Type SE (above-ground) power cables for installation in accordance with Article 338 and other applicable parts of the National Electrical Code (NEC). These cables are for the service-entrance and other (NEC) uses described in [1.4 – 1.8](#). In a multiple-conductor cable that is other than submersible-pump cable and does not have a grounding conductor it is appropriate to have one circuit conductor without insulation. It is also appropriate for a submersible pump cable to have a grounding conductor and for Type USE and USE-2 cables to have an insulated grounding conductor. Each insulated conductor in these cables is rated for 600 V. Type USE cable has thermoset insulation, except for the HDPE portion of HDPE-over-XL insulation where used for single-conductor Type USE cable. Type SE cable has thermoset or thermoplastic insulation.

1.2 These cables have insulation of solid, extruded dielectric material(s) that are for use in wet locations at 75°C (167°F) and lower temperatures. Cables that are marked with a conductor type that includes the letters "HH" have insulation that is for use in dry locations at temperatures as high as 90°C (194°F) as well as in wet locations at 75°C (167°F) and lower temperatures. Cables that are marked with a conductor type that includes "-2" have insulation that is for use in wet or dry locations at temperatures as high as 90°C (194°F).

1.3 Cables containing any conductor that is of a metal other than copper are marked to identify the metal as aluminum or copper-clad aluminum. Aluminum single-rated (see [1.4](#)) Type USE or USE-2 cables containing other than solid 12, 10 or 8 AWG conductor(s) are of an EC-1350 grade aluminum alloy or a registered AA-8000 series electrical-conductor-grade aluminum alloy. In all other cables, the aluminum conductor(s) are of a registered AA-8000 electrical-conductor-grade alloy only.

1.4 "Single-rated" Type USE cable is single-conductor, jacketed or coverless multiple-conductor, and submersible-pump cable without any indication of the conductor type letters on type cable, on the individual conductor(s), or on the tag, reel, or carton. "USE" is the only type designation associated with the cable. See [40.4](#).

1.5 Type SE cables that are not marked with conductor type letters or are marked with conductor type letters alone ("XHHW", "RHW", or "RHH OR RHW" not followed by "cdrs" or the like) have insulated conductors that do not comply with the Thermoset-Insulated Wires and Cables, UL 44, horizontal flame test. Type SE cables that are marked for use in cable trays comply with a 70,000 Btu/h (20.5 kW) vertical-tray flame test as described in Sections 4 – 11 of the Standard for Vertical-Tray Fire-Propagation and Smoke-Release Test for Electrical and Optical-Fiber Cables, UL 1685 or the FT4/IEEE 1202 flame test as described in Sections 12 – 19 of UL 1685. Smoke measurements are not applicable. See [31.1](#).

1.6 The outer surface of each single- and multiple-conductor cable that is marked for sunlight-resistance use and the outer surface of each Type SE cable that is marked for sunlight-resistance use in cable trays complies with a 720 h sunlight-resistance test. Each insulated conductor under an overall covering on such multiple-conductor cable complies with a 300 h sunlight-resistance test. All other cables are not marked "sunlight resistant" however they comply with a 300 h or equivalent (see [30.3.2](#)) sunlight-resistance test (each insulated conductor complies and, except in the case of submersible pump cable, any overall covering also complies).

1.7 Type USE and USE-2 cables are single-conductor in sizes through 2000 kcmil or are flat or round multiple-conductor in sizes through 4/0 AWG copper, 300 kcmil aluminum or copper-clad aluminum jacketed and through 2000 kcmil coverless. Type USE and USE-2 cables are not required to comply with a cable flame test. Jacketed multiple-conductor Type USE and USE-2 cables have 1 – 5 insulated conductors of the same size with or without an uninsulated grounded conductor that, in some cases, is smaller than the insulated conductors. It is appropriate to include one insulated equipment-grounding conductor that is in some cases smaller than the circuit conductors in a cable with no uninsulated