



---

# UL 867

## STANDARD FOR SAFETY

### Electrostatic Air Cleaners

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 867 2021

[ULNORM.COM](https://www.ulnorm.com) : Click to view the full PDF of UL 867 2021

UL Standard for Safety for Electrostatic Air Cleaners, UL 867

Fifth Edition, Dated August 4, 2011

### **Summary of Topics**

***This revision to ANSI/UL 867 August 16, 2021 is being issued to incorporate the following requirements:***

- Requirements for Battery Operated Air Cleaners; [1.1.1](#), [1.1.2](#), [4A.9.1](#), [6A.1](#), [6A.1.1](#), Section [33A](#) and Section [51D](#)***
- UL 508C Withdrawal and Replacement with UL 61800-5-1; [13A.3](#)***

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The new and revised requirements are substantially in accordance with Proposal(s) on this subject dated July 19, 2021.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical, photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 867 2021

**AUGUST 4, 2011**  
(Title Page Reprinted: August 16, 2021)



**ANSI/UL 867-2021**

1

## **UL 867**

### **Standard for Electrostatic Air Cleaners**

First Edition – December, 1980  
Second Edition – October, 1989  
Third Edition – March, 1995  
Fourth Edition – October, 2000

#### **Fifth Edition**

**August 4, 2011**

This ANSI/UL Standard for Safety consists of the Fifth Edition including revisions through August 16, 2021.

The most recent designation of ANSI/UL 867 as an American National Standard (ANSI) occurred on August 16, 2021. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

The Department of Defense (DoD) has adopted UL 867 on June 11, 1992. The publication of revised pages or a new edition of this Standard will not invalidate the DoD adoption.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

**COPYRIGHT © 2021 UNDERWRITERS LABORATORIES INC.**

No Text on This Page

[ULNORM.COM](http://ULNORM.COM) : Click to view the full PDF of UL 867 2021

## CONTENTS

### INTRODUCTION

1	Scope .....	7
2	General .....	7
	2.1 Components .....	7
	2.2 Units of measurement .....	7
	2.3 Undated references .....	7
3	Glossary .....	8

### CONSTRUCTION

4	General .....	11
4A	Components .....	11
	4A.1 General .....	11
	4A.2 Attachment plugs, receptacles, connectors and terminals .....	12
	4A.3 Boxes and raceways .....	13
	4A.4 Cords, cables and internal wiring .....	13
	4A.5 Cord reels .....	14
	4A.6 Ground-fault, arc-fault and leakage current detectors/interrupters .....	14
	4A.7 Light sources and associated components .....	14
	4A.8 Overcurrent protection .....	15
	4A.9 Power supplies .....	15
	4A.10 Supplemental insulation, insulating bushings and assembly aids .....	15
	4A.11 Transformers .....	16
	4A.12 Button or coin cell batteries .....	17
	4A.13 Information technology equipment .....	18
	4A.14 Optical isolators and semiconductor devices .....	18
5	Accessories .....	18
6	Frame, Cabinet and Enclosure .....	19
	6.1 General .....	19
	6.2 High-voltage power supply .....	20
	6.3 Fixed products .....	21
	6.4 Portable products .....	23
6A	Nonmetallic Parts .....	24
6B	Nonmetallic Materials .....	24
6C	Nonmetallic Material Ignition Sources Separation .....	24
7	Accessibility of Uninsulated Live Parts and Moving Parts .....	26
8	Mechanical Assembly .....	31
	8.1 General .....	31
	8.2 Assembly for shipping .....	32
	8.3 Mechanical barriers .....	32
9	Live Parts .....	33
10	Protection Against Corrosion .....	33
	10.1 Products intended for indoor use .....	33
	10.2 Products intended for outdoor use .....	33
11	Electrical Insulation .....	35
	11.1 All circuits .....	35
	11.2 Primary circuits .....	35
	11.3 Secondary circuits .....	35
	11.4 Insulating barriers .....	35
12	Supply Connections .....	36
	12.1 Permanently-connected products .....	36
	12.2 Cord-connected products .....	40

12.3	Cord-connected conversion to permanently connected	42
13	Polarization	42
13A	Switches and Controllers	43
13B	Remotely Operated Electrostatic Air Cleaners	48
14	Grounding	49
14.1	General	49
14.2	Bonding	49
14.3	Portable products	50
15	Internal Wiring	50
15.1	General	50
15.2	Primary circuits	51
15.3	High-voltage circuits	52
16	Capacitors	52
17	Coil Windings	54
18	Printed-Wiring Boards	54
19	Overcurrent Protection	54
19A	General Purpose Transformer – Insulation Systems	55
20	Motors and Motor Overcurrent Protection	55
21	Washing	56
22	Filters	56
23	Spacings	57
23.1	General	57
23.2	Low voltage and isolated-limited-energy circuits	57
23.3	Line-voltage circuits	58
23.4	High-voltage circuits	58
23.5	Insulating barriers	60
23.6	Alternate spacings – clearances and creepage distances	60
24	Separation of Circuits	61
24.1	General	61
24.2	Class 2 circuits	61
24.3	Permanently-connected products	61

## PROTECTION AGAINST INJURY TO PERSONS

25	General	62
26	Rotating Parts	62
27	Enclosures and Guards	63
28	Impact Test	63
29	Interlocks	64
29.1	Switches	64
29.2	Interlocks	64
30	Electronic Circuits	64
31	Stability	64
32	Collector Handle Securement Test	65
33	External Surface Temperatures	65
33A	Battery Operated Air Cleaners	65
33A.1	General	65

## PERFORMANCE

34	General	69
35	Leakage Current Test	69
35.1	General	69
35.2	Normal use	69
36	Leakage Current Following Humidity Conditioning	71

37	Partially Protected Parts .....	71
38	Input Test.....	72
39	Output Test .....	73
40	Ozone Test .....	73
	40.1 General.....	73
	40.2 Chamber specifications .....	74
	40.3 Equipment specifications .....	76
	40.4 Test method .....	76
41	Peak Ozone Emission Location Determination .....	79
42	Strain Relief Test.....	79
43	Pushback Relief Test.....	79
44	Grounding Resistance Test.....	80
45	Temperature Test .....	80
46	Dielectric Voltage-Withstand Test .....	85
	46.1 General.....	85
	46.2 High-voltage transformer core.....	87
	46.3 Induced potential .....	87
46A	General Purpose Transformers .....	87
	46A.1 General .....	87
	46A.2 Voltage measurement test.....	87
	46A.3 Overload test .....	87
	46A.4 Repeated dielectric voltage-withstand test.....	88
46B	Thermal Aging Test .....	88
46C	Endurance Test – Switching Devices .....	89
47	Stored Energy Test.....	90
48	Evaluation of Reduced Spacings on Printed-Wiring Boards .....	91
	48.1 General.....	91
	48.2 Shorted trace test .....	91
49	Abnormal Operation Test .....	92
	49.1 General.....	92
	49.2 High-voltage supply .....	93
	49.3 High-voltage spacings short circuit.....	93
	49.4 Unenclosed high-voltage power supply .....	93
	49.5 Component short- and open-circuit test .....	93
	49.6 Stalled rotor, restricted air inlet and blocked air outlet.....	94
	49.7 Low-voltage powered product overvoltage test.....	94
49A	Protective Electronic Circuit Tests.....	94
	49A.1 General .....	94
	49A.2 Fault conditions abnormal test.....	94
	49A.3 Electromagnetic compatibility (EMC) tests.....	96
	49A.4 Programmable component reduced supply voltage test.....	97
	49A.5 Fuse-link test .....	98
49B	Rain Test.....	98
49C	Accelerated Aging Tests – Gaskets .....	101
49D	Switch Mode Power Supply Units – Overload Test.....	103
50	Metallic Coating Thickness Test.....	103
51	High-Voltage Insulating Material Arcing Test.....	105
51A	Tests on Nonmetallic Materials .....	105
51B	Fastener Strength Test .....	107
51C	Wiring Endurance Test .....	107
51D	Non-Metallic Enclosure-Fastener Test for Battery Operated Appliances .....	108
52	Permanence of Marking.....	109

## MANUFACTURING AND PRODUCTION TESTS

53	Dielectric Voltage-Withstand Test .....	110
----	---	-----

54	Grounding Continuity.....	112
54A	Protective Electronic Circuit Test .....	112

## RATINGS

55	Details.....	112
----	--------------	-----

## MARKINGS

56	Visible During Installation and Inspection .....	112
57	Visible After Installation.....	113
58	Cautionary Markings.....	114
59	Manufacturer's Literature .....	115

## APPENDIX A

Appendix B – (Normative) – Operating and Protective (“Safety Critical”) Control Functions

ULNORM.COM : Click to view the full PDF of UL 867 2021

## INTRODUCTION

### 1 Scope

1.1 These requirements cover electrostatic air cleaners rated at 600 volts or less, intended to remove dust and other particles from the air and intended for use in accordance with the National Electrical Code, ANSI/NFPA 70.

1.1.1 In reference to [1.1](#), these requirements may be used to evaluate products that are:

- a) Powered entirely by a low-voltage supply source, such as those intended for connection to a Universal Serial Bus (USB) supply source; or
- b) Provided with or intended for use with one or more rechargeable battery system(s) for portable appliances intended for household use only.

1.1.2 These requirements do not cover battery operated products other than portable appliances intended for household use only.

1.2 These requirements do not cover electrostatic air cleaners for use in hazardous locations or to clean atmospheres defined as hazardous by the National Electrical Code, ANSI/NFPA 70.

1.3 These requirements do not cover air cleaners intended to remove particles other than dust and other particles normally found in heating and ventilating systems.

1.4 Requirements for the installation of duct-type electrostatic air cleaners are included in the Standard for the Installation of Air Conditioning and Ventilating Systems, NFPA 90A; and the Standard for the Installation of Warm Air Heating and Air Conditioning Systems, NFPA 90B.

### 2 General

#### 2.1 Components

2.1.1 *Deleted*

2.1.2 *Deleted*

2.1.3 *Deleted*

2.1.4 *Deleted*

2.1.5 No component shall contain liquid mercury.

#### 2.2 Units of measurement

2.2.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

#### 2.3 Undated references

2.3.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

### 3 Glossary

3.1 For the purposes of this standard the following definitions apply.

3.2 ACCESSIBLE PART – A part located so that it can be contacted by a person either directly or by means of a probe as specified in Accessibility of Uninsulated Live Parts and Moving Parts, Section 7.

3.3 AIR CLEANERS – An air cleaner is defined as one of the following:

a) Duct type – An air cleaner intended for installation in and at adjoining ducts, including the plenum, of heating, air conditioning, and ventilating systems. The air cleaner may not be provided with a fan, and the duct may provide part or all of the cabinet. This type of air cleaner may be either cord-and-plug connected or permanently connected to the electrical supply source.

b) Fixed type – An air cleaner intended to be:

1) Permanently connected to the electrical supply source;

2) Permanently mounted, such that tools are required for the product installation or removal; or,

3) Sized so that it is not easily moved from one place to another.

c) Portable type – A cord-and-plug-connected air cleaner that:

1) Can be easily moved from one place to another for use; and

2) Has no provision for permanent mounting. Tools are not required for the product installation or removal.

d) Deleted

e) Deleted

3.3.1 BARRIER, INSULATING – A partition for isolating parts of electrical circuits.

3.3.2 BARRIER, MECHANICAL – A partition for isolating ignition sources, moving parts or protection of wiring.

3.4 Deleted

3.4.0 CABINET – The part of the equipment that:

a) Provides physical protection to insulated wiring, enclosures, moving parts, motors, enclosed electrical parts, tubing or any other parts that may cause injury to persons; and,

b) Does not, by itself, enclose any high-voltage or line-voltage uninsulated live parts.

3.4.0.1 CAPACITOR, CLASS Y – Capacitor or resistor-capacitor unit of a type suitable for use in situations where failure of the capacitor could lead to danger of electric shock. (Examples would include capacitors connected across the primary and secondary circuits where electrical isolation is required to prevent an electric shock or between hazardous live parts and accessible parts.)

3.4.1 COMPONENT – A device or fabricated part of a product covered by the scope of a safety standard dedicated to that purpose. If incorporated in a product, a part that is otherwise typically field installed (e.g. luminaire) is considered to be a component. Unless otherwise specified, materials that compose a device

or fabricated part, such as aluminum or copper, are not considered components. Generally, components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under specific, limited conditions, such as certain temperatures not exceeding specified limits.

**3.4.2 CONTROL, OPERATING** – A device or assembly of devices, the operation of which starts or regulates the end product during normal operation. For example, a thermostat, the failure of which a thermal cutout/limiter or another layer of protection would mitigate the risk of electric shock, is considered an operating control and in this example could also be called a “regulating control”. Operating controls can also include other controlling devices such as switches, contactors, relays and similar devices. Appendix B specifies control functions that are not considered to result in a risk of fire, electric shock or injury to persons.

**3.4.3 CONTROL, PROTECTIVE** – A device or assembly of devices, the operation of which is intended to reduce the risk of fire, electric shock or injury to persons during normal and reasonably anticipated abnormal operation of the product. For example, a thermal cutout/limiter, or any other control/circuit relied upon for normal and abnormal conditions, is considered a protective control. Protective controls are also referred to as “limiting controls” or “safety controls” and are investigated under normal and single-fault conditions. Appendix B specifies control functions that are considered to result in a risk of fire, electric shock or injury to persons.

**3.4.4 ELECTRONIC COMPONENT** – A part in which electrical conduction is achieved principally by electrons moving through a vacuum, gas or semiconductor. A Metal Oxide Varistor (MOV) is considered to be an electronic component, but neon indicators are not.

©IEC. This material is reproduced from IEC 60335-1 Ed. 5.2 b:2016 with permission of the American National Standards Institute (ANSI) on behalf of the International Electrotechnical Commission. All rights reserved.

**3.4.5 ELECTRONIC DISCONNECTION** – The de-energizing of a load within a product by an electronic device of a circuit. No electro-mechanical component having an air gap, such as a switch, contactor or relay is used to de-energize the load.

**3.5 ELECTROSTATIC AIR CLEANER (AIR CLEANER)** – A product intended to remove dust and other particles from the air. The complete product consists of an assembly of a power pack, controls, ionizer-collector cell, and other components.

**3.5.1 ENCLOSURE** – The part of the equipment that does one or more of the following:

- a) Isolates ignition sources,
- b) Renders inaccessible all or any part(s) of the equipment that may otherwise present a risk of electric shock, including uninsulated high- or line-voltage parts.
- c) Retards propagation of flame initiated by electrical disturbances occurring within.

**3.6 EXPOSED PART** – A part that is subjected to handling in normal use without removing parts such as doors, covers, or other parts if removal requires the use of a tool.

**3.6.1 FUNCTIONAL PART** – A part other than an enclosure or cabinet used to maintain the intended relative physical position of fixed or moving parts, maintain the integrity of the structure or required for the intended operation of the product. A fan blade is an example of this type of part.

**3.6.2 GROUNDING, FUNCTIONAL** – Grounding of a point in a product which is necessary for a purpose other than safety.

3.7 HIGH-VOLTAGE CIRCUIT – A circuit involving a potential of more than 600 volts.

3.7.1 IGNITION SOURCE – Any high- or line-voltage electrical component not located within an enclosure. Wiring with VW-1 insulation is not considered an ignition source.

3.8 ISOLATED-LIMITED-ENERGY CIRCUIT – A circuit derived from an isolated-secondary winding of a transformer having a maximum capacity of 100 volt-amperes and an open-circuit-secondary voltage rating not exceeding 600 volts.

3.9 LINE-VOLTAGE CIRCUIT – A circuit involving a potential of not more than 600 volts, and having characteristics in excess of those of a low-voltage or an isolated-limited-energy circuit.

3.10 LOW-VOLTAGE CIRCUIT – A circuit involving a potential of not more than 30 volts rms and supplied by a primary battery, a Class 2 transformer, or by a combination of a transformer and fixed impedance that, as a unit, complies with all the performance requirements for a Class 2 transformer. A circuit derived from a line-voltage circuit by the connection of resistance in series with the supply circuit to limit the voltage and current is not considered to be a low-voltage or an isolated-secondary circuit.

3.11 *Deleted*

3.11.1 MOTOR CONTROLLER – Any device normally used to start and stop a motor, such as a switch, thermostat, pressure limiting control, or the like.

3.11.2 NONFUNCTIONAL PART – A part of the equipment that does not perform a specific function. Decorative trim is an example of this type of part.

3.12 PARTIALLY PROTECTED PART – A part that is exposed only during user servicing, with voltage and current limitations as specified in Partially Protected Parts, Section [37](#).

3.13 POWER SUPPLY – A unit consisting of a high-voltage transformer and other electrical component. The unit may also contain controls for the air cleaner.

3.13.1 PROTECTIVE ELECTRONIC CIRCUIT (PEC) – An electronic circuit that prevents a risk of fire, electric shock or injury to persons under abnormal operating conditions.

©IEC. This material is adapted from IEC 60335-1 Ed. 5.2 b:2016 with permission of the American National Standards Institute (ANSI) on behalf of the International Electrotechnical Commission. All rights reserved.

3.14 *Deleted*

3.14.1 SWITCH MODE POWER SUPPLY UNIT – Electronic device incorporating transformer(s) and electronic circuitry(ies), that converts electrical power into single or multiple power outputs by rapidly switching a solid-state device on and off. It may also isolate the input circuit from the output circuit and regulate and/or convert the output voltage and current. The device may consist of one or more individual units with identical or different waveforms and frequencies including dc output.

3.14.2 THERMISTOR – A thermally sensitive semiconductor resistor, which shows over at least part of its resistance/temperature characteristic a significant non-linear change in its electrical resistance with a change in temperature. A thermistor may be either of the positive temperature coefficient (PTC) type or of the negative temperature coefficient (NTC) type.

3.15 USER SERVICING – The replacing, cleaning, or adjusting of filters or adjustment of controls and the like intended to be done by the user.

3.16 VOLTAGE FOLDBACK – A circuit design feature intended to protect the power supply output transistors. When overcurrent is drawn by the load, the supply reduces the output voltage and current to within the safe power dissipation limit of the output transistors.

## CONSTRUCTION

### 4 General

4.1 The construction of a product shall be such that all of the following conditions are met:

- a) Normal use and user servicing do not result in a risk of electric shock, fire, or injury to persons.
- b) The materials and component are used within their electrical, mechanical, and temperature limits.
- c) The assembly protects the components and wiring from being displaced or damaged.

### 4A Components

#### 4A.1 General

4A.1.1 A component of a product covered by this standard shall:

- a) Comply with the requirements for that component as indicated in [4A.2](#) – [4A.10](#) or the individual component section;
- b) Be used in accordance with its rating(s) established for the intended conditions of use;
- c) Be used within its established use limitations or conditions of acceptability; and
- d) Additionally comply with the applicable requirements of this end product standard.

Note – Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

*Exception No. 1: A component of a product covered by this standard is not required to comply with a specific component requirement that:*

- a) *Involves a feature or characteristic not required in the application of the component in the product; or*
- b) *Is superseded by a requirement in this standard; or*
- c) *Is separately investigated when forming part of another component, provided the component is used within its established ratings and limitations.*

*Exception No. 2: A component complying with a component standard other than those cited in [4A.2](#) – [4A.10](#) or the individual component section is acceptable if:*

- a) *The component also complies with the applicable component standard of [4A.2](#) – [4A.10](#) or the individual component section; or*
- b) *The component standard:*
  - 1) *Is compatible with the ampacity and overcurrent protection requirements of the National Electrical Code, ANSI/NFPA 70, where appropriate;*

2) Considers long-term thermal properties of polymeric insulating materials in accordance with the Standard for Polymeric Materials – Long Term Property Evaluations, UL 746B; and

3) Any use limitations of the other component standard is identified and appropriately accommodated in the end use application. For example, a component used in a household application, but intended for industrial use and complying with the relevant component standard may assume user expertise not common in household applications.

4A.1.2 A component that is also intended to perform other functions, such as over current protection, ground-fault circuit-interruption, surge suppression, any other similar functions, or any combination thereof, shall comply additionally with the requirements of the applicable UL standard(s) that cover devices that provide those functions.

*Exception: Where these other functions are not required for the application and not identified as part of markings, instructions, or packaging for the appliance, the additional component standard(s) need not be applied.*

4A.1.3 A component not anticipated by the requirements of this standard, not specifically covered by the component standards of [4A.2](#) – [4A.10](#) or individual component sections and that involves a potential risk of electric shock, fire, or personal injury, shall be additionally investigated in accordance with the applicable UL standard, and shall comply with [4A.1.1](#)(b) – (d).

4A.1.4 With regard to a component being additionally investigated, reference to construction and performance requirements in another UL end product standard is appropriate where that standard anticipates normal and abnormal use conditions consistent with the application of this standard.

## **4A.2 Attachment plugs, receptacles, connectors and terminals**

4A.2.1 Attachment plugs, receptacles, appliance couplers, appliance inlets (motor attachment plugs), and appliance (flatiron) plugs, shall comply with the Standard for Attachment Plugs and Receptacles, UL 498. See [4A.2.9](#).

*Exception: Attachment plugs and appliance couplers integral to cord sets or power supply cords are covered under the requirements of the Standard for Cord Sets and Power-Supply Cords, UL 817, and need not comply with UL 498.*

4A.2.2 Quick-connect terminals, both connectors and tabs, for use with one or two 22 – 10 AWG copper conductors, having nominal widths of 3.5, 3.2, 4.8, 5.2, and 6.3 mm (0.110, 0.125, 0.187, 0.205, and 0.250 in), intended for internal wiring connections in appliances, or for the field termination of conductors to the appliance, shall comply with the Standard for Electrical Quick-Connect Terminals, UL 310.

*Exception: Other sizes of quick-connect terminals shall be investigated with respect to crimp pull out, insertion-withdrawal, temperature rise, and all tests shall be conducted in accordance with UL 310.*

4A.2.3 Single and multipole connectors for use in data, signal, control and power applications within and between electrical equipment, and that are intended for factory connection and for factory assembly to copper or copper alloy conductors, or for factory assembly to printed wiring boards, shall comply with the Standard for Component Connectors for Data, Signal, Control and Power Applications, UL 1977. See [4A.2.9](#).

4A.2.4 Wire connectors shall comply with the Standard for Wiring Connectors, UL 486A-486B.

4A.2.5 Splicing wire connectors shall comply with the Standard for Splicing Wire Connectors, UL 486C.

4A.2.6 Multi-pole splicing wire connectors that are intended to facilitate the connection of hard-wired utilization equipment to the branch-circuit conductors of buildings or that are intended for consumer connection within and between parts of electrical equipment, shall comply with the Standard for Multi-Pole Splicing Wire Connectors, UL 2459. See [4A.2.9](#).

4A.2.7 Equipment wiring terminals for use with all alloys of copper, aluminum, or copper-clad aluminum conductors, shall comply with the Standard for Equipment Wiring Terminals for Use with Aluminum and/or Copper Conductors, UL 486E.

4A.2.8 Terminal blocks shall comply with the Standard for Terminal Blocks, UL 1059, and, if applicable, be suitably rated for field wiring.

4A.2.9 Female devices (such as receptacles, appliance couplers, and connectors) that are intended, or that may be used, to interrupt current in the end product, shall be suitably rated for current interruption of the specific type of load, when evaluated with its mating plug or connector. For example, an appliance coupler that can be used to interrupt the current of a motor load shall have a suitable horsepower rating when tested with its mating plug.

### 4A.3 Boxes and raceways

4A.3.1 Electrical boxes and the associated bushings and fittings, and raceways, of the types specified in Chapter 3 of the National Electrical Code, ANSI/NFPA 70 and that comply with the relevant UL standard (such as the Standard for Metallic Outlet Boxes, UL 514A, Standard for Nonmetallic Outlet Boxes, Flush-Device Boxes, and Covers, UL 514C, Standard for Cover Plates for Flush-Mounted Wiring Devices, UL 514D) and [4A.1](#) are considered to fulfill the requirements of this Standard.

### 4A.4 Cords, cables and internal wiring

4A.4.1 A cord set or power supply cord shall comply with the Standard for Cord Sets and Power Supply Cords, UL 817.

4A.4.2 Flexible cords and cables shall comply with the Standard for Flexible Cords and Cables, UL 62. Flexible cord and cables are considered to fulfill this requirement when preassembled in a cord set or power supply cord complying with the Standard for Cord Sets and Power Supply Cords, UL 817.

4A.4.3 Internal wiring composed of insulated conductors shall comply with the Standard for Appliance Wiring Material, UL 758.

*Exception No. 1: Insulated conductors need not comply with UL 758 if they comply with one of the following:*

- a) Standard for Thermoset-Insulated Wires and Cables, UL 44;*
- b) Standard for Thermoplastic-Insulated Wires and Cables, UL 83;*
- c) Standard for Fixture Wire, UL 66; or*
- d) The appropriate UL standard(s) for other insulated conductor types specified in Chapter 3 (Wiring Methods and Materials) of the National Electrical Code, ANSI/NFPA 70.*

*Exception No. 2: Insulated conductors for specialty applications (e.g. data processing or communications) and located in a low-voltage circuit not involving the risk of fire or personal injury need not comply with UL 758.*

#### 4A.5 Cord reels

4A.5.1 A cord reel shall comply with the special-use cord reel requirements of the Standard for Cord Reels, UL 355.

#### 4A.6 Ground-fault, arc-fault and leakage current detectors/interrupters

4A.6.1 Ground-fault circuit-interrupters (GFCI) for protection against electrical shock shall comply with the Standard for Ground-Fault Circuit-Interrupters, UL 943. The following statement, or equivalent, shall be included as a marking near the GFCI, or as an instruction in the manual: " Press the TEST button (then RESET button) every month to assure proper operation."

4A.6.2 Appliance-leakage-current interrupters (ALCI) for protection against electrical shock shall comply with the Standard for Appliance-Leakage-Current Interrupters, UL 943B.

Note – An ALCI is not considered an acceptable substitute for a GFCI when NFPA 70 requires a GFCI.

4A.6.3 Equipment ground-fault protective devices shall comply with the Standard for Ground-Fault Sensing and Relaying Equipment, UL 1053, and the applicable requirements of the Standard for Ground-Fault Circuit-Interrupters, UL 943.

4A.6.4 Arc-fault circuit-interrupters (AFCI) shall comply with the Standard for Arc-Fault Circuit-Interrupters, UL 1699.

4A.6.5 Leakage-current detector-interrupters (LCDI) and any shielded cord between the LCDI and appliance shall comply with the Standard for Arc-Fault Circuit-Interrupters, UL 1699.

#### 4A.7 Light sources and associated components

4A.7.1 Lampholders and indicating lamps shall comply with the Standard for Lampholders, UL 496.

*Exception: Lampholders forming part of a luminaire that complies with an appropriate UL luminaire standard are considered to fulfill this requirement.*

4A.7.2 Lighting ballasts shall comply with the:

- a) Standard for Fluorescent-Lamp Ballasts, UL 935; or
- b) Standard for High-Intensity Discharge Lamp Ballasts, UL 1029.

*Exception No. 1: Ballasts forming part of a luminaire that complies with an appropriate UL luminaire standard are considered to fulfill this requirement.*

*Exception No. 2: Ballasts for other light sources shall comply with the appropriate UL standard(s).*

4A.7.3 Light emitting diode (LED) light sources shall comply with the Standard for Light Emitting Diode (LED) Light Sources For Use In Lighting Products, UL 8750.

*Exception No. 1: LED light sources forming part of a luminaire that complies with an appropriate UL luminaire standard are considered to fulfill this requirement.*

*Exception No. 2: Individual LED light sources mounted on printed wiring boards and intended for indicating purposes need not comply with UL 8750, but shall comply with the applicable requirements of this end product standard.*

#### 4A.8 Overcurrent protection

4A.8.1 Deleted

4A.8.2 Deleted

4A.8.3 Deleted

4A.8.4 Deleted

4A.8.5 Deleted

#### 4A.9 Power supplies

4A.9.1 A power supply other than a high-voltage power supply shall comply with one of the following:

a) For a power supply providing a low-voltage circuit output:

1) Standard for Class 2 Power Units, UL 1310; or

2) Standard for Information Technology Equipment – Safety – Part 1: General Requirements, UL 60950-1, or Standard for Household and Similar Electrical Appliances – Safety – Part 2-29: Particular Requirements For Battery Chargers, UL 60335-2-29; with an output marked "Class 2", or that complies with the limited power source (LPS) requirements and is marked "LPS".

b) For a power supply providing a line-voltage circuit output:

1) Standard for Power Units Other Than Class 2, UL 1012; or

2) Standard for Information Technology Equipment – Safety – Part 1: General Requirements, UL 60950-1.

c) For a switch mode power supply unit not complying with (a) or (b), the relevant requirements in this Standard, including the Switch Mode Power Supply Units – Overload Test, Section [49D](#), shall be applied.

#### 4A.10 Supplemental insulation, insulating bushings and assembly aids

4A.10.1 The requirements for supplemental insulation (e.g. tape, sleeving or tubing) are not specified unless the insulation or device is required to fulfill a requirement of this standard. In such cases:

a) Insulating tape shall comply with the Standard for Polyvinyl Chloride, Polyethylene, and Rubber Insulating Tape, UL 510;

b) Sleeving shall comply with the Standard for Coated Electrical Sleeving, UL 1441;

c) Tubing shall comply with the Standard for Extruded Insulating Tubing, UL 224.

4A.10.2 Insulating bushings that comply with Section [4A.1](#) of this end-product standard, and the Standard for Insulating Bushings, UL 635, are considered to fulfill the requirements of this Standard. Tests specified in this Standard (e.g. Strain Relief Test) may still need to be performed to confirm the combination of the insulating bushing and the supporting part are suitable.

## 4A.11 Transformers

4A.11.1 General-purpose transformers shall:

- a) Comply with the Standard for Low Voltage Transformers – Part 1: General Requirements, UL 5085-1; and the Standard for Low Voltage Transformers – Part 2: General Purpose Transformers, UL 5085-2; or
- b) Be completely enclosed within the cabinet and comply with the insulation requirements in [4A.11.3](#) – [4A.11.7](#) as well as the construction and performance requirements of this standard as far as they reasonably apply; or,
- c) Comply with the Standard for Transformers and Motor Transformers for Use in Audio-, Radio-, and Television-Type Appliances, UL 1411, if used in a circuit involving an audio or video component.

4A.11.2 Class 2 and Class 3 transformers shall:

- a) Comply with the Standard for Low Voltage Transformers – Part 1: General Requirements, UL 5085-1; and the Standard for Low Voltage Transformers – Part 3: Class 2 and Class 3 Transformers, UL 5085-3; or,
- b) Be entirely located within a low-voltage circuit that is not provided with a protective control.

4A.11.3 If a general purpose transformer has a Class 105 (A) insulation system, the transformer shall comply with:

- a) The spacings requirements in [Table 23.1](#); or
- b) Except as specified in [4A.11.4](#), be provided with an insulation system consisting of a combination of magnet wire and be one or more of the following major component insulation materials:
  - 1) Thermoset materials;
  - 2) Those specified in [Table 4A.1](#) at the specified minimum thickness;
  - 3) Materials or a combination of materials, whether polymeric or not polymeric (treated cloth, for example), that are thinner or other than those specified in [Table 4A.1](#), and used to isolate the windings from dead metal parts and:
    - i) Have a relative or generic thermal index for electrical properties of at least 221°F (105°C); and
    - ii) Be unfilled glass-reinforced nylon, polycarbonate, polybutylene terephthalate, polyethylene terephthalate, phenolic or acetal.
  - 4) Other polymeric materials complying with the Thermal Aging Test, Section [46B](#).

**Table 4A.1**  
**Primary class A insulating materials and minimum thicknesses**

Material	Minimum thickness	
	mm	(inches)
Vulcanized fiber	0.71	(0.028)
Polyethylene terephthalate film	0.18	(0.007)
Cambric	0.71	(0.028)
Treated cloth	0.71	(0.028)
Electrical grade paper	0.71	(0.028)
Mica	0.15	(0.006)
Aramid paper	0.25	(0.010)

4A.11.4 Insulating materials not complying with [4A.11.3](#)(b) shall comply with [4A.11.5](#) and be used between a crossover lead and the:

- a) Turns of the transformer winding to which the lead is connected;
- b) Adjacent winding;
- c) Metallic enclosure; or
- d) Transformer core.

4A.11.5 The insulating materials referenced in [4A.11.4](#) shall:

- a) Be electrical grade paper, waxed or otherwise treated to resist the absorption of moisture, having a total thickness not less than 0.013 inch (0.33 mm); or
- b) Be mechanically and thermally equivalent insulating material(s) to (a) and:
  - 1) Have a dielectric breakdown strength of 2500 volts or more in the thickness used; or
  - 2) Withstand the dielectric voltage-withstand test potential in [46.1.1](#)(a) with the potential applied between the coil leads and with the coil lead cut at the point where it enters the inner layer; or
  - 3) Withstand the induced-potential test in [46.3](#).

4A.11.6 Leads provided as part of a Class 105 (A) insulation system on a general purpose transformer shall be rated 194°F (90°C) minimum.

4A.11.7 The following shall comply with the Standard for Systems of Insulating Materials – General, UL 1446:

- a) Materials used in an insulation system operating above Class 105 (A) temperatures; or
- b) Insulation systems employing integral ground insulation.

#### **4A.12 Button or coin cell batteries**

4A.12.1 An appliance, or any accessory of the appliance such as a wireless control, intended for use with one or more single cell batteries, shall comply with [4A.12.2](#) if the batteries are sized with a maximum:

- a) Diameter of 1.25 inch (32 mm); and
- b) Height that is less than its diameter.

4A.12.2 An appliance for household use and provided with one or more batteries as specified in [4A.12.1](#) shall comply with the Standard for Products Incorporating Button or Coin Cell Batteries of Lithium Technologies, UL 4200A or be intended for one of the following:

- a) Countertop use only;
- b) Fixed installation and with the batteries located at a height not less than 4 feet (1.2 m) above the floor; or
- c) Use where the batteries are not intended to be replaced and are not referenced in the appliance markings or in any instructions provided with the appliance.

#### **4A.13 Information technology equipment**

4A.13.1 Information technology equipment such as a printer, visual display unit, router, communication connectors/data ports or computer shall comply with the Standard for Information Technology Equipment – Safety – Part 1: General Requirements, UL 60950-1.

#### **4A.14 Optical isolators and semiconductor devices**

4A.14.1 An optical isolator shall comply with the Standard for Optical Isolators, UL 1577 if it is relied upon to provide isolation between:

- a) Primary and secondary circuits;
- b) Low-voltage safety circuits; or
- c) Other high-voltage circuits.

4A.14.2 In addition to complying with [4A.14.1](#), an optical isolator relied upon to provide feedback between primary and secondary circuits of a switch mode power supply unit shall have a minimum isolation voltage of 1500V.

4A.14.3 A power switching semiconductor device that is relied upon to provide isolation to ground shall comply with the Standard for Electrically Isolated Semiconductor Devices, UL 1557. If the switching semiconductor is used as part of a switch mode power supply unit, it shall have a minimum isolation voltage of 1500 V.

### **5 Accessories**

5.1 An appliance having provision for the use of an electrical accessory intended to be attached in the field shall comply with the requirements in this standard, with or without the accessory installed.

5.2 Installation of an accessory by the user shall be by means of a locking type receptacle and plug-in connector.

5.3 When an accessory is to be installed by the user, the appliance shall comply with the requirements in Section [7](#), Accessibility of Uninsulated Live Parts and Moving Parts, during and after the installation of the accessory.

5.4 The installation of an accessory by service personnel shall be by means of receptacles, plug-in connectors, insulated wire connectors, or by connection to existing wiring terminals.

5.5 With reference to [5.4](#), an installation shall not require the cutting of wiring or the soldering of connections by the installer. Installations shall not require cutting, drilling, or welding in electrical enclosures and in other areas where such operations may damage electrical components and wiring within the cabinet or enclosure.

5.6 A means for strain relief shall be provided and comply with the strain relief test in Section [42](#), Strain Relief Test, at a force of 20 pounds (89 N), for the wiring in the accessory if there is a possibility of transmitting stress to the terminal connections during installation.

5.7 All terminals and wiring intended to be field connected shall be identified on the accessory, on the appliance if connections are made between the accessory and the appliance, and on the wiring diagram.

5.8 The intended installation of the accessory shall be indicated in the installation instructions included on or with the accessory. See [59.8](#).

5.9 As part of the investigation, an accessory is to be trial installed to determine that the installation is feasible, the instructions are detailed and correct, and the use of the accessory does not introduce a risk of electric shock, fire, or injury to persons.

5.10 An electrical accessory intended for field installation shall be marked in accordance with [57.9](#).

## **6 Frame, Cabinet and Enclosure**

### **6.1 General**

6.1.1 Electrical parts shall be provided within a cabinet or enclosure.

6.1.2 Other than as noted in [6.1.3](#), an air-inlet or an air-outlet opening of a duct-type product may be considered enclosed by the adjacent duct work if an insulated or an uninsulated live part accessible without the duct work installed is at an energy level equal to or below that of a partially-protected part as specified in Partially Protected Parts, Section [37](#).

6.1.3 An air-inlet or an air-outlet opening not always intended to be attached to duct work is not considered to be enclosed.

6.1.4 The cabinet, enclosure and parts of the cabinet or enclosure such as doors, covers, and the like, shall be provided with means for securing them in place.

6.1.5 An enclosure or cabinet shall be formed and assembled so that it will have the strength and rigidity necessary to resist the abuses to which it is likely to be subjected, without increasing its risk of fire, electric shock, or injury to persons due to total or partial collapse with resulting reduction of spacings, loosening or displacement of parts, or other serious defects.

6.1.6 A cast-metal or die-cast metal cabinet or enclosure shall be investigated to determine that it is equivalent to sheet metal.

6.1.7 *Deleted*

6.1.8 *Deleted*

6.1.9 Glass covering an observation opening shall be secured in place so that it cannot be readily displaced in service, and shall provide mechanical protection for the enclosed parts.

6.1.10 Glass for an opening not more than 4 inches (102 mm) in any dimension shall not be less than 0.055 inch (1.40 mm) thick. Glass for a larger opening, but not more than 144 square inches (929 cm<sup>2</sup>) in area and having no dimensions greater than 12 inches (305 mm), shall not be less than 0.115 inch (2.92 mm) thick.

6.1.11 Glass used to cover an opening larger than 144 square inches (929 cm<sup>2</sup>) shall be investigated to determine that it has the necessary mechanical strength and is otherwise suitable for the purpose.

6.1.12 Each gasket required to seal an enclosure against the entrance of rain and condensate shall be held in place by mechanical fasteners or adhesives except as indicated in [6.1.13](#), and shall:

- a) Be neoprene, rubber, thermoplastic, polyvinyl chloride or other materials with equivalent properties that comply with Section [49C](#); or
- b) Comply with the Standard for Gaskets and Seals, UL 157 if the gasket physical properties are equivalent to those specified in [49C.2](#) – [49C.10](#).

6.1.13 In reference to [6.1.12](#), gaskets which are not held in place by mechanical fasteners or adhesives but are intended to be retained in the correct position by some other means shall be prevented from displacement either:

- a) Due to their location within the equipment, or
- b) By the placement of other components in the enclosure so that if the equipment cover is removed, the gasket will be reengaged in the intended manner when the cover is replaced.

6.1.14 Adhesives required to secure gaskets shall comply with [49C.11](#).

6.1.15 Products intended for outdoor use shall comply with the Rain Test, Section [49B](#).

6.1.16 For products intended for installation within a concealed space of a building structure, an opening complying with Section [7](#), Accessibility of Uninsulated Live Parts and Moving Parts, but located on a part of the product concealed by the building structure shall not have any dimension exceeding 17/64 in. (6.75 mm) or a cross-sectional area exceeding 0.055 in<sup>2</sup> (35.5 mm<sup>2</sup>) and there shall be no more than:

- a) Four openings in the rear of the enclosure; and
- b) Two openings in each of the other four sides of the enclosure.

## 6.2 High-voltage power supply

6.2.1 A high-voltage power supply shall:

- a) Be housed within its own enclosure or comply with [49.4.1](#) – [49.4.3](#) if the power supply has uninsulated live parts; or
- b) Be housed within the cabinet if the live parts of the power supply are insulated.

6.2.2 A power-supply enclosure shall be:

- a) Uncoated sheet steel not less than 0.026 inch (0.66 mm) thick;
- b) Zinc-coated sheet steel not less than 0.029 inch (0.74 mm) thick;